

PROCESS SPECIFICATION COVER SHEET

Category II Rev 2

Form 44334

PROCESS SPECIFICATION	DATED	REVISION NO.	DATED	ORIGINAL ISSUE	SUPERSEDES PREVIOUS REVISIONS
PSPAS-01	5/26/77	0		<input type="checkbox"/>	<input type="checkbox"/>
ATTACHMENTS					

TITLE ASSEMBLY, FITTING, AND WELDING SEQUENCE FOR
PRIMARY LOOP PIPING

PROCESS: OPEN BUTT FITTING TECHNIQUE.

ROOT WELDING BY MANUAL GAS TUNGSTEN
ARC WITH BARE FILLER MATERIAL.

BALANCE OF JOINTS COMPLETED WITH
MANUAL SHIELDED METAL ARC TECHNIQUE.

Weld Parameter Data
2 Sheets

Weld Procedure
No. PSWLD-04

Butt Weld Preparation
Drawing SDPIP01

WELD END PREPARATION
FOR R.C. PIPE
DRAWING 271C950

This document contains proprietary information of  WPSD and is to be returned upon request. Its contents may not be disclosed to others or used for other than the express purpose for which loaned without written consent.

APPROVAL

	ORIGINAL ISSUE	REV. 1	REV. 2	REV. 3	REV. 4
AUTHOR	R.S. Eunson				

FOIA 85-59

Page 1 of 4 Pages

M343



PSPD

PROCESS SPECIFICATION

Revision

Revisions

Revised By

Revision No. <u>0</u>	
to	
P-Spec PSPAS-01	
Page <u>2</u> of <u>4</u> - Prc	

P-Spec PSPAS-01

Page 2 of 4 - Prc



PSPD

PROCESS SPECIFICATION

DESIGN AND PROCEDURE CONSIDERATION FOR SITE ERECTION.

Weld joint groove design is specified by PWR and is compatible with PSPD Welding Procedure Number PSWLD04. If this procedure or another Site Procedure encompassing the essential variables has been qualified, no further qualification is required.

OXIDATION PROTECTION DURING WELDING OPERATIONS.

Back-up gas can be either nitrogen or argon depending on the procedure qualification. Checks on purge to determine the acceptable, "less than 2% O₂ level," can best be accomplished with a gas analyzer.

HOT AND COLD LEG COMPONENTS.

Hot and cold leg piping is supplied in exact prefabricated lengths for field erection.

- (1) Both closure joints of either section are to be fit up simultaneously. The extended lips of the joint are to be fit metal to metal-no insert. Any gaps due to misalignment of the large components not correctible by fitting shall be filled manually with the heliarc process and inspected by a 5X visual examination. Any gaps in excess .065" (2.4MM) should be filled prior to the start of production welding.
- (2) Start production welding on both joints simultaneously (four (4) welders).
- (3) Employing the GTAW section of the procedure, start one man on each end in the 6 o'clock to 9 o'clock position and his counterpart from 3 o'clock to 12 o'clock. After completing these runs, the welders will move to the unwelded sections and complete the first pass, ie, (6 o'clock to 3 o'clock and 9 o'clock to 12 o'clock). Continue these operations with all four welders until a minimum 3/8" or maximum 3/4" weld depth has been deposited by the GTAW process.
- (4) Secure welding operations. Remove purge dams, evacuate back-up gas, and supply fresh air to the I.D. of pipe.
- (5) Inspection personnel will L.P. the I.D. root of both welds and specify any necessary repairs. Any additional welding required on the I.D. shall be performed with the GTAW process at this time.
- (6) Institute production welding with the SMAW process and continue the two welds to the 1" to 1 1/4" weld depth.
- (7) Secure welding and make an in-process radiographic examination.
- (8) Complete any repairs required.

Revision No. 0

to

P-Spec PSPAS-01

Page 3 of 4 Pages

- (9) Institute production welding (SMAW) and continue both welds to the 2" to 2 1/4" weld depth.
- (10) Repeat the in-process RT cycle and any necessary repairs.
- (11) Complete the production welding, perform cosmetics, and liquid penetrant test the completed welds.
- (12) Radiographic Test for record.

Upon successful radiograph acceptance, the joints are now ready for Customers in-service profile operations.

CLOSURE (MAKE-UP) COMPONENTS

Closure piping (steam generator to pump) is usually supplied in two sections.

Both sections can be erected at the same time. The designed end to end dimension will be approximately 3/16" too long to fit all joints for welding.

- (1) Using temporary clips for support set up pipe with centerline axis joints #1 and #3 equally spaced out board of the pump and generator nozzle axis. The holding clips on joints #1 and #3 shall be designed to permit movement caused by shrinkage during welding of joint #2.
- (2) Start production welding on joint #2 with two welders following the same format as specified for the hot and cold leg sequences.
- (3) A welding inspector shall continuously monitor the weld shrinkage by measurement and observing the position of joints #1 and #3.
- (4) When the axis points on the pipe at joints #1 and #3 are within 1/16" of the axis of pump and generator nozzles, the welding joint #2 shall be secured.
- (5) Finish fit joints #1 and #3.
- (6) Institute production welding on joints #1 and #3 employing the same format as specified for the hot and cold leg sequences.
- (7) When joints #1 and #3 approach the same level of completion as the secured operation on joint #2, work all three joints to completion at approximately the same rate of filler deposition.

Productive manhours for two loops-6300
Filler metal required-1500lbs.

Revision No. ____ 0 ____

10


P-Spec PSPAS-01

Page ____ 4 ____ of ____ 4 ____ Pages

Westinghouse Electric Corporation

WELD PARAMETER DATA - PSPAS-01 Sheet 1


PRIMARY COOLANT LOOP CLOSURE
SECTION-TWO PIECES



Westinghouse Electric Corporation

WELD PARAMETER DATA - PSPAS-01 Sheet 2

Surfaces of Welds



Accessible reverse surfaces of root passes shall be examined to the same requirements specified for completed welds.

(a) The surface condition of the finished weld shall be suitable for the proper interpretation of radiographic and other required nondestructive examinations of the welds. In those cases where there is a question regarding the surface condition on the interpretation of a radiographic film, the film shall be compared to the actual weld surface for interpretation and determination of acceptability.

(b) Reinforcements are permitted in accordance with Thickness of Weld Reinforcement for Piping Chart.

(c) Undercuts shall not exceed $\frac{1}{32}$ in. and shall not encroach on the required section thickness.

(d) Concavity on the root side of a single welded circumferential butt weld is permitted when the resulting thickness of the weld is at least equal to the thickness of the thinner member of the two sections being joined.

Thickness of Weld Reinforcement for Piping. For double welded butt joints, the limitation on the reinforcement given in Column 1 of the following tabulation shall apply separately to both inside and outside surfaces of the joint. For single welded butt joints, the reinforcement given in column 2 shall apply to the inside surface and the reinforcement given in Column 1 shall apply to the outside surface. The reinforcement shall be determined from the higher of the abutting surfaces involved.

Material Nominal Thickness, In.	Maximum Reinforcement Thickness, in.	
	Column 1	Column 2
Up to $\frac{1}{8}$, incl.	$\frac{3}{32}$	$\frac{3}{32}$
Over $\frac{1}{8}$ to $\frac{3}{16}$, incl.	$\frac{1}{8}$	$\frac{3}{32}$
Over $\frac{3}{16}$ to $\frac{1}{2}$, incl.	$\frac{5}{32}$	$\frac{1}{8}$
Over $\frac{1}{2}$ to 1, incl.	$\frac{3}{16}$	$\frac{3}{32}$
Over 1 to 2, incl.	$\frac{1}{4}$	$\frac{3}{32}$
Over 2	The greater of $\frac{1}{4}$ in. or $\frac{1}{8}$ times the width of the weld in inches.	$\frac{3}{32}$

ARMS
INDEXED


AP4, item 3

L	17.1.55
FILE LOC	ME 78-014-5505

CONSTRUCTION OPERATION TRAVELER 35-1195

(1) TRAVELER NO. <u>ME78-014-5505</u>	(2) EQUIPMENT NO. SD 140 <u>TRX-RLPCLL-01</u>	(3) UNIT NO. <u>1</u>	(4) QUANTITY <u>1</u>	(5) PAGE 1 OF <u>1</u>
(6) ACTIVITY DESCRIPTION <u>WDP N° 3 RL CROSSOVER LEG INSTALLATION</u>	(7) REFERENCE DRAWINGS <u>2323-M1-0520</u>			
(8) SPEC / PROC / ENG INSTR. <u>MELA</u>	(9) LOCATION <u>CONTAINMENT #1</u>	(10) SYSTEM <u>P.C.</u>		
PREPARED BY <u>J. D. Dillaw</u>	DATE <u>6-28-78</u> DEPT <u>MELA E&E</u>			
REVIEWED BY <u>J. D. Dillaw</u>	DATE <u>6-28-78</u> QA/QC ENG ANI			
ANI REVIEW <u>J. D. Dillaw</u>	DATE <u>6-28-78</u> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>			

OP. NO.	DEPT.	OPERATION	QA/QC ENG	ANI
1	PI	REMOVE THE N ₂ PURGE FROM THE STEAM GENERATOR PRIMARY SIDE.		
2	PI	STRIP THE PROTECTIVE COATING FROM THE STEAM GENERATOR PRIMARY OUTLET NOZZLE A MIN. 12" FROM THE WELD PREP. USE POWER WIRE BRUSH AS NEEDED QC MONITOR		YB 8/4/78
3	PI	REMOVE THE SHIPPING COVER BY GRINDING THE FILLET WELD FROM CENTER OF WELD TOWARD THE SHIPPING COVER. CARE SHOULD BE TAKEN TO PREVENT DAMAGE TO THE WELD BEVEL AND APPARENT BASE METAL OF THE NOZZLE. ANY TYPE OF CUTTING OR ARC GROUNDING IS NOT PERMITTED. QC MONITOR		



12
8/16/78

F01-A 05 00
100-000-000

M364


CONSTRUCTION OPERATION TRAVELER CONTINUATION

TRAVELER NO. ME78-014-5503	ACTIVITY DESCRIPTION LOOP U ² 3 R.C. CROSSOVER LEG INSTALLATION	PAGE 2 OF
-------------------------------	--	-----------

PREPARED BY J. Olson DATE 6-28-78

REVIEWED BY L. Lindholm DATE 6-28-78

ANI REVIEW J. Olson DATE 6-28-78

OP. NO.	DEPT.	OPERATION	QA/QC ENG	ANI
4	PI	DRESS THE REMAINING WELD DOWN TO BASE METAL. THE GRINDING WHEEL MUST NOT BE ALLOWED TO BURN THE BASE METAL. QC MONITOR		YD 8-16-78
5	QC ANI	PERFORM VISUAL EXAM. PER NDEP-200	Pump SG Hd Pump Hd SG Hd	Power 8-16-78 36 8-21-78 36 8-21-78 Pump Hd SG Hd SG Hd SG 8-21-78 8-21-78
6	QC	PERFORM L.P. EXAM. OF THE GROUND OUT FILLET WELD PER NDEP-300.		
7	WELD TECH.	PERFORM FERRITE CONTENT EXAM. PER S-52.01-107A PARR. 24.0. QC WITNESS		
PI.		NOTE: WHEN WORK IS NOT BEING DONE ON THE PIPING INSTALLATION KEEP THE NOZZLE COVERED WITH PLYWOOD OR PIPE CAPS.		

CONSTRUCTION OPERATION TRAVELER REVISION RECORD SHEET

TRAVELER NO. ME-78-014-5505 EQUIPMENT NO. S0.140 (BX - RFLCLL - 0)		ACTIVITY DESCRIPTION LOOP N° 3 RL. CROSSOVER LEC INSTALLATION		PAGE 1 OF 1	
① REV NO OP NO	② INITIAT- ED BY	③ REVIEWED BY	④ REVISION DESCRIPTION	⑤ QA/QC ENG	⑥ ANI
QC	ANI				
A 6,7	P.O.	LJF 11-7-78	<p>REVISE OPER#6 TO INCLUDE THE ENTIRE WELD END PREP.</p> <p>DELETE OPER #7</p> <p>REVISE OPER #6 TO INCLUDE THE R.C.P. INLET NOZZLE.</p> <p>ADD STEP 8</p> <p>PERFORM L.P. EXAM OF TWO WELD PREPS OF THE 40° ELL PER UDEP-300</p>	<p>VISUAL BOTH ENDS L.P. BOTH ENDS</p> <p>L.P. BOTH ENDS 11-7-78</p> <p>PT BY I.D. EXAM NO Q 11-7-78</p>	
B	JAS 11-7-78 LJF 11-7-78		Delete this traveler, see traveler No <u>ME78-026-5505</u> FOR CONTINUATION		
<p style="text-align: center;">BROWN & ROOT, INC RECEIVED DEC 07 1978 FILES NOTED</p> <p style="text-align: center;">QUALITY ASSURANCE INFORMATION</p> <p style="text-align: center;">COPY PPRV</p>					

CONSTRUCTION OPERATION TRAVELER 35-1195							
(1) TRAVELER NO. <u>ME78-014-5505</u>	(2) EQUIPMENT NO. 50.140 <u>TRX-RLPLC-01</u>	(3) UNIT NO. <u>1</u>	(4) QUANTITY <u>1</u>	(5) PAGE 1 OF <u>1</u>			
(6) ACTIVITY DESCRIPTION <u>R.C. CROSSOVER LEL INSTALLATION</u>	(7) REFERENCE DRAWINGS <u>WUP NO. 3</u> <u>2322-M1-0520</u>						
(8) SPEC./PROC./ENG. INSTR. <u>MS-100</u>	(9) LOCATION <u>CONTAINMENT #1</u>	(10) SYSTEM <u>R.C.</u>					
PREPARED BY <u>J. D. Shaw</u>	DATE <u>6-28-78</u>	DEPT. <u>MELA. ENG.</u>					
REVIEWED BY <u>J. D. Shaw</u>	DATE <u>6-28-78</u>	QA/QC ENG ANI					
ANI REVIEW <u>J. G. G.</u>	DATE <u>6-28-78</u>	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>					
OP. NO.	DEPT.	OPERATION	QA/QC ENG			ANI	
1	P1	REMOVE THE N ₂ PURGE FROM THE STEAM GENERATOR PRIMARY SIDE.	QUALITY ASSURANCE			BROWNING REC'D JUL 07 1978	
2	P1	STRP THE PROTECTIVE COATING FROM THE STEAM GENERATOR PRIMARY OUTLET NOZZLE A MIN. 12" FROM THE WELD PREP. USE POWER WIRE BRUSH AS NEEDED QL MONITOR	FILES NOT TO COPY			RECORD 014-5505 NETS-AUG-1978 5/8/79	
3	P1	REMOVE THE SHIPPING COVER BY GRINDING THE FILLET WELD FROM CENTER OF WELD TOWARD THE SHIPPING. THE WELD SHOULD BE TAKEN TO PREVENT DAMAGE TO AND APPARENT BASE METAL OF THE NOZZLE. ANY TYPE OF FLAME CUTTING OR ARC CUTTING IS NOT PERMITTED. QL MONITOR	INFORMATION COPY				

TRAVELER NO.

CONSTRUCTION OPERATION TRAVELER CONTINUATION

ACTIVITY DESCRIPTION

LOOP U4 3

R.C. CROSSOVER LEG INSTALLATION PAGE 2 OF

PREPARED BY

D. D. Brown

DATE

6-28-78

REVIEWED BY

J. C. Hansen

DATE

6-28-78

ANI REVIEW

DATE

6-28-78

OP NO.

DEPT. OPERATION

QA/QC
ENG ANI

4 P1 DRESS THE REMAINING WELD DOWN TO BASE METAL. THE GROUND WHEEL MUST NOT BE ALLOWED TO RUIN THE BASE METAL.

QC monitor

5 QC PERFORM VISUAL EXAM. PER APF WD-EP-200

6 QC PERFORM L.P. EXAM. OF THE GROUND OUT FILLET WELD PER WD-EP-300.

7 WELD PERFORM FERRITE COUNTERT WELD EXAM. PER S-52.01-107A PARA. 24.0.

QC witness

- P1. VOTE: WHEN WELDING BEING DONE,
INSTALLATION, KEEPS EYES
COVERED WITH SUPPLY
PLYWOOD OR PIPE CAPS.
- INFORMATION**
WELDING
SUPPLY
PIPE CAPS



Brown & Root, Inc.
QUALITY ASSURANCE DEPARTMENT
NDE LIQUID PENETRANT REPORT

PROJECT: COMANCHE PEAK JOB NO. 35-1196 UNIT / PAGE / OF /

DRAWING <u>2923-011-520</u>	SYSTEM <u>R.C.</u>	CLASS <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD/ITEM IDENTIFICATION <u>10X-RCPCPC-03 END AER</u>	LOCATION <u>Containment #1</u>	
MTL. TYPE <u>P-8</u>	MTL. THICK <u>2.48"</u>	DIA/LENGTH <u>31"</u> DIA/WIDTH <u>N/A</u> LENGTH <u>N/A</u>

PENETRANT MFG. MAGNAFLUX	BRAND SPOTCHECK	NDE PROCEDURE NO. CP-NDEP-300
CLEANER MFG. MAGNAFLUX	BRAND SPOTCHECK	
DEVELOPER MFG. MAGNAFLUX	BRAND SPOTCHECK	
STAGE OF MFG. <input checked="" type="checkbox"/> END PREP <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND	MACHINED <input checked="" type="checkbox"/> OTHER
DWELL TIME <u>15 min</u>	DEVELOPING TIME <u>15 min</u>	

REMARKS
REF TRAVELER # ME 78-014-5505

ACCEPTANCE STD. ASME SECTION III	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/>	DATE <u>8/22/78</u>
INSPECTOR <u>Art Angstom</u>	CERTIFICATION LEVEL <u>II</u>	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND	<input type="checkbox"/> OTHER
DWELL TIME	DEVELOPING TIME	

REMARKS

ACCEPTANCE STD. ASME SECTION III	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE <u>/ /</u>
INSPECTOR	CERTIFICATION LEVEL <u>INFORMATION</u>	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND	<input type="checkbox"/> OTHER
DWELL TIME	DEVELOPING TIME	

REMARKS

ACCEPTANCE STD. ASME SECTION III	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE <u>/ /</u>
INSPECTOR	CERTIFICATION LEVEL	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND	<input type="checkbox"/> OTHER
DWELL TIME	DEVELOPING TIME	

REMARKS

ACCEPTANCE STD. ASME SECTION III	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE <u>/ /</u>
INSPECTOR	CERTIFICATION LEVEL	

QUALITY ASSURANCE DEPARTMENT

NDE-

NDE REPORT


PROJECT: COMANCHE PEAK

JOB NO. 35-1195

UNIT 1PAGE 1OF 1

DRAWING <u>2323-011-520</u>	SYSTEM <u>P.C.</u>	CLASS <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD/ITEM NUMBER <u>NOZZLE T62-PCAPC-03 END PREP</u>	LOCATION <u>CONTAINMENT #1</u>	
CROSSOVER LEG LOOP ³		
MTL. TYPE	MTL. THICK <u>2.48</u>	DIA/LENGTH <u>31" DIA</u>
STAGE OF MFG. <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	<input checked="" type="checkbox"/> END PREP	JOINT DESIGN <input type="checkbox"/> SBRN <input type="checkbox"/> BKS <input type="checkbox"/> INS <input type="checkbox"/> OPEN BUTT <input checked="" type="checkbox"/> OTHER <u>MACHINED</u>
SKETCH AND REMARK (S)		

REF TRAVELER # ME 78-014-5505



ACCEPTANCE STD <u>ASME SECT. III</u>	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/>	DATE <u>8/22/78</u>
---	--	------------------------

INSPECTOR <u>Mark Langston</u>	PROCEDURE <u>NDEP-200</u>	CERTIFICATION LEVEL <u>II</u>
-----------------------------------	------------------------------	----------------------------------



Brown & Root, Inc.
QUALITY ASSURANCE DEPARTMENT
NDE LIQUID PENETRANT REPORT


PROJECT: COMANCHE PEAK		JOB NO. 35-1195	UNIT /	PAGE / OF /
DRAWING <u>2323-M1-520</u>	SYSTEM <u>R.C.</u>	CLASS <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER		
WELD/ITEM IDENTIFICATION <u>NOZZIE T87-RCP SC 03 END PREP</u>		LOCATION <u>CONTAINMENT #1</u>		
MTL. TYPE <u>P-8</u>	MTL. THICK <u>2.48</u>	DIA/LENGTH <u>31"</u>	DIA/WIDTH <u>N/A</u>	LENGTH <u>N/A</u>
PENETRANT MFG. MAGNAFLUX		BRAND SPOTCHECK	NDE PROCEDURE NO. CP-NDEP-300	
CLEANER MFG. MAGNAFLUX		BRAND SPOTCHECK		
DEVELOPER MFG. MAGNAFLUX		BRAND SPOTCHECK		
STAGE OF MFG. <input checked="" type="checkbox"/> END PREP <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	SURFACE <input type="checkbox"/> ASWELDED <input type="checkbox"/> GROUND		MACHINED <input checked="" type="checkbox"/> OTHER	
DWELL TIME <u>15 min</u>	DEVELOPING TIME <u>15 min</u>			
REMARKS <u>REF TRAVELER # ME 78-014-5505</u>				
ACCEPTANCE STD. ASME SECTION III	ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	DATE <u>8/21/78</u>	
INSPECTOR <u>R. Shaw</u>	CERTIFICATION LEVEL <u>II</u>			
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	SURFACE <input type="checkbox"/> ASWELDED <input type="checkbox"/> GROUND		<input type="checkbox"/> OTHER	
DWELL TIME	DEVELOPING TIME			
REMARKS				
ACCEPTANCE STD. ASME SECTION III	ACCEPT <input type="checkbox"/>	REJECT <input type="checkbox"/>	DATE <u>/ /</u>	
INSPECTOR	CERTIFICATION LEVEL			
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	FINAL	SURFACE <input type="checkbox"/> ASWELDED	<input type="checkbox"/> GROUND	<input type="checkbox"/> OTHER
DWELL TIME	DEVELOPING TIME			
REMARKS				
ACCEPTANCE STD. ASME SECTION III	ACCEPT <input type="checkbox"/>	REJECT <input type="checkbox"/>	DATE <u>/ /</u>	
INSPECTOR	CERTIFICATION LEVEL			
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	FINAL	SURFACE <input type="checkbox"/> ASWELDED	<input type="checkbox"/> GROUND	<input type="checkbox"/> OTHER
DWELL TIME	DEVELOPING TIME			
REMARKS				
ACCEPTANCE STD. ASME SECTION III	ACCEPT <input type="checkbox"/>	REJECT <input type="checkbox"/>	DATE <u>/ /</u>	
INSPECTOR	CERTIFICATION LEVEL			
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	FINAL	SURFACE <input type="checkbox"/> ASWELDED	<input type="checkbox"/> GROUND	<input type="checkbox"/> OTHER
DWELL TIME	DEVELOPING TIME			
REMARKS				
ACCEPTANCE STD. ASME SECTION III	ACCEPT <input type="checkbox"/>	REJECT <input type="checkbox"/>	DATE <u>/ /</u>	
INSPECTOR	CERTIFICATION LEVEL			

QUALITY ASSURANCE DEPARTMENT
NDE REPORT

NDER-

ANCHE PEAK	JOB NO. 35-1195	UNIT <u>1</u>	PAGE <u>1</u> OF <u>1</u>
<u>LM NUMBER</u> <u>1-M1-520</u>	SYSTEM <u>R.C.</u>	CLASS <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER	
<u>NOZZLE</u> <u>RCPCSG-03 END PREP</u>	LOCATION <u>CONTAINMENT #1</u>		
<u>OSSOUEC loop 3</u>			
MTL. TYPE <u>P-8</u>	MTL. THICK <u>2.48"</u>	DIA/LENGTH <u>31" dia</u>	
STAGE OF MFG. <input type="checkbox"/> REPAIR	<input checked="" type="checkbox"/> END PREP <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	<input type="checkbox"/> FINAL	JOINT DESIGN <input type="checkbox"/> BRN <input type="checkbox"/> BKS <input type="checkbox"/> INS <input type="checkbox"/> OPEN BUTT <input checked="" type="checkbox"/> OTHER <u>MACHINED</u>

SKETCH AND REMARK (S)

REF TRAVELER # ME 78-014-5505

ACCEPTANCE STD <u>ASME SECT III</u>	ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	DATE <u>8/24/78</u>
INSPECTOR <u>LorShaw</u>	PROCEDURE <u>NDEP-200</u>	CERTIFICATION LEVEL <u>II</u>	



Brown & Root, Inc.
QUALITY ASSURANCE DEPARTMENT
NDE REPORT

SERIAL NUMBER

NDER- 3340

PROJECT: COMANCHE PEAK

JOB NO. 35-1195


UNIT 1 PAGE 1 OF 1

DRAWING <u>2323-M1-520</u>	SYSTEM <u>R.C.</u>	CLASS <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD/ITEM NUMBER <u>1201(NORTH END PREP)</u>	LOCATION <u>CONTAINMENT #1</u>	
CROSSOVER LEG Loop #3		
MTL. TYPE <u>P-8</u>	MTL. THICK <u>.248</u>	DIA/LENGTH <u>31' Dia</u>
STAGE OF MFG. <input type="checkbox"/> REPAIR <input checked="" type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	<u>END PREP</u>	<input type="checkbox"/> FINAL <input type="checkbox"/> INS <input type="checkbox"/> OPEN BUTT <input checked="" type="checkbox"/> OTHER <u>MACHINED</u>

DESCRIPTION(S) AND INSPECTION REMARKS(S)

REF. TRAVELER # ME78-014-5505

45° ELBOW



ACCEPTANCE STD <u>ASME SECT III</u>	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/>	DATE <u>11/17/78</u>
--	--	----------------------

INSPECTOR <u>R. Shaw</u>	CERTIFICATION LEVEL <u>IV</u>
NDE PROCEDURE <u>NDEP 200</u>	



Brown & Root, Inc.
QUALITY ASSURANCE DEPARTMENT
NDE REPORT

SERIAL NUMBER

NDER- 3339

PROJECT: COMANCHE PEAK

JOB NO. 35-1195


UNIT 1PAGE 1 OF 1

DRAWING <u>2323-MI-520</u>	SYSTEM <u>R.C.</u>	CLASS <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD/ITEM NUMBER <u>1201 (SOUTH END PREP)</u>	LOCATION <u>CONTAINMENT #1</u>	
MTL. TYPE <u>P-8</u>	MTL. THICK <u>.78</u>	DIA/LENGTH <u>31" dia</u>
STAGE OF MFG. <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	<u>END PREP</u>	<input type="checkbox"/> FINAL
		JOINT DESIGN <input type="checkbox"/> BRN <input type="checkbox"/> BKS <input type="checkbox"/> INS <input type="checkbox"/> OPEN BUTT <input type="checkbox"/> OTHER
<u>MACHINED</u>		

DESCRIPTION(S) AND INSPECTION REMARKS(S)

REF. TRAVELER # ME78-014-5505

45° ELBOW



ACCEPTANCE STD <u>ASME SECT III</u>	ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	DATE <u>11/17/78</u>
--	--	---------------------------------	-------------------------

INSPECTOR <u>K. D. Shan</u>	CERTIFICATION LEVEL <u>II</u>
NDE PROCEDURE <u>NDEP 200</u>	



Brown & Root, Inc.

Post Office Box 1001, Glen Rose, Texas 76043

QUALITY ASSURANCE DEPARTMENT
NDE LIQUID PENETRANT REPORT

UNIT

PAGE / OF /

JOB NO. 35-1195

CLASS

 1 2 3 OTHER

COMANCHE PEAK

23-M1-520

(NORTH END PREP)

COVER LEG

P-8

ITEM IDENTIFICATION

Loop #3

MTL THICK

2.48

SYSTEM

R.C.

LOCATION

CONTAINMENT #1

BI/LENGTH

31"

DIA/WIDTH

1/1

LENGTH

N/A

FRANT

MAGNAFLUX

BRAND

SPOTCHECK

IFG.

MAGNAFLUX

BRAND

SPOTCHECK

INTER

MAGNAFLUX

BRAND

SPOTCHECK

MFG.

MAGNAFLUX

BRAND

SPOTCHECK

ELOPER

MAGNAFLUX

BRAND

SPOTCHECK

AGE OF MFG.

REPAIR

END PREP

ROOT

INTERMEDIATE

EXCAVATION

FINAL

SURFACE

AS WELDED

GROUND

OTHER

Dwell Time

15 MIN

REMARKS

REF TRAVELER # MET 78-014-5505

ACCEPTANCE STD.

ASME SECTION III

 ANSI B31.1

INSPECTOR

L. Rollan

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

11-7-78

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT

CERTIFICATION LEVEL

II

DATE

/ /

REMARKS

ACCEPTANCE STD.

ASME SECTION III

ANSI B31.1

INSPECTOR

REMARKS

ACCEPT

REJECT



Brown & Root, Inc.

Post Office Box 1001, Glen Rose, Texas 76043

QUALITY ASSURANCE DEPARTMENT
NDE LIQUID PENETRANT REPORT

PROJECT: COMANCHE PEAK

JOB NO. 35-1195

UNIT

PAGE 1 OF 1

DRAWING 2323-M1-520 WELD/ITEM IDENTIFICATION <i>Loop #3</i>	SYSTEM R.C.	CLASS <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER
LOCATION CROSSOVER LEG	CONTAINMENT #1	
MTL TYPE P-8	MTL THICK 2.48	BIA/LENGTH 31"
		DIA/WIDTH N/A LENGTH N/A

PENETRANT MFG. MAGNAFLUX	BRAND SPOTCHECK	NDE PROCEDURE NO. CP-NDEP-300	
CLEANER MFG. MAGNAFLUX	BRAND SPOTCHECK	<i>40° ELBOW</i>	
DEVELOPER MFG. MAGNAFLUX	BRAND SPOTCHECK		
STAGE OF MFG. <input checked="" type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND <input checked="" type="checkbox"/> OTHER	<i>MACHINED</i>	
DWELL TIME 15min			DEVELOPING TIME 15min

REMARKS

REF TRAVELER # ME78-014-5505

ACCEPTANCE STD. ASME SECTION III <input checked="" type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/>	DATE 11/7/78
INSPECTOR <i>Redhaul</i>	CERTIFICATION LEVEL <i>II</i>	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE	
DWELL TIME	DEVELOPING TIME	
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND <input type="checkbox"/> OTHER	DEVELOPING TIME
DWELL TIME		
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE <i>PRIV</i>
INSPECTOR	CERTIFICATION LEVEL	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND <input type="checkbox"/> OTHER	DEVELOPING TIME
DWELL TIME		
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	

CONSTRUCTION OPERATION TRAVELER CONTINUATION					
TRAVELER NO. ME78-007-5505		ACTIVITY DESCRIPTION R.C. CROSSOVER LRW INSTALLATION		PAGE <u>3</u> OF <u>1</u>	
PREPARED BY <u>P. D. S.</u>		DATE <u>9/16/78</u>			
REVIEWED BY _____		DATE _____			
ANI REVIEW _____		DATE _____			
OP. NO.	DEPT.	OPERATION	QA/QC ENG	ANI	
		ALL WORK TO BE ACCOMPLISHED IN ACCORDANCE WITH B&R S-S2.01-107A FOR ALL CUTTING, GRINDING, WELDING AND RELATED. SEE APPROPRIATE WELD DATA CARD FOR INSPECTION HOLD POINTS. SEE BRP-RL-1-S20-1 FOR WELD MAP.			
9	P1	OBTAIN PURGE DAMS FOR 56-40° ELL CONVENTION. FINAL ADJUSTMENT OF THE PURGE DAM SHALL BE MADE PRIOR TO ESTABLISHING THE PURGE			
10	P1	CLEAN AND DEGREASE WELD ENDS.			
11	P1	ALIGN AND FIT THE 40° ELL TO THE ST. GEN. OUTLET NOZZLE. THE JOINT SHALL BE FIT AND ALIGNED IN ACCORDANCE WITH THE WPS LISTED ON THE WELD INFORMATION DATA CARD AND NES-107A			

COPY


FOIA-85-59

PPRV

365

M365

CONSTRUCTION OPERATION TRAVELER CONTINUATION						
TRAVELER NO. ME78-007-5505		ACTIVITY DESCRIPTION LOOP N° 2 RC CROSSOVER LEG INSTALLATION			PAGE 4 OF _____	
PREPARED BY <u>P. Cole</u>		DATE <u>9/16/78</u>				
REVIEWED BY _____		DATE _____				
ANI REVIEW _____		DATE _____				
OP. NO.	DEPT.	OPERATION			QA/QC	
ENG	ANI					
12	PI	MARK CENTER OF WELD JOINT PER FSM-00106. APPLY PUNCH MARKS TO DETERMINE FINAL WELD SHRINKAGE. RECORD INITIAL GAGE READING ON <small>(CLOCKWISE LOOKING AT S.G. NOZZLE)</small> TRAVELER. 12 o'clock, 3 o'clock, 6 o'clock, 9 o'clock INITIAL READING - 4.046, 4.062, 3.953, 4.062				
13	PI WE	OBTAIN WELD DATA CARDS. CHECK FIT AND TACK THE JOINTS PER WELD DATA CARD.				
14	PI	PROCEEDED WELDING UNTIL $1\frac{1}{2}$ " - $3\frac{1}{4}$ " WELD METAL HAS BEEN DEPOSITED. MONITOR THE LEVELNESS OF THE ELBOW AND ADJUST WELDERS AS NECESSARY TO MAINTAIN LEVELNESS.				
15	PI	DISCONTINUE WELDING WHEN $1\frac{1}{2}$ " - $3\frac{1}{4}$ " WELD METAL HAS BEEN DEPOSITED.				
16	QC	PERFORM RT EXAM PER NDEP-101.				



INFORMATION
COP
PPRV

CONSTRUCTION OPERATION TRAVELER CONTINUATION						
TRAVELER NO. ME78-007-5505		ACTIVITY DESCRIPTION LOOP N° 2 RE. CROSSOVER LEG INSTALLATION			PAGE 5 OF _____	
PREPARED BY <u>P. Olson</u>		DATE <u>1/16/78</u>				
REVIEWED BY _____		DATE _____				
ANI REVIEW _____		DATE _____				
OP. NO.	DEPT.	OPERATION			QA/QC ENG	ANI
Y2 16A	P1 QL	<p>UPON RT ALLENTABLE, PROCEED WELDING. PERFORM RT PER UDEP-101 AFTER EACH $3\frac{1}{4}$" OF DEPOSITED WELD METAL.</p> <p>NOTE: WHEN REPAIRS ARE REQUIRED, THEY SHALL BE DOED AS GIVEN IN MES-107A.</p>				
Y5 16B	P1 WE QL	<p>AFTER WELDING IS COMPLETE, VERIFY THE FINAL WELD JOINT OFFSET IS NOT GREATER THAN $\frac{1}{8}$ X THE PIPE WALL THICKNESS FAIR THE FINISHED WELD TO AT LEAST A 3 TO 1 TAPER OVER THE WIDTH OF THE FINISHED WELD.</p>				
WT 16C	P1 WE	<p>PREPARE THE JOINT FOR INSERVICE INSPECTION AS FOLLOWS:</p> <p>A) THE WELD SHALL BE <u>FLUSH</u> PPRV WITH THE BASE METAL TO A MAX. $3\frac{1}{32}$" REFORDED CROWN.</p>				

**INFORMATION
COPY**

CONSTRUCTION OPERATION TRAVELER CONTINUATION					
TRAVELER NO. ME78-007-5505	ACTIVITY DESCRIPTION LOOP N° 2 R.L. CROSSOVER LEG INSTALLATION			PAGE 6 OF _____	
PREPARED BY <u>D Olls</u>	DATE <u>9/16/78</u>				
REVIEWED BY _____	DATE _____				
ANI REVIEW _____	DATE _____				
OP. NO.	DEPT.	OPERATION	QA/QC ENG ANI		
		<p>B) BLEND THE WELD CROWN INTO THE BASE METAL AS FOLLOWS:</p> <p>BREAK CORNERS 1:4 TAPER FLAT WITHIN $\frac{1}{32}$ $\frac{1}{2}$ min. RAD. NO GRINDING CONCAVITY ALLOWED.</p> <p>C) FINISH TO 250 RMS 7" EACH SIDE OF THE WELD CENTERLINE.</p> <p>16 D P, WE RECORD ON TRAVELER FINAL GAGE READING DETERMINE FINAL WELD SHRINKAGE.</p> <p>16 E QL PERFORM RT EXAM OF THE PREVIOUS FINISHED WELD PER NDEP-101.</p> <p>17 WE PERFORM DELTA FERRITE COUNT PER WELD DATA CARD.</p>			

CONSTRUCTION OPERATION TRAVELER CONTINUATION

TRAVELER NO. ME78-007-5505	ACTIVITY DESCRIPTION LOOP N ^o 2 R.L. CROSSOVER LEG INSTALLATION	PAGE <u>2</u> OF <u> </u>
-------------------------------	---	----------------------------

PREPARED BY E. Wilson DATE 9/16/78

REVIEWED BY _____ DATE _____

ANI REVIEW _____ DATE _____

OP. NO.	DEPT.	OPERATION	QA/QC	ENG	ANI
18	F.E.	AFTER COMPLETE WELD-OUT OF THE HOT & COLD LEGS, RECORD DIMENSIONS INDICATED ON ATTACHMENT #1. THESE RECORDINGS ARE TO BE SUBMITTED TO MECHANICAL ENGINEERING FOR REVIEW PRIOR TO PLACING CLOSURE SPOOLS ORDER WITH WESTINGHOUSE.			

INFORMATION
COPY
PPRV

CONSTRUCTION OPERATION TRAVELER REVISION RECORD SHEET

TRAVELER NO. ME-78-007-5505		ACTIVITY DESCRIPTION LOOP N° 2 R.C. CROSSOVER LEG INSTALLATION		PAGE <u>1 OF 1</u>
① REV NO OP NO	② INITIAT- ED BY	③ REVIEWED BY	④ REVISION DESCRIPTION	⑤ QA/QC ENG
		QC	ANI	⑥ ANI
1	PO	<i>JL</i>	REVISE OPER. #6 TO INCLUDE THE INTIRE WELD END PREP DELETE OPER. #7	<i>John 8/14/78</i>
2	PO	<i>JL</i>	REVISE OPER. #6 TO INCLUDE THE R.C.P. INLET NOZZLE ADD STEP 8	<i>John 8/16/78</i>
3	PO 8/25/78 PO	<i>JL</i>	PERFORM PT EXAM OF THE TWO WELD PREPS ON THE 40° ELL PER NDEP-300 AND VISUAL PER NDEP-200	<i>BOTH ENDS Spool 7Q1 JUL 8/25/78</i>
3	PO 8/16/78	<i>JL</i>	ADDED OPER. N° 9 THRU 18 & ATTACHMENT L-1	
4	PO 10/21/78 10/29/78	<i>JL</i>	① ADD TO STEPS 16, 16A, & 16B PRIOR TO PERFORMING PT EXAM, PERFORM PT PER NDEP-300. FIRST PT TO BE ON O.D. S. SUBSEQUENT PT'S ON O.D. ONLY. (REF TRX-SL-0021) ② CORRECTED NUMBERING SEQUENCE	<i>INFORMATION COPY PPRV</i>
5	<i>208510/14/78</i>	<i>JL</i>	DELETE ALL OPEN STEPS ON THIS TRAVELLER & REFER TO TRAVELLER NO. <u>ME-78-024-5505</u>	<i>BROWN & ROOT, INC RECEIVED DEC 07 1978 FILES NOTED</i>

QUALITY ASSURANCE

Ref NCR# 14651 - M Canner - 6-84


CONSTRUCTION OPERATION TRAVELER 35-1195					
① TRAVELER NO. WE78-026-5505	② EQUIPMENT NO. TBX-RCPCLL-01	③ UNIT NO. 1	④ QUANTITY 1	⑤ PAGE OF 1	
⑥ ACTIVITY DESCRIPTION RC Crossover Leg Installation FW19	LOOP NO. 3	⑦ PREFERENCE DRAWINGS 2323-M1-0520			
⑧ SPEC./PROC./ENG. INSTR. MS-100	⑨ LOCATION RB #1	⑩ SYSTEM RC			
PREPARED BY <i>John A. Stahl</i>	DATE 12/6/78	DEPT. Welding Eng.			
REVIEWED BY <i>L. D. Shaw</i>	DATE 12-6-78	QA/QC ENG ANI			
ANI REVIEW <i>Tom Lusser</i>	DATE 12-7-78	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>			
OP. NO.	DEPT.	OPERATION	QA/QC ENG	ANI	
		<u>NOTE:</u> All work to be accomplished in accordance with B & R CP-CPM-6.9 and drawing BRP-RC-1-520-1. For inspection hold points see appropriate weld data card.			
1	Pipe	Align and fit the 40° elbow to the Steam Generator outlet nozzle. The joint shall be fit and aligned in accordance with the HPS listed on the weld data card and CP-CPM-6.9.			
2	Pipe WE	Mark center of weld joint per FSM-00106. Apply punch marks to determine final weld shrinkage. Record initial gage reading at 12:00 _____, 3:00 _____ 6:00 _____ 9:00 _____			
3	WE	Monitor and document the weld metal thickness in each weld joint to attachment 4.			
4	Pipe	Welding will be discontinued at approximately $\frac{1}{2}$ " deposited metal.			
5	QC	See attachment 8 for intermediate RT, PT and WDC requirements.			
6	QC	The welds shall be contour ground with a maximum reinforcement of no more than 3/32" and shall have a taper of at least 3 to 1.			
7	Pipe QC	Remove all temporary lugs, supports and bracing.			
8	QC WE	Record the final gage reading to determine weld shrinkage.			
9	FE	After hot and cold legs are completely welded out and accepted, record dimensions indicated in attachment #1. These readings are to be submitted to mechanical engineering for review prior to installing closure stumps to be ordered by Westinghouse.			
INFORMATION COPY					
BROWN & ROOT, INC					
RECEIVED					
DEC 07 1978					
FILES NOTED					
QUALITY ASSURANCE					
FOIA-0339					
12-6-78 WE78-026-5505					
366 m [redacted]					

CONSTRUCTION OPERATION TRAVELER REVISION RECORD SHEET

TRAVELER NO. We78-026 - 5505	ACTIVITY DESCRIPTION RC Crossover Leg Installation FW 19	PAGE __ OF __
EQUIPMENT NO. SU 140 TBX-RCPCL-01		

ACTIVITY DESCRIPTION

① REV NO OP. NO.	② INITIAT- ED BY	③ REVIEWED BY		④ REVISION DESCRIPTION	⑤ QA/QC ENG	⑥ ANI
		QC	ANI			



QA RECORD

FILE'S
INDEXED

RTN.	QA REVIEW
Z 40 8684	
QA RECORD	FILE NO.
15.1	
SUBFILE NO.	NCR #
4	

BROWN & ROOT, INC. DATE:
 Quality Assurance Department
 Nonconformance Report (NCR)
 CPSES-35-1195

NCR NO. M- 14,651
 PAGE 1 OF 3

DRAWING/IDENTIFICATION (REV)	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
BC-1-520-001 10	EW 19	RB#1 826'	NA

NONCONFORMING CONDITION	SUBSYSTEM	ROOM NO.
DOCUMENT VIOLATED: CP-GAP 12.1	RC-1	C-1

REV. 11 PARA. 3.2.1.2 CATEGORY O-6

The original traveler ~~W-19~~ was issued for installation activities of loop 3 RC crossover leg for Field Weld 19 can not be located

INFORMATION
COPY
PPRV

(See attached copy which is also available at PPRV)

NO HOW+TAG APPLIED

REPORTED BY:	DATE:	REVIEW/APPROVAL:	DATE:	C.A.R. NUMBER:
<u>Ralph Clark</u>	<u>7/18/84</u>	<u>Old Neely</u>	<u>7/3/84</u>	<u>NA</u>
ACTION ADDRESSEE	'N' STAMPED ITEM	W-8-2 REQUIRED	ASME N-5 CERT.	
<u>Baker</u>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>			

DISPOSITION: REPAIR/REWORK USE AS IS OTHER

THIS TRAVELER WAS ORIGINALLY INTENDED TO BE WORKED IN CONJUNCTION WITH THE WOC FOR FW 19. THE W.E. TRAVELER PROGRAM FOR THE LOOP PIPING WAS DELETED SHORTLY AFTER ITS ORIGIN. W.E. TRAVELER LOG INDICATES THE TRAVELER IN QUESTION WAS NEVER ISSUED TO CONSTRUCTION. THE WOC PACKAGE STANDS ON ITS OWN. THEREFORE: QCI SHALL ANNOTATE THIS NCR # ON THE TRAVELER COPY THAT IS FILED IN THE PPRV.

Ref Traveler For closure - M.Cannon - 8/6/84

ENG REVIEW/ APPROVAL: <u>N/A</u>	DATE: <u>8/4/84</u>	QA REVIEW: <u>Old Neely</u>	DATE: <u>8/4/84</u>
CONSO. REVIEW/ APPROVAL: <u>Mary Madger</u>	DATE: <u>8-4-84</u>	ANI REVIEW/ CONCURRENCE: <u>Old Neely</u>	DATE: <u>8-4-84</u>
QC VERIFICATION: <u>M.Cannon</u>	DATE: <u>8-6-84</u>	WESTINGHOUSE CONCURRENCE: <u>N/A</u>	DATE: <u>8/4/84</u>
ANI REVIEW/ CONCURRENCE: <u>Jean Sherry</u>	DATE: <u>8/3/84</u>		
QA REVIEW/CLOSURE: <u>Old Neely</u>	DATE: <u>8/6/84</u>		

FOR INFORMATION ONLY

CONSTRUCTION OPERATION TRAVELER 36-1195

① TRAVELER NO. WE78-026-5505	② EQUIPMENT NO. S0140 TBX-RCPCLL-01	③ UNIT NO. 1	④ QUANTITY 1	⑤ PAGE OF
⑥ ACTIVITY DESCRIPTION RC Crossover Leg Installation	LOOP NO. 3 FW19	⑦ REFERENCE DRAWINGS 2323-M1-0520		
⑧ SPEC./PROC./ENG. INSTR. MS-100	⑨ LOCATION RB #1	⑩ SYSTEM RC		
PREPARED BY <i>John A. Shaff</i>	DATE 12/6/78	DEPT. Welding Eng.		
REVIEWED BY <i>D. Shaff</i>	DATE 12-6-78	QA/QC ENG ANI		
ANI REVIEW <i>for review</i>	DATE 12-7-78	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

OP. NO.	DEPT.	OPERATION	QA/QC ENG	ANI
		<u>NOTE:</u> All work to be accomplished in accordance with B & R CP-CPM-6.9 and drawing BRP-RC-1-520-1. For inspection hold points see appropriate weld data card.		
X 1	Pipe	Align and fit the 40° elbow to the Steam Generator outlet nozzle. The joint shall be fit and aligned in accordance with the HPS listed on the weld data card and CP-CPM-6.9.	FIT-UP	WDC
2	Pipe WE	Mark center of weld joint per FSM-00106. Apply punch marks to determine final weld shrinkage. Record initial gage reading at 12:00 _____, 3:00 _____, 6:00 _____, 9:00 _____	X	
3	HE	Monitor and document the weld metal thickness in each weld joint to attachment 4.		
4	Pipe	Welding will be discontinued at approximately $\frac{1}{2}$ " deposited metal.	X	
5	QC	See attachment 8 for intermediate RT, PT and WDC requirements.	SET UP WDC	
6	QC	The welds shall be contour ground with a maximum reinforcement of no more than 3/32" and shall have a taper of at least 3 to 1.	Final Gt 10/78	
7	Pipe QC	Remove all temporary lugs, supports and bracing.	Check wdc Set up	
R	QC WE	Record the final gage reading to determine weld shrinkage.		
F	FE	After hot and cold legs are completely welded out and accepted, record dimensions indicated in attachment #1. These readings are to be submitted to mechanical engineering for review prior to installing closure spools to be ordered by Westinghouse.	BROWN & ROOT, INC	

INFORMATION

COPY

PPRV

QA RECORD I

RTN.	QA REVIEW
FILE NO. 1201.55.11	
SUBFILE NO. WE78-026-5505	

RECEIVED


DEC 07 1978

FILES NOTED

QUALITY ASSURANCE

CONSTRUCTION OPERATION TRAVELER REVISION RECORD SHEET

TRAVELER NO. WE78-026-5505		ACTIVITY DESCRIPTION RC Crossover Leg Installation FW 19			PAGE OF
EQUIPMENT NO. SU 140	TBX-RCP CCL-01	① REV NO.	② REVIEWED BY	④ REVISION DESCRIPTION	⑤ QA/QC ENG
OP NO.	INITIAT- ED BY	QC	ANI		⑥ ANI



CONSTRUCTION OPERATION TRAVELER 35-1195					
(1) TRAVELER NO. WE-79-035-55-5	(2) EQUIPMENT NO. TBX- LOOP 1-SG & RCP	(3) UNIT NO. 1	(4) QUANTITY 2	(5) PAGE OF	
(6) ACTIVITY DESCRIPTION Erection of crossunder pipes		(7) REFERENCE DRAWINGS BRP-RC-1-520-1			
(8) SPEC./PROC./ENG. INSTR. MS-100	(9) LOCATION RB-1	(10) SYSTEM RC			
PREPARED BY <u>Douglas Mayo</u>		DATE <u>1-31-79</u>		DEPT. <u>WE</u>	
REVIEWED BY <u>S K Cashwell</u>		DATE <u>2/1/79</u>		QA/QC ENG ANI	
ANI REVIEW		DATE		<input type="checkbox"/>	<input type="checkbox"/>
OP. NO.	DEPT.	OPERATION	QA/QC ENG	ANI	
1	PI (QCCM)	<p>NOTE: All work is to be accomplished in accordance with B & R CP-CPM-6.9 and drawing BRP. RC-1-520-1. For inspection hold points see appropriate Weld Data Cards.</p> <p>Align and fit crossover connections. The three weld joints, with respect to each joint, shall be fit and aligned in accordance with the WPS listed on the appropriate Weld Data Card and CP-CPM-6.9.</p> <p>NOTE: The sequence for weldout of a two piece crossunder closure pipe is as follows: (The PHE will be notified prior to fit-up).</p> <p><u>Step 1</u> Mock fit the elbow to the RC pump volute and the intermediate vertical joint. The spool piece to 40° elbow joint is to be fit up on centerline only. The horizontal pipe section is intentionally manufactured long to allow for weld shrinkage in the intermediate vertical joint and its effect at the 40° elbow.</p> <p><u>Step 2</u> Deposit approximately $\frac{1}{2}$" of weld metal in the RC Pump to fitting joint. The subsequent metal shrinkage will effect the fitup of the two remaining joints. That effect must be monitored and corrective action taken as necessary. The limiting factor for how much metal to deposit is to be whenever the fitup is acceptable in the remaining joints.</p> <p><u>Step 3</u> Once either $\frac{1}{2}$" of weld deposit is reached or the 40° elbow vertical clearance is correct, deposit enough weld metal in the intermediate vertical joint to align the centerline of the pipe to the 40° elbow. If necessary, to obtain correct alignment, additional weld metal can be placed in the RC pump joint.</p> <p><u>Step 4</u> Once the 40° elbow is properly fitup, that joint should be welded to completion concurrently with the RC pump to fitting joint. This is to minimize any strain due to unequal weld shrinkage.</p>	FW4		
				FW5	
				FW16	

FOIA-85-59 M347

MEMORANDUM

WESTINGHOUSE FORM 2478 K

TBX-M-281

For.

Please see me

J

TO

CPSES

TUSI

J. B. GEORGE

JANUARY 23, 1979

LOCATION

DEPT.

NAME

DATE

SUBJECT

Note: The recommended sequence for weldout of a two piece crossunder closure pipe is as follows. C The P.W.E. will be notified prior to fit-up.

mock fit

1. Fit for weldout the elbow to the RC pump volute and the intermediate vertical joint. The spool piece to 40° elbow joint is to be fitup on centerline only. The horizontal pipe section is intentionally manufactured long to allow for weld shrinkage in the intermediate vertical joint and its effect at the 40° elbow.
2. Deposit approximately 1/2 inch of weld metal in the RC Pump to fitting joint. The subsequent metal shrinkage will effect the fitup of the two remaining joints. That effect must be monitored and corrective action taken as necessary. The limiting factor for how much metal to deposit is to be whenever the fitup is acceptable in the remaining joints.
3. Once either 1/2 inch of weld deposit is reached or the 40° elbow vertical clearance is correct, deposit enough weld metal in the intermediate vertical joint to align the centerline of the pipe to the 40° elbow. If necessary, to obtain correct alignment, additional weld metal can be placed in the RC pump joint. Obtain the typical shrinkage value based on the process being employed, and verify prior to welding that the intermediate joint shrinkage is enough for pipe alignment.
4. Once the 40° elbow is properly fitup, that joint should be welded to completion concurrently with the RC pump to fitting joint. This is to minimize any strain due to unequal weld shrinkage.
5. Complete the intermediate joint weldment. The majority of the weld shrink is to be expected during the first fifty percent of the total thickness. Weld shrink from the completion of the intermediate joint should be minimal and therefore induce a negligible amount of cold stress.

A Westinghouse representative must be notified prior to each fit up. It is recommended that all parties concerned be instructed in the method presented in the applicable traveler. This is a reasonably simple operation but an individual person's misinterpretation can cause a non reversible situation if specific verbal instructions are not presented.

*M. R. Wuestfeld*M. R. WUESTFELD
W Resident Mechanical Eng.
CPSEScc: U. D. Douglas, B&R
J. T. Merritt, TUST*P. S. Van Tesaar*P. S. VAN TESLAAR
W Site Manager
CPSESF. Shaikh, B&R
R. G. Tolson, TUGCO - Q/C
P. Clarke, B&R - Q/A

L 17.1.55

Category 11
AP4
item 6

WE 79-035-5505

CONSTRUCTION OPERATION TRAVELER 35-1195

(1) TRAVELER NO. WE-79-035-5505	(2) EQUIPMENT NO. TBX-* Loop 1-SG & RCP	(3) UNIT NO. 1	(4) QUANTITY 2	(5) PAGE OF
(6) ACTIVITY DESCRIPTION Erection of crossunder pipes		(7) REFERENCE DRAWINGS BRP-RC-1-520-1		
(8) SPEC / PROC / ENG. INSTR. TS-100	(9) LOCATION RD-1	(10) SYSTEM RC		
PREPARED BY <u>Douglas Mayo</u>	DATE <u>1-31-79</u>	DEPT.	WE	
REVIEWED BY <u>S K Cashwell</u>	DATE <u>2/1/79</u>	QA/QC ENG ANI		
ANI REVIEW <u>VJB Bawali</u>	DATE <u>2/13/79</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

OP. NO.	DEPT.	OPERATION	QA/QC ENG ANI
1	PI QCCM) ANI (PT end (Prep)	<p>NOTE: All work is to be accomplished in accordance with B & R CP-CPM-6.9 and drawing BRP. RC-1-520-1. For inspection hold points see appropriate Weld Data Cards.</p> <p>Align and fit crossover connections. The three weld joints, with respect to each joint, shall be fit and aligned in accordance with the WFS listed on the appropriate Weld Data Card and CP-CPM-6.9.</p> <p>NOTE: The sequence for weldout of a two piece crossunder closure pipe is as follows: (The PUE will be notified prior to fit-up).</p> <p><u>Step 1</u> Mock fit the elbow to the RC pump volute and the intermediate vertical joint. The spool piece to 40° elbow joint is to be fit up on centerline only. The horizontal pipe section is intentionally manufactured long to allow for weld shrinkage in the intermediate vertical joint and its effect at the 40° elbow.</p> <p><u>Step 2</u> Deposit approximately $\frac{1}{2}$" of weld metal in the RC Pump to fitting joint. The subsequent metal shrinkage will effect the fitup of the two remaining joints. That effect must be monitored and corrective action taken as necessary. The limiting factor for how much metal to deposit is to be whenever the fitup is acceptable in the remaining joints.</p> <p><u>Step 3</u> Once either $\frac{1}{2}$" of weld deposit is reached or the 40° elbow vertical clearance is correct, deposit enough weld metal in the intermediate vertical joint to align the centerline of the pipe to the 40° elbow. If necessary, to obtain correct alignment, additional weld metal can be placed in the RC pump joint.</p> <p><u>Step 4</u> Once the 40° elbow is properly fitup, that joint should be welded to completion concurrently with the RC pump to fitting joint. This is to minimize any strain due to unequal weld shrinkage.</p>	<p style="text-align: center;">INFORMATION COPY</p> <p style="text-align: right;">PPPA FHA FMC</p> <p style="text-align: right;">ARM'S INDEXED DATE 8-27-81</p>

* TBX-RCACFB-09 448 8-27-81

M368

CONSTRUCTION OPERATION TRAVELER CONTINUATION					
TRAVELER NO. WE-79-035-55-5		ACTIVITY DESCRIPTION Erection of crossunder pipes			PAGE <u> </u> OF <u> </u>
PREPARED BY <u>Douglas Mayo</u>		DATE <u>1/30/79</u>			
REVIEWED BY <u>K. White</u>		DATE <u>2/15/79</u>			
ANI REVIEW <u>N. J. Russell</u>		DATE <u>2/19/79</u>			
OP. NO.	DEPT.	OPERATION			QA/QC ENG ANI
2	PI WE	<u>Step 5</u> Complete the intermediate joint weldment. Mark center of weld joint per FSM 00106. Apply punch marks to determine final weld shrinkage. Record initial gage readings at: PUMP RC FW-4 <u>128.062</u> <u>38.00</u> <u>67.937</u> <u>98.062</u> FW-5 <u>128.00</u> <u>38.00</u> <u>68.062</u> <u>98.0</u> Ram air blow FW-6 <u>127.500</u> <u>37.500</u> <u>67.500</u> <u>97.625</u> Beam pump <small>Looking down on weld towards the SG.</small>			DAS 4/17/79 SW 4-16-79 SW 4-13-79
3	M/W	Monitor pump for any movement.			
4	WE	Intermediate R.T. will be done at the 1" level.			(1" LEVEL) DAS 4-23-79 FW4 DAS 4-23-79 FW5
5	WE	Intermediate R.T. will be done at the 2" level.			(2" LEVEL) DAS 4-23-79 FW6 SW 5-2-79
6	WE	Sign off final shrinkage measurements.			FW4 FW5 FW6 SW 6-11-79 SW 6-11-79 SW 6-11-79
<small>LOOKING DOWN TOWARD SG.</small> <small>LOOKING AT WELD TOWARD SG.</small>					
FW-4 <u>127.562</u> <u>37.625</u> <u>67.687</u> <u>97.625</u> FW-5 <u>127.625</u> <u>37.625</u> <u>67.750</u> <u>97.625</u> FW-6 <u>127.105</u> <u>37.00</u> <u>67.00</u> <u>97.250</u>					
INFORMATION COPY PPRV					

CONSTRUCTION OPERATION TRAVELER REVISION RECORD SHEET

TRAVELER NO. WE-79-035-55-5		ACTIVITY DESCRIPTION Erection of crossunder pipes			PAGE OF
EQUIPMENT NO. TBX- Loop 1-SG & RCP					
① REV NO OP NO	② INITIAT. ED BY	③ REVIEWED BY	④ REVISION DESCRIPTION		⑤ QA/QC ENG
QC	ANI				ANI
1 	BW 2-16-79 2-22-79 2-24-79	J. J. G. 2-16-79 2-24-79	PRIOR TO ERECTION ALL HELD ELD PREPS SHALL HAVE A PT. PERFORMED PER NDE P-300		
2 	DRM 3/23/79	WEC 3/23/79	HD8 4/13/79	N/A revision one	
3 	BW 4-20-79	EW 4/20/79	HD8 4/29/79	<p>ADD: NOTE*</p> <p>After 1" of metal has been deposited in the 40° EL and the RC Pump to fitting joint, welding on the intermediate vertical joint may be continued. On a case by case basis, repairs to the 40° EL and/or the RC Pump to fitting joint greater than $\frac{3}{8}$" in depth will be evaluated by the PWE and Westinghouse to decide if welding may continue at the Intermediate vertical joint.</p> <p style="text-align: right;">S/G Sauer (W) 4/20/79</p>	

INFORMATION
COPY
PPRV

17.1.55

Category 11
AP4
item 7

WE79-036-5505

CONSTRUCTION OPERATION TRAVELER 35-1195

(1) TRAVELER NO. WE-79-036-5505	(2) EQUIPMENT NO. TBX-RCPCFB-11	(3) UNIT NO. 1	(4) QUANTITY 1	(5) PAGE OF
(6) ACTIVITY DESCRIPTION Erection of Crossunder Pipes		(7) REFERENCE DRAWINGS BRP-RC-1-520-1		
(8) SPEC / PROC / ENG INSTR. IS-101	(9) LOCATION RF-1	(10) SYSTEM RC		
PREPARED BY Douglas Mayo	DATE 1/30/79	DEPT. WKE		
REVIEWED BY SK Cessell	DATE 2/1/79	QA/QC ENG ANI		
ANI REVIEW H. J. Powell	DATE 2/19/79	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

OP. NO	DEPT.	OPERATION	QA/QC ENG	ANI
		NOTE: All work is to be accomplished in accordance with B & R CP-CPM-6.9 and drawing BRP. RC-1-520-1. For inspection hold points see appropriate Weld Data Cards.		
1	PI (QC(M)) <i>AN</i> <i>frst</i>	Align and fit crossover connections. The three weld joints, with respect to each joint, shall be fit and aligned in accordance with the WPS listed on the appropriate Weld Data Card and CP-CPM-6.9.	FLU20 FLU21 FLU22	<i>2/28/79</i> <i>2/28/79</i> <i>2/28/79</i>
		NOTE: The sequence for weldout of a two piece crossover closure pipe is as follows: (The PWE will be notified prior to fit-up).		
	INFORMATION COPY	Step 1 Mock fit the elbow to the RC pump volute and the intermediate vertical joint. The spool piece to 40° elbow joint is to be fit up on centerline only. The horizontal pipe section is intentionally manufactured long to allow for weld shrinkage in the intermediate vertical joint and its effect at the 40° elbow.		
	PPRV	Step 2 Deposit approximately $\frac{1}{2}$ " of weld metal in the RC Pump to fitting joint. The subsequent metal shrinkage will effect the fitup of the two remaining joints. That effect must be monitored and corrective action taken as necessary. The limiting factor for how much metal to deposit is to be whenever the fitup is acceptable in the remaining joints.		
		Step 3 Once either $\frac{1}{2}$ " of weld deposit is reached or the 40° elbow vertical clearance is correct, deposit enough weld metal in the intermediate vertical joint to align the centerline of the pipe to the 40° elbow. If necessary, to obtain correct alignment, additional weld metal can be placed in the RC pump joint.		
		Step 4 Once the 40° elbow is properly fitup, that joint should be welded to completion concurrently with the RC pump to fitting joint. This is to minimize any strain due to unequal weld shrinkage.		
		* TBX-RCPCFB-11 DAS 8-27-81	ARMS INDEXED	DATE

FOIA 85-501369

CONSTRUCTION OPERATION TRAVELER CONTINUATION					
TRAVELER NO.		ACTIVITY DESCRIPTION			PAGE OF
WE-79-036-5505		Erection of Crossunder Pipes			
PREPARED BY Douglas Mayo DRM		DATE 1/30/79			
REVIEWED BY R. White		DATE 2/15/79			
ANI REVIEW B. J. Russell		DATE 2/19/79			
OP. NO.	DEPT.	OPERATION			QA/QC ENG ANI
2	PI WE	Step 5 Complete the intermediate joint weldment. Mark center of weld joint per FSM 00106. Apply punch marks to determine final weld shrinkage. Record initial gage readings at:			FW20 FW21 FW25 DRM 7-5-79 DRM 7-28-79 DRM 6-18-79
3	M/W	Monitor pump for any movement.			
4	WE	Intermediate R.T. will be done at the 1" level.			FW20 FW21 FW25 DRM 7-15-79 DRM 7-13-79 DRM 7-17-79
5	WE	Intermediate R.T. will be done at the 2" level.			FW20 FW21 FW25 DRM 7-15-79 DRM 7-13-79 DRM 7-17-79
6	WE	Sign off final shrinkage measurements.			FW20 FW21 FW25 DRM 7-15-79 DRM 7-13-79 DRM 7-17-79
		Looking North AT Pump, Down on Pipe FW-20 12 7 687 3 7 625 6 7 687 9 7 531 Looking North AT Pump 7-25-79 FW-21 12 7 531 3 7 375 6 7 781 9 7 375 Looking South AT SC Down on Pipe FW-22 12 7 002 3 7 175 6 7 002 9 7 156			DRM 7-25-79 DRM 7-25-79 DRM 7-25-79

CONSTRUCTION OPERATION TRAVELER REVISION RECORD SHEET

TRAVELER NO. WE-79-036-5505		ACTIVITY DESCRIPTION Erection of Crossunder Pipes				PAGE OF
① REV NO OF NO	② INITIAT- ED BY	③ REVIEWED BY	④ REVISION DESCRIPTION		⑤ QA QC ENG	⑥ ANI
			QC	ANI		
1	Bur 2-6 etc 2/10/79	ccc 2/10/79	HJG 4/13/79	Prior to ERECTION ALL WELD END PREPS SHALL HAVE A PT. PERFORMED PER NDE P-300.		
2	DRM 3/23/79	ccc 3/23/79	HDP 4/13/79	N/A revision one		
3	Bur 4-20-79	gav 4/20/79	HDP 4/20/79	add: Note After 1" of metal has been deposited in the 40° EL. and the RC Pump to fitting joint, welding on the intermediate vertical joint may be continued. On a case by case basis, up to the 40° EL and/or the RC Pump to fitting joint greater than $\frac{3}{8}$ " in depth will be evaluated by the PWE and Westinghouse to decide if welding may continue at the intermediate vertical joint. H.B. Soccy (4) 4/20/79		

INFORMATION
COPY
PPRV

L 17.155

WE79-037-5505

CONSTRUCTION OPERATION TRAVELER 35-1195

(1) TRAVELER NO.	037 INT WE-79-037-5505	(2) EQUIPMENT NO.	TEX- 1 Loop 4-SG and RCP	(3) UNIT NO.	1	(4) QUANTITY	2	(5) PAGE OF
(6) ACTIVITY DESCRIPTION					(7) REFERENCE DRAWINGS			
Fretion of crossunder pipes				BRP-RC-1-520-1				
(8) SPEC./PROC./ENG. INSTR.	(9) LOCATION				(10) SYSTEM			
WS-12	RC-1				RC			
PREPARED BY	Dowles have DCMY		DATE	1/30/79	DEPT.	WE		
REVIEWED BY	G.K. Caswell		DATE	2/1/79	QA/QC ENG ANI			
ANI REVIEW	H.J. Caswell		DATE	4/19/79	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

OP. NO.	DEPT.	OPERATION	QA/QC ENG	ANI
		NOTE: All work is to be accomplished in accordance with B & R CP CP-6.9 and drawing BRP. RC-1-520-1. For inspection hold points see appropriate Weld Data Cards.		
1	PI QC(N)	Align and fit crossover connections. The three weld joints, with respect to each joint, shall be fit and aligned in accordance with the WPS listed on the appropriate Weld Data Card and CP-CPM-6.9.	4/13/79 FW12 FM13 FM14	A-57 4/13/79
		NOTE: The sequence for weldout of a two piece crossunder closure pipe is as follows: (The PWE will be notified prior to fit-up.)		
		Step 1 Mock fit the elbow to the RC pump volute and the intermediate vertical joint. The spool piece to 40° elbow joint is to be fit up on centerline only. The horizontal pipe section is intentionally manufactured long to allow for weld shrinkage in the intermediate vertical joint and its effect at the 40° elbow.	XK 4/5/79	RLB 4.5 79
		Step 2 Deposit approximately $\frac{1}{2}$ " of weld metal in the RC Pump to fitting joint. The subsequent metal shrinkage will effect the fitup of the two remaining joints. That effect must be monitored and corrective action taken as necessary. The limiting factor for how much metal to deposit is to be whenever the fitup is acceptable in the remaining joints.		
		Step 3 Once either $\frac{1}{2}$ " of weld deposit is reached or the 40° elbow vertical clearance is correct, deposit enough weld metal in the intermediate vertical joint to align the centerline of the pipe to the 40° elbow. If necessary, to obtain correct alignment additional weld metal can be placed in the RC pump joint.		
		Step 4 Once the 40° elbow is properly fitup, that joint should be welded to completion concurrently with the RC pump to fitting joint. This is to minimize any strain due to unequal weld shrinkage.		
		* TBX-RCPCFB-10 MS 8-27-81		

INFORMATION
COPY
PPRV

ARMS
INDEXED

TUIH-00-JY

m370


CONSTRUCTION OPERATION TRAVELER CONTINUATION					
TRAVELER NO. 037 WRM WE-79-037-5505		ACTIVITY DESCRIPTION Friction of crossunder pipes			PAGE <u> </u> OF <u> </u>
PREPARED BY <u>Douglas Mayo</u>		DATE <u>1/30/79</u>			
REVIEWED BY <u>T. White</u>		DATE <u>2/02/79</u>			
ANI REVIEW <u>B. D. Smith</u>		DATE <u>2/02/79</u>			
OP. NO.	DEPT.	OPERATION			QA QC ENG ANI
		<u>Step 5</u> Complete the intermediate joint weldment.			
2	PI WE	Mark center of weld joint per FSM 00106. Apply punch marks to determine final weld shrinkage. Record initial gage readings at:			FW12 FW13 FW14
		FW-12 12 ^{8 1/2} 39.937 68.312 9 8.250	^{north} ^{east} ^{PC}	^{south} ^{west} ^{PC}	Bur 4-13-79
		FW-13 12 8.062 3 8.187 6 8.000 9 8.000	^{PC}		4/9/79
		FW-14 12 7.500 3 7.750 6 7.937 9 7.437	^{PC}	^{GEN.}	4/10/79 4/11/79 4/12/79 4/13/79
3	M/W	Monitor pump for any movement.			(1" LEVEL) 4/12/79 — 4/13/79
4	WE	Intermediate R.T. will be done at the 1" level.			FW12 FW13 FW14
5	WE	Intermediate R.T. will be done at the 2" level.			4/12/79 — 4/13/79
6	WE	Sign off final shrinkage measurements.			FW12 FW13 FW14
		FW-12 12 ⁰⁰ 7.750 3 7.500 6 7.937 9 7.875			Bur 5-2-79
		FW-13 12 ⁰⁰ 7.687 3 7.697 6 7.687 9 7.843			Bur 7-14-79
		FW-14 12 ⁰⁰ 7.53 3 7.53 6 7.343 9 7.156			FINAL SHRINK. 7-14-79
		<i>Facsimile keeping no. 037-5505</i>			

INFORMATION
COPY
PPRV

760 5/1/79

CONSTRUCTION OPERATION TRAVELER 35-1195										
(1) TRAVELER NO. WE-79-037-5505		(2) EQUIPMENT NO. TBX Loop 2-SG and RCP		(3) UNIT NO. 1	(4) QUANTITY 2	(5) PAGE OF				
(6) ACTIVITY DESCRIPTION Erection of crossunder pipes				(7) REFERENCE DRAWINGS BRP-RC-1-520-1						
(8) SPEC./PROC./ENG. INSTR. MS-100		(9) LOCATION RB-1		(10) SYSTEM RC						
PREPARED BY <i>David G. Stiles</i>		DATE <u>5/1/79</u>		DEPT <u>WE</u>						
REVIEWED BY <i>L.K. Resnick</i>		DATE <u>5-1-79</u>		QA QC ENG ANI						
ANI REVIEW <i>SL Limbo</i>		DATE <u>5-1-79</u>		<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		
OP. NO.	DEPT.	OPERATION	FW-12					QA/QC ENG	ANI	
		FW-12: The present location of R.T. station marks on FW-12 prohibits accomplishing a 3 to 1 taper. Therefore the following steps shall be performed.								
1.	Q.C. <i>ANI</i>	1.	Transfer R.T. station markers to an acceptable location				<i>d.m.f</i> <u>5-2-79</u> <u>RLD</u> <u>5-2-79</u>			
2.	P.D.	2.	Transfer any weldor's symbols to the nozzle on steam generator side.							
3.	W.E. G.H.	3.	The P.W.E. and Gibbs and Hill evaluate the final X-ray. (OF BASE METAL CONTAINING WELD)				<i>5/2/79</i> <i>REC 5-2-79</i> <i>SCR 5-2-79</i>			
<div style="text-align: center; border: 1px solid black; padding: 10px; margin-top: 20px;"> INFORMATION COPY PPRV </div>										

CONSTRUCTION OPERATION TRAVELER CONTINUATION					
TRAVELER NO. WE-79-037-5505		ACTIVITY DESCRIPTION Weld a 3 to 1 Taper		PAGE OF _____	
PREPARED BY <u>David A. Stutes</u>		DATE <u>5-2-79 (we)</u>			
REVIEWED BY <u>L.K. Seshu CC</u>		DATE <u>5-2-79</u>			
ANI REVIEW <u>JM Ober</u>		DATE <u>5/2/79</u>			
OP. NO.	DEPT.	OPERATION			QA/QC ENG
A.	Q.C.	FW-12	A. Weld approximately 3/4" back from the toe of weld on to the spool 8Q1, in order to achieve a 3 to 1 taper.		<u>J. J.</u> <u>5/4/79</u>


 INFORMATION
COPY
 PPRV

CONSTRUCTION OPERATION TRAVELER REVISION RECORD SHEET

TRAVELER NO 037 WRM WE-79-037-5505		ACTIVITY DESCRIPTION Erection of crossunder pipes			PAGE OF
① REV NO OP NO	② INITIAT- ED BY	③ REVIEWED BY QC	④ REVISION DESCRIPTION	⑤ QA/QC ENG	⑥ ANI
1	Su - 2623 3/23/79 3/23/79 3/23/79	QC 3/23/79	Prior to Erection ALL WELD END PREPS SHALL HAVE A PT. PERFORMED PER NDEP 300	H.E.S. 3/23/79	SRT 3/23/79
2	DRAM 3/23/79 3/23/79 3/23/79		No revision one DRAM 3/23/79		
3	but 4-20-79	gav 4/20/79	XDP 4/20/79	Add! Note # After 1" of metal has been deposited in the 40° El. and the KC Pump to fitting joint, welding on the intermediate vertical joint may be continued. On a case by case basis, repairs to the 40° El and/or the KC Pump to fitting joint greater than $\frac{3}{8}$ " in depth will be evaluated by the PWE and Westinghouse to decide if welding may continue at the intermediate vertical joint. H.B. Doocy (W) 4/20/79	

INFORMATION
COPY
 PPRV



Brown & Root, Inc.
QUALITY ASSURANCE DEPARTMENT
NDE LIQUID PENETRANT REPORT

SERIAL NUMBER


PROJECT: COMANCHE PEAK JOB NO. 35-1195 UNIT / PAGE / OF /

DRAWING BRP-RC-1-520-1	SYSTEM 5505	CLASS <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD/ITEM IDENTIFICATION FLW-13 SPOOL 9Q1	LOCATION R.B.	

MTL. TYPE P-8	MTL. THICK 2.48	DIA/LENGTH 31" ID	DIA./WIDTH	LENGTH
STAGE OF MFG. <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE	END PREP	<input type="checkbox"/> FINAL	<input type="checkbox"/> BRN <input type="checkbox"/> BKS <input type="checkbox"/> INS <input type="checkbox"/> OPEN BUTT	<input type="checkbox"/> OTHER

PENETRANT MFG. MAGNAFLUX	BRAND SPOTCHECK BATCH	DWELL TIME 10 MIN
CLEANER MFG. MAGNAFLUX	BRAND SPOTCHECK BATCH	
DEVELOPER MFG. MAGNAFLUX	BRAND SPOTCHECK BATCH	DEVELOPING TIME 7 MIN
NDE PROCEDURE NO. 300	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND	MACHINED <input type="checkbox"/> OTHER

SKETCH & REMARKS

OD


ID

INFORMATION COPY PPRV

ACCEPTANCE STD. NDEP-300	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/>	DATE 3/22/79
INSPECTOR H.L. Stutler	SRT 3/23/79	CERTIFICATION LEVEL II



Brown & Root, Inc.

Post Office Box 1000 • Houston, Texas 77001

**QUALITY ASSURANCE DEPARTMENT
NDE LIQUID PENETRANT REPORT**

PROJECT: COMANCHE PEAK

JOB NO. 35-1195

UNIT 1

PAGE 1 OF 1

DRAWING BRP-RC-1-520-1	SYSTEM RC.	CLASS <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD/ITEM IDENTIFICATION Fw 13 Spec 1 8 G1 A End	LOCATION CONTAINMENT	
MTL TYPE P-8	MTL THICK 2.48"	BIA/LENGTH 31"10 DIA/WIDTH
PENETRANT MFG. MAGNAFLUX		INDE PROCEDURE NO. CP-NDEB-00
CLEANER MFG. MAGNAFLUX		BRAND SPOTCHECK
DEVELOPER MFG. MAGNAFLUX		BRAND SPOTCHECK
STAGE OF MFG. <input checked="" type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND <input checked="" type="checkbox"/> OTHER	MACHINED
DWELL TIME 10	DEVELOPING TIME 10	
REMARKS		

INFORMATION**COPY****PPRV**

ACCEPTANCE STD. ASME SECTION III <input checked="" type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/>	DATE 3/21/79
INSPECTOR W.T. Sims	3/21/79	CERTIFICATION LEVEL II
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE	
DWELL TIME	DEVELOPING TIME	
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND <input type="checkbox"/> OTHER	
DWELL TIME	DEVELOPING TIME	
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND <input type="checkbox"/> OTHER	
DWELL TIME	DEVELOPING TIME	
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	



Brown & Root, Inc.

P.O. Box 1000 • Dallas, Texas 75204

QUALITY ASSURANCE DEPARTMENT
NDE LIQUID PENETRANT REPORT

PROJECT: COMANCHE PEAK

JOB NO. 35-1195

UNIT /

PAGE / OF /

DRAWING BRP-RC-1-520-1	SYSTEM R.C.	CLASS <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD/ITEM IDENTIFICATION FW 14 spcc 19G1 A END	LOCATION CONTAINMENT	
MTL TYPE P-8	MTL THICK 2.48"	BIA/LENGTH 31" TD DIA/WIDTH LENGTH
PENETRANT MFG. MAGNAFLUX	BRAND SPOTCHECK	NDE PROCEDURE NO. CP-NDEPC
CLEANER MFG. MAGNAFLUX	BRAND SPOTCHECK	
DEVELOPER MFG. MAGNAFLUX	BRAND SPOTCHECK	
STAGE OF MFG. <input checked="" type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND <input checked="" type="checkbox"/> OTHER	MACHINED DDRV DEVELOPING TIME 10
DWELL TIME 10		
REMARKS		

INFORMATION COPY

ACCEPTANCE STD. ASME SECTION III <input checked="" type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/>	DATE 3/21/79
INSPECTOR W.T. Sims	<i>898</i> 3-21-79	CERTIFICATION LEVEL II
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE	
DWELL TIME		DEVELOPING TIME
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND <input type="checkbox"/> OTHER	
DWELL TIME	DEVELOPING TIME	
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED <input type="checkbox"/> GROUND <input type="checkbox"/> OTHER	
DWELL TIME	DEVELOPING TIME	
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	



Brown & Root, Inc.

Post Office Box 1001, Glen Rose, Texas 76043

**QUALITY ASSURANCE DEPARTMENT
NDE LIQUID PENETRANT REPORT**

PROJECT: COMANCHE PEAK

JOB NO. 35-1195

UNIT 1

PAGE 1 OF 1

DRAWING BRP-RC-1-520-1	SYSTEM R.C.	CLASS <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD/ITEM IDENTIFICATION FW 12 Spec 8 A 1	LOCATION CONTAINMENT	

MTL. TYPE P-8	MTL. THICK 2.48"	BIA/LENGTH 31" ID	DIA/WIDTH	LENGTH
PENETRANT MFG. MAGNAFLUX		BRAND SPOTCHECK	NDE PROCEDURE NO. CP-NDEP-300	
CLEANER MFG. MAGNAFLUX		BRAND SPOTCHECK		
DEVELOPER MFG. MAGNAFLUX		BRAND SPOTCHECK		
STAGE OF MFG. <input checked="" type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED	INFORMATION COPY		
DWELL TIME 10 min			PPRV MACHINED GROUNDED <input checked="" type="checkbox"/> OTHER 10 min	
REMARKS				

ACCEPTANCE STD. ASME SECTION III <input checked="" type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/>	DATE 3 / 21 / 79
INSPECTOR <i>Jim Ruiz</i>	<i>3-21-79</i>	CERTIFICATION LEVEL II
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED	
DWELL TIME	DEVELOPING TIME	
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED	<input type="checkbox"/> GROUNDED <input type="checkbox"/> OTHER
DWELL TIME	DEVELOPING TIME	
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	
STAGE OF MFG. <input type="checkbox"/> END PREP <input type="checkbox"/> EXCAVATION <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL	SURFACE <input type="checkbox"/> AS WELDED	<input type="checkbox"/> GROUNDED <input type="checkbox"/> OTHER
DWELL TIME	DEVELOPING TIME	
REMARKS		

ACCEPTANCE STD. ASME SECTION III <input type="checkbox"/> ANSI B31.1 <input type="checkbox"/>	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /
INSPECTOR	CERTIFICATION LEVEL	



Brown & Root, Inc.
INSPECTION REPORT

PAGE 1 OF 1

	5505	
PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-4	5-10	11-16
PURCHASE ORDER NUMBER	VEND CODE	
56-69	70-73	

FW-13
SPOOL 901 BRP-RC-1-520-1

TAG/SPIN/IDENT NO						DRAWING/SPECIFICATION NO			SERIAL NO		
A	B	C	D	E	F	G	(Units)	H	(Units)	J	(Units)
						17-55					

						NCR # <u>17-1377</u>	<u>3/22/79</u>
MRR NUMBER	RIR NUMBER	VENDORS HEAT/LOT/BATCH NO.	COUNT	UNITS	PURCH'S OR NO.	RLS HOLD NO	CODE
			QUANTITY			STATUS	
74-79	80-85	86-95	96-105		106-111	112-121	122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE:


P.T. OF END PREP

RESULTS OF INSPECTION / SURVEILLANCE:

UPON RE-INSPECTION OF THE END PREP THE INDICATIONS WHICH WERE PREVIOUSLY REJECTS WERE EVALUATED WITH AN OPTICAL COMPARITOR AND FOUND TO BE ACCEPTABLE I.A.W. NDEP-300.

BASED UPON THE ABOVE THE REJECTABLE NDE REPORT AND NCR# 17-1377 SHOULD BE VOIDED/CANCELED.

HOLD TAG HAS BEEN REMOVED.



NCR NO. 17-1377

QA-15 1/1-0(4-1-77)

H. E. Stahl
QC ENGINEER/INSPECTOR

DATE 3/22/79

35-1195
2-27-79**Brown & Root, Inc.** Post Office Box 1001, Glen Rose, Texas 76043

BRF-9181

February 27, 1979



Mr. J. T. Merritt, Jr.
Texas Utilities Services, Inc.
P. O. Box 1002
Glen Rose, TX 76043

TEXAS UTILITIES SERVICES, INC.
COMANCHE PEAK STEAM ELECTRIC STATION
1981-83 2300 MW INSTALLATION
REACTOR COOLANT PIPE
REF: BRF-9152 2-19-79
P.O. # CP-0001
[Redacted]
[Redacted]


Dear Mr. Merritt:

Attached is revision-1 to the measurements transmitted by the referenced letter. The revision affects the miter to be machined on the end prep adjacent to the steam generator. All other dimensions remain the same.

Please contact us if any questions arise concerning these measurements.

Very truly yours,


BROWN & ROOT, INC.


U. D. Douglas
Project Manager

JHR
UDD:JHM:JJR:eh
cc: ARMS OL,1A
L. A. Ashley 1L,1A
J. T. Merritt 1L,1A

FOIA-85-59

M371



LOOKING TOWARDS THE REACTOR

SCALE:
1/4" = 1'-0"

CLIENT TEXAS UTILITIES SHEET NO. 1 OF 2
SUBJECT CLOSURE LOOP FIELD MEASUREMENTS UNIT-1, LOOP-2
BASED ON FILED MEASUREMENTS DRAWING NO.
COMPUTER FILED ENR. CHG. BY J.H.H. APP'D. BY J.R. DATE 2-19 1979

BROWN & ROOT, INC. ENGINEERING DIVISION



BROWN & ROOT, INC.
ENGINEERING DIVISION

SHEET NO. 2 OF 2

CLIENT TEXAS UTILITIES

JOB NO. 35-1195

SUBJECT CLOSURE LOOP FIELD MEASUREMENTS, UNIT-1, LOOP-2

BASED ON FIELD MEASUREMENTS

DRAWING NO.


COMPUTER FIELD ENGR. CHN'D BY J.T.R.

APP'D. BY

Jay Ry DATE 2/27 1975

Revision-1

R.C. PUMP
NOZZLE




#1 - $3' - 9 \frac{7}{64}''$
#2 - $3' - 9 \frac{7}{64}''$
#3 - $3' - 9 \frac{7}{64}''$
#4 - $3' - 9 \frac{7}{64}''$
Avg - $3' - 9 \frac{7}{64}''$

$$\begin{array}{r} 8' - 4 \frac{35}{64} \\ 3' - 9 \frac{2}{64} \\ \hline 4' - 7 \frac{1}{16}'' \end{array}$$

N

STM. GEN.
NOZZLE



#1 - $8' - 4 \frac{43}{64}''$
#2 - $8' - 4 \frac{37}{64}''$
#3 - $8' - 4 \frac{29}{64}''$
#4 - $8' - 4 \frac{35}{64}''$
Avg. - $8' - 4 \frac{25}{64}''$

35-1195
3-12-79

Category II
AP 4
Item II

Brown & Root, Inc. Post Office Box 1001, Glen Rose, Texas 76043

BRF- 9207

March 12, 1979



Mr. J. T. Merritt, Jr.
Texas Utilities Services, Inc.
P. O. Box 1002
Glen Rose, TX 76043

Texas Utilities Services, Inc.
COMANCHE PEAK STEAM ELECTRIC STATION
1981-83 2300 MW Installation
P. O. CP-0001
Reactor Coolant Pipe Field Measurements

Dear Mr. Merritt:

Attached are the field measurements required for the fabrication of the closure loop for Unit-1, Loop-4. Also, noted on the sketch are the fabrication allowances for weld shrinkage and consumable insert.

Please contact us if you have any questions concerning these measurements.

Very truly yours,

BROWN & ROOT, INC.


U. D. Douglas
Project Manager

Attachment ~~DR~~

UDD:JHM:JJR:eh
cc: ARMS OL, 1A
L. A. Ashley 1L,1A
J. T. Merritt 1L,1A

HUIA-85-55

M372



NOT: ALLOW $\frac{3}{8}$ " FOR SINKAGE AND $\frac{1}{8}$ " FOR
FIT-UP AT ALL FIELD WELDS

SCALE:
 $\frac{1}{4}" = 1'-0"$

CLIENT TEXAS UTILITIES
SHEET NO. 1 OF 1
PROJECT CLOSURE LOOP FIELD MEASUREMENTS, UNIT-1, LOOP-4
BASED ON AS-BUILT MEASUREMENTS
DRAWING NO. 35-1195
COMPUTER FIELD ENGR. CHK'D BY JR APP'D BY JAY DR DATE 3-12-1972

BROWN & ROOT, INC.
ENGINEERING DIVISION

Brown & Root, Inc. Post Office Box 1001, Glen Rose, Texas 76043-

BRF-9211

March 13, 1979



Mr. J.T. Merritt, Jr.
Texas Utilities Services, Inc.
P. O. Box 1002
Glen Rose, Texas 76043

Texas Utilities Services, Inc.
Comanche Peak Steam Electric Station
1981-83 2300 MW Installation
Reactor Coolant Pipe Field Measurements

Dear Mr. Merritt:

Attached are the field measurements required for the fabrication of the closure loop for Unit 1, Loop-1. Also, noted on the sketch are the fabrication allowances for weld shrinkage and consumable insert.

Please contact us if you have questions concerning these measurements.


Very truly yours,
BROWN & ROOT, INC.

U. D. Douglas
U. D. Douglas
Project Manager

Attachment *JTR*
UDD:JHM:JJR:kc
cc: ARMS (OL,1A)
L. A. Ashley (1L,1A)
J. T. Merritt (1L,1A)

FOIA-85-59

M373



NOTE:
ALLOW $\frac{3}{8}$ " FOR SHRINKAGE AND $\frac{1}{16}$ " FOR
FIT-UP AT ALL FIELD WELDS

SCALE:
 $\frac{1}{4}" = 1'-0"$

CLIENT TEXAS UTILITIES SHEET NO. 1 OF 1
SUBJECT CYCLIC LOOP FIELD MEASUREMENTS BASED ON AS BUILT MEASUREMENTS DRAWING NO.
COMPUTER FILED ENGR. CHG'D BY DR APPROVED DATE 3-13 1975

BROWN & ROOT, INC. ENGINEERING DIVISION

Also Available On
Aperture Card

TI
APERTURE
CARD

Aperture Card
Also Available On

WELD END DIMENSIONAL CHECK

(11)	C = 31.200" $\pm .010"$ ACTUAL = 31.200" - 31.206"	LIP THICKNESS = .090" $\pm .015"$ ACTUAL = .082" - .102"
(12)	C = 31.200" $\pm .010"$ ACTUAL = 31.202" - 31.210"	LIP THICKNESS = .090" $\pm .015"$ ACTUAL = .083" - .098"
(C)	C = 2.693" $\pm .010"$ ACTUAL = 2.692" - 2.694"	LIP THICKNESS = .055" $\pm .005"$ ACTUAL = .060" - .064"

BEV. ITEM	0°	90°	180°	270°	W. B.W. LOCATION
(11)	2.507	2.494	2.506	2.499	2 1-9 1/8"
(12)	2.481	2.491	2.494	2.490	2 1-7 13/16"
(13)	2.507	2.509	2.508	2.513	1-10 13/16"
(14)	2.519	2.501	2.503	2.516	9 5/16"

EDGE OF HOLE MUST BE CLEAN & SHARP .005" MAX.
RADIUS, FREE FROM BURRS, WIRE EDGES, OR OTHER
IRREGULARITIES.




TBX-LOOP-1-RCP-SIDE
SER# 13277


DRILL THRU &
REAM OR GRIND
TO DEBURR.
(AFTER WELDING)
(CPLG. TO ELL)

T.I.G. ROOT PASS
(FULL PENETRATION)

DETAIL "X"
(TYPICAL 4 PLACES)




SECT. "A-A"




DETAIL "A"

SHOP INSTALL ON SAME AS PIPE MFG. R



1-EACH REQ'D MK: A" SHOWN

NO.



DETAIL "B"

ASME III / 1974 THIS ADDENDA
WINTER 1975 Case CASE 1423-2

1. MARK WITH LOW STRESS STENCIL OR RETCH.
HEAT AND SERIAL NO. TO BE APPLIED TO
EACH PART OF THE FABRICATED ASSEMBLY.
2. SEE ATTACHED MANUFACTURING RECORD SHEET
FOR DOCUMENTATION AND PROCEDURES.
3. INSTALL 3/4" THRU 2" NOZZLES PER SHEET
4B (R/I)
4. INSTALL 3" AND LARGER NOZZLES PER SHEET
4A (R/I)
5. T.T.G. ROOT PASS OF ALL WELDS.
6. CONTOUR GRIND ALL WELDS - 250 RMS MAX.
7. MAXIMUM REINFORCEMENT OF BUTT WELDS IS
1/16" PER DET. "A".
8. ALL TEMPORARY ATTACHMENTS SHALL BE OF A
COMPATIBLE AND IDENTIFIED MATERIAL.
9. ALL SURFACES FROM WHICH METAL HAS BEEN
GROUND BY THE SHOP, SHALL BE LIQUID
PENETRANT EXAMINED PER PROCEDURE.
10. LIQUID PENETRANT EXAMINE PER PROCEDURE
THE ROOT PASS, AND ALL ACCESSIBLE
SURFACES OF FINISHED BUTT WELDS, NOZZLE
WELDS, VELLET WELDS, AND THE NEAR
AFFECTED ZONE OF THE BASE METAL
ADJACENT TO THE WELD. IN ADDITION,
FOR NOZZLES 4" AND SMALLER, LIQUID
PENETRANT EXAMINE EACH 1/2" INCREMENT
OF WELD DEPOSITS.
11. REMOVE LOGS FROM ELL & P.T. GROUND
SURFACES PER PROCEDURE.
12. LIQUID PENETRANT EXAMINE PER PROCEDURE
ACCESSIBLE FINISHED MACHINED NOZZLE HOLES,
BEVELS AND GROUND SURFACE INSIDE HEADER
AT NOZZLE WELDS.
13. LIQUID PENETRANT EXAMINE PER PROCEDURE
ALL PIPE WELD BEVELS AND WELD SURFACE
CUT IN WALL FOR I.D. NOZZLE WELD.
14. RADIGRAPH 4" AND LARGER BUTT WELDS
AND NOZZLE WELDS PER PROCEDURE.
15. CLEAN AND PREPARE FOR SHIPMENT PER
PROCEDURES. WAPD 4 1/4 & WAPD 6 R/I.
16. DIMENSION INCLUDES $\frac{1}{16}$ " FOR FIELD WELD
SHRINKAGE. (1 PLACE).
17. DIMENSION INCLUDES — FOR FIELD WELD
SHRINKAGE (— PLACES).
18. SHOT TO COMPLETE W/ SPIN NO. ON PIPE
RPM. NAME PLATE.
19. FILLER METAL: TP 308 STAINLESS STEEL.
20. RECORD WALL THK. AT C BORE AND MEASURED
LOCATION OF BUTT WELD OF NAME PLATE AND
TABLE PER DETAIL A.
21. 3 1/2" MIN. DESIGN THICKNESS = 2.48"
22. CONT. WELD MFG. NAME & IN LOCATION
INDICATED BY NAME MFG. AT 4 DOCUMENTS

SOUTHWEST FABRICATING & WELDING CO. PD BOX 9449 HOUSTON, TEXAS 77011

NO	QUA	DESCRIPTION	QUA	UNIT	TOTAL
A 1	31" I.D. 90° ELL (1/2) (100% RTJ AT ALL SURFACES) CE BA HEAT # 3-319/2655 SER# 2	SA-351 100% RTJ (AT ALL SURFACES) CE BA 1/2" MIN. 1/2" MAX 1/2" (1/2)			EXCEPT HYDRO. AFTER ERECTIO.
B 1	31" I.D. 90° ELL WITH PLIUM (100% RTJ (AT ALL SURFACES) CE BA 1/2" MIN. 1/2" MAX 1/2" (1/2)	SA-351 100% RTJ (AT ALL SURFACES) CE BA 1/2" MIN. 1/2" MAX 1/2" (1/2)			EXCEPT HYDRO. AFTER ERECTIO.
C 1	3" SCH 160 NOZ. ON 31" I.D. HDPE PER SH. M-4A (50 MACHINE FEIGN IN SHOP PER SH. M-4A (50 SCH 160 NOZ. ON 31" I.D. HDPE IN 401CA SER# 32378-12	SA-187 PER SH. M-4A (50 MACHINE FEIGN IN SHOP PER SH. M-4A (50 SCH 160 NOZ. ON 31" I.D. HDPE IN 401CA SER# 32378-12			
D 1	1" WELD BEVELS 2P H 10 BOXE FLASH 4 1/4" (100% RTJ) (1/2" MIN. SUPA) HT# 414CX SER# 22778-6	SA-187 FLASH 4 1/4" (100% RTJ) (1/2" MIN. SUPA) HT# 414CX SER# 22778-6			
E 4	3/4" 6000# SOLID HDPE HALF CPG 250" MAX. BORE ID 1" IN SHOP PER DET. "X" HEAT # SER# AS NOTED. (100% RTJ) PT ACCESSIBLE SURFACES HT# 45CA 3ECP 32478-13 HT# 45CA 3ECP 32478-24 HT# 45CA 3ECP 32478-25 HT# 45CA 3ECP 32478-15	SA-187 250" MAX. BORE ID 1" IN SHOP PER DET. "X" HEAT # SER# AS NOTED. (100% RTJ) PT ACCESSIBLE SURFACES HT# 45CA 3ECP 32478-13 HT# 45CA 3ECP 32478-24 HT# 45CA 3ECP 32478-25 HT# 45CA 3ECP 32478-15			
F 1	2.48" MWCAST PIPE (1/2) (100% RTJ (AT ALL SURFACES) CE BA 1/2" DIA. 1/2" OA 1/2" MIN. DESIGN THICKNESS HEAT # 15701-PC-1	SA-351 100% RTJ (AT ALL SURFACES) CE BA 1/2" DIA. 1/2" OA 1/2" MIN. DESIGN THICKNESS HEAT # 15701-PC-1			EXCEPT HYDRO. AFTER ERECTIO.
G 1	31" I.D. 90° ELL HEAT/C 15701-PC-2	SA-187 31" I.D. 90° ELL HEAT/C 15701-PC-2			

TOTAL

8606120564-01

546-CVH-253731-BM

TBX-RCPFB-09

ADDED AS BUILT DATA	5-18-77
REMOVED HOLDS	68 3-15-72
"E" SPEC WAS REV. 0	68 12379
AE DRG. WAS REV. 2	68 (027-71)
ORIGINAL ISSUE	68 5-18-77
REVISION	CHK'D. DATE

PREPARED 50° F MIN.	PAINT	CUSTOM WESTINGHOUSE
WORK AREA	WASH PREP	546-CVH-253731-B
DATE 6/6/77		CUST DRG NO 2323-M
NOTE 31U2314/23	COLOR CODE	DATE 5-10-77 RV
		Q-6214-TBT 11
RADIOGRAPH	SPIN# TBX-RCPFB-09	
NOTE 15	FAIR CODE ASME III CLASS 1	
	WEIGHT 19.133	
	DATE 7-19-4	

35-1195
5-4-79

Category II, AP4, Item 3

Brown & Root, Inc. Post Office Box 1001, Glen Rose, Texas 76043

BRF-9348

May 4, 1979



Mr. J. T. Merritt
Texas Utilities Services, Inc.
P. O. Box 1002
Glen Rose, TX 76043

Texas Utilities Services, Inc.
COMANCHE PEAK STEAM ELECTRIC STATION
1981-83 2300 MW Installation
P. O. CP-0001
Reactor Coolant Pipe Field Measurements

Dear Mr. Merritt:

Attached are the field measurements required for the fabrication of the closure loop for Unit-1, Loop-3. Also, noted on the sketch is the fabrication allowance for weld shrinkage.

Please contact us if you have any questions concerning these measurements.

Very truly yours,
BROWN & ROOT, INC

D.C. Deakum

U. D. Douglas
Project Manager

Attachment *DR*


UDD:JHM:JJR:dt

cc: ARMS OL, 1A

L. A. Ashley 1L, 1A
J. T. Merritt 1L, 1A

FUIA-05-59

m375



NOTE:
ALLOW $\frac{3}{8}$ " FOR SHRINKAGE

HT ALL FIELD WELDS

SCALE:
 $\frac{1}{4}" = 1'-0"$

CLIENT TEXAS UTILITIES
SHEET NO. 1 OF 1
SUBJECT CLOSURE LOG FIELD MEASUREMENTS, UNIT-1, LOOP-3
JOB NO. 35-1195
BASED ON DRAWING NO.
COMPUTER FIELD ENGR. CH-0, BY DR DATE 5-4 1979



BROWN & ROOT, INC. CPSES	INSTRUCTION NUMBER	REVISION	ISSUE DATE	PAGE
	01-QAP-11.1-26	0	1-3-80	1 of 40
ASME PIPING & WELDING INSPECTIONS	APPROVED BY: <i>S. DeLackey</i> 1/3/80 DATE			

1.0 REFERENCES

- 1-A QA Personnel Training Manual
- 1-B WES-16, "Schedule of Standard Test Welder Qualification Matrix and Welder Performed Qualification Log"
- 1-C QI-QAP-11.1-22, "Cleanliness Control"
- 1-D VT-NDEP, "Visual Examination"
- 1-E G&H Specification, MS-100, "Piping Erection Specification"
- 1-F G&H Specification, MS-43B, "Piping Nuclear Ship Fabrication"
- 1-G CP-NDEP-000, "Marking Requirements for NDE"

INFORMATION COPY

2.0 PURPOSE

To outline QC inspection activities for welding during site fabrication and installation of ASME piping.

PPR/W

3.0 INSTRUCTIONS

3.1 VERIFICATION PRIOR TO FABRICATION/INSTALLATION

The QC Inspector shall verify that the documentation to be used in fabrication or installation corresponds to the revision of the construction drawings that are part of the documentation package.

Welder qualification shall be verified on a random basis by consulting the "Welder Qualification Matrix" at Weld Filler Material Log entries. This shall be performed at fit-up.

3.2 DOCUMENTING WELD INSPECTIONS

Upon verification, witnessing, or monitoring that an operation or the results of an inspection are acceptable, the QC Inspector shall initial, or sign and date the applicable documentation in the space provided. Work may not proceed beyond an established QC or ANI hold point until it is witnessed, monitored, or verified, or where permitted for an ANI inspection point, waived. ANI inspection points will be waived by the ANI in writing.

The NDE Procedure and revision date shall be entered on the applicable Weld Data Card by the QC Inspector. For RT and UT, the NDE report number should also be entered in the blank block to the right of the UT-NDEP space.

FOIA-85-59

m 374

BROWN & ROOT, INC. CPSES JOB 35-1195 (Supplement 6.9D-II)	PROCEDURE NUMBER QI-QAP 11.1-26	REVISION 1	ISSUE DATE 2-6-80	PAGE 1 of 8
TITLE: QI-QAP-11.1-26 (SUPPLEMENT 6.9D-II) ASME WELD INSPECTIONS	ORIGINATOR: <i>Lynn E. Abita</i>		2-6-80	DATE
	REVIEWED BY: <i>Eugene M. Bennett</i>	35-1195	2-6-80	DATE
	CONTROLLED BY: <i>Richard W. Linton</i>	Site QA Manager	2-6-80	DATE
0.1 TABLE OF CONTENTS	INTRODUCTION		CORRELATES WITH APPENDIX 6.9D SECTION	
2.0 GENERAL				
2.1 DOCUMENTING WELD INSPECTIONS	2.5			
2.1.1 QC Hold Points	2.5.1			
2.1.2 QC NDE and Welding Inspection	2.5.2			
2.1.3 General Requirements for Visual Inspection of Weldments	2.5.1			
2.1.4 Nondestructive Examination (NDE)	2.5.2			
3.0 INSTRUCTION				
3.1 PREFABRICATION/INSTALLATION	2.5			
VERIFICATION				
3.2 MATERIAL/PARTS VERIFICATION	2.5.			
3.2.1 Material Traceability Control	2.5.4			
3.2.2 Traceability Marking Transfer	2.5.5			
3.2.3 Prefabrication (QCI-M)	2.5.6			
3.2.4 Procedure and Welder Qualification Verification				
3.3 VERIFICATION OF LIMITED ACCESS FOR WELDING	3.1			
3.4 GENERAL REQUIREMENTS DURING WORK	3.13			
3.4.1 Inspection After Tack Welding	3.11			
3.4.2 Root Weld Inspection	3.10/3.11			
3.4.3 Attachment Welds	3.14			
3.4.4 Purge Dam Removal	3.5			
3.4.5 RT Flagging	3.17			
3.4.6 Piping Subassembly/Component Support Final Inspection	N/A			
3.4.6.1 Surface and Dimensional Examination	N/A			
3.4.7 Repairs	3.19			
3.4.8 PWHT/QC Inspections (QCI-M)	3.21			
4.0 SUPPORTING MATERIAL				
4.1 REFERENCES				

6

FOIA-85-59
M377

BROWN & ROOT, INC. CPSES JOB 35-1195 (Supplement 6.9D-II)	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1.26	1	2-6-80	2 of 8

- 4.1.1 B&R Nondestructive Examination
Procedures Manual
4.1.2 B&R Personnel Training Manual
4.1.3 B&R ASME Quality Assurance Manual

0.ii TABLES

11.1-26-1 Matrix of QC Inspections

1.0 INTRODUCTION

This instruction has been prepared to delineate ASME Welding and NDE inspection requirements and shall be used with the corresponding Appendices to Procedure CPM-6.9, "General Piping Procedure", and the Brown & Root Nondestructive Examination Procedures Manual.

2.0 GENERAL

2.1 DOCUMENTING WELD INSPECTIONS

When the results of an inspection are determined, the QC Inspector shall initial or sign and date the applicable documentation in the space provided indicating the results of the inspection. Work may not proceed beyond an established QC or ANI holdpoint until all such holdpoints have been witnessed, monitored, or verified (see 2.1.1) or, alternatively, waived where permitted for ANI inspection points. Definitions are given in Procedure CPM-6.9, Section 2.2 and below.

2.1.1 QC Holdpoints

The following QC holdpoints may be established:

1. Verification (QCI).

This type of inspection does not require the QC Inspector to observe an operation being performed, but allows the inspector to physically inspect an item after performance of an operation. The QC Inspector must be notified subsequent to performance of an operation with "QCI" designated; example: Fit-up Inspection.


2. Witness (QCI-W).

Witnessing requires the inspector to observe the entire operation being performed. The QC Inspector must be notified before the operation to assure presence during performance of it when "QCI-W" is designated; example: Pressure Test Inspection.

INFORMATION
COPY
3.0
PPRV

Void Pages per Rev. 2

BROWN & ROOT, INC. CPSES JOB 35-1195	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-CPM 6.9E	1	5/23/80	1 of 22
TITLE: CP-CPM 6.9E (APPENDIX E) PIPE FABRICATION AND INSTALLATION	ORIGINATOR: <u>D.P. L. Lewis</u>		5/1/80	DATE
	REVIEWED BY: <u>J.M. Kamm</u>		5-22-80	DATE
	APPROVED BY <u>O.C. Shankum</u> CONSTRUCTION PROJECT MANAGER		5-23-80	DATE
0.1	<u>TABLE OF CONTENTS</u>		VOID	ARMS INDEXED
1.0	<u>INTRODUCTION</u>			
2.0	<u>GENERAL</u>			
2.1	<u>APPROVAL AUTHORITY</u>		DATE	
2.2	<u>RESPONSIBILITY</u>			
3.0	<u>PIPE FABRICATION AND INSTALLATION PROCEDURE</u>			
3.1	<u>GENERAL</u>			
3.2	PIPING SYSTEMS REQUIRING THE REMOVAL OF THE MANUFACTURERS' INTERIOR COATINGS			
3.3	CONTROL OF PIPING MATERIALS IN THE PIPE FABRICATION SHOP			
3.4	PIPE BENDER QUALIFICATION			
3.5	REQUIREMENTS FOR PIPE JOINTS			
3.6	PENETRATIONS THROUGH WALLS AND SLABS			
3.7	VALVES			
3.8	TEMPORARY STRAINERS			
3.9	BURIED PIPING			
3.10	FABRICATION TOLERANCES			
3.11	TORQUING			
3.12	PIPING DESIGN LOCATION			
3.13	PIPE, HANGER, AND OTHER STRUCTURAL MATERIAL SALVAGING			
3.14	VALVE DISASSEMBLY/REASSEMBLY			
3.15	MARKING			
3.16	INSULATION			
DCN #1				
DCN #2				
DCN #3				
DCN #4				
0.ii	<u>LIST OF TABLES</u>			
6.9E-1	Length of Thread on Pipe			
0.iii	<u>LIST OF FIGURES</u>			
6.9E-1	Buttweld End Pipe - Nuclear Pipe			
6.9E-2	Buttweld Preps - Non-Nuclear			
6.9E-3	Determining Wall Thickness After Machining			
6.9E-4	Half Coupling Revel Detail			
6.9E-5	Pipe Bender Qualification Form			
6.9E-6	Valve Spools			
6.9E-7	Fabrication Tolerance			
6.9E-8	Material Salvage Sheet			



FOIA-85-59 M378

BROWN & ROOT, INC. CPSES JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	CP-CPM 6.9E	1	5/23/80	15 of 22

3.12 PIPING DESIGN LOCATION

Verification of alignment shall be made at the time of fit-up (flanged connections or weld joints).

The piping shall be located to the dimensions shown on the B&R installation drawings. Erection tolerances shall be as required by Appendix 6.9F.

Prior to making a piping connection to equipment, verify that the equipment has been "approved" for piping as per Procedure MCP-1. Contact the mechanical superintendent to facilitate the removal of desiccant and/or purge, and to monitor the alignment of rotating equipment during welding operations. Final connections to equipment and valve flanges or nozzles shall be accomplished by adjustment of the piping and supports to provide accurate alignment at these joints without stressing of the pipe, equipment, or valves. Springing, bending, or localized heating to obtain alignment shall not be done without approval of engineering.



Weld joint alignment, temporary attachment lugs, straps, etc. used for weld fit-up and alignment shall in accordance with Appendix 6.9D.



Once the piping has been brought into position, the piping location shall be checked against the installation drawing for conformity by the craftsman. Piping out of design location shall be adjusted until it is within the allowed tolerance. When this tolerance cannot be met without bending of the piping, cold spring, or localized heating, the PS should advise engineering.

Measurement for piping locations shall be taken using control base lines and bench marks set up by the B&R Field Engineering Department. The use of as-built column lines, floor lines and other structures as reference is not permitted.

3.13 PIPE, HANGER, AND OTHER STRUCTURAL MATERIAL SALVAGE

- When items cannot be used because of redesign, misfabrication, damage, the disposition to Nonconformance Reports, etc., the items may be scrapped, salvaged, or returned to bulk stock. The responsible foreman shall make this determination based on the NCR, CMC or the item's physical condition, as appropriate. When subassembly modification results, documentation for such modification shall be prepared as required by Appendix 6.9G, and the modification accomplished accordingly.

BROWN & ROOT, INC. CPSES JOB 35-1195 (Supplement 6.9D-II)	NUMBER OI-OAP 11.1-26	REVISION 2	ISSUE DATE	PAGE 1 of 8
--	------------------------------	-------------------	------------	--------------------

TITLE: OI-OAP-11.1-26 (SUPPLEMENT 6.9D-II) ASME WELD INSPECTIONS	ORIGINATOR: <i>Lynn E. Wilson</i>	6-26-80 DATE
	REVIEWED BY: <i>D. Shaw</i>	6-26-80 DATE
	APPROVED BY: <i>Lynn E. Wilson</i> Site QA Manager	6-26-80 DATE

0.1 TABLE OF CONTENTS

CORRELATES WITH
APPENDIX 6.9D
SECTION

ARMS
INDEXED

1.0	INTRODUCTION	
2.0	GENERAL	
2.1	DOCUMENTING WELD INSPECTIONS	2.5 DATE
2.1.1	QC Hold Points	2.5.1
2.1.2	QC NDE and Welding Inspection	2.5.2
2.1.3	General Requirements for Visual	
2.1.4	Inspection of Weldments	2.5.1
	Nondestructive Examination (NDE)	2.5.2
3.0	INSTRUCTION	
3.1	PREFABRICATION/INSTALLATION	
3.2	VERIFICATION	2.5
3.2.1	MATERIAL/PARTS VERIFICATION	2.5.3
3.2.2	Material Traceability Control	2.5
3.2.3	Traceability Marking Transfer	2.5.5
3.2.4	Prefabrication (OCI-M)	2.5.6
	Procedure and Welder Qualification	
	Verification	
3.3	VERIFICATION OF LIMITED ACCESS FOR	
	WELDING	3.1
3.4	GENEPAL REQUIREMENTS DURING WORK	3.13
3.4.1	Inspection After Tack Welding	3.11
3.4.2	Root Weld Inspection	3.10/3.11
3.4.3	Attachment Welds	3.14
3.4.4	Purge Dam Removal	3.5
3.4.5	RT Flagging	3.17
3.4.6	Piping Subassembly/Component Support	
	Final Inspection	N/A
3.4.6.1	Surface and Dimensional Examination	N/A
3.4.7	Repairs	3.19
3.4.8	PWHT/QC Inspections (OCI-M)	3.21
4.0	SUPPORTING MATERIAL	
4.1	REFERENCES	

2.5
DATE
2.5.1
2.5.2
2.5.1
2.5.2
2.5
2.5.3
2.5
2.5.5
2.5.6

3.1
3.13
3.11
3.10/3.11
3.14
3.5
3.17
N/A
N/A
3.19
3.21

FOIA-85-58379

4

BROWN & ROOT, INC. CPSES JOB 35-1195 (Supplement 6.9D-II)	NUMBER OI-OAP-11.1.26	REVISION 2	ISSUE DATE	PAGE 2 of 8
--	------------------------------	-------------------	------------	--------------------

- 4.1.1 B&R Nondestructive Examination Procedures Manual
- 4.1.2 B&R Personnel Training Manual
- 4.1.3 B&R ASME Quality Assurance Manual

0.1f TABLES

11.1-26-1 Matrix of QC Inspections 3.0

1.0 INTRODUCTION

This instruction has been prepared to delineate ASME Welding and NDE inspection requirements and shall be used with the corresponding Appendices to Procedure CPM-6.9, "General Piping Procedure", and the Brown & Root Nondestructive Examination Procedures Manual.

2.0 GENERAL

2.1 DOCUMENTING WELD INSPECTIONS

When the results of an inspection are determined, the OC Inspector shall initial or sign and date the applicable documentation in the space provided indicating the results of the inspection. Work may not proceed beyond an established QC or ANI holdpoint until all such holdpoints have been witnessed, monitored, or verified (see 2.1.1) or, alternatively, waived where permitted for ANI inspection points. Definitions are given in Procedure CPM-6.9, Section 2.2 and below.

2.1.1 OC Holdpoints

The following OC holdpoints may be established:

1. Verification (OCI).

This type of inspection does not require the OC Inspector to observe an operation being performed, but allows the inspector to physically inspect an item after performance of an operation. The OC Inspector must be notified subsequent to performance of an operation with "OCI" designated; example: Fit-up Inspection.

2. Witness (OCI-W).

Witnessing requires the inspector to observe the entire operation being performed. The OC Inspector must be notified before the operation to assure presence during performance of it when "OCI-W" is designated; example: Pressure Test Inspection.

INFORMATION
COPY

PPRV



QA RECORD

Brown & Root, Inc. INDEXED

QUALITY ASSURANCE DEPARTMENT
NONCONFORMANCE REPORT (NCR)

NCR No. M-2305

DATE:

PROJECT CPSES


JOB NO. 35-1195

PAGE 1 OF 8

(2) UNIT	STRUCTURE/SYSTEM	COMPONENT	TAG/ID NUMBER	LOCATION OR ELEVATION	R/R NO
1	3700 Auxiliary Feedwater	Field Weld 8-A & 9	AF-1-SB-032	SB. #1 790'	N/A
(3) NONCONFORMING CONDITION					
(3) DOCUMENT VIOLATED	OI-OAP-11.1.2	REV 1	PARA 2.13	41TREND CATEGORY	M-10

During random surveillance of piping installation FW-8A & 9 were observed to be cold sprung by use of jacking device forcing spool 203 away from the wall. Both weldments are in intermediate stage of weldout.

See attached NDER A-1251 for plan view detail.



Hold tags applied

(5) REPORTED BY: S. R. Dodd	(6) DATE: 5 / 28 / 80	(9) REVIEW/APPROVAL: <i>S. R. Dodd</i> 7/15/80 + 1-1-80	(10) DATE: 1-1-80
(7) PREPARED BY: S. R. Dodd	(8) DATE: 6 / 10 / 80	(11) ISSUED BY: <i>Clara Halladay</i>	(12) DATE: 6/11/80

(13) DISPOSITION ASSIGNED TO: D. C. Frankum	(14) DUE DATE: 6 / 24 / 80	(15) CORRECTIVE ACTION REQUEST: CAR NO. <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Required	(16) ASME CODE CLASS
--	-------------------------------	---	----------------------

(17) DISPOSITION: REWORK _____	REPAIR _____	USE AS IS <input checked="" type="checkbox"/> XX	SCRAP _____
-----------------------------------	--------------	--	-------------

Subject pipe cannot be cold sprung in the configuration that it is in, ie., pipe has a free end. Slope of pipe is within construction tolerance. Use as is based on acceptable R.T. on welds to valve.

(18) CONSTRUCTION REVIEW/APPROVAL: <i>George R. Hiles</i>	(19) DATE: 7/15/80	(20) QA/QC REVIEW APPROVAL: <i>G. Hiles</i>	(21) DATE: 7/16/80
(22) ENG. REVIEW/APPROVAL: <i>John D. Barr</i>	(23) DATE: 7/15/80	(24) ANI REVIEW APPROVAL: <i>Stanley O. Tuckett</i>	(25) DATE: 7/16/80

(26) VERIFICATION: <input checked="" type="checkbox"/> Satisfactory <input type="checkbox"/> Unsatisfactory <input type="checkbox"/> Not Req'd	(33) REMARKS: QA RECORD
(27) QA/QC ENGR/INSPR. VERIFICATION: <i>George M. Smith</i>	(28) DATE: 10/16/80
(29) ANI CONCURRENCE: <i>W.R. Leavens</i>	(30) DATE: 10/16/80
(31) QA REVIEW/CLOSURE: <i>James E. Cook</i>	(32) DATE: 10/16/80

RTN.	QA REVIEW
L	C4 102-5
FILE NO.	
P-151	
SUBFILE NO.	
M-123019	

FOIA-

m380



Brown & Root, Inc.
QUALITY ASSURANCE DEPARTMENT
NDE REPORT

SERIAL NUMBER

NDER-A 1251

PROJECT: COMANCHE PEAK

JOB NO. 35-1195


UNIT 1

PAGE 1

OF 1

DRAWING AF-1-5B-032	SYSTEM 3700 Aux Feedwater	CLASS <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD/ITEM NUMBER FW-98 8A	LOCATION 790' SB #1	NCRN-2305 <i>1/2.2 of 8</i>

MTL. TYPE P-1	MTL. THICK .438	DIA/LENGTH 3"	
STAGE OF MFG. <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT	<input checked="" type="checkbox"/> INTERMEDIATE	<input type="checkbox"/> FINAL	JOINT DESIGN <input type="checkbox"/> BRN <input type="checkbox"/> BKS <input type="checkbox"/> INS <input type="checkbox"/> OPEN BUTT <input type="checkbox"/> OTHER



Jacking device located 13" from FW-8A. Total deflection over 11' (approx) is $\frac{3}{4}$ " with FW-8A 89 in intermediate stage of weldout. Centerline measurements taken @ end of 2Q3 FW-8A and approx 8' north of FW-8A to determine amount of deflection.

Attachment to NCR 2305

ACCEPTANCE STD M3-100	ACCEPT <input type="checkbox"/>	REJECT <input checked="" type="checkbox"/>	DATE 6/11/80
---------------------------------	---------------------------------	--	------------------------

INSPECTOR <i>JR Dodek</i>	CERTIFICATION LEVEL <i>JR</i>
NDE PROCEDURE 200 10/8/79	

INSPECTION REPORT

NCR NO. 112305
10-16-80

PAGE 1 OF 1

BRP-AF-1-SKB-32 F448A


PLANT CODE	SYSTEM CODE	COMPONENT CODE	TAG PN COUNT NO	DRAWING SPECIFICATION NO	SERIAL NO
1-4	5-10	11-8			
			A B C D E F	G H J U-NITS	J U-NITS

PURCHASE ORDER NUMBER	VEND. CODE
59-59	112-121

MRR NUMBER	RIR NUMBER	VENDORS HEAT LOT/BATCH NO.	COUNT QUANTITY	PURCH'S OR NO.	ALS HOLD NO. CODE STATUS	INPUT DATE
74-79	80-85	86-95	96-105	112-111	112-121	122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: TO CLEAR NCR 112305

RESULTS OF INSPECTION / SURVEILLANCE:

DISPOSITION OF NCR 112305
IS COMPLETE

NCR NO. 112305

S. Walters
QG ENGINEER/INSPECTOR

DATE 10-16-80

卷之三

Drawing No.

49

FCC 5.4

F.C. & A.

1st 1st rec - m-e 855 DESCRIPTION OF DEFECT (SKETCH)

Approved structures shall be situated so they immediately below the last 1000' of access roads.

KT 17297

BRUNO & CO., INC.
QUALITY ASSURANCE DEPARTMENT
NDE RADIOGRAPHIC REPORT

SERIAL NUMBER 13-500

BT N^o 17237

PROJECT COMANCHE PEAK

JOB NO 35-1195

UNIT

PAGE OF

DRAWING E&P AE 15232	SYSTEM S700	CLASS <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD ITEM NUMBER EW-8A	LOCATION 9'11" of es wall 16'11" of 35 at elev. 792'3"	

MTL. TYPE	MTL. THICK.	DIA. LENGTH	(PIPE) DIA	PLATE - LONG SEAM LENGTH
STAGE OF MFG.	A		B	C
REPAIR	POOT	STATE	FINAL	BRN. BKS. OPEN BUTT

X RAY	ISOTOPE	LEAD SCREENS		
MAKE	Iridium 192 <input checked="" type="checkbox"/> Cobalt 60 <input type="checkbox"/>	FRONT	CENTER	BACK
KVP.	SIZE	.005 <input type="checkbox"/>		.005 <input type="checkbox"/>
M.A.	DIA. <u>1</u> LENGTH <u>11+</u>	.010 <input checked="" type="checkbox"/>	<u>N/A</u>	.010 <input checked="" type="checkbox"/>
FOCAL SPOT SIZE	CURIES <u>12</u>	TECHNIQUE T <u>3-4</u> (if not standard, attach sketch)		
FILM MFG. EKC ASTM CLASS 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/>	LOADED <u>1</u> <input type="checkbox"/> <u>2</u> OTHER <input type="checkbox"/>	UNSHARPNESS		
FFD. <u>3.5</u>	EXPOSURE TIME MIN. <u>1</u> SEC. <u>20</u>	$U_g = \frac{Ft}{d}$	$F =$ "	$U_g =$ <u>✓</u>
PENETRAMETER SIZE <u>12</u> MTL. <u>5/8</u>	ASTM <input checked="" type="checkbox"/> ASME <input type="checkbox"/>	$t =$ "	$d =$ "	
PENETRAMETER SOURCE SIDE <input type="checkbox"/>	FILM SIDE <input checked="" type="checkbox"/>			
SHIM MTL. <u>5/8</u> THICK <u>.005</u>	NDE PROCEDURE CPNDEP-101			

RADIOGRAPHER

Parker, Musick

CERTIFICATION

EVE ~~P~~ dTR

RT
COMPANY B4R

אָמֵן תְּהִלָּתָךְ

BAR INTERPRETER		CERTIFICATION LEVEL
FILM EVALUATION DATE	COMMENTS	
IF APPLICABLE CLIENT REP	DATE	IF APPLICABLE A.I.A. REP DATE

NCR M-2305
10-6-80

INSPECTION REPORT

PAGE 1 OF 1

PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-4	5-10	11-18

FACILITY COUNTING						STATION COUNTING			SERIAL NO	
4	3	2	1	E	F	3	4	5	6	UNITS
										7-15

PURCHASE ORDER NUMBER	END CODE
56-99	7-15

MRR NUMBER	RIR NUMBER	VENDOR'S HEAT/LOT/BATCH NO.	COUNT UNITS	PURCHASES OF NO.	PLSHOLD NO. CODE	INPUT DATE
			QUANTITY	ITEM NO.	STATUS	
74-79			96-105	04111	112-121	122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: TO COLLECT NCR 11012 112305

RESULTS OF INSPECTION / SURVEILLANCE:

DISPOSITION OF NCR 112305
IS COMPLETE

INFORMATION

READY

DATA

NCR NO. 112305

FEWalters
QC ENGINEER-INSPектор

GA-151-1-Q(4-1-77)

DATE 10-16-80

REPAIR PROCESS SHEET

2020 年卷 - 2

Drawing No.

11-3-11

A. E. G. VAN DER

— 5 —

Weld No. EWD-13

K 1 nif-nid-Mazoo
-230

DESCRIPTION OF DEEP (SKETCH)

Additional structures 1961-38 appear to lie immediately below the last stage.
1962-1963 1963-1964,
1963-1964 1963-1964, 30, 30, 30,
1964-1965 1964-1965, 10, 10.

LIT-~~II~~ 17295

جعفر بن محبث

QUALITY ASSURANCE DEPARTMENT
NDE RADIOGRAPHIC REPORT

SERIAL NUMBER Pg. S. 15

RT No 17298

PROJECT CORRANCHE PEAK

SEARCHED NO 35-1195

UNIT 1 PAGE 1 OF 1

DRAWING <u>BH-1-HF-1-SB-32</u>	SYSTEM <u>3700</u>	CLASS <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> 3 <input type="checkbox"/> OTHER
WELD/ITEM NUMBER <u>F4 19 79-2023-3</u>	LOCATION <u>9 WEST ES 112" NEAR 36 WALL FFL 792 1/2" 2 1/4 PT ECON</u>	

MTL. TYPE P-1	MTL. THICK. 447	DIA LENGTH	(PIPE) DIA. <u>3"</u>	(PLATE - LONG SEAM) LENGTH <u>14 1/4"</u>
STAGE OF MFG.	REPAIR	ROOT	INTERMEDIATE	FINAL
				BRN BKS <input type="checkbox"/>
				OPEN BUTT <input checked="" type="checkbox"/>

X RAY		ISOTOPE		LEAD SCREENS		
MAKE		IRIDIUM 192 <input checked="" type="checkbox"/>	COBALT 60 <input type="checkbox"/>	FRONT	CENTER	BACK
KVP.	1 M.A.	SIZE	DIA. <u>1/2"</u> LENGTH <u>16"</u>	.005 <input type="checkbox"/>	<input type="checkbox"/>	.005
FOCAL SPOT SIZE		CURIES	<u>.12</u>	.010 <input checked="" type="checkbox"/>	<u>.14</u>	.010
FILM MFG. <u>EKC</u>	ASTM CLASS <u>1</u> <input checked="" type="checkbox"/> <u>2</u> <input type="checkbox"/>	LOADED	<u>1</u> <input type="checkbox"/> <u>2</u> <input checked="" type="checkbox"/> OTHER <input type="checkbox"/>	TECHNIQUE T <u>3C</u> (if not standard, attach sketch.)		
FFD. <u>3'</u>		EXPOSURE TIME	MIN. <u>1</u> SEC. <u>20</u>			
PENETRAMETER	SIZE <u>12</u>	MTL. <u>S/S</u>	ASTM <input checked="" type="checkbox"/> ASME <input type="checkbox"/>	UNSHARPNESS		
PENETRAMETER	SOURCE SIDE <input type="checkbox"/>	FILM SIDE <input checked="" type="checkbox"/>		$U_g = \frac{ft}{d}$	$F =$ "	$U_g =$ <u> </u>
SHIM	MTL. <u>S/S</u> THICK. <u>.090</u>	INDE PROCEDURE		$t =$ "	$d =$ "	
		<u>CP-NDEP 101</u>				

RADIOGRAPHER
PARKER + MUSICK

CERTIFICATION

LEVEL I TR

RT
COMPANY B&R

精英教育网 www.yingling.org

FILM EVALUATION DATE

COMMENTS

CERTIFICATION

Q.21 100

IF APPLICABLE
CLIENT REP

卷之三

REFERENCES

845


ARMS

BROWN & ROOT, INC. CPSES JOB 35-1195 (Supplement 6.9D-II)	NUMBER QI-QAP 11.1-26	REVISION 3	ISSUE DATE DATE 7-22-80	INDEXED PAGE 1 of 8
TITLE: QI-QAP-11.1-26 (SUPPLEMENT 6.9D-II) ASME WELD INSPECTIONS	ORIGINATOR: <i>Lynn E. Whitton</i>	DATE 7-21-80		
	REVIEWED BY: <i>Darby R. Liles</i>	DATE 7-21-80		
	APPROVED BY: <i>James F. King</i> Site QA Manager	DATE 7-21-80		

0.1

TABLE OF CONTENTSCORRELATES WITH
APPENDIX 6.9D
SECTION

1.0	<u>INTRODUCTION</u>	
2.0	GENERAL	
2.1	DOCUMENTING WELD INSPECTIONS	2.5
2.1.1	QC Hold Points	2.5.1
2.1.2	QC NDE and Welding Inspection	2.5.2
2.1.3	General Requirements for Visual Inspection of Weldments	
2.1.4	Nondestructive Examination (NDE)	2.5.1 2.5.2
3.0	<u>INSTRUCTION</u>	
3.1	PREFABRICATION/INSTALLATION	2.5
3.2	VERIFICATION	2.5.3
3.2.1	MATERIAL/PARTS VERIFICATION	2.5.4
3.2.2	Material Traceability Control	2.5.5
3.2.3	Traceability Marking Transfer	2.5.6
3.2.4	Prefabrication (QCI-M)	
3.3	Procedure and Welder Qualification Verification	3.1
3.4	VERIFICATION OF LIMITED ACCESS FOR WELDING	3.13
3.4.1	GENERAL REQUIREMENTS DURING WORK	3.11
3.4.2	Inspection After Tack Welding	3.10/3.11
3.4.3	Root Weld Inspection	
3.4.4	Attachment Welds	3.14
3.4.5	Purge Dam Removal	3.15
3.4.6	RT Flagging	3.17
3.4.6.1	Piping Subassembly/Component Support	
3.4.7	Final Inspection	
3.4.8	Surface and Dimensional Examination	3.19
3.4.8	Repairs	3.21
3.4.8	PWHT/OC Inspections (QCI-M)	
4.0	<u>SUPPORTING MATERIAL</u>	
4.1	<u>REFERENCES</u>	



FOIA-85-59

M381

BROWN & ROOT, INC. CPSES	NUMBER	REVISION	ISSUE DATE	PAGE
JOB 35-1195 (Supplement 6.9D-II)	QI-QAP-11.1-26	3	7-22-80	2 of 8

- 4.1.1 B&R Nondestructive Examination Procedures Manual
 - 4.1.2 B&R Personnel Training Manual
 - 4.1.3 B&R ASME Quality Assurance Manual

0.11 TABLES

11.1-26-1 Matrix of QC Inspections

3.0

1.0 INTRODUCTION

This instruction has been prepared to delineate ASME Welding and NDE inspection requirements and shall be used with the corresponding Appendices to Procedure CPM-6.9, "General Piping Procedure", and the Brown & Root Nondestructive Examination Procedures Manual.

2.0 GENERAL

2.1 DOCUMENTING WELD INSPECTIONS

When the results of an inspection are determined, the OC Inspector shall initial or sign and date the applicable documentation in the space provided indicating the results of the inspection. Work may not proceed beyond an established QC or ANI holdpoint until all such holdpoints have been addressed, monitored, or verified (see 2.1.1) or, alternatively, waived where permitted for ANI inspection points. Definitions are given in Procedure CPM-6.9, Section 2.2 and below.

2.1.1 QC Holdpoints

The following QC holdpoints may be established:

1. Verification (QCI).

This type of inspection does not require the QC Inspector to observe an operation being performed, but allows the inspector to physically inspect an item after performance of an operation. The QC Inspector must be notified subsequent to performance of an operation with "QCI" designated; example: Fit-up Inspection.

2. Witness (QCI-W).

Witnessing requires the inspector to observe the entire operation being performed. The QC Inspector must be notified before the operation to assure presence during performance of it when "QCI-W" is designated; example: Pressure Test Inspection.



BROWN & ROOT, INC. CPSSES	NUMBER	REVISION	ISSUE DATE	PAGE
JOB 35-1195				
(Supplement 6.9D-II)	OI-OAP 11.1-26	4	8-28-80	1 or 8
TITLE: OI-OAP-11.1-26 (SUPPLEMENT 6.9D-II) ASME WELD INSPECTION	ORIGINATOR: <i>John Henry</i>		8-24-80	DATE

REVIEWED BY: *Aug. M.R.*

DATE: 8-21-80



APPROVED BY: *James L. Gandy*

DATE: 8/22/80
SICe QA Manager

0.1 TABLE OF CONTENTS

CORRELATES WITH
APPENDIX 6.9D
SECTION

1.0	<u>SUPPORTING MATERIAL</u>	
1.1	<u>REFERENCES</u>	
1.1.1	B&R Nondestructive Examination Procedures Manual	
1.1.2	B&R Personnel Training Manual	
1.1.3	B&R ASME Quality Assurance Manual	
2.0	<u>INTRODUCTION</u>	
3.0	<u>GENERAL</u>	
3.1	DOCUMENTING WELD INSPECTIONS	2.5
3.1.1	QC Hold Points	2.5.1
3.1.2	QC NDE and Welding Inspection	2.5.2
3.1.3	General Requirements for Visual Inspection of Weldments	2.5.1
3.1.4	Nondestructive Examination (NDE)	2.5.2
4.0	<u>INSTRUCTION</u>	
4.1	PREFABRICATION/INSTALLATION VERIFICATION	2.5
4.2	MATERIAL/PARTS VERIFICATION	2.5.3
4.2.1	Material Traceability Control	2.5.4
4.2.2	Traceability Marking Transfer	2.5.5
4.2.3	Prefabrication (QCI-M)	2.5.6
4.2.4	Procedure and Welder Qualification Verification	
4.3	VERIFICATION OF LIMITED ACCESS FOR WELDING	
4.4	GENERAL REQUIREMENTS DURING WORK	
4.4.1	Inspection After Tack Welding	3.11
4.4.2	Root Weld Inspection	3.10/3.11



6

FOIA-85-59

M382

BROWN & ROOT, INC. CPSES JOB 35-1195 (Supplement 6.9D-II)	NUMBER OI-QAP-11.1-26	REVISION 4	ISSUE DATE 8-28-80	PAGE 2 of 8
--	------------------------------	-------------------	---------------------------	--------------------

4.4.3	Attachment Welds	3.14
4.4.4	Purge Dam Removal	3.5
4.4.5	RT Flagging	3.17
4.4.6	Piping Subassembly/Component Support Final Inspection	N/A
4.4.6.1	Surface and Dimensional Examination	N/A
4.4.7	Repairs	3.19
4.4.8	PWHT/QC Inspections (QCI-M)	3.21
4.1.1	B&R Nondestructive Examination Procedures Manual	
4.1.2	B&R Personnel Training Manual	
4.1.3	B&R ASME Quality Assurance Manual	

0.ii TABLES

11.1-26-1 Matrix of QC Inspections 3.0

1.0 SUPPORTING MATERIAL

1.1 REFERENCES

1.1.1 B&R Nondestructive Examination Procedures Manual

1.1.2 B&R Personnel Training Manual

1.1.3 B&R ASME Quality Assurance Manual


2.0 INTRODUCTION

This instruction has been prepared to delineate ASME Welding and NDE inspection requirements and shall be used with the corresponding Appendices to Procedure CPM-6.9, "General Piping Procedure", and the Brown & Root Nondestructive Examination Procedures Manual.

3.0 GENERAL

3.1 DOCUMENTING WELD INSPECTIONS

When the results of an inspection are determined, the QC Inspector shall initial or sign and date the applicable documentation in the space provided indicating the results of the inspection. Work may not proceed beyond an established QC or ANI holdpoint until all such holdpoints have been witnessed, monitored, or verified (see 2.1.1) or, alternatively, waived where permitted for ANI inspection points. Definitions are given in Procedure CPM-6.9, Section 2.2 and below.




BROWN & ROOT, INC. CPSES JOB 35-1195	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	0	2/25/81	1 of 7
TITLE: (Supplement 6.9E-III) INSTALLATION INSPECTION OF THREADED PIPE CONNECTIONS	ORIGINATOR: William Hartshen		2-25-81	DATE


REVIEWED BY: *JL* 2/25/81 DATE

APPROVED BY: *James R. S.* 2-25-81 DATE
Site OA Manager

- 0.1 TABLE OF CONTENTS
- 1.0 REFERENCES
- 2.0 GENERAL
- 2.1 SCOPE
- 2.2 PURPOSE
- 2.3 THREADED CONNECTION IDENTIFICATION
- 3.0 INSTRUCTION
- 3.1 MATERIAL
- 3.1.1 Pipe Wall Thickness
- 3.1.2 Thread Compound
- 3.1.3 Threads
- 3.1.4 Pipe Thread Engagement
- 4.0 BACK-FIT INSPECTIONS
- 5.0 DOCUMENTATION




HISTORICAL FILE



BROWN & ROOT, INC. CPSES JOB 35-1195 Supplement 6.9E-III	NUMBER QI-QAP-11.1-31	REVISION 1	ISSUE DATE SEP 28 1981	PAGE 1 of 7
TITLE: INSTALLATION INSPECTION OF THREADED PIPE CONNECTIONS	ORIGINATOR: <u>Seralia R. Oci</u> <u>9/25/81</u> REVIEWED BY: <u>James Fagan</u> <u>9/25/81</u> APPROVED BY: <u>James F. Fagan</u> <u>9/28/81</u> Site QA Manager			

- 0.1 TABLE OF CONTENTS
- 1.0 INTRODUCTION
- 2.0 GENERAL
- 2.1 THREADED CONNECTION IDENTIFICATION
- 2.2 RESPONSIBILITY
- 3.0 INSTRUCTION
- 3.1 MATERIAL
- 3.1.1 Pipe Wall Thickness
- 3.1.2 Thread Compound
- 3.1.3 Threads
- 3.1.4 Pipe Thread Engagement
- 4.0 BACK-FIT INSPECTIONS
- 5.0 DOCUMENTATION




FOIA-88-59

3

M385

BROWN & ROOT, INC. CPSSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE																																															
JOB 35-1195																																																			
(Supplement 6.9D-II)	QI-QAP 11.1-26	5	APR 29 1981	1 of 7																																															
TITLE:		ORIGINATOR:	<u>Seraina R. Raw</u> 4/28/81																																																
QI-QAP-11.1-26 (SUPPLEMENT 6.9D-II) ASME PIPING WELD INSPECTIONS		REVIEWED BY:	<u>Seraina R. Raw</u> 4/28/81																																																
APPROVED BY:		<u>James R. St. John</u> Site QA Manager		4/28/81																																															
<p style="text-align: center;">HISTORICAL FILE</p> <table> <tbody> <tr><td>0.1</td><td><u>TABLE OF CONTENTS</u></td></tr> <tr><td>1.0</td><td><u>INTRODUCTION</u></td></tr> <tr><td>2.0</td><td><u>GENERAL</u></td></tr> <tr><td>2.1</td><td><u>DOCUMENTING WELD INSPECTIONS</u></td></tr> <tr><td>2.1.1</td><td>QC Hold Points</td></tr> <tr><td>2.1.2</td><td>QC NDE and Welding Inspection</td></tr> <tr><td>3.0</td><td><u>INSTRUCTION</u></td></tr> <tr><td>3.1</td><td>PREFABRICATION/INSTALLATION VERIFICATION</td></tr> <tr><td>3.2</td><td>MATERIAL/PARTS VERIFICATION</td></tr> <tr><td>3.2.1</td><td>Material Traceability Control</td></tr> <tr><td>3.2.2</td><td>Traceability Marking Transfer</td></tr> <tr><td>3.2.3</td><td>Prefabrication (QCI-M)</td></tr> <tr><td>3.2.4</td><td>Procedure and Welder Qualification Verification</td></tr> <tr><td>3.3</td><td>VERIFICATION OF LIMITED ACCESS FOR WELDING</td></tr> <tr><td>3.4</td><td>GENERAL REQUIREMENTS DURING WORK</td></tr> <tr><td>3.4.1</td><td>Inspection After Tack Welding</td></tr> <tr><td>3.4.2</td><td>Root Weld Inspection</td></tr> <tr><td>3.4.3</td><td>Attachment Weld</td></tr> <tr><td>3.4.4</td><td>Purge Dam Removal</td></tr> <tr><td>3.4.5</td><td>RT Flagging</td></tr> <tr><td>3.4.6</td><td>Piping Subassembly Final Inspection</td></tr> <tr><td>3.4.6.1</td><td>Surface and Dimensional Examination</td></tr> <tr><td>3.4.7</td><td>Repairs</td></tr> <tr><td>3.4.8</td><td>PWHT/QC Inspections (QCI-M)</td></tr> </tbody> </table>				0.1	<u>TABLE OF CONTENTS</u>	1.0	<u>INTRODUCTION</u>	2.0	<u>GENERAL</u>	2.1	<u>DOCUMENTING WELD INSPECTIONS</u>	2.1.1	QC Hold Points	2.1.2	QC NDE and Welding Inspection	3.0	<u>INSTRUCTION</u>	3.1	PREFABRICATION/INSTALLATION VERIFICATION	3.2	MATERIAL/PARTS VERIFICATION	3.2.1	Material Traceability Control	3.2.2	Traceability Marking Transfer	3.2.3	Prefabrication (QCI-M)	3.2.4	Procedure and Welder Qualification Verification	3.3	VERIFICATION OF LIMITED ACCESS FOR WELDING	3.4	GENERAL REQUIREMENTS DURING WORK	3.4.1	Inspection After Tack Welding	3.4.2	Root Weld Inspection	3.4.3	Attachment Weld	3.4.4	Purge Dam Removal	3.4.5	RT Flagging	3.4.6	Piping Subassembly Final Inspection	3.4.6.1	Surface and Dimensional Examination	3.4.7	Repairs	3.4.8	PWHT/QC Inspections (QCI-M)
0.1	<u>TABLE OF CONTENTS</u>																																																		
1.0	<u>INTRODUCTION</u>																																																		
2.0	<u>GENERAL</u>																																																		
2.1	<u>DOCUMENTING WELD INSPECTIONS</u>																																																		
2.1.1	QC Hold Points																																																		
2.1.2	QC NDE and Welding Inspection																																																		
3.0	<u>INSTRUCTION</u>																																																		
3.1	PREFABRICATION/INSTALLATION VERIFICATION																																																		
3.2	MATERIAL/PARTS VERIFICATION																																																		
3.2.1	Material Traceability Control																																																		
3.2.2	Traceability Marking Transfer																																																		
3.2.3	Prefabrication (QCI-M)																																																		
3.2.4	Procedure and Welder Qualification Verification																																																		
3.3	VERIFICATION OF LIMITED ACCESS FOR WELDING																																																		
3.4	GENERAL REQUIREMENTS DURING WORK																																																		
3.4.1	Inspection After Tack Welding																																																		
3.4.2	Root Weld Inspection																																																		
3.4.3	Attachment Weld																																																		
3.4.4	Purge Dam Removal																																																		
3.4.5	RT Flagging																																																		
3.4.6	Piping Subassembly Final Inspection																																																		
3.4.6.1	Surface and Dimensional Examination																																																		
3.4.7	Repairs																																																		
3.4.8	PWHT/QC Inspections (QCI-M)																																																		



BROWN & ROOT, INC. CPSES	NUMBER	REVISION	ISSUE DATE	PAGE
JOB 35-1195 (Supplement 6.9D-II)	QI-QAP-11.1-26	5	APR 29 1981	2 of 7

1.0 INTRODUCTION

This instruction has been prepared to delineate ASME Welding and NDE inspection requirements and shall be used with the corresponding Appendices to Procedure CPM-6.9, "General Piping Procedure", and the Brown & Root Nondestructive Examination Procedures Manual.

2.0 GENERAL

2.1 DOCUMENTING WELD INSPECTIONS

When the results of an inspection are determined, the QC Inspector shall initial or sign and date the applicable documentation in the space provided indicating the results of the inspection. Work may not proceed beyond an established QC or ANI holdpoint until all such holdpoints have been witnessed, monitored, or verified or, alternatively, waived where permitted for ANI inspection points. Definitions of QC holdpoints are given below.

2.1.1 QC Holdpoints

The following QC holdpoints may be established:

A. Verification (QCI)

This type of inspection does not require the QC Inspector to observe an operation being performed, but allows the inspector to physically inspect an item after performance of an operation.

The QC Inspector must be notified subsequent to performance of an operation with "QCI" designated; examples: Fit-up Inspection.

B. Witness (QCI-W).

Witnessing requires the inspector to observe the entire operation being performed. The QC Inspector must be notified before the operation to assure presence during performance of it when "QCI-W" is designated; example: Pressure Test Inspection.

C. Monitor (QCI-M).

Conformance verification by monitoring is accomplished by observing a task being performed on a periodic or random basis. The QC Inspector monitoring an operation determines