

BROWN & ROOT, INC. CPSES	NUMBER	REVISION	ISSUE DATE	PAGE
JOB 35-1195 PPRV	QI-QAP-11.1-31	3		1 of 9
TITLE: <b>100</b> INSTALLATION INSPECTION OF MECHANICAL JOINTS NOTELVINGOINTS	ORIGINATOR: <i>[Signature]</i>	1-25-82 DATE		
	REVIEWED BY: <i>[Signature]</i>	1-25-82 DATE		
	APPROVED BY: _____ Site QA Manager	_____ DATE		

## 1.0 REFERENCES

- 1-A QI-QAP-11.1-26, "ASME Pipe Fabrication and Installation Inspection"
- 1-B QI-QAP-11.1-37, "Instruction for QA/QC Review, Approval and Utilization of Construction Operation Travelers."
- 1-C CP-QAP-16.1, "Control of Nonconforming Items"

## 2.0 GENERAL

## 2.1 PURPOSE AND SCOPE

This instruction delineates the requirements to be used when performing installation inspection of mechanical joints.

## 2.2 RESPONSIBILITY

The Site Quality Assurance Manager is responsible for review, approval and implementation of this instruction.


## 2.3 BOUNDARIES

The boundaries of a component to which piping is attached shall be at the limit of reinforcement. This boundary shall not be closer to the main shell of a vessel, pump, or valve than:

- the first bolted flange face; the bolts shall be considered part of the piping;
- the first threaded joint in screwed connections.

FOIA-85-59

BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	3		2 of 9



### 3.0 INSTRUCTION

### 3.1 IDENTIFICATION

The Quality Control Inspector (QCI) shall verify that pipe spools to be joined are identified as described in Reference I-A. Additionally, the QCI shall record the Material Requisition number the pipe spool is released on for threaded connections only.

## 3.2 THREADED CONNECTIONS

### 3.2.1 Pipe Wall Thickness

The QCI shall verify the pipe wall schedule is as specified on the applicable drawing by review of pipe markings and the Material Requisition Sheet.

### 3.2.2 Thread Compound

The QCI shall verify that only Neolube No. 2 is used as a thread compound and is applied as follows:

- a. Neolube is limited to threads and shall not protrude onto the unthreaded portion of the pipe;
- b. Neolube is applied in an even, uninterrupted coat and allowed to dry prior to thread engagement.

### 3.2.3 Threads

The QCI shall verify the following:


- a. all threaded ends are reamed and free of burrs;
- b. threaded ends are not damaged and free of obstruction.

### 3.2.4 Pipe Thread Engagement

The QCI shall verify the minimum thread engagement of threaded connections as shown in Attachment 1, column L<sub>2</sub>.



BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	3		3 of 9



### 3.2.5 Threaded Connections Requiring Seal Welding

#### 3.2.5.1 Prior to Welding

The QCI shall verify:

a. a minimum of 2 inches on each side of the weld joint shall be degreased prior to welding. Mechanical preparation shall result in a clean surface 1/2 inch to 1 inch on each side of the joint;

b. no thread compound used.

#### 3.2.5.2 After Welding

The QCI shall visually inspect seal welds on threaded connections (to include 1/2 inch on each side of the weld) in accordance with the following acceptance criteria:

- a. exposed threads are completely covered with weld metal;
- b. weld edges are free from overlap forming a re-entrant angle less than 90°;
- c. undercut shall not exceed 1/32 inch or cause a reduction in base metal below minimum wall;
- d. no cracks;
- e. no incomplete fusion;
- f. no slag;
- g. no porosity;
- h. no arc strikes; and
- i. no weld spatter.

#### 3.2.6 Documentation

The results of QCI verifications shall be recorded on the Construction Operation Traveler (Reference 1-B), if utilized by Construction, and on Inspection Report, Attachment 3 with the following exceptions.



*why both; why not re or the other?*

BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	3		4 of 9

PPRV  
COPY  
INFORMATION

a. Threading QCI verification (see 3.2.1) shall be documented on the Manufacturing Record Sheet (Reference 1-A).

b. Visual inspection of seal welding (see 3.2.5) shall be documented on the Weld Data Card and on an Inspection Report, Attachment 3, for acceptable conditions. Unacceptable conditions shall be documented on ~~W~~NDER, Attachment 4. *why both? how merged up?*

On completion of all QCI verification, the responsible QC Superintendent shall review the documented results and indicate approval by signing and dating the appropriate document.

### 3.3 FLANGE CONNECTIONS

#### 3.3.1 Cleanliness

The QCI shall verify flange faces are thoroughly cleaned to remove rust, scale, dirt, paint, etc. *How after assembly?*

#### 3.3.2 Traceability

The QCI shall verify Material Requisition number and color code of gasket material, heat number or lot number of nuts and bolts or studs are recorded on the Construction Operation Traveler (Reference 1-B).

#### 3.3.3 Alignment

The QCI shall verify flanges are aligned as follows: *[Thought this was being eliminated!]*


- within 3/64 inch normal and with respect to flange outside diameter; except
- when pipe is to connect to a flange on equipment (i.e., valves, pumps, etc.), the face of the flange is aligned to the lesser of 25% of the gasket thickness or as described in a. above.

#### 3.3.4 Bolting

The QCI shall verify at least one complete thread is exposed above the nut face.



BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	3		5 of 9



#### Documentation

The Construction Operation Traveler shall be used to document the QCI verifications described in this section (Reference 1-8).


#### NONCONFORMANCES

All nonconforming conditions will be reported in accordance with Reference 1-C.

*Same comment  
# 3.3.2*



ATTACHMENT 1



Nominal <sup>b</sup> Pipe Size	Outside Diameter of Pipe, <i>D</i>	Threads per inch, <i>n</i>	Pitch of Thread, <i>P</i>	Pitch Diameter at beginning of External Thread, <i>E<sub>s</sub></i>	Handtight Engagement			Effective Thread, External		
					Length <sup>c</sup> , <i>L<sub>1</sub></i>		Dia <sup>d</sup> , <i>E<sub>1</sub></i>	Length <sup>c</sup> , <i>L<sub>2</sub></i>		Dia <sup>d</sup> , <i>E<sub>2</sub></i>
					In.	Thds.		In.	Thds.	
1	2	3	4	5	6	7	8	9	10	11
1/8	0.405	27	0.03704	0.35351	0.1615	4.36	0.37360	0.2639	7.12	0.38000
1/4	0.540	18	0.05556	0.47739	0.2278	4.10	0.49163	0.4018	7.23	0.50250
3/8	0.675	18	0.05556	0.61201	0.240	4.32	0.62701	0.4078	7.34	0.63750
1/2	0.840	14	0.07143	0.75843	0.320	4.48	0.77843	0.5337	7.47	0.79179
3/4	1.050	14	0.07143	0.96768	0.339	4.75	0.98887	0.5457	7.64	1.00179
1	1.315	11.5	0.08696	1.21363	0.400	4.60	1.23863	0.6828	7.85	1.25630
1 1/4	1.660	11.5	0.08696	1.55713	0.420	4.83	1.58338	0.7068	8.13	1.60130
1 1/2	1.900	11.5	0.08696	1.79609	0.420	4.83	1.82234	0.7235	8.32	1.84130
2	2.375	11.5	0.08696	2.26902	0.436	5.01	2.29627	0.7565	8.70	2.31630
2 1/2	2.875	8	0.12500	2.71953	0.682	5.46	2.76216	1.1375	9.10	2.79062
3	3.500	8	0.12500	3.34062	0.766	6.13	3.38850	1.2000	9.60	3.41562
3 1/2	4.000	8	0.12500	3.83750	0.821	6.57	3.88881	1.2500	10.00	3.91562
4	4.500	8	0.12500	4.33438	0.844	6.75	4.38712	1.3000	10.40	4.41562

BROWN & ROOT, INC.  
CPSES

JOB 35-1195

NUMBER

REVISION

ISSUE  
DATE

PAGE

QI-QAP-11.1-31

3

7 of 9

PPRV

ATTACHMENT 2

COMANCHE PEAK STEAM ELECTRIC STATION  
INSPECTION REPORT

ITEM DESCRIPTION, VERIFICATION, INSTALLATION IDENTIFICATION NO.

SYSTEM/STRUCTURE DESIGNATION

OF THREADED SPOOLS

REF. QI-QAP-11.1-31 REV. & CHANGE NO.

MEASURE OR TEST EQUIP. IDENT. NO.

☐ IN PROCESS  
INSPECTION

☐ PRE-INSTALLATION  
VERIFICATION

☐ INSTALLATION  
INSPECTION

☐ FINAL  
INSPECTION

☐ PRE-TEST  
INSPECTION

INSPECTION RESULTS

☐ INSPECTION COMPLETED, ALL APPLICABLE ITEMS SATISFACTORY

☐ INSPECTION COMPLETED, UNSATISFACTORY ITEMS LISTED BELOW

QC INSPECTOR

DATE

ITEM NO.

INSPECTION ATTRIBUTES

SAT

UNSAT

DATE

QC  
SIGNATURE

1. Spool is properly identified per QI-QAP-11.1-26

2. Spool is released on MR#

3. There are no obstructions inside spool

4. Threads are not damaged (Flat, Buried, Chipped)

5. Neolube properly applied

6. Thread engagement correct per QI-QAP-11.1-31, Attachment 2

7. Excess neolube removed

8. Record the following:

A. Spool # to Spool

B. Line No. Rework ☐

\*Indicates Threaded Spool

\*\*Check Rework If Applicable

REMARKS (DWG, SPECS, ETC.)

RELATED QCR NO.

LR. CLOSED ☐


DATE

SIGNATURE

QC Superintendent

BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	3		8 of 9

### ATTACHMENT 3



**Brown & Root Inc.**

Post Office Box 1001, Clear Lake, Texas 75043

#### QUALITY ASSURANCE DEPARTMENT VISUAL EXAMINATION CHECKLIST

PROJECT: COMANCHE PEAK	JOB NO. 35-1195	UNIT	PAGE 1 OF
SYSTEM	CLASS <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER		
LOCATION			

Enter NA adjacent to attribute when not applicable. Enter Sat./Unsat. or NA above results in each section 1 through 4 as applicable.

WDC#

CHECKER AND REMARKS (R)	Procedure	Rev.
<b>CHECK LIST</b> <b>1. FITUP (Prior and During)</b> Base Material _____ Joint Design _____ Cleanliness _____ Joint Spacing _____ Joint Fitup _____ Joint Alignment _____ Bevel Engagement _____ Bevel End Gap _____ Impurities Inspection Stamp _____ Drips _____ IF BRANCHION/DIRECTION OF FLOW _____		
	Results	
	Inspector	Level DATE
<b>2. AFTER WELDING OF ROOT</b> External Surface _____ Internal Surface _____		
	Results	
	Inspector	Level DATE
<b>3. COMPLETION OF WELD (IO)</b> Surface _____ Root Reinforcement _____ Concavity _____ Cracks _____ Crater Pits _____ Underbead Indent _____ Line Fusion Line Penetration _____ Burn-Through _____ Undercut _____		
	Results	
	Inspector	Level DATE
<b>4. COMPLETION OF WELD (OO)</b> Surface _____ Root Reinforcement _____ Undercut _____ Fillet Size _____ Spacing of Surface _____ Joint/Reinforcement Indent _____ Suitability of Surface for NDT _____ Removal of Tensile Attachments _____ Surface Free from Air and Solids _____ Weld Spatter, etc. _____ Pore Caps Removed _____		
	Results	
	Inspector	Level Date


QC Supervision	Date
Procedure	CERTIFICATION LEVEL
Rev.	

NO-100/90

12/26/78 SA-100-8



BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	3		9 of 9



# ATTACHMENT 4

## Brown & Root Inc. QUALITY ASSURANCE DEPARTMENT NDE REPORT

PROJECT: COMMANDER PEAK	JOB NO. 35-1195	UNIT	PAGE	OF
DRAWING	SYSTEM	CLASS	1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER	
WELD/ITE NUMBER	LOCATION			

MTL. TYPE	MTL. THICK	DIA/LENGTH
STAGE OF MPQ. <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL		JOINT DESIGN <input type="checkbox"/> BRN <input type="checkbox"/> SKS <input type="checkbox"/> INS <input type="checkbox"/> OPEN BUTT <input type="checkbox"/> OTHER

SKETCH AND REMARK (3)		
ACCEPTANCE STD	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE / /

INSPECTOR	
NDE PROCEDURE	CERTIFICATION LEVEL

QA-502 8



BROWN & ROOT, INC. CPSES	NUMBER	REVISION	ISSUE DATE	PAGE
JOB 35-1195	QI-QAP-11.1-31	3	JAN 27 1982	1 of 9

TITLE:

INSTALLATION INSPECTION  
OF MECHANICAL JOINTS

ORIGINATOR: *R. Faulkner*

1-26-82  
DATE

REVIEWED BY: *J. E. Anderson*

1-26-82  
DATE

APPROVED BY: *E. D. Ruddy*

Site QA Manager

1-26-82  
DATE

**HISTORICAL FILE**

1.0 REFERENCES

1-A QI-QAP-11.1-26, "ASME Pipe Fabrication and Installation Inspection"

1-B QI-QAP-11.1-37, "Instruction for QA/QC Review, Approval and Utilization of Construction Operation Travelers."

1-C CP-QAP-16.1, "Control of Nonconforming Items"

2.0 GENERAL

2.1 PURPOSE AND SCOPE

This instruction delineates the requirements to be used when performing installation inspection of mechanical joints.


2.2 RESPONSIBILITY

The Site Quality Assurance Manager is responsible for review, approval and implementation of this instruction.

2.3 BOUNDARIES

The boundaries of a component to which piping is attached shall be at the limit of reinforcement. This boundary shall not be closer to the main shell of a vessel, pump, or valve than:

- the first bolted flange face; the bolts shall be considered part of the piping;
- the first threaded joint in screwed connections.



*860 6120572*

FOIA-85-59

M388

BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	3	JAN 27 1982	2 of 9

### 3.0 INSTRUCTION

#### 3.1 IDENTIFICATION

The Quality Control Inspector (QCI) shall verify that pipe spools to be joined are identified as described in Reference 1-A. Additionally, the QCI shall record the Material Requisition number the pipe spool is released on for threaded connections only.

#### 3.2 THREADED CONNECTIONS

##### 3.2.1 Pipe Wall Thickness

The QCI shall verify the pipe wall schedule is as specified on the applicable drawing by review of pipe markings and the Material Requisition Sheet.

##### 3.2.2 Thread Compound

The QCI shall verify that only Neolube No. 2 is used as a thread compound and is applied as follows:

- a. Neolube is limited to threads and shall not protrude onto the unthreaded portion of the pipe;
- b. Neolube is applied in an even, uninterrupted coat and allowed to dry prior to thread engagement.


##### 3.2.3 Threads

The QCI shall verify the following:

- a. all threaded ends are reamed and free of burrs;
- b. threaded ends are not damaged and free of obstruction.

##### 3.2.4 Pipe Thread Engagement

The QCI shall verify the minimum thread engagement of threaded connections as shown in Attachment 1, column L<sub>2</sub>.



BROWN & ROOT, INC. CPSES	NUMBER	REVISION	ISSUE DATE	PAGE
JOB 35-1195	QI-QAP-11.1-31	3	JAN 27 1982	3 of 9

### 3.2.5 Threaded Connections Requiring Seal Welding

#### 3.2.5.1 Prior to Welding

The QCI shall verify:

- a. a minimum of 2 inches on each side of the weld joint shall be degreased prior to welding. Mechanical preparation shall result in a clean surface 1/2 inch to 1 inch on each side of the joint;
- b. no thread compound used.


#### 3.2.5.2 After Welding

The QCI shall visually inspect seal welds on threaded connections (to include 1/2 inch on each side of the weld) in accordance with the following acceptance criteria:

- a. exposed threads are completely covered with weld metal;
- b. weld edges are free from overlap;
- c. undercut shall not exceed 1/32 inch or cause a reduction in base metal below minimum wall;
- d. no cracks;
- e. no incomplete fusion;
- f. no slag;
- g. no porosity;
- h. no arc strikes; and
- i. no weld spatter.

#### 3.2.6 Documentation

The results of QCI verifications shall be recorded on the Construction Operation Traveler (Reference 1-B), if utilized by Construction, and on Inspection Report, Attachment 2 with the following exceptions:



BROWN & ROOT, INC. CPSES JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	3	JAN 27 1982	4 of 9

a. Threading QCI verification (see 3.2.1) shall be documented on the Manufacturing Record Sheet (Reference 1-A).

b. Results of final visual inspection (see 3.2.5) shall be documented on the Weld Data Card and on the Visual Inspection Checklist, Attachment 3. Unacceptable conditions shall be documented on NDER, Attachment 4.

On completion of all QCI verification, the responsible QC Superintendent shall review the documented results and indicate approval by signing and dating the appropriate document.

### 3.3 FLANGE CONNECTIONS

#### 3.3.1 Cleanliness

The QCI shall verify flange faces are thoroughly cleaned to remove rust, scale, dirt, paint, etc.

#### 3.3.2 Traceability

The QCI shall verify Material Requisition number and color code of gasket material, heat number or lot number of nuts and bolts or studs are recorded on the Construction Operation Traveler (Reference 1-B).

#### 3.3.3 Alignment

The QCI shall verify flanges are aligned as follows:

- a. within 3/64 inch normal and with respect to flange outside diameter; except
- b. when pipe is to connect to a flange on equipment (i.e., valves, pumps, etc.), the face of the flange is aligned to the lesser of 25% of the gasket thickness or as described in a. above.

#### 3.3.4 Bolting

The QCI shall verify at least one complete thread is exposed above the nut face.



BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	3	JAN 27 1982	5 of 9

3.3.5 Documentation

The Construction Operation Traveler shall be used to document the QCI verifications described in this section (Reference 1-B).

4.0 NONCONFORMANCES

All nonconforming conditions will be reported in accordance with Reference 1-C.

INFORMATION  
**COPY**  
PPRV



ATTACHMENT 1




Table 2. Basic Dimensions of USA (American) Standard Taper Pipe Thread, NPT'

Nominal Pipe Size	Outside Diameter of Pipe, D	Threads per inch, n	Pitch of Thread, P	Pitch Diameter at beginning of External Thread, E <sub>1</sub>	Handlight Engagement			Effective Thread, External		
					Length <sup>1</sup> , L <sub>1</sub>		Dia <sup>2</sup> , E <sub>2</sub>	Length <sup>3</sup> , L <sub>2</sub>		Dia, E <sub>3</sub>
					In.	Thds.		In.	Thds.	
1	2	3	4	5	6	7	8	9	10	11
1/8	0.405	27	0.03704	0.36351	0.1615	4.36	0.37360	0.2639	7.12	0.38000
1/4	0.540	18	0.05556	0.47739	0.2278	4.10	0.49163	0.4018	7.23	0.50250
3/8	0.675	18	0.05556	0.61201	0.240	4.32	0.62701	0.4078	7.34	0.63750
1/2	0.840	14	0.07143	0.75843	0.320	4.48	0.77843	0.5337	7.47	0.79179
3/4	1.050	14	0.07143	0.96768	0.339	4.75	0.98887	0.5457	7.64	1.00179
1	1.315	11.5	0.08696	1.21363	0.400	4.60	1.23863	0.6878	7.85	1.25630
1 1/4	1.660	11.5	0.08696	1.55713	0.420	4.83	1.58338	0.7068	8.13	1.60130
1 1/2	1.900	11.5	0.08696	1.79609	0.420	4.83	1.82234	0.7235	8.32	1.84130
2	2.375	11.5	0.08696	2.26902	0.436	5.01	2.29627	0.7565	8.70	2.31630
2 1/2	2.875	8	0.12500	2.71953	0.682	5.46	2.76216	1.1375	9.10	2.79062
3	3.500	8	0.12500	3.34062	0.766	6.13	3.38850	1.2000	9.60	3.41562
3 1/2	4.000	8	0.12500	3.83750	0.821	6.37	3.88881	1.2500	10.00	3.91562
4	4.500	8	0.12500	4.33438	0.844	6.75	4.38712	1.3000	10.40	4.41562

INFORMATION  
NOT TO BE  
REPRODUCED  
WITHOUT  
PERMISSION  
OF THE  
COPYRIGHT  
OWNER

BROWN & ROOT, INC.  
CPSES

JOB 35-1195

NUMBER

REVISION

ISSUE  
DATE

PAGE

QI-QAP-11.1-31

3

JAN 27 1982

7 of 9

ATTACHMENT 2

COMANCHE PEAK STEAM ELECTRIC STATION

INSPECTION REPORT

ITEM DESCRIPTION VERIFY INSTALLATION IDENTIFICATION NO.		SYSTEM/STRUCTURE DESIGNATION	
OF THREADED SPOOLS			
SPEC. NO.	REV.	REF. CC. CCC. & REV. & CHANGE NO.	MEASURE OR TEST EQUIP. IDENT. NO.
<input type="checkbox"/> IN PROCESS INSPECTION	<input type="checkbox"/> PRE-INSTALLATION VERIFICATION	<input type="checkbox"/> INSTALLATION INSPECTION	<input type="checkbox"/> FINAL INSPECTION
<input type="checkbox"/> PRE-TEST INSPECTION			
INSPECTION RESULTS			
<input type="checkbox"/> INSPECTION COMPLETED, ALL APPLICABLE ITEMS SATISFACTORY			
<input type="checkbox"/> INSPECTION COMPLETED, UNSATISFACTORY ITEMS LISTED BELOW			
QC INSPECTOR	DATE		
ITEM NO.	INSPECTION ATTRIBUTES	SAT	UNSAT
1.	Spool is properly identified per QI-QAP-11.1-26		
2.	Spool is released on MR#		
3.	There are no obstructions inside spool		
4.	Threads are not damaged (Flat, Burred, Chipped)		
5.	Neolube properly applied		
6.	Thread engagement correct per QI-QAP-11.1-31, Attachment 2		
7.	Excess neolube removed		
8.	Record the following:		
	A. Spool * to Spool		
	B. Line No. Rework <input type="checkbox"/>		
	*Indicates Threaded Spool		
	**Check Rework if Applicable		
9. OC Superintendant Review			
REMARKS (DWGS, SPECS, ETC.)			
RELATED NCR NO.			
L.R. CLOSED <input type="checkbox"/>			
DATE			
SIGNATURE			
OC Inspector			

TYPICAL

INFORMATION  
COPY  
PPRV



BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-31	3	JAN 27 1982	8 of 9

### ATTACHMENT 3



**Brown & Root Inc.**

Post Office Box 1001, Glen Rose, Texas 76043

#### QUALITY ASSURANCE DEPARTMENT VISUAL EXAMINATION CHECKLIST

PROJECT: COMANCHE PEAK	JOB NO. 35-1195	UNIT	PAGE	OF
DRAWING	SYSTEM	CLASS		
WELDMENT NUMBER	LOCATION	<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> OTHER		

Enter NA adjacent to attribute when not applicable. Enter Sat./Unsat. or NA above results in each section 1 through 4 as applicable.

WDC#

CHECKER AND REVISIONS (S)		Procedure	Rev.
<b>CHECK LIST</b> <b>1. FITUP (Prior and During)</b> Base Material _____ Joint Design _____ Grooves _____ Edge Spacing _____ Joint Fitup _____ Joint Alignment _____ Spacing Engagement _____ Spacing End Gap _____ Undercut/Underlap/Overlap _____ CRACK _____ UNDERCUT/VITIFICATION OF FLOW _____		Results	
<b>2. AFTER WELDING OF ROOT</b> External Surface _____ Internal Surface _____		Procedure	Rev.
<b>3. COMPLETION OF WELD (10)</b> Surface _____ Reinforcement _____ Corrosion _____ Cracks _____ Crater Pits _____ Undercut/Underlap/Overlap _____ Ins. Flange (Ins. Penetration) _____ Burn Through _____ Undercut _____		Results	
<b>4. COMPLETION OF WELD (00)</b> Surface _____ Reinforcement _____ Undercut _____ Underlap _____ Spacing of Surface _____ Underlap/Underlap _____ Suitability of Surface for NOT _____ Removal of Tack, Attachments _____ Surface Free from Air Solids _____ Weld Spatter, etc. _____ Puddle Dam Removal _____		Procedure	Rev.
		Results	
		Inspector	Level Date

INFORMATION

Results

Inspector

Level

Date

QC Supervision

Date

Procedure

Rev.

CERTIFICATION LEVEL


NO-000/00

12/20/79 SA-000-1



BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAR-11.1-31	3	JAN 27 1982	9 of 9

ATTACHMENT 4



**Brown & Root Inc.**  
QUALITY ASSURANCE DEPARTMENT  
NDE REPORT

PROJECT: COMANCHE PEAK		JOB NO. 35-1195	UNIT	PAGE	OF
DRAWING	SYSTEM		CLASS		
WELD/ITEM NUMBER	LOCATION		<input type="checkbox"/> IC <input type="checkbox"/> EC <input type="checkbox"/> JO <input type="checkbox"/> OTHER		

MTL. TYPE	MTL. THICK	DIA/LENGTH
STAGE OF MFG.      JOINT DESIGN <input type="checkbox"/> BRN <input type="checkbox"/> BKS <input type="checkbox"/> REPAIR <input type="checkbox"/> ROOT <input type="checkbox"/> INTERMEDIATE <input type="checkbox"/> FINAL <input type="checkbox"/> INS <input type="checkbox"/> OPEN BUTT <input type="checkbox"/> OTHER		

SKETCH AND REMARK (S)

INFORMATION  
**COPY**  
PPRV



ACCEPTANCE STD	ACCEPT <input type="checkbox"/> REJECT <input type="checkbox"/>	DATE      /      /
----------------	---	--------------------

INSPECTOR	CERTIFICATION LEVEL
NDE PROCEDURE	


QA-602 8



PROCEDURE/INSTRUCTION REVIEW FORM

Procedure/Instruction No: <u>QI-QAP-11 1-31 rev 3</u>		Title: <u>Installation Inspection of Mech. Joints</u>	
Originator: <u>D. Faulkner</u>		Reviewing Organization: <u>Pipe Supr.</u>	Page <u>1</u> of <u>1</u>
Paragraph	Comment	Resolution	
			
			

Resolution(s) Acceptable


  
Signature

1-27-92  
Date

CP-QAP-6.1

PROCEDURE/INSTRUCTION REVIEW FORM


Procedure/Instruction No: <u>CP-QAP-11-1-3/rev 3</u>		Title: <u>Installation Inspection of Mechanical Joints</u>	
Originator: <u>R. Faulkner</u>		Reviewing Organization: <u>Quinn Rep.</u>	
Page: <u>1</u>		Page: <u>1</u>	
Paragraph	Comment	Resolution	
3.2.5.2	OVERLAP BY DEFINITION IS PERMANENT Angle $\angle 90^\circ$	3.2.5.2 - Yes, this is true.	
3.2.6(a)	Where on MRS?	3.2.6(a) - On <sup>crat</sup> the operation designated as the GCI's verification of threading acceptability.	
3.2.6(b)	QTS this to say all visually unacceptable welds will have an NDE?	3.2.6 b.1 yes	
	(2) QC Superintendent's Signature on IR is not what that space has been allocated for.	<p>(2) CP-QAP-18.05 is being revised to reflect "QC Superintendent."</p> <p><i>For Speed Letter dated 12/28/82 T. Brimble to G. Brady</i></p> <p>3.2.5.2 - Overlap definition has been deleted.</p> <p>3.2.6.b.2 - "Typical" attachment #2 has been corrected to allow close-out by Inspector as required by CP-QAP-18.05</p> <p><del>CP-QAP-18.05 will</del> QC Superintendent will sign as shown on Attachment #2.</p> <p>CP-QAP-18.05 will not be revised at this time.</p>	



Resolution(s) Acceptable

Signature [Signature] Date 1/26/82

PROCEDURE/INSTRUCTION REVIEW FORM

Procedure/Instruction No: <i>DI-QAP-11.1-31,AL3</i>		Title: <i>Installation Inspection of Mechanical Joints</i>	
Originator: <i>P. Faulkner</i>		Reviewing Organization: <i>Project Manager</i>	Page <i>1</i> of <i>1</i>
Paragraph	Comment	Resolution	
	<i>Comments marked on copy.</i>  <i>1/26/82</i>		

INFORMATION  
 COPY  
 PPRV

Resolution(s) Acceptable

Signature

Date

CP-QAP-6.1

## Speed Letter.

To

G. R. Purdy

From

C. T. Brown

Subject

Resolution of Comments on QF-QAP-11.1-31 R-3

MESSAGE

Date

1/26 1982

The resolution of comments is unacceptable for following reasons:

- ① OVERLAP IS POSSIBLE WITH REENTRANT ANGLE  $> 90^\circ$ ; hence your definition is NOT ALL INCLUSIVE.
- ② YOU CANNOT ISSUE A PROCEDURE WHICH VIOLATES A REFERENCED PROCEDURE. The IR AS YOU HAVE CONSTRUCTED IT IN QF-QAP 11.1-31 LEAVES NO CLOSEOUT SIGNATURE

Signed

T. O. S.

REPLY

Date

19

Signed

BROWN & ROOT, INC. CPSES	NUMBER	REVISION	ISSUE DATE	PAGE
JOB 35-1195	QI-QAP 11.1-25	7	MAR 12 1982	1 of 52
TITLE:  ASME PIPE FABRICATION AND INSTALLATION INSPECTIONS	ORIGINATOR: <u>Ronald C. Washington</u>	<u>3-4-82</u> DATE		
	REVIEWED BY: <u>J. L. Hinder</u>	<u>3-4-82</u> DATE		
	APPROVED BY: <u>ASME</u> Site QA Manager	<u>3/12/82</u> DATE		

1.0 REFERENCES

- 1-A ASME Boiler & Pressure Vessel Code, Section III, 1974 Edition with Addenda through Summer, 1974
- 1-B CP-QAP-2.1-5, "Training and Certification of Inspection Personnel"
- 1-C CP-QAP-8.1, "QC Receiving Inspection"
- 1-D CP-QAP-16.1, "Control of Nonconforming Items"
- 1-E QI-QAP-11.1-31, "Installation Inspection of Mechanical Joints"
- 1-F CP-QAP-10.3-7, "QC Surveillance of Welder Performance Qualification"
- 1-G CP-QAP-16.1-2, "Documenting Base Metal Repairs, Minimum Wall Violations, and Arc Strike Repairs"
- 1-H CP-QAP-18.2, "QA Review of ASME Section III Documentation"

2.0 GENERAL

2.1 PURPOSE AND SCOPE

This instruction delineates the requirements and criteria to be used when performing fabrication or installation inspection of ASME Code piping (Reference D-1).

2.2 RESPONSIBILITY

The Quality Control Manager shall be responsible for implementation of this instruction.



FOIA-85-59

M389

BROWN & ROOT, INC. CPSES	NUMBER	REVISION	ISSUE DATE	PAGE
JOB 35-1195	QI-QAP-11.1-26	7	MAR 12 1982	3 of 52

## 2.6 ROUTINE OBSERVATIONS

Inspection personnel performing inspections shall routinely observe general workmanship conditions in all areas of plant construction. Observations shall include such items as:

- a. Handling/Rigging
- b. Housekeeping/Storage Maintenance
- c. Contamination of Stainless Steel (Material Segregation)
- d. Physical Damage

Observations which are adverse to quality and existing site procedures shall be documented using Field Deficiency Reports (FDR's). The FDR's shall be forwarded to Quality Engineering for evaluation.

## 2.7 INSPECTION OF MECHANICAL JOINTS

Inspection of flanged joints, threaded joints, etc., shall be accomplished in accordance with Reference 1-E.

## 3.0 IDENTIFICATION, MARKING, CLEANING, FIT-UP AND FINAL VISUAL INSPECTION REQUIREMENTS

### 3.1 MATERIAL IDENTIFICATION AND MARKING REQUIREMENTS

Material identification shall be maintained on all items during fabrication and installation activities. The material identification shall be such that traceability is maintained between the item and its associated documentation.

#### 3.1.1 Maintenance of Material Identification during Cutting Operations

When cutting is performed in order to modify a vendor-supplied piping spool, a B&R fabricated piping spool, or cut process bulk pipe for fabrication purposes, the QEI shall verify the following is transferred legibly, and in accordance with paragraph 3.1.4, to each cut piece prior to cutting:

- a. Vendor supplied piping spool - the spool number and drawing number.
- b. Process bulk pipe - the heat number, ASTM/ASME type and grade, schedule/wall thickness, spool number, drawing number, and piece number.

BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER  QI-QAP 11.1-26	REVISION  8	ISSUE DATE  APR 15 1982	PAGE  1 of 53
TITLE:  ASME PIPE FABRICATION AND INSTALLATION INSPECTIONS	ORIGINATOR: <u>Ronald C Washington</u>  REVIEWED BY: <u>P. V. Laboti</u>  APPROVED BY: <u>[Signature]</u> Site QA Manager		<u>4-14-82</u> DATE  <u>4-14-82</u> DATE  <u>4-14-82</u> DATE	

1.0 REFERENCES

- 1-A ASME Boiler & Pressure Vessel Code, Section III, 1974 Edition with Addenda through Summer, 1974
- 1-B CP-QAP-2.1-5, "Training and Certification of Inspection Personnel"
- 1-C CP-QAP-8.1, "QC Receiving Inspection"
- 1-D CP-QAP-16.1, "Control of Nonconforming Items"
- 1-E QI-QAP-11.1-31, "Installation Inspection of Mechanical Joints"
- 1-F CP-QAP-10.3, "QC Surveillance of Welder Performance Qualification"
- 1-G CP-QAP-16.1-2, "Documenting Base Metal Repairs, Minimum Wall Violations, and Arc Strike Repairs"
- 1-H CP-QAP-18.2, "QA Review of ASME Section III Documentation"

2.0 GENERAL

2.1 PURPOSE AND SCOPE

This instruction delineates the requirements and criteria to be used when performing fabrication and installation inspection of ASME Code piping (Reference: [illegible]).

2.2 RESPONSIBILITY

The Quality Control Manager shall be responsible for implementation of this instruction.

**HISTORICAL FILE**

**COPY**  
PPRV

FOIA-85-59



M390

BROWN & ROOT, INC. CPSES	NUMBER	REVISION	ISSUE DATE	PAGE
JOB 35-1195	QI-QAP-11.1-26	8	APR 15 1987	3 of 53

## 2.6 ROUTINE OBSERVATIONS

Inspection personnel performing inspections shall routinely observe general workmanship conditions in all areas of plant construction. Observations shall include such items as:

- a. Handling/Rigging
- b. Housekeeping/Storage Maintenance
- c. Contamination of Stainless Steel (Material Segregation)
- d. Physical Damage

Observations which are adverse to quality and existing site procedures shall be documented using Field Deficiency Reports (FDR's). The FDR's shall be forwarded to Quality Engineering for evaluation.

## 2.7 INSPECTION OF MECHANICAL JOINTS

Inspection of flanged joints, threaded joints, etc., shall be accomplished in accordance with Reference 1-E.

## 3.0 IDENTIFICATION, MARKING, CLEANING, FIT-UP AND FINAL VISUAL INSPECTION REQUIREMENTS



### 3.1 MATERIAL IDENTIFICATION AND MARKING REQUIREMENTS

Material identification shall be maintained on all items during fabrication and installation activities. The material identification shall be such that traceability is maintained between the item and its associated documentation.

#### 3.1.1 Maintenance of Material Identification during Cutting Operations

When cutting is performed in order to modify a vendor-supplied piping spool, a B&R fabricated piping spool, or cut process bulk pipe for fabrication purposes, the QCI shall verify the following is transferred legibly, and in accordance with paragraph 3.1.4, to each cut piece prior to cutting:

- a. Vendor supplied piping spool - the spool number and drawing number.
- b. Process bulk pipe - the heat number, ASTM/ASME type and grade, schedule/wall thickness, spool number, drawing number, and piece number.



BROWN & ROOT, INC. CPSES	NUMBER	REVISION	ISSUE DATE	PAGE
JOB 35-1195	QI-QAP-11.1-26	8	APR 15 1982	10 of 53

### 3.3.4 Cold Springing

The QC Inspector shall verify at fit-up, prior to welding, that cold springing does not exist, and document results on the Visual Examination Checklist.

### 3.4 PREHEAT/INTERPASS TEMPERATURE

The preheating and interpass temperatures to be used for welding shall be in accordance with the applicable WPS.

Where the temperature of the surface of material to be welded falls below 60°F and a higher preheat is not required by the WPS, the weld area shall be preheated to a hand warm condition.

The preheat specified on the WPS shall be established before any welding. However, except for P4 and P5 materials, preheating above 60°F is not required before tacking.


Preheat and interpass temperatures shall be measured by the use of approved temperature indicating crayons, attached thermocouples, pyrometers or any other method approved by the Owner. Temperature indicating crayons shall be of the special lead-free, sulphur-free and halogen free type such as Tempilstick.

The area to be preheated on any weld joint shall be 3 times the wall thickness on each side of the maximum weld width. The area shall be uniformly preheated to the required temperature before the start of production welding.

Temperature indicating crayons, when used for preheat and interpass temperature measurement shall be applied to avoid direct contact with the surface to be welded.

The interpass and preheat temperature shall be measured on the surface of the base material, on the side which the welding is performed, within 1 inch of the weld joint edge, and along the joint 1 inch from the starting point for the next weld pass.

Preheat and Interpass (if necessary) temperatures are verified by the QCI in accordance with the above and documented on the Preheat and Interpass temperature blocks on the applicable WDC.



BROWN & ROOT, INC. CPSES  JOB 35-1195	NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QAP-11.1-26	8	APR 15 1982	44 of 53

# ATTACHMENT 16



Brown & Root Inc.

Post Office Box 1001, Glen Rose, Texas 75043

## QUALITY ASSURANCE DEPARTMENT VISUAL EXAMINATION CHECKLIST

PROJECT: COMANCHE PEAK	JOB NO. 35-1195	UNIT	PAGE 44 OF 53
BRIDGE	SYSTEM	CLASS	
SECTION NUMBER	LOCATION	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100	OTHER

Enter NA adjacent to attribute when not applicable. Enter Sat./Unsat. or NA above results in each section 1 through 4 as applicable.

WDC#

CHECK LIST		QI-QAP-11.1-26	Rev.
1. FITUP (Prior and During)			
<ul style="list-style-type: none"> <li>Base Metal</li> <li>Weld Metal</li> <li>Weld Joint</li> <li>Weld Root</li> <li>Weld Face</li> <li>Weld Toe</li> <li>Weld Cracks</li> <li>Weld Spatter</li> <li>Weld Defects</li> <li>Weld Surface</li> <li>Weld Undercut</li> <li>Weld Porosity</li> <li>Weld Inclusions</li> <li>Weld Discontinuities</li> <li>Weld Imperfections</li> <li>Weld Defects</li> <li>Weld Surface</li> <li>Weld Undercut</li> <li>Weld Porosity</li> <li>Weld Inclusions</li> <li>Weld Discontinuities</li> <li>Weld Imperfections</li> </ul>		Results	
2. AFTER WELDING OF ROOT		QI-QAP-11.1-26	Rev.
<ul style="list-style-type: none"> <li>Weld Metal</li> <li>Weld Joint</li> <li>Weld Root</li> <li>Weld Face</li> <li>Weld Toe</li> <li>Weld Cracks</li> <li>Weld Spatter</li> <li>Weld Defects</li> <li>Weld Surface</li> <li>Weld Undercut</li> <li>Weld Porosity</li> <li>Weld Inclusions</li> <li>Weld Discontinuities</li> <li>Weld Imperfections</li> <li>Weld Defects</li> <li>Weld Surface</li> <li>Weld Undercut</li> <li>Weld Porosity</li> <li>Weld Inclusions</li> <li>Weld Discontinuities</li> <li>Weld Imperfections</li> </ul>		Results	
3. COMPLETION OF WELD (10)		QI-QAP-11.1-26	Rev.
<ul style="list-style-type: none"> <li>Weld Metal</li> <li>Weld Joint</li> <li>Weld Root</li> <li>Weld Face</li> <li>Weld Toe</li> <li>Weld Cracks</li> <li>Weld Spatter</li> <li>Weld Defects</li> <li>Weld Surface</li> <li>Weld Undercut</li> <li>Weld Porosity</li> <li>Weld Inclusions</li> <li>Weld Discontinuities</li> <li>Weld Imperfections</li> <li>Weld Defects</li> <li>Weld Surface</li> <li>Weld Undercut</li> <li>Weld Porosity</li> <li>Weld Inclusions</li> <li>Weld Discontinuities</li> <li>Weld Imperfections</li> </ul>		Results	
4. COMPLETION OF WELD (00)		QI-QAP-11.1-26	Rev.
<ul style="list-style-type: none"> <li>Weld Metal</li> <li>Weld Joint</li> <li>Weld Root</li> <li>Weld Face</li> <li>Weld Toe</li> <li>Weld Cracks</li> <li>Weld Spatter</li> <li>Weld Defects</li> <li>Weld Surface</li> <li>Weld Undercut</li> <li>Weld Porosity</li> <li>Weld Inclusions</li> <li>Weld Discontinuities</li> <li>Weld Imperfections</li> <li>Weld Defects</li> <li>Weld Surface</li> <li>Weld Undercut</li> <li>Weld Porosity</li> <li>Weld Inclusions</li> <li>Weld Discontinuities</li> <li>Weld Imperfections</li> </ul>		Results	
		Inspector	Level Date

QC Supervision	DATE
QI-QAP-11.1-26	Rev.
CERTIFICATION LEVEL	

