

APR 14 1976

Docket No. 50-133

Robert Reid, Chief, Operating Reactors Branch 4, OR

RESPONSE FROM PACIFIC GAS & ELECTRIC COMPANY WITH RESPECT TO APPENDIX I
TO 10 CFR PART 50 FOR HUMBOLDT BAY

We have reviewed the letter of response from Pacific Gas & Electric
Company for Humboldt Bay, dated March 23, 1976 with respect to Appendix I
to 10 CFR Part 50 and we have the following comments.

We find PG&E's response to be unacceptable. Section V.B.1 of Appendix I
requires, in part, that all licensees shall, within a period of 12 months
from June 4, 1975, file with the Commission "such information as is
necessary to evaluate the means employed for keeping levels of radio-
activity in effluents to unrestricted areas as low as practicable including
all such information as is required by 50.34a(b) and (c) not already
contained in his application".

The licensee should indicate what information he can provide by June 4, 1976.
If all of the information requested in our February letter cannot be
furnished by this date, then the licensee should provide us a schedule
indicating when the rest of the information will be available.

ORIGINAL SIGNED BY
JOHN T. COLLINS

John T. Collins, Chief
Effluent Treatment Systems Branch
Division of Site Safety and
Environmental Analysis

cc: H. Denton
R. Vollmer
K. Goller
W. Kreger
L. Hulman
E. Markee
F. Congel
T. Verdery
W. Burke
R. Buras

/ Docket File 50-133
NRR Reading
DSE Reading
ETSB Reading

OFFICE X 27775 SUBNAME	DSE:ETSB JTCollins:do DATE 04/14/76	8602260443 851212 PDR FOIA FIREST085-665 PDR		
------------------------------	--	--	--	--