

Georgia Power Company  
333 Piedmont Avenue  
Atlanta, Georgia 30308  
Telephone 404-526-6774

Mailing Address:  
Post Office Box 4545  
Atlanta, Georgia 30302

R. E. Conway  
Senior Vice President

the southern electric system

June 13, 1986

Director of Nuclear Reactor Regulation  
Attention: Mr. B. J. Youngblood  
PWR Project Directorate #4  
Division of PWR Licensing A  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

File: X7N00-24  
Log: GN-929

NRC DOCKET NUMBERS 50-424 AND 50-425  
CONSTRUCTION PERMIT NUMBERS CPPR-108 AND CPPR-109  
VOGTLE ELECTRIC GENERATING PLANT - UNITS 1 AND 2  
FSAR AMENDMENT NUMBER 24

Dear Mr. Denton:

Georgia Power Company, acting on its own behalf and as agent for Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and the City of Dalton, Georgia, hereby submits Amendment 24 to the Vogtle Electric Generating Plant (VEGP) Final Safety Analysis Report (FSAR).

This amendment consists of revised pages for the FSAR as documented in previous correspondence with the NRC, design and/or operational updates, and closure of SER items. A listing of the letters and updates are itemized in Attachment 1. Please note that some of the revisions may require changes to the SER. Also included are instructions for inserting the Amendment 23 FSAR changes.

In accordance with the requirements of 10 CFR 54.30(b) and (c), three (3) signed originals and sixty (60) copies of Amendment 24 are submitted for your use.


Should you have any questions on the enclosed submittals, do not hesitate to contact me.

Yours truly,

  
R. E. Conway

8606180112 860613  
PDR ADOCK 05000424  
K PDR

SWORN AND SUBSCRIBED BEFORE ME, THIS  
14th DAY OF June, 1986

  
Notary Public, Georgia State at Large

My Commission Expires Apr. 11, 1988

13001  
3/60  
7 Extra  
CYS To: M. Miller  
PM

Director of Nuclear Reactor Regulation  
June 13, 1986  
Page 2

File: X7N00-24  
Log: GN-929

xc: M. A. Miller  
R. A. Thomas  
G. Bockhold, Jr.  
L. T. Gucwa  
J. E. Joiner, Esquire  
B. W. Churchill, Esquire  
B. Jones, Esquire  
H. H. Gregory, III  
D. C. Teper  
W. C. Ramsey  
Vogtle Project File

0362V

ATTACHMENT 1

<u>FSAR Section</u>	<u>Reason for Change</u>
1.9.26, 3.1	Clarification, Walker to Kelley, 3/15/86
1.9.68, Q640.25	Update to agree with NSSS standard start-up procedures
1.9.88	Clarification to reflect incorporation of WCAP-8370/7800 in Section 17.1
1.9.133	Reflect Technical Specifications
1.9.150, 5.2.3.4	Clarification to RV weld inspection
T1.9-1, 2, & 3	Update to reflect use of NRC approval code cases
2.4, 2.5	Revised to reflect latest information and analysis for groundwater hydrology
3.6.1, 3..6.2	Revised criteria to reflect actual rather than mechanistic breaks
3.7.B.3	Reflect use of multiple response spectra methodology (1)
3.8.1	Reflect current design, wedge material in containment post-tensioning system
3.9.B.1	Reflect use of additional computer program
3.9.B.3, Q210.54	Amplification of deflection criteria for supports
3.11.N.1	Reflect EQ updates
3F	Reflect flood level analysis
4A	CI-15; update to reflect use of RTDs in place of thermocouples

<u>FSAR Section</u>	<u>Reason for Change</u>
6.2.5	Reflect Technical Specifications
7.1.1	Clarify "Phase B" isolation; human factor HED implementation
7.2.1, 7.3.5, 7.3.6, 7.3.7	CI-26; update logic diagrams to reflect override of control room isolation signals
T7.5.2-1	Update instrument ranges
8.2.2	Documentation of use of ASTM-B189
8.3.1, Q430.62	Reflect Technical Specifications
8.3.1.4	Clarification of cable tray fill at transition points
8.3.2.1	Reflect current design, upgraded minimum inverter operating voltage (2)
8.3.2	Reflect current design; resolve NRC finding 424/85-21-02
9.2.6	Reflect current analysis and Technical Specifications; minimum CST capacity (3)
9.2.10, 9.2.11	Reflect current design, turbine plant cooling load
9.5.1, 9A, 9B	OI-7 & 8; reflect safe shutdown analysis
10.3.5	Consistency with Q281.6 commitment to use EPRI-NP-2704 for chemistry control
10.4.9	Reflect current design; check valves in AFW system, and location of CST level alarm (3)
T12.3.4-2	Instrument setpoint change to reflect actual testing
Chapter 13	OI-11; reflect new corporate structure, Bailey to Denton, GN-878, 4/21/86; training, Bailey to Denton, GN-862, 4/4/86, and 5/26/86 NRC teleconference
14.2.8	Reflect current test procedures

FSAR SectionReason for Change

Q210.47	Clarification from NRC during teleconference, 1/15/86
Q271.1	CI-14; Bailey to Denton, GN-903, 5/7/86; P&V operability
Q430.2	CI-35; Bailey to Denton, GN-877, 4/21/86; diesel load test

- (1) SER impacted, pages 3-28 & 29, by the additional use of multiple response spectra methodology rather than the exclusive use of the envelope method.
- (2) SER impacted, page 8-7, vital AC buses will operate at a minimum of 105 rather than 104 volts.
- (3) SER impacted, pages 9-22 & 10-19, by requirement for 340,000 rather than 330,000 gallons in the CST.

ATTACHMENT 1

<u>FSAR Section</u>	<u>Reason for Change</u>
1.9.26, 3.1	Clarification, Walker to Kelley, 3/15/86
1.9.68, Q640.25	Update to agree with NSSS standard start-up procedures
1.9.88	Clarification to reflect incorporation of WCAP-8370/7800 in Section 17.1
1.9.133	Reflect Technical Specifications
1.9.150, 5.2.3.4	Clarification to RV weld inspection
T1.9-1, 2, & 3	Update to reflect use of NRC approval code cases
2.4, 2.5	Revised to reflect latest information and analysis for groundwater hydrology
3.6.1, 3..6.2	Revised criteria to reflect actual rather than mechanistic breaks
3.7.B.3	Reflect use of multiple response spectra methodology (1)
3.8.1	Reflect current design, wedge material in containment post-tensioning system
3.9.B.1	Reflect use of additional computer program
3.9.B.3, Q210.54	Amplification of deflection criteria for supports
3.11.N.1	Reflect EQ updates
3F	Reflect flood level analysis
4A	CI-15; update to reflect use of RTDs in place of thermocouples

FSAR SectionReason for Change

Q210.47	Clarification from NRC during teleconference, 1/15/86
Q271.1	CI-14; Bailey to Denton, GN-903, 5/7/86; P&V operability
Q430.2	CI-35; Bailey to Denton, GN-877, 4/21/86; diesel load test

- (1) SER impacted, pages 3-28 & 29, by the additional use of multiple response spectra methodology rather than the exclusive use of the envelope method.
- (2) SER impacted, page 8-7, vital AC buses will operate at a minimum of 105 rather than 104 volts.
- (3) SER impacted, pages 9-22 & 10-19, by requirement for 340,000 rather than 330,000 gallons in the CST.



"SAR SectionReason for Change

6.2.5	Reflect Technical Specifications
7.1.1	Clarify "Phase B" isolation; human factor HED implementation
7.2.1, 7.3.5, 7.3.6, 7.3.7	CI-26; update logic diagrams to reflect override of control room isolation signals
T7.5.2-1	Update instrument ranges
8.2.2	Documentation of use of ASTM-B189
8.3.1, Q430.62	Reflect Technical Specifications
8.3.1.4	Clarification of cable tray fill at transition points
8.3.2.1	Reflect current design, upgraded minimum inverter operating voltage (2)
8.3.2	Reflect current design; resolve NRC finding 424/85-21-02
9.2.6	Reflect current analysis and Technical Specifications; minimum CST capacity (3)
9.2.10, 9.2.11	Reflect current design, turbine plant cooling load
9.5.1, 9A, 9B	OI-7 & 8; reflect safe shutdown analysis
10.3.5	Consistency with Q281.6 commitment to use EPRI-NP-2704 for chemistry control
10.4.9	Reflect current design; check valves in AFW system, and location of CST level alarm (3)
T12.3.4-2	Instrument setpoint change to reflect actual testing
Chapter 13	OI-11; reflect new corporate structure, Bailey to Denton, GN-878, 4/21/86; training, Bailey to Denton, GN-862, 4/4/86, and 5/26/86 NRC teleconference
14.2.8	Reflect current test procedures