AMERICIUM-241 FOIL INTEGRITY TESTS:

Performed for Nuclear Radiation Developments Corporation
May 1976

Investigators:
Glen Greenberg, B.A.
David A. Dooley, B.A., M.A.

8606200131 860505 REG2 L1C30 09-17650-02 PDR

INTRODUCTION

A series of independent environmental stress tests were performed on Nuclear Radiation Developments Corp. Model A001, Americium-241 foils mounted in source holders used in fire detection devices. Different groups of foils were subjected to prolonged immersion in Buffalo City water; exposure to constant relative humidity and temperature; and finally, to a test simulating the human digestive process. All tests were performed between February 27, 1976 and March 23, 1976. The purpose of these tests is to determine whether or not the surface integrity of the foil is affected by such conditions, and if the radioactivity is lost, is it in a soluble or an insoluble form. All foils tested contained an original activity of 2 microcuries of Americium-241, in the form of Americium-241 dioxide. The oxide is incorporated in a gold matrix and rolled into a final source foil containing several laminations of gold and silver, effecting a sealing of the Americium.

MATERIALS and METHODS

Immersion Test

Three NRD Model A001 Americium-241 foils were placed in separate 50 milliliter Erlenmeyer flasks, into which 3 ml of Buffalo City tap water was added.* The top of the flasks were sealed with Parafilm, leaving an orifice large enough to allow a 1 ml glass pipette to be inserted and samples withdrawn. Two ml aliquots were removed from each flask every 24 hours. The volume removed was immediately replaced with fresh tap water. One ml was placed on a one inch planchette and allowed to air dry. The other one ml sample was drawn through a 0.45 micron (um) Millipore filter to assay for possible particulate activity. The filters were allowed to dry by evaporation. Both samples were then assayed for their radioactive

^{*}Buffalo City water is classified as hard water, with a pH of 7.56 as determined by a pH meter.

content by counting them in a 27 gas-flow proportional detector.**

Samples were removed on a 24 hour basis over a 12 day period, beginning February 27, 1976 and ending March 9, 1976. A one ml aliquot was left in each flask from March 9, 1976 until March 21, 1976. These samples were removed and placed on one inch aluminum planchettes, allowed to dry, and then assayed for radioactive content.

A new test to assay for particulates began on March 21, 1976 and ended 48 hours later on March 23. The purpose of this test was to determine if any appreciable amounts of radioactivity could be detected, in the particulate form, beyond the original 12 day test period. In this test only 1 ml of tap water was added to each flask. The flasks were then aggitated and allowed to stand for the duration of the test. Samples were then assayed for particulate activity, as per previously described methods.

Three Weck Environmental Test

Three NRD Model A001 Americium-241 foils were subjected to an environment of constant relative humidity [803] and constant temperature [1120 Fahrenheit, 44.440C] for a three week period, in separate closed systems. See Figure I for a representation of the system.

The paper by D. S. Carr and B. L. Harris, Solutions for Maintaining Constant Relative Humidity I; and the work by R. H. Stokes, entitled Standard Solutions for Humidity Control at 25°C I, were used to formulate the conditions necessary to maintain the relative humidity of the chamber at 80%. From the data presented in these papers, it was determined that a saturated solution of potassium chloride [KC1] at 70°C would maintain the relative humidity at exactly 80%. However, the desired temperature for this experiment was 112°F, or 44.44°C. A saturated KC1 solution, kept at 44.44°C, will yield a relative humidity of 81.5%. This value is derived from graphic interpolation. [See Figure XI., & Relative Humidity vs. Temperature in °C.] . Therefore, the relative humidity used for this test was 1.6% higher than

^{**} For type of instrument used, etc., see RESULTS

the desired value. This minor alteration should have no affect on the results since higher humidity would make the conditions even more adverse. The Americium foil was suspended from the top of the chamber in a one inch aluminum planchette supported by copper wire. The units were then sealed with a combination of grease, paraffin and Parafilm, and placed in a Blue-M Stabil-Therm gravity oven at 44°C for a three week period beginning 2/27/76 and ending 3/17/76. Reeve Angel glass fiber circular filters (size: 2.4 cm, grade: 934AH), were used to take wipe samples of all surfaces on the interior of the chamber, in addition to sampling the KC1 solution itself. All filters were allowed to dry, then placed on planchettes and assayed for their radioactive content in a gas flow Proportional detector.

Digestion Test

The purpose of this test was to determine to what extent the Americium-241 foils would be degraded by normal human digestive processes
if one of the foils were accidently swallowed.

A.) Saliva Test - The normal physiologic make-up of himan saliva is 99% water and 1% of a mixture of enzymes, salts and proteins. Amylase, the most significant protein, serves to catalyze the breakdown of polysaccharides to disaccharides. Saliva normally has a pH of 6.8. The Americium foil was immersed in a fresh specimen of human saliva, in a sterile test tube. After 5 minutes of agitation, in a water bath at $37^{\circ}\text{C}(98.6^{\circ}\text{F})$, the foil was removed from the tube and placed into another test tube containing a solution of gastric juices (see below). The saliva was then placed on an aluminum planchette, allowed to dry and assayed for possible radioactive content.

It is assumed that prolonged exposure to salivary juices would have little or no effect on the integrity of the foil coating since saliva has been proven to be inactive against gold. This is documented in many dental references, since, today, the use of gold in dentistry is a common practice.

B.) Gastric Test - After immersion in saliva for five minutes, the foil was wipe tested and transferred to a new test tube contain-

ing normal digestive juices for 7.5 hours. Normal gastric mucosal secretions include: an isotonic acid of 150 mN H † , 150 mN C1 $^{-}$ and 5mN K † ; a collection of enzyme precursors, an example being pepsinogen, which is converted to its active form (pepsin) by H † at a pH of 1-6; several complex mucoproteins; and the intrinsic factor. The most important digestive factor in the stomach is hydrochloric acid, since this acid, in the proper concentrations, is capable of degrading almost all substances. Another important substance in gastric digestion is pepsin. It was assumed, since most, if not all of the degradation of the foil coating would occur due to its exposure to HC1, that the experimental model would contain 150 mN HC1, 5 mN K † and 1% pepsin (swine). This solution was mixed thoroughly and brought to a temperature of 37°C with a water bath. The pH of the solution was 1.96.

In this test, one must consider gastric emptying the major factor in determining how long the foil will remain in the stomach. If the foil was accidently or intentionally swallowed, the longest stay-time in the stomach would occur if it were swallowed just before bedtime. The maximum elapsed time for retention of the foil would be approximately 7.5 hours. The foil would definitely be passed onto the small intestine following breakfast the next morning, unless the foil should be lodged in a diverticulum somewhere between the esophogeal crifice and the pyloric sphincter, in which case, the amount of digestion would depend on the location of the diverticulum.

C.) Pancreatic Test - The normal physiologic make-up of the small intestine includes such enzymes as trypsin, chymotrypsin, carboxypeptidase, lypase, etc., which are available commercially as Pancreatin. A one percent solution of Pancreatin, containing 150 mN sodium bicarbonate (Na $_2$ CO $_3$) and 15 mN HC1 was prepared for this test. The pH of the solution was measured at 8.1. The foil was transferred from the gastric test tube, wipe tested, and placed in a new test tube containing the pancreatic solution for a period of 20 hours, in a water bath at 37° C.

P.) Large Intestine Test - As a final test to simulate the passage of the foil through the large intestine, a test tube was prepared containing Escherichia coli and normal Buffalo tap water. The pH of the solution was measured at 7.56. This test was run for a 50 hour period in a water bath at 37°C.

Note: The normal oral-rectal transit time as established by Dr. Danield Burkitt³, is approximately 90 hours for people living in western cultures.

Radioactive Assay

All sample counting was done on a Nuclear Chicago 186-A Proportional preflush gas-flow detector. The counting gas employed was P-10, which contains 90% argon and 10% methane. The alpha plateau of the detector was determined with a New England Nuclear alpha reference standard (model NES-302-S, Americium-241) containing 5.0x10⁻² microcuries (6.7x10⁴ alphas per minute). This standard was calibrated in October of 1973. The operating voltage was determined to be 1270 volts. (See Figure II.) An alpha reference source of lesser activity was then used to determine the alpha counting efficiency at this voltage. This alpha reference source was also made by NEN and contained 3.29x10⁻² microcuries on September 11, 1975. The data for these tests appears on page 17. The detector uses a 27 counting geometry and it is not known to what extent backscatter of the alpha particles contributes to the net counting rate of the source. The counting efficiency was determined to be 55.83% - 0.04%.

Statistical Analysis

Statistical evaluation of the counting data was deemed necessary due to the very low background counting rate, and in most cases to the equally low sample count rate. Such a procedure allows for reporting of the results to a significant confidence interval.

Nuclear Chicago's Technical Bulletin number 14, How to Apply Statistics to Nuclear Measurements, was used as a reference for this analysis. The number of microcuries removed from the foil surface and the % error involved in counting each sample were calculated. The parent equation used to determine the per cent error is as follows:

% Error = Observed Value - Expected Value x 100

For the purpose of calculating the % error of all samples, the above equation was substituted as follows:

$$CPM_{net} + 1.96[\frac{Gross\ Counts\ +\ Bkg\ Counts\ \}^{\frac{1}{2}}}{T_{G}^{2}}]^{\frac{1}{2}}$$

$$\$\ Error = \frac{Efficiency\ -\ Efficiency\ Error\ Eff.\ x\ 100}{CPM_{net}}$$

Where T_G is the counting time in minutes for the gross counts; T_{Bkg} is the background counting time (in minutes). By subtracting the error from the counting efficiency in the numerator, the value of the entire equation is maximized for the per cent error. Then, multiplying the square root expression by 1.96 gives a 95% level of confidence to the values obtained employing this equation.

The activity removed from the foil surface, in microcuries, was calculated as follows:

Activity Removed (uCi) = $\frac{CPM_{net}}{Counting \ Efficiency} \cdot \frac{1}{2.22 \times 10^{\circ} \ dpm/uCi}$

All values are reported in terms of uCi removed from the foil surface. Tables I. through III. present the results of all tests in terms of uCi removed.

RESULTS

Immersion Test

The data for the immersion test appears on page 18 through page 24. The corresponding graphs of counts per minute verses time (in days), are contained in Figures III. through X. Figure IX is a composite of the average values of all three gross sample assays, while Figure X. is a similar composite of the Millipore filter tests. The values obtained by the additional tests performed on March 21 and March 23 are plotted on their respective composites, on an insert labeled TIME EXTENSION DATA. Table 1. contains data pertaining to the activity leached in the gross and Millipore filter assays.

The foil surface and particularly the foil structure showed extensive corrosion and pitting in almost all area due to its exposure to Buffalo tap water.

Three Week Environmental Test

Only eight out of the 30 filters assayed in this test yielded sufficient counts to give a positive number after background counts had been subtracted. However none of these counts were statistically different from background on a 2 sigma basis. The actual counting data is presented on pages 29 and 30. Special disposable gloves were used in handling the individual parts of each chamber when it was dismantled. The glove fingertips were then assayed for possible contamination at the end of all handling procedures. No significant activity (greater than background) was obtained by these assays.

Digestion Test

A.) Saliva Test - The data obtained when the saliva samples were analyzed proved insignificant; the gross count rate was only twice the background rate. This test had the least effect of all of the digestion procedures with respect to removing radioactivity from the foil surface. A wipe sample was taken from the foil surface at the conclusion of this test using a glass fiber filter. The wipe test data also showed that no significant activity was removed from the foil. (See Table II. and page 27.)

B.) Gastric Test - As was expected, the larger amount of degradation of the foil surface was caused by the action of HC1. Table II contains the results of this test. The test tube used was rinsed with distilled water and this sample was assayed as per previous procedures. A wipe sample was taken of the foil surface and subsequently assayed.

6

- C.) Pancreatic Test Since the pH of this solution was 8.1, foil surface integrity was less affected as compared to the gastric test. The test tube used was rinsed and assayed for residual activity. The foil surface was again wipe tested before beginning the next procedure.
- Of the foil surface and the long exposure of the foil to this solution, this test proved to be second only to the gastric test in its ability to remove activity from the foil surface. The test tube was rinsed with distilled water, the sample was allowed to dry and assayed. Finally a wipe sample was taken of the foil surface. [See Table II. and page 27.]

DISCUSSION

A direct comparison of the values obtained in the Immersion test using two different methods of assaying for Am-241 activity (i.e. gross sampling versus Millipore Filter sampling) produced a correlation factor of 99.24%. This is a definite indication that all of the activity which was removed from the foil surface is indeed particulate and therefore insoluble. All foils tested produced nearly the same relationship when plotted as a function of activity -(counts per minute) versus time (days). Peak activity appears in the third day of the test in each individual case, as well as when an average was computed (see Figures III-IX.). At the five day mark, the count rate of all samples began to approximate background, and, in general, remained at this low level until the end of the test. The additional gross and particulate assays performed, produced a counting rate near background. The additional particulate test gave a somewhat higher value than the additional gross assay, probably due to the fact that fresh water was added to the flask.

For all practical purposes, it can be assumed that in the immersion test, the total water volume is replaced each day. The one ml that was left in the flask should have produced an increase in its radioactive concentration with time, if the sample was leaching. Am-241 activity continuously. However, this was not the case, since the actual concentration decreased with time. Therefore it is possible to make the assumption that the entire volume was replaced each day.

On Table I. a direct comparison is made between the activity detected by the gross and Millipore of the tests, including the margins of error for each determination. The amount of activity detected by the gross assay should always exceed that due to the filter assay since some particulates could conceivably escape being trapped. However, in some instances this is not the case, which would tend to indicate that the Am-241 is not homogeneously distributed in the water sample taken from the flask. This would again lend support to the observation that the Am-241 being leached from the goil is in the particulate form and is therefore insoluble.

CONCLUSION

On the basis of the data obtained in performing the various tests on the Am-241 foils, it must be concluded that their exposure to stressful environmental conditions would produce no significant hazard to the biosphere involved.

ACKNOWLEDGEMENTS

The authors thank Dr. Alan K. Bruce and Charles C. Thomas for. their expert advice and use of laboratory facilities, and Alfred Alson and Harold Spector for their technical assistance.

The conditions employed for the immersion test may not duplicate actual (real life) conditions, since the volume used is probably much less than that of expected situations. However, it is assumed that the concentration in uCi per ml of leachate is representative of realistic test conditions. In such instances, the foil would be immersed in a larger volume of water, thus making the relative concentration of Am-241 presumably lower. In addition, in the immersion test the leachate concentration was considerably less than the MPC $_{\rm W}^{11}$ (3x10 $^{-5}$ uCi/ml) after the fifth to seventh day. During the first few days, however, the concentrations are slightly larger or equal to MPC $_{\rm W}$ values (Table III.).

In the immersion test, it is necessary to point out that an average value of uCi removed per day, for the 12 day test, would not be representative of the rate at which activity was removed from the foil surface, since the concentration was constantly changing. The most representative value of uCi removed per ml of leachate would be that which is obtained on the third day of the test, since in almost all cases, it was the largest value obtained. It is then possible to compare this value to the established MPC for Am-247 to give the most conservative estimate of actual releases from the foil. The activity removed on the third day as a function of the total activity removed is also calculated to demonstrate that, in most cases, the amount of activity removed on the third day is a significant fraction of the total. Table III. gives a comparison of the amount of activity leached per ml on the third day of the immersion test, and compares it to the MPC value for an unrestricted release of Am-241.

The reason why these samples show this particular relationship in the immersion test may be due to the fact that, as the gold coating is placed on the foil surface, some of the Am-241 may be lodged in the upper layer of the coating. Therefore, when the foil is exposed to water, the corrosive properties of water are sufficient to remove this small amount of "tramp" material in the gold coating, however it is not corrosive enough to entirely destroy the coating integrity. This is proven by the observation that after 5 to 7 days, little or no activity is removed from the foil surface upon continued exposure to water.

REFERENCES

- 1. Industrial and Engineering Chemistry, 1949, p. 2013-15
- 2. Skinner's Science of Dental Materials, Phillips, Ralph W., W. B. Saunders Co., 7th Ed., 1973, Chapter 23.
- 3. Burkitt, D.P.: Epidemiology of Cancer of the Colon and Rectum, Cancer 28: 3-13, 1971.
- 4. Human Physiology, Vander, Sherman, Luciano; McGraw Hill Book Co., 1970.
- 5. Pancreatic Function and Pancreatic Disease, Lagerlof, The Macmillan Co., 1942.
- 6. Pathophysiology, Frolich, E.D., J.B. Lippincott, 1972.
- 7. Physiology of the Digestive Tract, Davenport, H.W., Ed. 2. Chicago, Year Book Medical Publishers, 1966.
- 8. The Physiology of Gastric Secretion, Semb, Lars S., The Williams and Wilkins Co., 1968.
- 9. Handbook of Radioactive Nuclides, The Chemical Rubber Co., Cleveland, Ohio, 1969.
- 10. Radiological Health Handbook, U.S. Department of Health, Education and Welfare, Revised Edition January 1970.
- 11. State Sanitary Code, Chapter 1, Part 16, IONIZING RADIATION, New York State Department of Health.
- 12. Code of Federal Regulations, Title 10, Part 20, U.S. Government Printing Office, Washington, D.C.
- 13. U.S. Department of Commerce, National Bureau of Standards Handbook 69, U.S. Government Printing Office, Washington, D.C., August 1963.

Proportional Plateau Determination

COUNTING DATA

Exp No. Test	Name Greenberg	Date_ 2/24/76		
Scaler	Voltage	Bkg -		
Detector Prop. preflush	1 mv Window	_Baseline		

Am-241 6.7x104

Sample	Time, Min.	Counts	. СРМ	CPU-Bkg.	Voltage
alpha pm	10/73				
"	1	23,258	23,258		800
"	1	34,930	34,930		850
"	1	42,144	42,144	-	900
n	1	51,804	51,804		950
"	1	55,236	55,236		1000
n	1	59,888	59.888		1050
"	1	60,828	60.828		1100
"	1 .	61,494	61,494		1150
n	1	61,602	61,602		1200
n	1	62,326	62,326		1250
"	1	62,723	62,723		1300
n	1	63,141	63,141		1350
,	1	63,752	63,752		1400
n	1	64,109	64,109		1450
	1	65,532	65,532		1500
n	1	69,694	69,694		1550
n	1	75,570	75,570		1600
н	1	80,432	80,432		1650
9/11/75	3	104,406	34,802		1270

Am-241 .0329uCi

DPM = 7.238 x 104

Immersion Test with Am-241 Foils in Buffalo City Water COUNTING DATA

	Exp No 0	16	Name Gr	eenberg	Date 2/27/76-3/9/76		
	Scaler	Voltage	1270	Bkg Determined Daily			
	Detector Pr	top. preflus	h 1mv w	indow	Baseline		
		Counting Time, Min.	Total Counts	СРИ	CPM-Bkg.	Bhg/Hin	
Gross	1ml ea.			M-m.		* .	
	2/27	3	10	3.33	3.33	0	
	2/28	3	47	15.66	15.56	0	
	2/29	3	132	44	44	0	
	3/1	5	118	23.6	23.4	. 2	
	3/2	5	20	4	3.5	. 5	
3	3/3	5	104	20.8	20.3	. 5	
	3/4	5	3.4	6.8	6.7	. 1	
	3/5	5	19	3.8	3.4	. 4	
	3/6	5	31	6.2	5.8	. 4	
	3/7	5	22	4.4	3.6	8	
	3/8	5	12	2.2	2.2	0	
	3/9	5	15	3	2.8	. 2	
	-						
					A 184		
	-						
					0.000		

Immersion Test with Am-241 Foils in Buffalo City Water COUNTING DATA

Gross

Exp No	One	Nam	e Greenbe	erg Date 2	127/76-3/9/78
Scaler _		Vol	tage .12:	70 Bkg	
Detector	Prop. prefle	ush 1	mV Window	vBaseli	ne
Sample #2	Counting Time, Min		СРМ	CPM-Bkg.	Bkg./Min.
Iml ea.	July 10 km/s				
2/27	3	31	10.33	10.33	0
2/28	3	42	14	14	0
2/29	3	131	43.67	43.67	0
3/1	5	69	13.8	13.6	.2
3/2	5	28	5.6	5.1	.5
3/3	5	25	5	4.5	.5
3/4	5	8	1.6	1.5	.1
3/5	5	26	5.2	4.5	. 4
3/6	5	26	5.2	4.8	.4
3/7	5	9	1.8	1.0	. 8
3/8	5	9	1.8	1.8	0
3/9	5	3	. 6	. 4	. 2
		1	1		* 1-93,476

Immersion Test with Am-241 Foils in Buffalo City Water COUNTING DATA

Gross

Exp No. 0	ne			Date 2/27	/76-3/9/7
Scaler				Bkg	
Detector_	Prop. preflui FLOW	sh 1 mV W	indow	Baseline_	2012
Sample #3 ·····	Counting Time, Min.	Total Counts	СРМ	CPM-Bkg.	Bkg./Mir
1ml ea.					
2/27	3	10	3.33	3.33	0
2/28	3	159	53	53	0
2/29	3	207	69	69	0
3/1	5	106	21.2	21	. 2
3/2	5	42	8.4	7.9	. 5
3/3	5	62	12.4	11.9	. 5
3/4	5	20	4	3.9	.1
3/5	5	65	13	12.5	. 4
3/6	5	3,1	6.2	5.8	.4
3/7	5	9	1.8	1.0	8
3/8	5	5	1.0	1.0	0
3/9	5	10	2	1.8	. 2
					· ·

Immersion Test with Am-241 Foils in Buosalo City Water COUNTING DATA

	Exp No	One	Name_	Greenberg	Date		
	Scaler_	-	Voltag	3e_1270	Bkg		
	Detector_	Prop. preflush blow	1 mV	_Window	Baselin	e	
	# J	Counting Time, Min.	Total Counts	CPM	CPM-Bkg.	Bkg./Min	
pore bil							
	2/27	3	9	3	3	. 0	
	2/28	3	43	14.33	14.33	0	
	2/29	3	99	33	33	0	
	3/1	5	167	33.4	32.7	. 7	
	3/2	5	53	10.6	10.6	0	
	3/3	5	108	21.6	21.4	. 2	
	3/4	5	27	5.4	4.9	. 5	
	3/5	5	8	1.6	1.1	.5	
	3/6	5	77	15.4	15	.4	
	3/7	5	33	6.6	5.8	. 8	
	3/8	5	22	4.2	4.2	0	
	3/9	5	8	1.6	1.4	. 2	
				- 2 4			

Immersion Test with Am-241 Foils in Buffalo City Water COUNTING DATA

Scalex		Exp No	One	Name _	Greenberg	Date 2/	27/76-3/9-76
Sample Counting Total CPM CPM-Bkg Bkg./Min -45 um milli- poke filter 2/27		Scaler_		Voltag	e_1270	Bkg.	
#2 Time, Min Counts .45 um milli- pone filter 2/27		Detector_	Prop. preflu	sh 1 mV	_Window	Basel	ine
2/27 3 14 4.66 4.66 0 2/28 3 6 2 2 0 2/29 3 222 74 74 0 3/1 5 72 14.4 13.1 .7 3/2 5 23 4.6 4.5 0 3/3 5 40 8 7.3 .2 3/4 5 13 2.6 2.1 .5 3/5 5 30 6 5.5 .5 3/6 5 18 3.6 3.2 .4 3/7 5 11 2.2 1.4 .8 3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2		Sample #2			СРМ	CPM-Bkg	Bkg./Min
2/28 3 6 2 2 0 2/29 3 222 74 74 0 3/1 5 72 14.4 13.1 .7 3/2 5 23 4.6 4.5 0 3/3 5 40 8 7.8 .2 3/4 5 13 2.6 2.1 .5 3/5 5 30 6 5.5 .5 3/6 5 18 3.6 3.2 .4 3/7 5 11 2.2 1.4 .8 3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2							
2/29 3 222 74 74 0 3/1 5 72 14.4 13.1 .7 3/2 5 23 4.6 4.5 0 3/3 5 40 8 7.8 .2 3/4 5 13 2.6 2.1 .5 3/5 5 30 6 5.5 .5 3/6 5 18 3.6 3.2 .4 3/7 5 11 2.2 1.4 .8 3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2		2/27	3	14	4.66	4.66	0
3/1 5 72 14.4 13.1 .7 3/2 5 23 4.6 4.5 0 3/3 5 40 8 7.5 .2 3/4 5 13 2.6 2.1 .5 3/5 5 30 6 5.5 .5 3/6 5 18 3.6 3.2 .4 3/7 5 11 2.2 1.4 .8 3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2		2/28	3	6	2	2	0
3/2 5 23 4.6 4.5 0 3/3 5 40 8 7.5 .2 3/4 5 13 2.6 2.1 .5 3/5 5 30 6 5.5 .5 3/6 5 18 3.6 3.2 .4 3/7 5 11 2.2 1.4 .8 3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2		2/29	3	222	74	74	0
3/2 5 23 4.6 4.5 0 3/3 5 40 8 7.3 .2 3/4 5 13 2.6 2.1 .5 3/5 5 30 6 5.5 .5 3/6 5 18 3.6 3.2 .4 3/7 5 11 2.2 1.4 .8 3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2		3/1	5	72	14.4	13.1	. 7
3/3 5 40 8 7.8 .2 3/4 5 13 2.6 2.1 .5 3/5 5 30 6 5.5 .5 3/6 5 18 3.6 3.2 .4 3/7 5 11 2.2 1.4 .8 3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2		3/2	5	23	4.6	4.5	
3/5 5 30 6 5.5 .5 3/6 5 18 3.6 3.2 .4 3/7 5 11 2.2 1.4 .8 3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2	0	3/3	5	40	8	7.8	
3/6 5 18 3.6 3.2 .4 3/7 5 11 2.2 1.4 .8 3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2		3/4	5	13	2.6	2.1	.5
3/7 5 11 2.2 1.4 .8 3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2		3/5	. 5	30	6	5.5	.5
3/8 5 7 1.4 1.4 0 3/9 5 3 .6 .4 .2		3/6	5	18	3.6	3.2	.4
3/9 5 3 .6 .4 .2		3/7	5	11	2.2	1.4	. 8
		3/8	5	7	1.4	1.4	0
			5	3	. 6	. 4	. 2
			1912 1917		, .		
		*					

Immersion Test with Am-241 Foils in Buffalo City Water COUNTING DATA

	Exp No	One	Name_ (Greenberg	Date 2/1	27/76-3/9/76
	Scaler_		Voltage	1270	Bhg	
	Detector_	Prop preflush	1 mV	Window	Baseline_	
	Sample #3	Counting Time, Min.	Total Counts	CPM	CPM-Bkg	Bkg/Min.
.45 um i	nilli- lter					
	2/27	3	4	1.33	1.33	0
	2/28	3	113	37.66	37.66	0
	2/29	3	222	74	74	0
, , , , , , , , , , , , , , , , , , , ,	3/1	5	122	24.4	23.7	.7
	3/2	5	43	8.6	8.6	0 -
•	3/3	5	23	4.6	4.3	. 2
	3/4	5	10	2	1.5	. 5
	3/5	5	69	13.8	13.3	. 5
	3/6	5	30	6	5.6	.4
	3/7	5	14	2.8	2.0	. 8
	3/8	5	10	2	2	0
	3/9	5	5	1	. 8	.2
•				July Service		
			1			

Three Week Environmental Test 80% Relative Humidity and 112 Degrees F

COUNTING DATA

Scaler	/76-3/17/76
Detector Prop. preflush 1 mV Window Basel	
Time, Min. Counts Bottle Water 5 2 .4 -	
#1 Water 5 2 .4 - Screen 5 3 .6 .1 Wire 5 5 1 .5 Dry P.W.T.1 5 1 .2 - P.W.T.0 5 2 .4 -	
Dry Wire 5 5 1 .5 P.W.T.1 5 1 .2 - P.W.T.0 5 2 .4 -	
Dry P.W.T.I 5 1 .2 - P.W.T.O 5 2 .4 -	
P.W.T.0 5 1 .2 - P.W.T.0 5 2 .4 -	
	No. 14 E. H
-	
Foil W.T. 5 8 1.6 1.1	
Wet P.W.T.1 5 1 .2 - 1	
P.W.T.0 5 1 .2 -	
Foil W.T. 5 7 1.4 .9	in a said
Jan 5 1 .2 -	1 4 1 2
Bottle	
#2 Water 5 2 .4 -	
Screen 5 0 0 -	
Wire 5 3 .6 .1	
Dry P.W.T. I 5 1 .2 -	
P.W.T. 0 5 0 0 -	
Foil W.T. 5 1 .2 -	
et P.W.T. 1 5 2 .4 -	
P.W.T. 0 5 2 .4 -	
FOLL WT 5 0 0 -	
Jan 5 0 0 -	

Three Week Environmental Test 80% Relative Humidity and 112 Degrees F

COUNTING DATA

	kow preflu	sh 1 mV	Window_	Baseli	ne
Sample	Counting Time, Min.		СРМ	CPM-Bkg	
Water	5	2	. 4		
Screen	5	1	. 2	_	
Wire	5	0	0		*****
P.W.T. 1	5	0	0	-	
P.W.T. 0.	5	1	. 2		
Foil WT	5	8	1.6	1.1	
P.W.T. 1	5	2	. 4		
P.W.T. 0	5	2	. 4		
Foil WT	5	6	1.2	. 7	
Jar	5	3	.6	.1	×4.
Fingertip	s of gloves contaminatio	used duri	ng this	process we	re assa
			-		

(

02

Digestion Test

COUNTING DATA

	Exp No	3	Name_G	reenberg	Date 3/19	176-3/2
	Scaler		Voltag	e_1270	Background	0.2 C
	Detector 1	Prop. prefl	ush Gain_1	mV Window	Baseli	ne
	Sample	Counting Time, Min		СРМ	CPM-Bkg	
	Bhg.	5	1	. 2		
n.	Saliva	5	2	. 4	. 2	
	Wipe Tst	5	2	.4	.2	
m	Gastric	5	20,779	4156	4155.8	
× * .	Tube*	5	1,354	271	270.3	
	Wipe Tst Pancre-	5	1,812	362.4	362.2	
2 m	atic	5	418	83.6	83.4	
	Tube*	5	97	19.4	19.2	
	Wipe Tot	5	1,550	310	309.8	
? m	L.1.	5	1,466	293.3	293	W.
	Tube* .	5	808	161.6	161.4	
	Wipe Tst	5	1,335	267	266.8	
-	*All test This was	tubes were then placed	rinsed wind	th 2 ml of ichett, dr	distilled ied and cou	water. inted.
1						
-						

Table I.

Digestion Test

Date		Leachate		Leachate		Leachate
	Gross (x10	-6) Filter	Gross (x10	-6) Filter	Gross (x10	Filter
2/27	2.7-1.7	2.4-1.6	8.3-2.9	3.8-2.0	2.7-1.7	NSS*
2/28	1.3-0.4	11.5-3.5	11.3-3.4	1.6-1.3	42.7-6.8	30.4-5.8
2/29	33.5-5.7	26.5-5.3	35.2-6.0	NSS*	55.6-7.8	59.7-7.8
3/1	18.9-3.4	26.3-4.2	11.0-2.6	10.6-2.8	16.9-2.2	19.1-3.6
3/2	2.8-1.5	8.5-2.3	4.1-1.8	3.7-1.5	6.4-2.1	6.9-2.1
3/3	16.4-3.3	17.0-3.2	3.6-1.7	6.3-2.0	9.6-2.5	3.5-1.5
3/4	5.4-1.9	3.9-1.7	1.2-0.9	NSS*	3.1-1.4	NSS*
3/5	2.7-1.4	0.9-0.8	3.9-1.7	4.4-1.8	1.025	10.7-2.7
3/6	4.7-1.8	12.1-2.8	3.9-1.7	2.6-1.4	4.7-1.8	4.5-1.8
3/7	2.9-1.6	4.7-1.9	NSS*	NSS*	NSS*	1.6-1.5
3/8	1.8-1.1	3.4-1.5	1.4-0.9	1.1-0.8	0.8-0.7	1.6-1.0
3/9	2.3-1.3	1.1-0.9	NSS*	NSS*	1. 4-1.0	NSS*
Total	(+95.4 (-25.1)	118.4	(+83.9 (-23.6)	(+34.4 (-13.6)	144.9 (-23.3)	[38.0

Additional Immersion Test Assays uCi/ml of Leachate (x10⁻⁶)

	Sample	Gross	Filter	Wipe Test**
	#1 #2 #3	1.3 3.7 NSS*	8.1 2.9 1.1	5.1 7.1 4.5
Total		5.0	12.0	16.7

^{*} Not Statistically Significant **Performed at the conclusion of the Immersion Test

Table 11.

Digestion Test

Sample	Activity Removed (uCi)
Saliva	NSS*
Wipe Test	NSS
Gastric	$(3.4 \pm 0.1) \times 10^{-3}$
- Wipe Test	$(2.9 \pm 0.1) \times 10^{-4}$
Tube	(2.2-+ 0.1) x10-4
Pancreatic	(6.7 = 0.6) x10-5
Wipe Test	$(2.5 \pm 0.1) \times 10^{-4}$
- Tube	$(1.5 \pm 0.3) \times 10^{-5}$
Large Intestine	$-(2.4 - 0.1) \times 10^{-4}$
Wipe Test	12.2 ± 0.1) x10-4
Tube	$(1.3 \pm 0.1) \times 10^{-4}$
Total lexcluding Wipe Tests	$(4.1 \pm 0.1) \times 10^{-3}$
Total Wipe Tests	$(7.6 \pm 0.4) \times 10^{-4}$
Total Activity Removed	$(4.9 \pm 0.1) \times 10^{-3}$

Table 111.

Comparison of Results with Non-occupational Exposure Limits


Gross Sample	uCi/ml of Leachate (Day 3)	% Total	Fraction of M	PC **
#1 #2 #3 Auc.	3.4×10-5 3.5×10-5 5.6×10-5 4.2×10-5	28.2 29.6 46.8	1.13 1.16 1.86 1.46	
Millipore Sample #1 #2 #3 Avc.	2.7×10 ⁻⁵ 6.0×10 ⁻⁶ 6.0×10 ⁻⁵ 3.1×10	22.4 13.8 40.6-	0.90 0.20 2.00 1.03	
Digestion Test Total (exclud		Fra	o.136	
Wipe Tests Total Wipe Te	- 1		0.025	
Total Activity Re	moved 4.9×10 ⁻³		0.163	

^{*} Not Statistically Significant


** 3x10-5 uCi/ml

*** 0.03 uCi

Schematic Representation of the Environmental Test Chamber









APPLIED VOLTAGE

FIGURE III.

Gross Sample #1










FIGURE V.

Gross Sample #3




FIGURE VI.
Millipore Filter Test - Sample # 1




FIGURE VII.

Millipore Filter Test - Sample # 2




FIGURE VIII.

Millipore Filter Test - Sample # 3




FIGURE IX.

Composite - Gross Samples






FIGURE X.

Composite - Millipore Samples



Saturated Potassium Chloride Solution



JOB AND USER (DWG. TITLE BLOCK INFORMATION)

CHLOULATION OF ALDIA PARTICLE RANGE

SQUARE D COMPANY

CALCULATION OF MAXIMUM ENERGY RELEASE IN DECAY OF AMERICIUM 241

CALCULATION OF RX = RANGE OF X PARTICLE IN CM OF AIR AT I ATMOSPHERE AND 15°C

AT THE ENERGY RANGE 4LELS Rec = 1.24 E - 2.62 Rx = 1.24 x 5,638 - 2.62 Ra = 4.37 cm

CALCULATION OF RANGE OF & PARTICLE IN TISSUE

PER BRAGG-KLEEMAN RULE: GIVEN, REAR = 4.37 cm

PAIR = ,001293 gmcm AAIR = 14,52

Prissue = 10gm cm-3 ATISSUE = 6

· · Rec Tissue , 0036 Cm

As THE PROTECTIVE LAYER of The Skin is Approx. , corem Thick, No Alpha PARTICLE WILL PENETRATE INTO LIVE TISSUE.

JOB AND USER (DWG. TITLE BLOCK INFORMATION)

DATE PAGE 2 OF S

RI CALCULATION OF GAMMA Exposure RATE

SQUESE D COMPRNY

X = Exposure Rh-1

A JUC: AMERICIUM 241 SOURCE PRODUCES . 060 MeV GAMMA RADIATION WITH A VIELD OF 36%.

 $\dot{x}_{o} = \frac{1.56 \times 10^{5} \cdot A \cdot T_{x} \cdot Y_{x} \cdot \mu_{ob}}{T^{2}} \qquad A = /\mu C_{i} = .001 m C_{i}$ $\dot{x}_{o} = \frac{1.56 \times 10^{5} (.001)(.000)(36)(3.715 \times 10^{5})}{T^{2}} \quad Y_{8} = .368 d^{-1}$ $\dot{x}_{o} = \frac{1.56 \times 10^{5} (.001)(.000)(36)(3.715 \times 10^{5})}{T^{2}} \quad \mu_{in} = .00003775 em^{-1}$ $\dot{x}_{o} = \frac{127.17 \times 10^{-6}}{T^{2}} \quad Rh^{-1} \qquad T = D_{istrance} \quad From \quad Source$

TO CALCULATE THE RADIATION EXPOSURE RATE AT

A. RADIATION PASSING Through Copper CLAD of PRINTED CIRCUIT BOARD

LINEAR ABSORBTION = MASS Ati MATION X. DENSITY
COEFFICIENT COEFFICIE. ST OF Shield

M = 1.62 x 8.94

M = 14.483

... Mx = 14.483 x .005

Mx = .072

B. RADIATION PASSING Through STEEL Smoke Plate

M = 1.20 × 7.86 M = 9.432

 $\mu = 9.432 \times .038$ $\mu = .358$

JOB AND USER (DWG. TITLE BLOCK INFORMATION)

CALCULATION OF GAMMA Exposure RATE

DATE PAGE

BY

Gen Hangleri

APPROVED BY DATE

SQUARE D COMPANY

EXPOSURE RATE AT OUTSIDE SURFACE OF SMOKE DETECTOR

$$\dot{X}_{o} = \frac{127.17 \times 10^{-6}}{(3.18)^{2}}$$

AT SURFACE SHIELDED BY STEEL

EXPOSURE RATE AT 50M FROM DUTSIDE SURFACE

$$X_0 = \frac{127.17 \times 10^{-6}}{(8.78)^2}$$

where T = 8,180m

JOB AND USER (DWG. TITLE BLOCK INFORMATION)

CALCULATION OF GAMMA EXPOSURE PATE

DATE 8/4/85 PAGE H OF S

SQUARE D COMPANY

$$\dot{X}_{0} = \frac{127.17 \times 10^{-6}}{(28.78)^{2}}$$

MD-88	NO.
JOB AND USER (DWG. TITLE BLOCK INFORMATION) CALQULATION OF GAMMA RADIATION EXPOSURE BY DOGGOTO D.	DATE 8/6/85 PAGE BY OF
R.I SY OPERATOR ASSEMBLING Sources	APPROVED BY - DATE

SQUARE D COMPANY

IF The operator SITS NexT TO 5 FULL TUBES (145/TUBE OF ION SOURCES FOR 8 HOURS FOR DAY HIS TOTAL BODY EXPOSURE WILL BE:

AT $T = 20 \text{cm} \times_{Body} = 85 \times \frac{127.17 \times 10^{-6}}{20^2} = 27.02 \times 10^{-6} R/h$ AT $T = 25 \text{cm} \times_{Body} = 120 \times \frac{127.17 \times 10^{-6}}{25^2} = 24.42 \times 10^{-6} R/h$ AT $T = 30 \text{cm} \times_{Body} = 160 \times \frac{127.17 \times 10^{-6}}{30^2} = 22.61 \times 10^{-6} R/h$ At $T = 35 \text{cm} \times_{Body} = 160 \times \frac{127.17 \times 10^{-6}}{35^2} = 16.6/ \times 10^{-6} R/h$ At $T = 40 \text{cm} \times_{Body} = 100 \times \frac{127.17 \times 10^{-6}}{40^2} = 7.95 \times 10^{-6} R/h$ At $T = 45 \text{cm} \times_{Body} = 100 \times \frac{127.17 \times 10^{-6}}{45^2} = 6.28 \times 10^{-6} R/h$ Total $725 \times 10^{-6} R/h$ **O TOTAL $725 \times 10^{-6} R/h$ **O TOTAL $725 \times 10^{-6} R/h$ = 839.2 \times 10^{-6} R/h

= 839.2 \times 10^{-6} R/h

= .0545 R/QtR
Which is Below The Permissible Dose Level of
11/4 Rems/Qtr per 20.101, "Exposure of INDIVIDUALS
TO RADIATION IN RESTRICTED AREAS"

JOB AND USER (DWG. TITLE BLOCK INFORMATION)

OF OPERATOR ASSEMBLING ION SOURCES

DATE PAGE
2/4/85 2 OF 2
BY
Jun Hampter
APPROVED BY DATE

SQUARE D COMPANY

Assume That The operator Has A

FULL TUBE of 145 ION Sources AT The Work

STATION AT ALL TIMES DURING AN 8 HOUR DAY, AND

HE PICKS UP THE SOURCES FURTHEST AWAY FROM

HIS BODY FIRST, AND HIS HANDS AND FOREARMS

ARE ICM OVER THE TOP OF THE TUBE OF ION

SOURCES EVERYTIME A SOURCE IS PICKED UP

WITH TWEEZERS. WE CAN THEN ASSUME THAT

FOR 4.0 HOURS EACH DAY HIS HAND IS ON AN AVERHEE

OF I CM FROM APPROXIMATELY 145 ION SOURCES

The Exposure To His HAND & FOREMENT:

XHAND = 127.17 × 10-6 × 145 = 18.44 mR/hR

XHAND = 18.44 × 4.0 = 73.76 mR/DAY

XHAND = 73.76 × 65 = 4.79 R/CAL. QtR.

which is Below the PermissiBLE DOSE Level of 1834 REMS/ CAL. Qtr per 20,101," Exposure of INDIVIDUALS TO RADIATION IN RESTRICTED AREAS"

SQUARE D COMPANY

DURING THE ASSEMBLY OF THE ION PLATE
TO THE PRINTED WIRING BOARD, THE OPERATOR
WOULD Receive Exposure To THE HAND AT
A DISTANCE OF APPROXIMATELY 4cm.

THE GAMMA EXPOSURE WOULD BE:

$$\dot{x}_{o} = 127.17 \times 10^{-6}$$

$$\dot{x}_{o} = 7.95 \times 10^{-6} R/h$$

IF WE ASSUME THAT HE HANDLES These FLATES

FOR 6.4 HOURS PER DAY (FROM TIME STUDY OBSERVATION)

THEN, XHAND = 7.95 × 10-6 × 6.4

XHAND = 50.9 × 10-6 R/DAY

Which is Below The permissible Dose Level of 183/4 REMS/CAL QUE per 20.101, "Exposure of Individuals To PADIATION IN RESTRICTED AREAS"

JOB AND USER (DWG. TITLE BLOCK INFORMATION)

CALCULATION OF GAMMA RADIATION EXPOSURE

OPERATOR CARRYING TUBES OF SOURCES

APPROVED BY - DATE

SQUARE TI COMPANY

IF THE OPERATOR WENT TO THE STORAGE CABINET 9 TIMES A DAY TO Remove 5 Tubes (145 Sources/TUBE) EACH TIME AND WE ASSUME THAT HIS HAND WILL BE WITHIN . 18 CM of The EMMITTINE SURFACE of 160 SOURCES, Then The TOTAL EXPOSURE TO HIS HAND WILL BE:

AT 20 SEC 9 Times per DAY:

31.4 × 65 = 2.0 Rems/CAL GtR

WHICH IS Below The permissible Dose LEVEL of 183/4 REMS/CAL. EtR.

JOB AND USER (DWG. TITLE BLOCK INFORMATION)

CALCULATION OF GAMMA RADIATION

DATE Jim Hamplon APPROVED BY - DATE

BI EXPOSURE OF PERSON AT STORAGE CABINET

SQUARE D COMPANY

IF WE ASSUME THAT A PERSON STANDING IN FRONT OF THE OPEN STORAGE CABINET CONTAINING 100,000 Sources IS EXPOSED AT DISTANCES OF 25,30,35,40,45450 Cm, THE FOllowing CALBULATIONS Apply.

ATT = 25cm x = 16,667 x 127.17 x 10-6 = 3.391 mRh-1

AT T = 30 cm X = 16,667 x 127.17 × 10-6 = 2.355 mRh-1

ATT = 35cm x = 16,667 x 127.17 x 10-6 = 1.730 m Rh-1

x = 16,667 x 127.17x 10-6 = 1.325 m Rh-1

X= 16,667 × 127.17×10-6 = 1.047mRh-1 AT T = 45 cm

ATT = 50 cm x = 16,667 x 127.17 x 10-6 = .848 mRh-1

. IF HE STOOD IN FRONT OF THE CABINET FOR AS LONG AS I HOUR EACH DAY HIS TOTAL BODY EXPOSURE WOULD BE 10.7 mR/DAY.

HIS WHOLE BODY EXPOSURE DER CALENDAR QUARTER WOULD BE: 65 x 10.7 = .696 R/CAL Q+R

WHICH IS BELOW THE PERMISSIBLE DOSE LEVEL OF 1/4 REMS DER CHLENDER GTRO


FIRE TEST EGD-6 SERIES SMOKE DETECTOR

I. OBJECTIVE

To test the containment of americium oxide in the source holder and to test the containment of the source holder in the source plate during a fire which destroys the smoke detector.

II. METHOD

The smoke detector was suspended 14" above (4) UL standard 217 wood cribs by the normal mounting holes. The wood cribs were ignited via small kindling and allowed to burn approximately 10 minutes. Flame occurred about 5 minutes into the fire. At approximately 7.5 minutes the detector had melted sufficiently to fall from its mounting into the fire. Test ended at 10 minutes.



EGD-6B set up beforefire test




7.25 min. into fire test

III. RESULTS


- 1. The incinerated smoke detector was photographed.
- 2. The smoke plate could not be removed without the aid of a screw-driver. Examination of the source plate revealed that the source and source holder were still intact and securely fastened to one another.
- 3. Examination of the source under a microscope revealed no damage to either the source or source holder.
- 4. The emission level of source was checked and compared to a .6586uCi standard. One reason for the decreased emission level was due to a thick layer of soot and tar which covered both emitting surfaces.



7.50 min into fire test



EGD-6B after fire was extinguished



EGD-6B side view after fire test




EGD-6B after fire test




EGD-6B view of source with smoke plate lifted



reference chamber side of source after fire test



Smoke chamber side of source after fire test




Smoke chamber side of source after being cleaned with alcohol




Reference chamber side of source after being cleaned with alcohol

source reference chamber side after fire



MAGNIFICATION 12X

source smoke chamber side after fire



MAGNIFICATION 12X

WIPE TEST RESULTS

1 MINUTE COUNT

WIPE TEST	COUNT #1	COUNT #2	COUNT #3	AVG COUNT	ACTIVITY
Background	0	1	1	.66	.60pCi
Exterior of housing	0	0	0	0	0
Both sides of source	1	0	1	.66	.69pCi

EMISSION TEST RESULTS

TES	T	COUNT #1	COUNT #2	COUNT #3	AVG COUNT	ACTIVITY
.65	86 4Ci calibration standard	623,571	623,769	624,906	624,082	.6586uCi
Ion	source from incinerated detectors:					
a.	Smoke Chamber side	150,740	149,954	150,319	150,337	.16uCi
b.	Ref Chamber side	178,871	181,785	181,498	180,618	.20uCi

IV. CONCLUSION

From the test results achieved, the following conclusion can be made:

- Wipe tests indicate no americium oxide was liberated during the fire.
- 2. The source and source holder remained in tact attached to the source plate.
- 3. During the fire test, the melting plastic covered the smoke plate making it very difficult to get to the source plate.

Jim Hampton July 25, 1985

DROP TEST

EGD-6 SERIES DETECTOR

I. OBJECTIVE

The objective of the drop test was to determine if repeated drops of a fully assembled smoke detector would result in the radioactive source being jarred loose or if any other condition would develop that would result in an abnormal radiological survey.

II. METHOD

A test unit was dropped from an 8' height into a concrete surface. The unit was dropped so that the impact was on the face of the detector. This was determined to be the worst case. The test unit was dropped 25 times with a separate wipe over the external surface taken after each drop. After the 25th drop, the unit was disassembled down to te printed wiring board assembly. Wipe tests were then performed on the chamber assembly and the surrounding board area.

III. RESULTS

Each radiological wipe was counted for one minute using the Eberline Instrument Corporation scintillation alpha counter, model SAC-4. No single wipe was found to be in excess of normal background count.

WIPE TEST PESULTS

Wipe Test #	CPM	Activity*	Wipe Test #	CPM	Activity *
1	0	0	14	0	0
2	0	0	15	0	0
3	0	0	16	0	0
4	0	0	17	0	0
5	0	0	18	0	0
6	0	0	19	0	0
7	1	1.1pCi	20	0	0
8	0	0	21	0	0
9	0	0	22	0	0
10	0	0	23	0	0
11	0	0	24	0	0
12	0	0	-5	0	0
13	1	1.1pCi	26**	2	2.1pCi

^{*}Activity calculated using .6586uCi standard.

IV. CONCLUSION

Based on physical examinations and wipe test results, no damage was sustained to the radioactive source and the source remained contained within the confines of the detector and attached to the source plate.

Jim Hampton August 6, 1985

^{**}Wipe test was inside smoke detector housing as well as the PCB and chamber cover.

I. OBJECTIVE

To test the containment of americuim oxide in the source holder and to test the containment of the source holder in the source plate during the immersion of the smoke detector in water (both room temperature and boiling).

II. METHOD

- 1. A clean aluminum pot was rinsed with cold deicnized water, refilled with deionized water and brought to a boil. The water was then allowed to cool and filtered through a .45 millipore filter. The filter was analyzed for radioactive contamintion and a wipe test performed on the pot and exterior surface of the smoke detector.
- 2. The pot was refilled with the refiltered deionized water and the smoke detector was immersed in the water. The detector was allowed to soak for 1 hour during which time the pot was agitated every ten minutes. At the completion of 1 hour soaking at room temperature, the smoke detector was removed from the water and allowed to drain into the pot. The water from the pot was then refiltered through a .45u filter. The inside of the pot and the exterior surface of the smoke detector were wipe tested.
- The pot was rinsed and refilled with clean filtered deionized water. The filter was again analyzed for radioactive contamination. The pot was placed on the hot plate and alowed to come to a boil. The smoke detector was wipe tested on the exterior surface and immersed into the boiling water for 1 hour. The water was not agitated during the 1 hour of boiling.
- 4. After 1 hour the smoke detector was removed from the boiling water and allowed to drain into the pot. The water from the pot was refiltered through a .45u filter and the filter analyzed for radioactive contamination. The exterior surfaces of the smoke detector and inside of the pot were wipe tested.
- 5. The printed wiring board assembly was removed from the detector and the inside of the detector housing and the outside and inside of the insulator were wipe tested.
- 6. The ion source was then examined under a 30% microscope. No discrepanceies were noted.

JOB	AND	USER	fDWG.	TITLE	BLOCK	INFO	RMAT
-----	-----	------	-------	-------	-------	------	------

ING Smoke Derectors BY

PAGE

OF PERSON INSTALLING SMOKE DETECTORS

APPROVED BY . DATE

SQUARE D COMPRNY

IF WE ASSUME THAT AN ELECTRICIAN CAN INSTALL

SMOKE DETECTORS IN (2) Homes per Day and the

MAXIMUM NUMBER OF SMOKE DETECTORS PER HOME

15 (6), HE WILL BE HANDLING (12) SMOKE DETECTORS

PER DAY. DURING INSTALLATION, HE WILL BE HOLDING

EACH SMOKE DETECTOR ABOUT 25 CM AWAY FROM

HIS FACE FOR ABOUT 4 MINUTES.

Exposure To HIS FACE:

$$\dot{X}_{c} = \frac{127.17 \times 10^{-6}}{25^{2}}$$

: Exposure To HIS FACE PER DAY

IF HE WORKS 6 DAYS PER Week, 50 Weeks per YEAR

X FACE = . 0027 REM PER YEAR

WHICH IS FAR BELOW THE PERMISSIBLE DOSE LEVEL OF . 5 REM DER YEAR

EXPOSURE TO HIS = EXPOSURE RATE AT THE OUTSIDE HANDS SURFACE OF THE SMOKE DETECTOR

X HANDS = 8,29×10-6 Rh-1 PER CALCULATION OF 8 EXPOSURE RATE ATTACHMENT B-6

.. TOTAL XHANDS 8,29 x 10-6 x 4 x 12.

XHANDS = 397.9 × 10-6 R/DAY

If He works 6 DAYS/WEEK, 50 Weeks/year

X HANDS = 397.9 x 10 -6 x 6 x 50

X HANDS = . 119 REM/YEAR

oshich is BELOW THE PERMISSIBLE DOSE Level of

ATTACHMENT B-14

FIRE HAZARD ANALYSIS

The bulk of the completed Smoke Detectors will be stored at the Physical Distribution Center (PDS) in Florence, Kentucky. At PDS mainly Class I materials are stored. Smoke Detectors are pallitized at 240 units per 50 cu ft.


PDS consists of 2 buildings at 178,000 sq ft each. They are protected from fire by a water sprinkler system. The sprinkler system has a 286°F actuation temperature. The sprinkler heads are mounted 18 ft high on 8 ft by 10 ft centers. The sprinkler system is capable of pumping water at the rate of .18 gal/mim/ft² (14 gal/min/head).

PDS is a high volume distribution center and may have many of its loading doors open at any one time during normal work hours. This makes it difficult to calculate the number of air changes which would occur during a fire. However, on a randomly chosen day, the number of openings at the check time would allow approximately 3 complete air changes per hour in one building.

PDS has its own emergency squad, however, the City of Florence, Kentucky would fight any fire. The Florence, Kentucky Fire Department has a basic full time force and is rated as a Class VI department by the insurance industry.

The balance of the radioactive sources will be located at the Square D plant in Pinellas Park, Florida. The unassembled sources will be stored in a fire resistant, steel cabinet located in a locked room within a limited access area.

The room and the limited access area will be constructed of fire proof materials and will be protected by a sprinkler system. The sprinkler system will conform to N.F.P.A. standards and all applicable state and federal codes. The building in which the limited access area is located, relies on hand held type ABC fire extinguishers. Any fire, however, would be fought by the City of Pinellas Park Fire Department. The City of Pinellas Park



James Hampton Nov. 9, 1981

/mk

JOB AND USER (DWG. TITLE BLOCK INFORMATION)
LALCULATION OF ALPHAY GAMMA RADIATION

XPOSURE TO A FIRE FIGHTER DURING A FIRE

DATE PAGE
S/6/85 PAGE
APPROVED BY - DATE

SQUARE D COMPANY

TETAL MAXIMUM INVENTORY OF SMOKE DETECTORS

AT P.D. S. WAREHOUSE IN FLORENCE, KENTUCKY =

150,000. If ALL THE SMOKE DETECTORS ARE

STORED IN ONE BUILDING OF 178,000 Sq. feet, WITH

AN 18 FOOT High Ceiling AND WE ASSUME THAT IN

A CATASTROPHIC FIRE ALL 150,000 SMOKE DETECTORS

ARE INCINERATED, WE CAN Then CALCULATE THE '

HMOUNT OF AM 241 LIBERATED. USING OAK RIDGE

NATIONAL KABORATORY TEST RESULTS OF DETOISER 21, 1969,

31 % of Am 241 WILL BE KIBERATED DURING A 1 HOUR

FIRE. SINCE EACH SMOKE DETECTOR CONTAINS IN C'

OF AM 241:

TOTAL AMOUNT of AM 241 LIBERATED = 1x 150,000 x.0031

IF WE ASSUME THAT THIS TOTAL AMOUNT OF ACTIVITY
WILL BE DISTRIBUTED THROUGHOUT THE BUILDING AND
THAT THERE WILL BE 3 COMPLETE AIR CHANGES PER
HOUR IN THE BUILDING, THEN WE CAN CALCULATE THE
TOTAL CONCENTRATION OF AM 241 IN THE AIR DURING
THE FIRE.

TOTAL VOLUME OF AIR = 3 x 178,000 x 18

= 9.412 x 106 Cu FT./HR

= 9.612 x 28.32

= 272.2 x 106 LITRES/HR

TOTAL Volume of AIR = 272.2 x 109 ML/HR.

JOB AND USER (DWG. TITLE BLOCK INFORMATION) CALCULATION OF ALPHAY GAMMA RADIATION

Jim Kanystin APPROVED BY DATE

EXPOSURE OF FIRE FIGHTER DURING A FIRE

SQUARE D COMPAN

CONCENTRATION OF AM 241 = 465 IN AIR DURING FIRE 272.2×109

:. Am 241 CONCENTRATION IN AIR = 1.71×10 uC:/ml

DURING A CATASTROPHIC FIRE, WE WOULD EXPECT THE Roof To COLLAPSE AND THUS ALLOW MORE AIR TO DILUTE THE CONCENTRATION. ALSO, THE OVERHEAD SPRINKIER SYSTEM WOULD PREVENT Much OF THE LIBERATED AMERICIUM FROM BECOMING AIRBORNE PRIOR TO COLLAPSE OF THE ROOF.

IF THE FIRE FIGHTER INHALES 20000 LITRES OF AIR (10-12 HOURS OF HEAVY BREATHING) DURING THE TOTAL DURATION OF THE FIRE, AND THE CONCENTRATION OF Am 241 IN THE AIR REMAINS AT THE 1.71×10-9 MCi/ml level. WE KNOW THAT 50% OF THE AM 241 INHALED WILL BE IMMEDIATELY EXHALED AND THEREFORE HAVE No Effect.

:. HIS TOTAL UPTAKE OF AM 241 WILL BE = .5 x 1.71x 10 - 20,000 x 103 = 17.1 × 10 3 µ Ci

IF WE ASSUME THAT OF This TOTAL UPTAKE 50% WILL BE ELIMINATED THROUGH THE LUNGS AND GASTRO-INTESTINAL TRACT AND 50% WILL BE ABSORBED INTO THE BEDY AND RETAINED IN THE BONES FOR A PERIOD OF 50 YEARS, then HIS INTERNAL DOSE COMMITMENT TO HIS LUNGS WILL BE:

INTERNAL DOSE COMMITMENT (SOFT DRGANS) = 20139 f. E (1-e-Next)

JOB AND USER (DWG. TITLE BLOCK INFORMATION)

CALCULATION OF ALPHAY GAMMA RADIATION

EXPOSURE TO FIRE FIGHTER DURING A FIRE

APPROVED BY . DATE

SQUARE D COMPANY

Soft ORGAN DOSE = 2,13(8,55×10-3)×,043×268,7(1-e-1002406×278 3000 x , 002406

= 2.915 × 10-2 (1-.5)

= 1.46 × 10-2 REM

INTERNAL DOSE Commitment (SKELETON) = 2.13 9 f. E (1-e-XEHT)

Where

9 = 8.55 x 10 3 a Ci

fz = FRACTION OF TOTAL BOCKY BURDEN (SKELETON)

m = mass of skeleron

= 1000 gm

E = 273 MeVd- REM RAD-

(PER REPORT BY I.C.R.P.)

TEFF = Tr. To

Tr = 4012080 HRS Tb = 50 yes

TEFF = 4012080 x 438000 4012080 + 438000

Teff = 3.9489 × 105 Hes

NEFF = 693 NEFF = 693 3.9489 × 105

ne4= 1.754 x 10-6

JOB AND USER (DWG. TITLE BLOCK INFORMATION)

CALCULATION OF ALPHAY GAMMA RADIATION

EXPOSURE TO FIRE FIGHTER DURING A FIRE

R.1

DATE PAGE 5 OF 5

BY Juny Hampton
APPROVED BY DATE

SQUARE D COMPANY

INTERNAL DOSE COMMITMENT (SKELETON) = 2.13 x 8.55 x 10 x .14 x 283 (1-e-1.7549 x 10 x 488000.

= 411.157 x 15 (.536)

TOTAL DOSE = 22.04 REM

OR, TOTAL DOSE TO SKELETON = . 441 REM/YEAR

THE PROBABILITY OF THE FIRE FIGHTER RECEIVING THIS


DOSE IS ACTUALLY REMOTE SINCE THE BURNING

PLASTIC IN THE HOUSING WOULD REQUIRE THE

WEARING OF OXYGEN BREATHING EQUIPMENT; HENCE

ELIMINATING ANY INTERNAL RADIATION HAZARD.

DURING THE CLEAN UP
OPERATIONS, THE PERSON
SWEEPING THE FLOOR AND
SWEEPING ALL THE DEBRIS
INTO A HEAP AND THEN
LOADING IT INTO DRUMS FOR
TRANSPORTATION TO A
LICENSED BURIAL SITE, WOULD
BE EXPOSED TO THE FOLLOWING
RADIATION DOSE.



PERSON CAN SWEEP THE WHOLE
AREA IN 16 HOURS, AND THERE WILL BE 150,000
RADIOACTIVE SOURCES SCATTERED ALL OVER THE
WAREHOUSE. FURTHER, LET US ASSUME THAT THE
AVERAGE DISTANCE OF HIS BODY FROM AN AVERAGE
OF APPROXIMATELY 10000 AMERICIUM SOURCES DURING
THE TOTAL 16 HOURS IS APPROXIMATELY 76 cm.

THEN
$$\dot{X}_{BODY} = \frac{127.17 \times 10^{-6}}{76^2} \times 10000$$

 $\dot{X}_{BODY} = 220 \times 10^{-6} \text{ Rh}^{-1}$

: TOTAL EXPOSURE = 220 × 10-6 × 16

.. TOTAL EXPOSURE X BODY = 3.52 m REM

WHICH IS FAR BELOW THE PERMISSIBLE DOSE LEVEL OF .5 REM PER § 32.28 "TABLE OF ORGAN DOSES", COLUMN \overline{II} .

THERE WILL BE PROBABLY MORE THAN I PERSON CLEANING UP, AND SO THE LENGTH OF EXPOSURE PER PERSON WILL DECREASE, ALSO IT IS MOST UNLIKELY THAT THE PERSON WILL BE CLOSE TO 10000 ION SOURCES AT ALL TIMES DURING HIS CLEAN UP SHIFT.

BUT EVEN IF HE IS AS CLOSE AS 50 m TO ALL 67500 ION SOURCES FOR AS LONG AS 2 HOURS.

(DURING THE LOADING OF THE DEBRIS INTO THE TRANSPORTATION DRUMS), HIS TOTAL EXPOSURE WOULD ONLY BE:

X 800Y = 127.17 ×10-6 × 67500 × 2

X 8004 = 6.867 m REM

ALL OF THE ABOVE CALCULATIONS DO NOT TAKE INTO CONSIDERATION ANY SHIELDING OF THE GAMMA RADIATION DUE TO THE PLASTIC MELTING AROUND THE ION SOURCE OR DUE TO THE SOURCES BEING BURIED IN THE DEBRIS OF THE FIRE.

** IF WE ASSUME A HOME OF 1200 SQ.FT. WITH AN 8 FT. CEILING CONTAINING A SINGLE SMOKE DETECTOR. IF WE ASSUME THAT IN A CATASTROPHIC FIRE, THE SMOKE DETECTOR WILL BE TOTALLY INCINERATED, AND THAT PER THE OAK RIDGE NATIONAL LABORATORY TEST OF OCTOBER 21, 1969, 31% OF THE AMERICIUM 241 WILL BE LIBERATED DURING A 1 HOUR FIRE.

AS THE SMOKE DETECTOR CONTAINS 1 A C OF A 241,

TOTAL AMOUNT OF Am 241

LIBERATED : 1.0 × .0031

= 0031 Ma/HR.

WILL BE IN A ROOM OF 15 FT. x 12 FT., THEN WE CAN CALCULATE THE TOTAL CONCENTRATION OF A. 241 IN THE AIR, IN THIS ROOM, DURING THE FIRE.

TOTAL VOLUME OF AIR = 15 x 12 x 8 cm FT/HR.

= 1440 CM FT./HR.

= 1440 × 28.32 LITRES/HR.

= 40780.8 LITRES / HR.

TOTAL VOLUME OF AIR = 40.78 × 106 mL/HR.

AM 241 IN AIR DURING FIRE 40.78 × 106 MG/ML

Am 241 CONCENTRATION IN AIR = 7.60 × 10-11 M C: /mL

IF THE FIRE FIGHTER IS IN THIS ROOM FOR 2 HRS.
THEN HE WILL HAVE INHALED 3400 LITRES OF AIR
(2 HOURS OF HEAVY BREATHING). IF THE CONCENTRATION
OF Am 241 IN THE AIR REMAINS AT 7.60 × 10-1/4 C/ML
LEVEL, AND 50% OF THE Am 241 INHALED WILL BE
IMMEDIATELY EXHALED, WE CAN CALCULATE HIS TOTAL
UPTAKE.


CHKD. BY DATE 11-29-11 SUBJECT CHLCULHIION OF & \$ 8 SHEET NO. 2 OF 4 CHKD. BY DATE RADIATION EXPOSURE OF FIRE JOB NO. CORRECTED 12-6-77 FIGHTER DURING A HOME FIRE
: HIS TOTAL UPTAKE
OF Am 241 WILL BE = .5 x 7.60 x 10 - 1 x 3400 x 103
= 1.292 × 10-4 m Ci
F WE ASSUME THAT THE CONCENTRATION IN THE REMAINDER OF THE HOME IS AS CALCULATED BELOW:
TOTAL VOLUME OF AIR = 1200 × 8 × 28.32 LITRES/HR.
= 2.719 × 105 LITRES / HR.
TOTAL VOLUME OF AIR = 2.719 × 108 mL/HR.
CONCENTRATION OF Am 241 IN AIR IN REMAINDER = 10031 OF HOME 2.719 × 108
= 1.14 × 10-11 ua/ml
1 HE IS IN THE REMAINDER OF THE HOME FOR 8 HRS. AND HE INHALES 13600 LITRES OF AIR.
HIS TOTAL UPTAKE OF Am 241 WILL BE = 5 × 1.14 × 10-11 × 13600 × 103
= 7.75 × 10-5 MCi
the state of the s
OF Am 241 WILL BE = 1.292 × 10-4 + 7.75 × 10-5
= 2.067 × 10-4 / Ci
IF WE ASSUME THAT OF THIS TOTAL UPTAKE 50% WILL

IF WE ASSUME THAT OF THIS TOTAL UPTAKE 50% WILL BE ELIMINATED THROUGH THE LUNGS AND GASTRO INTESTINAL TRACT AND 50% WILL BE ABSORBED INTO THE BODY AND RETAINED IN THE BONES FOR A PERIOD OF 50 YEARS. THEN HIS INTERNAL DOSE COMMITMENT WILL BE:

CHKD. BY DATE RADIATION EXPOSURE OF FIRE JOB NO. CORRECTED 12-6-77 FIGHTER DURING A HOME FIRE
INTERNAL DOSE 2.13 af 2 E 1. C- ASSET
COMMITMENT (LUNGS & G.I.) = 2.13 ay F2 E (1-e-XEFFT)
WHERE 95 × 2.067 × 10-4 = 1.034 × 10-4 mci
f2 = FRACTION OF TOTAL BODY BURDEN (LUNGS)
M - TOTAL MASS OF LUNGS JOT
TOTAL MASS OF LUNGS & G.I.
TO NEXT BY TO TO TO TO THE SECOND SEC
E = 268.7 MeV d-1 REM RAD-1
λεες • .002406
: INTERNAL DOSE 2 13 - 102/1 002406x
COMMITMENT (LUNGS & G.I) = 2.13 × 1.034 × 10-4 × .043 × 268.7 (1-0.002406 × 3000 × .002406
3000 × .002406
7 526 - 10-4 / 1 5001
= 3.526 × 10-4 (15001)
SOFT ORGAN DOSE : 1.76 × 10-4 REM
INTERNAL DOSE DIBOLE
COMMITMENT (SKELETON) = 2.13 9 f2 E (1-e-X EFFT)
WHERE 9 = 1.034 × 10-4 / Ci
fz = FRACTION OF TOTAL BODY BURDEN (SKELE
= .14
m = MASS OF SKELETON
: 10000 gmo.
E = 283 MeV d-1 REM RAD-1 (PER REPORT BY I.C.R.P.
λ EFF: 1.7549 × 10-6

CHKD. BY DATE 11-29-7	7 SUBJECT CALCULATION OF & & SHEET NO. 4 OF 4 RADIATION EXPOSURE OF FIRE JOB NO. FIGHTER DURING A HOME FIRE
OMMITMENT (SKE	LETON) = 2.13 9 fz E (1-e-XeffT)
	$= \frac{2.13 \times 1.034 \times 10^{-4} \times .14 \times 283}{10000 \times 1.7549 \times 10^{-6}} \left(1 - e^{-1.7549 \times 10^{-6} \times 438000}\right)$ $= .4972 \left(14636387\right)$
(SKELETON)	(SKELETON) = 5.33 × 10-3 REM / YEAR
	The state of the s
	-b

in which the loss of the total



BY UK. Vens	DATE 11-29-77
CHKD. BY	
COPPECTED	12-6-77

RADIATION EXPOSURE OF SPECTATOR WATCHING A HOME FIRE

SHEET NO	1 of 2
JOB NO.	

IF WE ASSUME THE SAME CONDITIONS OF A HOM	E
FIRE AS DESCRIBED IN CALCULATION OF "RADIATION	2
EXPOSURE OF FIRE FIGHTER DURING A HOME FIR	€."
IF WE ASSUME THAT THE WALLS AND ROOF OF	
THE HOME COLLAPSE AND THEREBY RELEASING	
0031 MCI/HR. OF Am 241 INTO THE ATMOSPHER	E.
AND IF WE ASSUME THAT A SPECTATOR IS WITH	IIN
50 FT. OF THE HOME FOR AT LEAST I HOUR.	

TOTAL VOLUME OF AIR = 3 TT 73

WHERE T = 50 FT

= = TI × 503 CU.FT/HR.

= 2 T × 503 × 28.32 LITRES/HR.

= 7.414 × 106 LITRES/HR.

TOTAL VOLUME OF AIR = 7.414 × 109 mL/HR.

: CONCENTRATION OF - . 0031 - Ma/ml

Am 241 CONCENTRATION IN AIR = 4.18 × 10-13 M CI/ML

THIS CONCENTRATION OF Am 241 IN AIR IS TOTALLY INACCURATE AND EXAGGERATED BECAUSE DUE TO THE HOT AIR RISING FROM THE FIRE, THERE WILL BE A STRONG FLOW OF AIR FROM THE SPECTATOR TOWARDS THE FIRE AND THERE WILL BE MANY HUNDREDS OF AIR CHANGES DURING THE HOUR. IF THE SPECTATOR STAYS FOR I HOUR, THEN HE WILL INHALE 1200 LITRES OF AIR (I HOUR NONOCCUPATIONAL). IF 59% OF THE Am 241 INHALED WILL BE IMMEDIATELY EXHALED, THEN HIS TOTAL UPTAKE WILL BE:

TOTAL UPTAKE : .5 × 4.18 × 10-13 × 1200 × 103


= 2.5 × 10-7 MCi

CHKD. BY DATE RADIATION EXPOSURE OF JOB NO. CORRECTED 12-6-77 SPECTATOR WATCHING A HOME FIRE
IF WE ASSUME THAT OF THIS TOTAL UPTAKE, 50% WILL BE ELIMINATED THROUGH THE LUNGS AND GASTRO INTESTINAL TRACT_AND 50% WILL BE ABSORBED INTO THE BODY AND RETAINED IN THE BONES FOR A PERIOD OF 50 YEARS. THEN HIS INTERNAL DOSE COMMITMENT WILL BE :-
INTERNAL DOSE 2.13 9 F2 E (1 = e- LEFF T) ELCOMMITMENT (LUNGS & G.I) THE M REFF
WHERE 9 = .5 × 2.5 × 10-7 = 1.25 × 10-7 µ Ci
f ₂ = .043
= 3000 gms E = 268.7 MeVd-1 REM RAD-1
$\lambda_{EFF} = .002406$
O. INTERNAL DOSE
SOFT ORGAN DOSE = 2.13 × 10-7 REM
INTERNAL DOSE (1-e-1.7549×10-6,4380) = 2.13×1.25×10-7×.14×283 (1-e-1.7549×10-6,4380)
TOTAL DOSE (SKELETON) = 3.22 × 10-4 REM
OR, TOTAL DOSE (SKELETON) = 6.448 × 10-6 REM / YEAR

the first section of the section of

CHARLETTERING TO THE INCHES WITH THE CONTRACTOR AND A CON

CHKD. BY DATE DOSE FROM INGEST CORRECTED 12-6-77 (1) ION SOURCE.	
TOTAL DOSE = 2.13 of f2 m A EFF	The second secon
WHERE: 9 : I M Ci Am 241 f_2 : FRACTION OF TOTAL : 029 : TOTAL MASS OF : 2000 gm	AL BODY BURDEN IN G.I. TRACT
$E_{\alpha} : E.F. (RBE)n$ $E_{\alpha} : [(5.49 \times .85) + (5.44 \times .13)] \times 1 \times $	RATE = REE = RELATIVE BIOLOGICAL EFFECTIVENESS FACTOR I IO N = RELATIVE DAMAGE FACTOR = 5 WHERE E & GAMMA RAY ENERGY F & NO. OF & PER DISINTEGRATION Ma = LINEAR ENERGY ABSORBTION COEFFICIENT = 0312
E: 268.7 MeVd-1 rem	Tad-1
Teff = Tr.Tb Tr+Tb Teff = 4012080 × 31 4012080 + 31 Teff = 30.999 Hrs.	WHERE Ty = 458 YEARS = 4012080 Hrs. Tb = 31 Hrs. (NORMAL BIDLOGICAL ELIMINATION
rice and	RATE)



CHED. BY DATE CORRECTED 12-6-77	DOSE FROM INGEST		o _F 3
	-693 Teff = -693 = 3.9489 × 10	The second section of the second section is the second section of the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the second section in the second section is the second section in the section is the second section in the section is the section in the section in the section in the section is the section in the section is the section in the section in the section is the section in the section is the section in the section in the section is the section in the section in the section is the section in the section in the section is the section in the section is the section in the section in the	
TOTAL DO	SE = 2.13 × 4.9 × 10 - 10000 × 1.75	3×.14×283 (1-e 49×10-6 14636387)	-1.7549×10 ⁻⁶ ,4380
	DOSE TO SKELETO		YEAR.
TO THE STREET COMME TO SERVICE STREET			

THE RESERVE THE PROPERTY OF TH

ACTOR DE LOS TORISTANCIONES

** IF WE ASSUME A HOME OF 1200 SQ.FT. WITH AN 8 FT. CEILING CONTAINING A SINGLE SMOKE DETECTOR. IF WE ASSUME THAT IN A CATASTROPHIC FIRE, THE SMOKE DETECTOR WILL BE TOTALLY INCINERATED, AND THAT PER THE OAK RIDGE NATIONAL LABORATORY TEST OF OCTOBER 21, 1969, .31% OF THE AMERICIUM 241 WILL BE LIBERATED DURING A 1 HOUR FIRE. AS THE SMOKE DETECTOR CONTAINS 1 M C OF A 241,

TOTAL AMOUNT OF Am 241

= 1.0 × .0031

= .0031 ma/HR.

JF_WE ASSUME THAT THE GREATEST CONCENTRATION WILL BE IN A ROOM OF 15 FT. x 12 FT., THEN WE CAN CALCULATE THE TOTAL CONCENTRATION OF A 241 IN THE AIR, IN THIS ROOM, DURING THE FIRE.

TOTAL VOLUME OF AIR = 15 × 12 × 8 cm FT/HR.

= 1440 CM FT./HR.

= 1440 × 28.32 LITRES/HR.

= 40780.8 LITRES / HR.

: TOTAL VOLUME OF AIR = 40.78 × 106 mL/HR.

Am 241 IN AIR DURING FIRE 40.78 × 106 MC/ML

Am 241 CONCENTRATION IN AIR = 7.60 × 10-1 M Ci/ML

IF THE FIRE FIGHTER IS IN THIS ROOM FOR 2 HRS.
THEN HE WILL HAVE INHALED 3400 LITRES OF AIR
(2 HOURS OF HEAVY BREATHING). IF THE CONCENTRATION
OF AM 241 IN THE AIR REMAINS AT 7.60 × 10-11/4 CI/ML
LEVEL, AND 50% OF THE AM 241 INHALED WILL BE
IMMEDIATELY EXHALED, WE CAN CALCULATE HIS TOTAL
UPTAKE.


CHKD. BY DATE RADIATION EXPOSURE OF FIRE JOB NO. CORRECTED 12-6-77 FIGHTER DURING A HOME FIRE
HIS TOTAL UPTAKE OF Am 241 WILL BE = .5 × 7.60 × 10 - 11 × 3400 × 10 3 = 1.292 × 10 - 4 m CL
REMAINDER OF THE HOME IS AS CALCULATED BELOW:
TOTAL VOLUME OF AIR = 1200 × 8 × 28.32 LITRES/HR. = 2.719 × 105 LITRES/HR.
TOTAL VOLUME OF AIR = 2.719 × 108 mL/HR.
: CONCENTRATION OF Am 241 IN AIR IN REMAINDER = .0031 OF HOME = 1.14 × 10-11 µ G/mL
IF HE IS IN THE REMAINDER OF THE HOME FOR 8 HRS. AND HE INHALES 13600 LITRES OF AIR.
HIS TOTAL UPTAKE
= 2.067 × 10-4 m Ci
IF WE ASSUME THAT OF THIS TOTAL UPTAKE 50% WILL BE ELIMINATED THROUGH THE LUNGS AND GASTRO INTESTINAL TRACT AND 50% WILL BE ABSORBED INTO THE BODY AND RETAINED IN THE BONES FOR A PERIOD OF 50 YEARS. THEN HIS INTERNAL DOSE COMMITMENT WILL BE:
in the state of th

CHKD. BY DATE RADIATION EXPOSURE OF FIRE JOB NO. CORRECTED 12-6-77 FIGHTER DURING A HOME FIRE
COMMITMENT (LUNGS & G.I.) = 2.13 q f2 E (1-e-XEFFT)
WHERE Q = .5 × 2.067 × 10-4 = 1.034 × 10-4 x Ci
f2 = FRACTION OF TOTAL BODY BURDEN (LUNGS & G.)
m = TOTAL MASS OF LUNGS & G.I.
E = 268.7 MeV d-1 REM RAD-1
λεεε • •002406
COMMITMENT (LUNGS & G.I) = 2.13 × 1.034 × 10-4 × .043 × 268.7 (1-0.002406 × 288
= 3.526 × 10-4 (15001)
SOFT ORGAN DOSE : 1.76 × 10-4 REM
INTERNAL DOSE = 2.13 0 f2 E (1-e-XEFFT)
WHERE 9 = 1.034 × 10-4 MCi
fz = FRACTION OF TOTAL BODY BURDEN (SKELETON)
m = MASS OF SKELETON : 10000 gmo.
E = 283 MeV d-1 REM RAD-1 (PER REPORT)
λ _{εεε} : 1.7549 × 10-6

CHKD. BY DATE 11-29-77 CHKD. BY DATE CORRECTED 12-6-77	SUBJECT CALCULATION OF & \$ SHEET NO. 4 OF 4 RADIATION EXPOSURE OF FIRE JOB NO. FIGHTER DURING A HOME FIRE
INTERNAL DOSE COMMITMENT (SKELET	ON) = 2.13 q f2 E (1-e-LEFFT)
CMPHIMENT (SKELET	$= \frac{2.13 \times 1.034 \times 10^{-4} \times .14 \times 283}{10000 \times 1.7549 \times 10^{-6}} \left(1 - e^{-1.7549 \times 10^{-6} \times 438000}\right)$
TOTAL DOSE	= .4972 (14636387)
(SKELETON)	* 2667 REM - 100 REM / YEAR - 100 REM / YEAR

No. 10 Mart Janes Commen

NEW YORK CO., NO.



BY UK. Veng	DATE 11-29-77
HKD. BY	
COPPECTED	12-6-77

RADIATION EXPOSURE OF SPECTATOR WATCHING A HOME FIRE

SHEET	NO	OF	2
JOB NO			

TOTAL VOLUME OF AIR = 2 TTr3

WHERE T = 50 FT.

= = TI × 503 CU.FT/HR.

= \frac{2}{3} T \times 503 \times 28.32 LITRES/HR.

= 7.414 × 106 LITRES/HR.

TOTAL VOLUME OF AIR = 7.414 × 109 mL/HR.

: CONCENTRATION OF - . 0031 - Ma/ml

Am 241 CONCENTRATION IN AIR = 4.18 × 10-13 M CI/ML

THIS CONCENTRATION OF Am 241 IN AIR IS TOTALLY INACCURATE AND EXAGGERATED BECAUSE DUE TO THE HOT AIR RISING FROM THE FIRE, THERE WILL BE A STRONG FLOW OF AIR FROM THE SPECTATOR TOWARDS THE FIRE AND THERE WILL BE MANY HUNDREDS OF AIR CHANGES DURING THE HOUR. IF THE SPECTATOR STAYS FOR I HOUR, THEN HE WILL INHALE 1200 LITRES OF AIR (I HOUR NONOCCUPATIONAL). IF 59% OF THE Am 241 INHALED WILL BE IMMEDIATELY EXHALED, THEN HIS TOTAL UPTAKE WILL BE:

TOTAL UPTAKE : .5 × 4.18 × 10-13 × 1200 × 103

ta magazatkora erre kaketal akeral tarik aran dadaking indaketal dadaka ketelek di di errepet erekakar beli dentek


= 2.5 × 10-7 MCi

CHECTED 12-6-77 SPECTATOR WATCHING A HOME FIRE
IF WE ASSUME THAT OF THIS TOTAL UPTAKE, 50% WILL BE ELIMINATED THROUGH THE LUNGS AND GASTRO INTESTINAL TRACT AND 50% WILL BE ABSORBED INTO THE BODY AND RETAINED IN THE BONES FOR A PERIOD OF 50 YEARS, THEN HIS INTERNAL DOSE COMMITMENT WILL BE:
INTERNAL DOSE 2.13 9 F2 E (1-e-XEFF T)
WHERE 9 = .5 × 2.5 × 10-7 = 1.25 × 10-7 MCi
f ₂ = .043
m = :3000 grs
E = 268.7 MeV d-1 REM RAD-1 λε = .002406
O. INTERNAL DOSE
SOFT ORGAN DOSE = 2.13 × 10-7 REM
INTERNAL DOSE (1-e-1.7549×10-6,43800) = 2.13×1.25×10-7×.14×283 (1-e-1.7549×10-6,43800
TOTAL DOSE (SKELETON) = 3.22 × 10-4 REM
OR. TOTAL DOSE (SKELETON) = 6.448 × 10-6 REM / YEAR

The Company of the International Company of the Com

PERMIT

CHKD. BY DATE CORRECTED 12-6-77	SUBJECT CALCULATION O DOSE FROM INGEST (1) ION SOURCE.		HEET NO. 1 OF 3
TOTAL E	ATTACHMENT B-	The same of the same of	T)
f ₂	FRACTION OF TOTAL .029 TOTAL MASS OF 2000 gm	L BODY BURD	EN IN G.I. TRACT
Ex : (4.66	E.F. (RBE)n (85)+(5.44×:13)]×1× (65+.7072) 50 (68 MeVd-1 rem tad-1	10×5 F = RBE =	TOTAL ENERGY ABSORBED RATIO OF DISINTEGRATION RATE = RELATIVE BIOLOGICAL EFFECTIVENESS FACTOR IO RELATIVE DAMAGE FACTOR = 5
εχ: .060 εχ: .013	Fx (1-e-Max) x.36 (1-e-0312-30) x.36 (1-e-392) MeV d-1 rem rod-1 8.68 + .013 58.7 MeV d-1 rem	fr: Ma	GAMMA RAY ENERGY NO. OF & PER DISINTEGRATION LINEAR ENERGY ABSORBTION COEFFICIENT 2.0312 EFFECTIVE RADIUS 30 cm.
Teff = T	7. Tb 7+ Tb 012080 × 31	WHERE TY :	458 YEARS 4012080 Hrs. 31 Hrs. (NORMAL BIDLOGICAL ELIMINATION RATE)



CORRECTED 12-6	DOS	CT CALCULATION SE FROM IN ION SOUR	GESTION	0-	EET NO. 3	o _F 3	
0	λ _{EFF}	- 693 Teff					
		3.9489	×105				
	λ _{EFF}	: 1.754	9 × 10-6				
		2.13 × 4.9 10000 × 23.563	(1	+		1.7549×10	-6×4380
	e la les seus	E TO SKE		.253	REM / Y	EAR.	

	- H						
Coke Constitutions	the little in E	The second secon	(विकास कार कार कार	THE TART	Literate 1	mand to ment	יוי מידור
		5 - 100° 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1					
	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1						
			-		• • • • • • • • • • • • • • • • • • • •		

in TELL

ALPA IN A CONTRACTOR OF THE FIRM