

March 17, 1986
NRC/TMI-86-025

MEMORANDUM FOR: Harold R. Denton, Director
Office of Nuclear Reactor Regulation

Frank J. Miraglia, Director
Division of PWR Licensing-B

FROM: William D. Travers, Director
TMI-2 Cleanup Project Directorate

SUBJECT: NRC TMI-2 CLEANUP PROJECT DIRECTORATE WEEKLY STATUS
REPORT FOR MARCH 10 - MARCH 16, 1986

50-324

1. DEFUELING

- As of March 16, 1986, 25 canisters with an approximate net weight of 26,490 lbs have been transferred from the reactor vessel to the spent fuel pool storage racks.
- Defueling remains hampered by poor visibility in the reactor vessel because of biologic growths. The "mature colony" contains aerobes, anaerobes, fungi, algae and bacteria. Research continues in an effort to identify treatments to remove the growths. This colony is about the same as found in river water.
- Early in the week the debris bucket hanger apparently became jammed in the canister positioning system, preventing movement. Upon removal and inspection, the canister system was unloaded, and a Quality Assurance (QA) inspection of the system was conducted. Upon QA release, the canister system was reloaded with five empty fuel canisters and defueling resumed. The pick and place operation now uses a wide-mouthed funnel to guide debris into the canister opening with a resultant increase in loading efficiency.

2. PLANT STATUS

- The reactor remains in long term cold shutdown, vented to atmosphere. Core cooling is by natural heat loss to ambient building atmosphere. Calculated decay heat is 10.7 KW. Incore thermocouples average is 81°F.
- The defueling platform is mounted above the modified internals indexing fixture which is mounted on the reactor vessel flange. These provide water coverage of 15½ feet over the core region. This water level is about 5 feet over the top of any debris canisters in

8603240312 860317
PDR ADOCK 05000320
R PDR

OFFICE									
SURNAME									
DATE									

the reactor vessel. The airborne radioactivity on the platform is 8.9 E-8 uCi/cc Tritium and 2.8 E-11 uCi/cc particulates, predominately Cesium-137.

3. WASTE MANAGEMENT

- The Submerged Demineralizer System (SDS) completed processing batch 129, (neutralizer tanks) to the monitor tanks (8,579 gallons) and began processing batch 130 ("C" reactor coolant bleed tank) to the monitor tanks. SDS total processed to date is 3,842, 869 gallons.
- EPICOR II completed processing batch 277 (10,877 gallons); batch 278 (9,763 gallons); and batch 279 (8,937 gallons) from the SDS monitor tanks to CC-T-2. EPICOR II total processed to date is 2,854,371 gallons.

4. ENVIRONMENTAL MONITORING

- US Environmental Protection Agency (EPA) sample analysis results show TMI site liquid effluents to be in accordance with regulatory limits, NRC requirements, and the City of Lancaster Agreement.
- TMI water samples taken by EPA at the plant discharge to the river consisted of seven daily composite samples taken from February 22 through March 1, 1986. A gamma scan detected no reactor related activity.
- The Lancaster water sample taken at the water works intake and analyzed by EPA consisted of a seven day composited sample taken from February 22 through March 1, 1986. A gamma scan detected no reactor related radioactivity.
- The NRC outdoor airborne particulate sampler at the TMI site collected a sample between March 5, and 13, 1986. No reactor related radioactivity was detected. Analysis showed Iodine-131 and Cesium-137 concentrations to be less than the lower limits of detectability.

5. AUXILIARY AND FUEL HANDLING BUILDING ACTIVITIES

- Installation of the balance of Defueling Water Cleanup System (DWCS) continued.
- Preparations are being made for decontamination in the Seal Injection Room, 281' auxiliary building.

6. NRC EVALUATIONS IN PROGRESS

- Technical Specification Change Request number 49.
- Recovery Operations Plan Change number 31.
- SDS Technical Evaluation and System Description Update.
- Core Stratification Sample Safety Evaluation.
- Containment Air Control Envelope Technical Evaluation Report, Revision 5.

OFFICE							
SURNAME							
DATE							

Harold R. Denton
Frank J. Miraglia

3

March 17, 1986
NRC/TMI-86-025

- Solid Waste Facility Technical Evaluation Report.
- Reactor Building Sump Criticality Safety Evaluation Report.
- TMI-2 Temporary Reactor Vessel Filtration System Safety Evaluation Report, Revision 1.

ORIGINAL SIGNED BY,
William D. Travers

William D. Travers
Director
TMI-2 Cleanup Project Directorate

OFFICE ▶							
SURNAME ▶							
DATE ▶							

Harold R. Denton
Frank J. Miraglia

4

March 17, 1986
NRC/TMI-86-025

INTERNAL DISTRIBUTION

EDO
OGC
Office Directors
Commissioner's Technical Assistants
NRR Division Directors
NRR A/D's
Regional Administrators
IE Division Directors
TAS
EIS
TMI Cleanup Project Directorate (10)
PHS
EPA
DOE
RI Division Directors
Public Affairs, RI
State Liaison, RI
TMIPO HQ r/f
TMI SITE r/f
CENTRAL FILE
NRC PDR
LOCAL PDR
TMI-2 Project Section File

OFFICE	TMICPD	TMICPD	TMICPD	TMICPD			
SURNAME	DCollins	Jes CCowgill	Act. Chief	WTravers			
DATE	3/17/86	3/17/86	3/17/86	3/17/86			