



Illinois Power Company
Clinton Power Station
P.O. Box 678
Clinton, IL 61727
Tel 217 935-5623
Fax 217 935-4632

John G. Cook
Senior Vice President

U-602862
2C.220

November 13, 1997

Docket No. 50-461

10CFR50 73

Document Control Desk
Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Clinton Power Station - Unit 1
Licensee Event Report No. 97-026-00


Dear Madam or Sir:

Enclosed is Licensee Event Report (LER) No. 97-026-00: Inadequate Procedure for Inspection of Shutdown Service Water Pumps For Excess Silt Results in Shutdown Service Water Pump Inoperability. This report is being submitted in accordance with the requirements of 10CFR50.73.

Illinois Power is committing to take the following actions as documented in this LER:

- Clean the Plant Service Water Intake Structure to achieve an acceptable level of silt.
- Revise Clinton Power Station (CPS) Procedure 24001.01, "CPS Corbicula (Asiatic Clams) Control," to include an acceptance criteria for silt level, trending of silt accumulation, and require inspection of the Shutdown Service Water (SX) pump intake area.
- Evaluate, test, or inspect the heat exchangers served by the Division I and II SX pumps for operability due to silt accumulation.

Sincerely yours,


J.G. Cook
Senior Vice President

9711210175 971113
PDR ADOCK 05000461
S PDR



MRS/krk

Enclosure

cc: NRC Clinton Licensing Project Manager
NRC Resident Office, V-690
Regional Administrator, Region III, USNRC
Illinois Department of Nuclear Safety
INPO Records Center