



Northeast
Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

November 12, 1997

Docket No. 50-423
B16798

Re: 10 CFR 50.73(a)(2)(i)(B)

Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station Unit 3
Licensee Event Report 97-052-00
Submitted Pursuant to 10 CFR 50.73(a)(2)(i)(B)

This letter forwards Licensee Event Report 97-052-00, documenting a condition that was determined reportable at Millstone Unit No. 3 on October 14, 1997. This LER is submitted pursuant to 10 CFR 50.73(a)(2)(i)(B). NNECO's commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. David A. Smith at (860) 437-5840.

Very truly yours,

NORTHEAST NUCLEAR ENERGY
COMPANY

G. D. Hicks
Unit Director, Millstone Unit No. 3

9711210301 971112
PDR ADDCK 05000423
S PDR



Attachment: 1) NNECO's commitments in response to LER 97-052-00
2) LER 97-052-00

cc: H. J. Miller, Region I Administrator
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3
J. W. Andersen, NRC Project Manager, Millstone Unit No. 3
W. D. Travers, Dr., Director, Special Projects
Corrective Action Group Files (CR M3-97-3449)

Docket No. 50-423
B16798

Attachment 1

Millstone Nuclear Power Station, Unit No. 3
NNECO's Commitments
In Response To
(LER 97-052-00)

November 12, 1997

Enclosure
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
	A review of the "B" train PORV circuitry was conducted for similar conditions. Results of the review concluded that the "B" train PORV circuitry is completely tested by surveillance procedures.	Complete
	The controller card was calibrated on October 16, 1997.	Complete
B16798-01	The Manual / Auto Station component will be individually calibrated.	Prior to entry into Mode 3
B16798-02	Applicable surveillance procedures will be revised to include the omitted pressurizer pressure narrow range channel calibration components.	Prior to entry into Mode 3
B16798-03	A review of surveillance procedures will be conducted to determine if there are other missed occurrences of Technical Specification components actuated by control cabinet circuitry.	Prior to entry into Mode 3

Docket No. 50-423
B16798

Attachment 2

Millstone Nuclear Power Station, Unit No. 3
NNECO's Submittal of
(LER 97-052-00)

November 12, 1997