

January 21, 1998

South Carolina Electric & Gas Company
ATTN: Mr. Gary J. Taylor
Vice President, Nuclear Operations
Virgil C. Summer Nuclear Station
P. O. Box 88
Jenkinsville, SC 29065

SUBJECT: MEETING SUMMARY - V. C. SUMMER EMERGENCY DIESEL GENERATOR ISSUES

Dear Mr. Taylor:

This letter refers to the meeting conducted at your request at the NRC Region II office in Atlanta on January 14, 1998. The purpose of the meeting was to allow South Carolina Electric & Gas Company (SCE&G) to make a presentation on V. C. Summer's Emergency Diesel Generator issues. Although not discussed, your staff also provided an information handout on Refuel 10.

It is our opinion that this meeting was beneficial and provided a better understanding of the issues and status of the Emergency Diesel Generator.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

Should you have any question concerning this letter, please let us know.

Sincerely,

Orig signed by Robert C. Haag

Robert C. Haag, Chief
Reactor Projects Branch 5
Division of Reactor Projects

Docket No. 50-395
License No. NPF-12

Enclosures: 1. List of Attendees
2. SCE&G Presentation Slides
3. Refuel 10 Handout

040065

OFFICIAL COPY

9802040187 980121
PDR ADOCK 05000395
P PDR



2245

cc w/encls:

R. J. White
Nuclear Coordinator Mail Code 802
S.C. Public Service Authority
Virgil C. Summer Nuclear Station
P. O. Box 88
Jenkinsville, SC 29065

J. B. Knotts, Jr., Esq.
Winston and Strawn
1400 L Street, NW
Washington, D. C. 20005-3502

Chairman
Fairfield County Council
P. O. Box 60
Winnsboro, SC 29180

Virgil R. Autry, Director
Radioactive Waste Management
Bureau of Solid and Hazardous
Waste Management
S. C. Department of Health
and Environmental Control
2600 Bull Street
Columbia, SC 29201

R. M. Fowlkes, Manager
Operations (Mail Code 303)
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
P. O. Box 88
Jenkinsville, SC 29065

April Rice, Manager
Nuclear Licensing & Operating
Experience (Mail Code 830)
Virgil C. Summer Nuclear Station
P. O. Box 88
Jenkinsville, SC 29065

SCE&G

3

Distribution w/encls:

M. Padovan, NRR

R. Aiello, RII

P. Fillion, RII

R. Gibbs, RII

D. Jones, RII

L. Garner, RII

M. King, RII

PUBLIC

NRC Resident Inspector
U.S. Nuclear Regulatory Commission
Route 1, Box 64
Jenkinsville, SC 29065

OFFICE	RII	RE: APP						
SIGNATURE	AMT	L.W. Garner						
NAME	P Hopkins	L Garner						
DATE	1/ 2 / 98	1/ 2 / 98	1/ 2 / 98	1/ 2 / 98	1/ 2 / 98	1/ 2 / 98	1/ 2 / 98	1/ 2 / 98
COPY?	YES	NO	YES	NO	YES	NO	YES	NO

OFFICIAL RECORD COPY

DOCUMENT NAME: G:\SUMMTG14.SUM


LIST OF ATTENDEES

Nuclear Regulatory Commission


L. Reyes, Regional Administrator, Region II (RII)
J. Johnson, Director, Division of Reactor Projects (DRP), RII
J. Jaudon, Director, Division of Reactor Safety, RII
M. Padovan, Project Manager, Project Directorate II-1, Office of Nuclear
Reactor Regulation
R. Haag, Chief, Branch 5, DRP, RII
B. Bonser, Senior Resident Inspector, V. C. Summer
P. Hopkins, Project Engineer, Branch 5, DRP, RII
M. King, Project Engineer, Branch 5, DRP, RII

South Carolina Electric and Gas Company

S. Byrne, Plant Manager
B. Williams, General Manager, Engineering
B. Waselus, Manager, System Engineering
M. Fowlkes, Operations Manager
R. Sloane, System Engineer
D. Gatlin, Engineering Analyst
A. Rice, Manager, Licensing




Enclosure 2




Participants

- ❖ Steve Byrne Plant Manager
- ❖ Bruce Williams Gen. Mgr. Engineering
- ❖ Bob Waselus Mgr. Syst. Engineering
- ❖ Mike Fowlkes Operations Mgr.
- ❖ Richard Slone System Engineer
- ❖ Dan Gatlin Engineering Analyst
- ❖ April Rice Mgr. Licensing



Agenda

- ❖ Introduction and Overview
- ❖ DG Monthly Operability Testing
- ❖ DG Equipment Overview
- ❖ History of DG Operation
- ❖ Actions Completed
- ❖ DG Operability Retesting
- ❖ Future Plans
- ❖ Summary




“A”

Diesel Generator Issues




"A" Diesel Generator




Issues

- ❖ **Parts**
 - Aging
 - Vendor testing of refurbished components
- ❖ Upgrade to next generation or digital?
- ❖ Objective overview
- ❖ Not each failure counted under
GL 94-01
 - Possible T.S. change



- ❖ Failures were distinctly different
 - Electrical Governor (EGA) #1
 - ID relay (not valid test failure)
 - EGA #2
 - “Mechanical” Governor (EGB)
(only oscillated unloaded)
- ❖ DG reliability still good
- ❖ No start failures
- ❖ Retesting more comprehensive than most
- ❖ Conservative decision to S/D



Monthly Operability Test Description

Mike Fowlkes




Operability Test

- ❖ Perform Emergency Start of EDG
- ❖ Record Time to Reach Speed,
Voltage, and Frequency
- ❖ Perform Test Start of EDG
- ❖ Run at No Load for Stabilization




Operability Test

- ❖ Parallel to Bus and Run Loaded for One Hour
- ❖ Reduce Load To 50 kW and Open EDG Feeder Breaker to Bus
- ❖ Verify Steady State - No Load Voltage
- ❖ Stop and Align EDG for Automatic Start



Diesel Generator Equipment Overview

Bob Waselus




Overview of Operation of the Governor Control System


- ❖ **Electrical Governor (EGA)
Operation**

- ❖ **“Mechanical” Governor (EGB)
Operation**

Overview of Operation of the Governor Control System




Overview of Operation of the Governor Control System




Overview of Operation of the Governor Control System


EGA Block Diagram




Overview of Operation of the Governor Control System



Overview of Operation of the Governor Control System




Overview of Operation of the Governor Control System




Overview of Operation of the Governor Control System


EGB Block Diagram



Event #1


EGA Failure 11-11-97






Event #2

Droop Relay Failure
11-21-97



Event #3

EGA Failure 12-2-97




Event #4

EGB Failure 12-28-97




Diesel Generator History Electrical Governor (EGA)



Diesel Generator History

Mechanical Governor (EG 'B')



1 = 1380933

— Installed

2 = 1790986

- - - Warehouse

3 = 1790985

..... At Refurb

4 = 1391786



- ❖ CT / PT Evaluation
- ❖ Evaluation of Ambient Temperature
- ❖ Lube Oil Consumption
- ❖ Outage Scope Review
- ❖ Viscosity and Synthetic Oil Evaluation




Actions Completed

- ❖ Fuel Oil Delivery System
- ❖ Voltage Regulator Evaluation
- ❖ Independent Design Engineering
Determination of Troubleshooting
- ❖ Design Engineering Review of
Set-up Procedures




Actions Completed

- ❖ Vendor Shop Visits
- ❖ OE Review By INPO
- ❖ State of the Art Test Equipment
- ❖ Bench Tests
- ❖ No Load Frequency Tolerance
- ❖ PM Scope Review for Normal
and Accelerated Testing



DG Operability Retesting

Mike Fowlkes



Operability Retesting


RF10

- ❖ Three Maintenance Runs
- ❖ Monthly Operability Test
- ❖ Twenty-Four Hour Refueling Surveillance Test
- ❖ Load Rejection Test
- ❖ Loss of Offsite Power Test
- ❖ Integrated Safeguards Test




Operability Retesting For First Three Events

- ❖ Maintenance Runs
- ❖ Monthly Operability Test
- ❖ Load Rejection Test
(Modified to Check Loading Stability)




Operability Retesting For Fourth Event

- ❖ Maintenance Runs
- ❖ Pre-Operability Tests Per Monthly Surveillance Procedure
- ❖ Monthly Operability Test
- ❖ Load Rejection Test
- ❖ Loss of Offsite Power Test
- ❖ Semi-Annual Cold Start-Fast Load Test



Summary of Retesting Activities

- ❖ Maintenance Runs
- ❖ Monthly Surveillance Tests
- ❖ Other Surveillance Testing Per Technical Specifications



Bruce Williams



Planned Activities

- ❖ Expert Panel Independent Assessment - 1/19
- ❖ Part 21 Evaluation - 2/8
- ❖ Analog Governor Upgrade Evaluation
- ❖ Speed Control System Overhaul Evaluation
- ❖ Periodic Diagnostics
- ❖ Shelf Life Assessment

Summary

Steve Byrne



Summary

- ❖ **Questioned Similarity and Number of Events**
- ❖ **Continue to Evaluate**
 - Parts Issues
 - Vendors
 - Tech Spec Methodologies
 - Governor Upgrades
- ❖ **Established Operability**

Summary

- ❖ MR to Establish Confidence Over Time
- ❖ History Shows DGs Very Reliable



Participants


- ◆ Steve Byrne Plant Manager
- ◆ Bruce Williams Gen. Mgr. Engineering
- ◆ Bob Waselus Mgr. Syst. Engineering
- ◆ Mike Fowlkes Operations Mgr.
- ◆ Richard Slone System Engineer
- ◆ Dan Gatlin Engineering Analyst
- ◆ April Rice Mgr. Licensing

Agenda

- ◆ Introduction and Overview
- ◆ DG Monthly Operability Testing
- ◆ DG Equipment Overview
- ◆ History of DG Operation
- ◆ Actions Completed
- ◆ DG Operability Retesting
- ◆ Future Plans
- ◆ Summary



"A" *Diesel Generator Issues*



Issues

- ◆ Parts
 - Aging
 - Vendor testing of refurbished components
- ◆ Upgrade to next generation or digital?
- ◆ Objective overview
- ◆ Not each failure counted under GL 94-01
 - Possible T.S. change

Boirts

- ◆ Failures were distinctly different
 - Electrical Governor (EGA) #1
 - ID relay (not valid test failure)
 - EGA #2
 - "Mechanical" Governor (EGB)
(only oscillated unloadsed)
- ◆ DG reliability still good
- ◆ No start failures
- ◆ Retesting more comprehensive than most
- ◆ Conservative decision to S/D

Monthly Operability Test Description

Mike Fowlkes

Operability Test

- ◆ Perform Emergency Start of EDG
- ◆ Record Time to Reach Speed, Voltage, and Frequency
- ◆ Perform Test Start of EDG
- ◆ Run at No Load for Stabilization

Operability Test

- ◆ Parallel to Bus and Run Loaded for One Hour
- ◆ Reduce Load To 50 kW and Open EDG Feeder Breaker to Bus
- ◆ Verify Steady State - No Load Voltage
- ◆ Stop and Align EDG for Automatic Start


Diesel Generator Equipment Overview

Bob Waselus


Overview of Operation of the Governor Control System

- ◆ Electrical Governor (EGA) Operation
- ◆ "Mechanical" Governor (EGB) Operation


Overview of Operation of the Governor Control System



Overview of Operation of the Governor Control System




Overview of Operation of the Governor Control System



Overview of Operation of the Governor Control System



Overview of Operation of the Governor Control System





Overview of Operation of the Governor Control System



Overview of Operation of the Governor Control System



EGB Block Diagram




EGA Failure 11-11-97




Droop Relay Failure
11-21-97



EGA Failure 12-2-97




EGB Failure 12-28-97




*Diesel Generator History
Electrical Governor (EGA)*

Dg#	Initial Commission (10/82)				11/12
	LBL	124A	142A	142B	
1	"B" DG				"A" DG (1)
2	"A" DG				"A" DG
3					"A" DG
4		"B" DG			

1 = 1425251 Installed
 2 = 1425252 Warehouse
 3 = 1790987 At Refurb
 4 = 1790988 (1) - Refurb Failed Benchtest






11/21/47

ID Relay Failure

CHARTER GRAPHIC CONTROLS CORPORATION SUSSALD, NEW YORK

EVENT # 2



12/2/97
STP - 125.002
(Failure)

SECOND
EGA FAILURE

EVENT #3

← 5:00 - 6:00 12/30/97

7.5

6

4.5

1.5 V.M.

3

1.5

0


GRAPHIC CONTROLS CORPORATION

BUFFALO, NEW YORK

EVENT #4

RECORDING CHARTS

Diesel Generator History Mechanical Governor (EG 'B')



Actions Completed

- ◆ CT / PT Evaluation
- ◆ Evaluation of Ambient Temperature
- ◆ Lube Oil Consumption
- ◆ Outage Scope Review
- ◆ Viscosity and Synthetic Oil Evaluation

Actions Completed

- ◆ Fuel Oil Delivery System
- ◆ Voltage Regulator Evaluation
- ◆ Independent Design Engineering Determination of Troubleshooting
- ◆ Design Engineering Review of Set-up Procedures

Actions Completed

- ◆ Vendor Shop Visits
- ◆ OE Review By INPO
- ◆ State of the Art Test Equipment
- ◆ Bench Tests
- ◆ No Load Frequency Tolerance
- ◆ PM Scope Review for Normal and Accelerated Testing

Operability Retesting

Mike Fowlkes

Operability Retesting RF10

- ◆ Three Maintenance Runs
- ◆ Monthly Operability Test
- ◆ Twenty-Four Hour Refueling Surveillance Test
- ◆ Load Rejection Test
- ◆ Loss of Offsite Power Test
- ◆ Integrated Safeguards Test

Operability Retesting For First Three Events

- ♦ Maintenance Runs
- ♦ Monthly Operability Test
- ♦ Load Rejection Test
(Modified to Check Loading Stability)

Operability Retesting For Fourth Event

- ♦ Maintenance Runs
- ♦ Pre-Operability Tests Per Monthly Surveillance Procedure
- ♦ Monthly Operability Test
- ♦ Load Rejection Test
- ♦ Loss of Offsite Power Test
- ♦ Semi-Annual Cold Start-Fast Load Test

Summary of Retesting Activities

- ♦ Maintenance Runs
- ♦ Monthly Surveillance Tests
- ♦ Other Surveillance Testing Per Technical Specifications

Future Plans

Bruce Williams

Planned Activities

- ♦ Expert Panel Independent Assessment - 1/19
- ♦ Part 21 Evaluation - 2/8
- ♦ Analog Governor Upgrade Evaluation
- ♦ Speed Control System Overhaul Evaluation
- ♦ Periodic Diagnostics
- ♦ Shelf Life Assessment

Summary

Steve Byrne


Summary

- + Questioned Similarity and Number of Events
- + Continue to Evaluate
 - Parts Issues
 - Vendors
 - Tech Spec Methodologies
 - Governor Upgrades
- + Established Operability

Summary

- + MR to Establish Confidence Over Time
- + History Shows DGs Very Reliable

REFUEL 10



RF - 10

SCHEDULE VS VCSNS BEST


TOTAL DURATION

(BREAKER OPEN TO BREAKER CLOSURE)

SCHEDULE-35 DAYS


VCSNS BEST-39 DAYS, 17 HOURS

34 DAYS, 5 HOURS



REVIEW OF THE 10 OBJECTIVES


- ∴ Outage Start
 - October 4, 1997
- ∴ Continue Excellence in Nuclear Safety
- ∴ Achieve Business Plan Objectives
 - Dose \leq 60 Man Rem
 - Duration \leq 35 Days
 - Cost \leq 15 Million



Safety

Nuclear Safety


- No Safety Significant Events
- Safety Over Schedule Philosophy Maintained



Safety

Industrial Safety


- Increased Safety Awareness Training
- Two Lost time Accidents
- No Contractor Lost Time Accidents



OVERTAGE EXPOSURE

- :: Projected To Be 95 ManRem
- :: Actual 170 ManRem
- :: Contributors
 - Unanticipated RCS Exposure Levels Resulting From Crud Burst
 - Elevated Dose Rates The Entire Outage
 - Emergent Snubber Testing Scope

V.C. SUMMER OUTAGE HISTORY



1996 TOP 11


US RETAILING OUTAGE DURATIONS


PLANT UTILITY VENDOR DURATION

Bethlehem 2	PECO	CEC	21
South Texas 1	SUL&P	W	22
Cimarrick 1	PECO	CEC	25
Point Beach 1	WEPCO	W	25
Dobinson	CP&L	W	27
North Anna 1	Virginia Power	W	29
Cahoway	Union Electric	W	30
Browns Ferry 2	TVA	CEC	31
Armco	ES	CEC	33
Coors Creek 1	CE&I	CEC	33
Sbury 2	Virginia Power	W	33

Refueling Outage Duration

Source: TDM Analysis






OUTLINE OF COSTS


Business Plan Goal of \leq 15 Million


- ∴ RF 10 Actuals Approximately
12.8 Million

RF10 Financial Performance

Actuals to date vs. Revised Budget




- 
- Snubber Removal and Inspection
 - Inspections of 'C' Steam Generator
 - Preventative & Corrective Maintenance
 - Outage Improvement Modifications
 - CRDM Ring Duct
 - Fuel Handling Machine Upgrade
 - Thermo-Lag Elimination



Scribblers


- :: Snubber Reduction
- :: Tech Spec Inspection



Snubbers (con't)


Problems Found

- Increased Drag on Snubber Reduction Components**
- Evidence of Fretting Corrosion**
- Evidence of Transients**
 - * RHR
 - * Feedwater
 - * Blowdown
 - * Pressurizer Spray



RESULTS

- ∴ Significantly increased # of Snubbers to be tested (411)
 - 44 Were Degraded
 - 29 Failures
- ∴ Ongoing evaluation in process




CONDENSER TUBE SHEET REPAIRS

↳ Cleaning Methodology

- Shot Gun Blast
- Standard Lancing

↳ Corrective Action

- Re-roll all tubes in Water Box 1



RF'10 ENHANCEMENTS

- **Teamwork and Communication**
- **Use of OPS Windows Managers**
- **Manageable Plant Modification Scope**
- **Pre-Outage Task Reviews**
- **Resource Sharing (SBU and SCE&G)**

SUMMARY

- » Station conducted a good, safe outage
- » Resolved a number of long-standing equipment/reliability issues