


LTS PROGRAM
CONFIRMATORY ANALYSIS
OF SONGS 1
PIPING AND PIPE SUPPORTS

M. J. Russell

Published June 1986

EG&G Idaho, Inc.
Idaho Falls, Idaho 83415

Prepared for the
U.S. Nuclear Regulatory Commission
Washington, D.C. 20585
Under DOE Contract No. DE-AC07-76ID01570
FIN No. A6808



ABSTRACT

A series of confirmatory piping and pipe support analyses have been performed to ensure that the criteria and methodology employed by Southern California Edison Company (the licensee) in seismically upgrading the San Onofre Nuclear Generating Station, Unit 1 (SONGS 1), are acceptable. Four piping systems--SI-51, SI-04, SI-158, and a run of SI-51 tubing--were subjected to confirmatory finite element analysis. These analyses were performed to the requirements of the USNRC Systematic Evaluation Program (SEP) guidelines and current industry practice. In addition, the run of tubing was subjected to a confirmatory hand calculation. Supports for the SI-51 and SI-04 systems, a total of 50 supports, were also analyzed. Results of the confirmatory finite element analyses were compared with those of the licensee. Results were compared for the tubing between the finite element analysis and the hand calculation. The conclusion was drawn that the criteria and methodology employed by the licensee in analyzing the piping and pipe supports of SONGS 1 meet the requirements and are acceptable.

ACKNOWLEDGMENTS

This report is a product of the efforts of several people.

S. L. Morton wrote the first draft of the report and did much of the piping analysis. Much of the pipe support analysis was done by V. B. Call and C. Edgar. B. J. Quintana provided invaluable technical assistance.

CONTENTS

ABSTRACT	11
ACKNOWLEDGMENTS	111
1. INTRODUCTION	1
2. PIPING SYSTEM DESCRIPTION	2
3. PIPING SYSTEM SEISMIC ANALYSES	3
4. PIPING ANALYSIS RESULT COMPARISONS	6
5. PIPE SUPPORT ANALYSIS RESULT COMPARISONS	13
6. CONCLUSION	15
7. REFERENCES	16
APPENDIX A--DESCRIPTION OF COMPUTER CODE	A-1
APPENDIX B--MICROFICHE OF COMPUTER OUTPUT	B-1
APPENDIX C--SMALL-SORE PIPING HAND CALCULATION	C-1
APPENDIX D--PIPING SUPPORT CALCULATIONS	D-1

FIGURES

1. Isometric of the SI-51 computer model	17
2-6. Partial isometric of the SI-51 computer model	18-22
7. Isometric of the SI-04 computer model	23
8-9. Partial isometric of the SI-04 computer model	24-25
10. Isometric of the SI-158 computer model	26
11-13. Partial isometric of the SI-158 computer model	27-29
14. Isometric of the SI-51 tubing computer model	30
15. Partial isometric of the SI-51 tubing model	31
16. North-South response spectrum for SI-51	32
17. Vertical response spectrum for SI-51	33
18. East-West response spectrum for SI-51	34

19.	North-South response spectrum for SI-04	35
20.	Vertical response spectrum for SI-04	36
21.	East-West response spectrum for SI-04	37
22.	North-South response spectrum for SI-158	38
23.	Vertical response spectrum for SI-158	39
24.	East-West response spectrum for SI-158	40
25.	North-South response spectrum for SI-51 tubing	41
26.	Vertical response spectrum for SI-51 tubing	42
27.	East-West response spectrum for SI-51 tubing	43

TABLES

1.	Pipe data and material specifications--SIS problem SI-51	44
2.	Pipe data and material specifications--SIS problem SI-04	45
3.	Pipe data and material specifications--SIS problem SI-158	46
4.	Pipe data and material specifications--SIS problem SI-51 tubing	47
5.	Pipe system valve descriptions	48
6.	Summary of first ten natural frequencies and periods of vibration--SIS model SI-51	49
7.	Summary of first ten natural frequencies and periods of vibration--SIS model SI-04	50
8.	Summary of first ten natural frequencies and periods of vibration--SIS model SI-158	51
9.	Summary of first ten natural frequencies and periods of vibration--SIS model SI-51 tubing	52
10.	Comparison of stress results for SI-51	53
11.	Comparison of stress results for SI-04	54
12.	Comparison of stress results for SI-158	55
13.	Comparison of stress ratio results for SI-51 supports	56
14.	Comparison of stress ratio results for SI-158 supports	57

LTS PROGRAM
CONFIRMATORY ANALYSIS
OF SONGS 1
PIPING AND PIPE SUPPORTS

1. INTRODUCTION

A confirmatory analysis of the piping and supports at the San Onofre Nuclear Generating Station Unit 1 (SONGS 1) was requested by the Nuclear Regulatory Commission (NRC). This analysis was performed in an effort to verify a portion of the SONGS 1 Long Term Service Seismic Reevaluation Program,^a (Reference 1) specifically, the analysis techniques utilized by the SONGS 1 piping and support analysts for the LTS Program. Three Safety Injection System (SIS) piping models and one SIS tubing model were selected to represent the wide variety of pipe sizes incorporated in the plant. The four pipe sections chosen for detailed examination were SI-51, SI-04, SI-158, and SI-51 (tubing). Emphasis was placed on modeling techniques, accuracy, loading conditions, and pipe and support stresses. This report summarizes the confirmatory analyses performed on the four models and associated supports. It also provides a comparison of results for the analyses done by EG&G and by the licensee, Southern California Edison Co.

a. Hereafter referred to as the LTS Program.

2. PIPING SYSTEM DESCRIPTION

Information pertaining to the details of these piping systems was provided by the licensee. Much of it was verified by independent line walkthroughs by the author. The information provided contained the latest as-built pipe dimensions, pipe specifications, valve weights, response spectra, seismic and thermal anchor movements, detailed pipe support drawings, and other miscellaneous data required to perform the independent piping analyses.

SIS problem SI-51 includes the piping between feedwater pumps FWS-G-3A and FWS-G-3B and the six-inch branch piping from this line to the containment sphere. Figures 1 through 6 are computer model plots defining problem SI-51. The non-safety related piping included in this analysis, shown in these computer plots, was provided to include its effects on the safety related piping. SIS problem SI-04 includes the piping between pump SIS-G-50A and feedwater pump FWS-G-3A. Computer model plots, Figures 7 through 9, describe the problem in more detail. SIS problem SI-158, seen in Figures 10 through 13, is a small model which includes six-inch piping from the containment sphere penetration B-1B to the cold leg of reactor coolant loop C. Finally, tubing problem SI-51 is defined in Figures 14 and 15. The tubing runs from flow transmitter SIS-FT-912 to valve 870E-3/4"-T57 (on the SI-51 piping).

Tables 1 through 4 list the significant pipe data and material specifications utilized in the analyses described in this summary. Design and service conditions are also included in these tables.

Various service levels were analyzed. This included deadweight, pressure, thermal expansion, thermal anchor movements, and the inertial and anchor motions due to the 0.67 g modified Housner response spectra earthquake. These analyses were performed utilizing the ASME Code Class 2 rules (Reference 2) as specified by the SEP Guidelines (Reference 3) and compared to the stresses calculated by the licensee.

3. PIPING SYSTEM SEISMIC ANALYSES

All four finite element analyses were performed using the program NUPIPE-II, a proprietary program developed by Quadrex Corporation. NUPIPE-II capabilities are briefly described in Appendix A. Idaho National Engineering Laboratory (INEL) program module V4AGINL was utilized for these analyses.

The piping system data, drawings, and response spectra necessary for these analyses were provided by the licensee. The following assumptions based on experience and engineering judgment were employed where information was missing or incomplete:

1. All components meet the dimensional requirements of the standards listed in Table NC-3132-1 of the ASME Code.
2. The requirements of the ASME Code, Section III, Subarticle NC-3640 are satisfied. This subarticle deals with ensuring adequate wall thickness of the components for the Design Pressure at the Design Temperature. Since the change in design requirements involves the seismic load case only and pressure stress has been included in the seismic analyses, an explicit check for adequate wall thickness was deemed unnecessary.
3. The only thermal mode assumed was the normal operating mode.

A summary of weight and center of gravity information for all valves on the four safety injection piping models is contained in Table 5. This table also includes the face-to-face dimension for each of the valves.

The four models were analyzed for weight, thermal expansion plus thermal anchor movements, earthquake, and seismic anchor motion (SAM) loads. All were analyzed in accordance with the SEP Guidelines (Reference 3). Details of the analyses not specified in this document were in accord with standard EG&G piping analysis practice. These details were

at a level not controlled explicitly by the regulatory process. There is one exception to this. EG&G SAM load generation methodology involves envelopment of structural motion displacements in the area of the support to obtain SAM values. These are then applied individually, with the results combined by square root of the sum of the squares (SRSS) combination. Preliminary result comparisons showed significant differences between EG&G and utility SAM stresses. This initiated an investigation to identify the source of the differences. A different SAM load generation methodology is used by the licensee. SAM values are obtained by interpolation between appropriate structural motion displacements, with either algebraic or absolute value combination of loadings depending on the location and direction of the supports. The basis for this methodology was evaluated, and it was found acceptable. There are a sufficient number of points on the structural steel model with associated SAM data to allow interpolation for support point attachment SAMs. Algebraic combination of specified directions and locations is based on a study of the motion of the buildings which concluded that these particular directions and locations move in phase. Absolute summation of the remainder is conservative. The licensee's methodology was adopted in the EG&G analyses in order to prevent the potential masking of other sources of discrepancy.

An additional analysis was done for the SI-51 tubing model. The second analysis of the SI-51 tubing was done according to the alternate calculation methodology allowed by the licensee's small-bore piping criteria. This methodology was found to predominate in the small-bore piping calculations audited. It consists of an equivalent static analysis based on a simply supported beam calculation.

PVRC damping spectra obtained from the licensee's structural analyses were appropriately enveloped for each particular piping model and used for the earthquake load case in these analyses. These enveloped response spectra curves are shown in Figures 16 through 27. The spectra were applied in all three directions simultaneously and the results were combined using the square-root sum of the squares (SRSS) method. All seismic anchor movements were applied and combined using the licensee's methodology, as discussed above.

Microfiche copies of the finite element analyses are contained in
Appendix B. The small-bore piping hand calculation is contained in
Appendix C.

4. PIPING ANALYSIS RESULT COMPARISONS

The piping finite element analyses were performed per the requirements of the SEP guidelines and the ASME Class 2 equations specified there. The results obtained from the loadings previously described were used to calculate the piping stresses. The small-bore piping hand calculation was performed using the methodology found to predominate in the audits of small-bore piping calculations. Allowable stresses, per the SEP guidelines, were 2.4Sh for the equivalent of Class 2 piping and 1.8Sh for the equivalent of Class 1 piping. Except for a small length of pipe near the reactor coolant loop, the piping analyzed is the equivalent of Class 2 piping.

Although calculated stresses were compared to allowable stresses, the focus of this work was a comparison of stresses as calculated by EG&G and the licensee to ensure that the stress calculation criteria and methodology employed by the licensee is acceptable. Some differences in methodology were found. Different techniques were initially used to combine seismic anchor motion (SAM) loads. This is discussed in detail in Section 3 of this report. The licensee's technique was found acceptable and adopted in the EG&G analyses to prevent the differences in this methodology from masking any other differences which may have existed. Other differences in methodology were found. This includes differences in valve and reducer modeling techniques and anchor point stiffness calculations. These are discussed in the following paragraphs.

As is common industry practice, all modes of vibration with natural frequencies under 33 Hz were included in the dynamic analyses. The effects of the higher frequency modes, the "missing mass effect" were automatically included in the results by the NUPIPE-II program. Tables 6 through 9 show the first ten modes of vibration for each of the piping models. The SI-51 model was calculated to have 52 natural frequencies below 33 Hz with rod hangers modeled rigidly and 50 without rod hangers. The SI-04 model displayed 42 natural frequencies under 33 Hz with rigid rod hangers and

43 without rod hangers. The SI-158 model, which has no rod hangers, had 13 natural frequencies under 33 Hz. The SI-51 tubing model exhibited 17 natural frequencies below 33 Hz.

Comparisons of stress results are presented in Tables 10 through 13. The first column of each table identifies the EG&G node point and the licensee's data point at which stresses are compared. The EG&G node point (the first number) can be used to locate the point under consideration in the plots of the models (Figures 1 through 15). The next two columns identify the type of component being analyzed and its associated stress intensification factor (SIF). The remaining six columns are divided into two sets, one for the seismic inertia plus normal operating load (SI) stress, and one for the seismic anchor motion load (SAM) stress. This separation allowed a clear identification of the source of any differences in stress results. There are three columns for each type of stress. The first is for stresses from the EG&G analysis, the second for the licensee's stresses, and the third for the percent difference between the two sets of results, with the average value used listed in the percentage column header. This type of comparison was chosen because it emphasized the most significant differences, those in the areas of maximum stress, and because it allows a comparison of results among the models.

Stress results comparisons were limited to points in the models with SIF greater than 1.0, and at support points in the straight runs of piping, since these represent local stress maxima. Due to the large size of the SI-51 model, stress results were compared only in areas of maximum stress, which were found to be in the same areas of the model in both sets of results. These areas were found in the vicinity of both feedwater pump nozzles and in the vicinity of the branch point for the west side 6-in. line running to containment. Stress result comparisons were presented for all of the SI-04 model except for nodes 5 through 60 and those nodes associated with boundary condition piping (non-safety related), where the comparison yielded identical trends to those presented. All stress result comparisons are presented for the SI-158 model.

Comparison of stress results for the SI-51 analyses shows close agreement (see Table 10). The EG&G stresses are based on as-built data and standard practice at EG&G with the following exceptions. The rod hanger support at node 145 (Figure 3) was given full credit for vertical support. Although not in agreement with the as-built condition, this reflects the licensee's decision to upgrade the rod hanger to a full vertical support (typically done by adding a bumper near the rod hanger to restrain uplift of the piping). This modification to EG&G's SI-51 model was done to obtain an identical support configuration with the licensee's model. A two element reducer model was used in the EG&G analysis, each element having the section properties of the attached piping. This is in contrast with standard EG&G practice, which is to use a single element with the section properties of the smaller of the attached pipes, and to increase the stress on the large end of the reducer to reflect the larger pressure stress there. This practice is known to be overly conservative, and the refined two element model is used at EG&G in cases where the standard model indicates an overstress.

There were also instances of EG&G common practice different from the licensee's which were not changed. In EG&G common practice, anchor stiffness is based on the associated pipe section properties, while the licensee uses a single fixed value. These are the default procedures found in the two computer analysis codes used. EG&G valve element stiffnesses are based on a factored stiffness for the equivalent piping element, while the licensee's are based on the associated pipe element with a doubled wall thickness. Valve masses are distributed differently, although the center of gravity of the valve and total mass are the same. EG&G uses a single mass for both the valve body and the operator; the licensee uses a separate mass for each. Since the valve models are included only to simulate the effect of the valves on the piping, these differences are negligible. Centerline offsets for axial supports are modeled by EG&G but not by the licensee.

Differences in common practice between EG&G and the licensee had no significant effect on the stress results, as indicated in Table 10. Extremely close agreement was obtained, with the maximum difference appearing in the area of tee components. These differences are attributed to the accumulation of the differences in stiffness along each portion of the piping that terminates at the tee.

The results of the SI-04 analyses did not compare as favorably as those for the SI-51 analyses (see Table 11). The EG&G model was strictly as-built. This resulted in two differences between EG&G's and the licensee's models. The vertical support at node 265 (Figure 9) in the EG&G model was located at the position corresponding to node 260 in the licensee's model. The reducer between nodes 335 and 340 of the EG&G model was modeled as 14 in. long in the EG&G model, and 7 in. long in the licensee's model. In both cases, the EG&G model was closer to the as-built configuration, but both variations in the licensee's models were within IE Bulletin 79-14 tolerances. The same differences in common practice found in the SI-51 models were also found. Reducer model refinements made in EG&G's SI-51 analysis were not made in the SI-04 analysis.

Since the differences in stress results for the SI-04 analyses were larger than those for the SI-51 analyses, an attempt was made to isolate the cause. The EG&G SI-04 model was modified to duplicate the licensee's support configuration, valve and reducer models, and anchor stiffnesses. Stress results from analysis of the modified model were compared with no improvement seen. The location of stress variation was different, but the degree and number of variations were the same. The models were closely compared and found to be as near to identical as could be obtained using different analysis computer codes.

The source of differences in stress results was found in a contrast between the SI and SAM stress comparisons for the SI-04 analyses. The agreement in stresses is much better for the SAM load. This indicates that the discrepancies affect the dynamic analyses more strongly than the static analyses. Differences in SAM stress greater than 10% occur only in

reducers and elbows. This is not anomalous for the reducers, which are modeled differently, but it indicates that elbow element stiffness formulations differ slightly. The effect of this small variation is negligible for the static (SAM) analyses, but can be significant in the dynamic (SI) stress results. Such variations would have little effect on the calculation of the lower frequency modes of vibration, which are more accurately defined than the higher frequency modes in dynamic analysis. This characteristic makes the effect of minor variations in elbow stiffness on stress results dependent on the frequency content of the response spectra used in the dynamic analysis. Response spectra with relatively more excitation in the low frequencies, such as the SI-61 spectra, generate resultant stresses with larger contribution from the low frequency modes. The effects of the elbow stiffness variation are attenuated, and the stresses compare closely. The SI-04 spectra, having relatively less low frequency excitation, generate resultant stresses with relatively more contribution from the higher frequency modes. The effect of the elbow stiffness variation is emphasized, and the stress comparison is less favorable.

The existence of small variations in elbow stiffness formulation is not particularly harmful in seismic analysis, because the effects of the variation are concentrated in the calculation of the higher frequency response. Seismic events are essentially low frequency events, a result of the fact that high frequency motion is rapidly attenuated in transmission through the ground. Large seismic stresses are therefore associated with low frequency response, where the variation in elbow stiffness is not significant. This can be seen in a comparison between the maximum stresses calculated in the SI-61 and SI-04 analyses. The average maximum SI-61 analysis stress, which is in the range of the SEP guidelines allowable stress, is 2.6 times larger than the SI-04 average maximum stress.

A comparison of stresses for the SI-158 analyses are presented in Table 12. Good agreement is indicated. These results compliment the conclusions drawn in the discussion of the SI-61 and SI-04 results.

For an overall comparison, the differences in stress for all entries of Tables 10 through 13 were averaged for the seismic inertia and SAM stresses. On the average, EG&G seismic inertia stresses were 1.0 ksi higher, and the SAM stresses differed by less than 0.1 ksi. The difference in seismic inertia stress can be attributed to differences in spectral definition. EG&G spectra were limited to 30 points, while the licensee's spectra contained 160 points. In performing the reduction, envelopment criteria were imposed, which would result in a marginally higher stress calculated using the reduced spectra.

A comparison between finite element calculated stresses and allowable stresses showed the EG&G analyses and the licensee's analyses to be in exact agreement in terms of a conclusion of adequacy. SI-04 and SI-158 are acceptable with good margin. SI-51 had two components with stresses that exceeded allowable stresses. Both were reducers located on the discharge side of the feedwater pumps. This indicates that the licensee's criteria and methodology produce comparable results to those of the SEP guidelines. Supports have been added to the SI-51 piping to reduce stresses to acceptable levels.

A comparison between stresses calculated for the SI-51 tubing model using finite element analysis and hand calculations showed the hand calculation to be conservative. The maximum finite element analysis stress was 14.5 ksi, versus a hand calculated maximum stress of 71.8 ksi. According to the hand calculation, the tubing is severely overloaded. According to the finite element analysis (which is more accurate, and hence controls the conclusion concerning adequacy of the tubing), the tubing is acceptable to the SEP guideline limits with large margin.

Based on the detailed comparison of the results of three piping system finite element analyses, the criteria and methodology used by the licensee in analyzing piping were found to be in keeping with the SEP guidelines and current industry practice and are acceptable. The comparison of the confirmatory finite element analysis for the tubing with the confirmatory

hand calculation showed the hand calculation to be conservative and acceptable.

S. PIPE SUPPORT ANALYSIS RESULT COMPARISONS

Pipe support analyses were performed per the requirements of the SEP guidelines and current industry practice. Hand calculations were predominately used. Nominal stresses were calculated based on the loads supplied by the confirmatory piping analyses and nominal member section properties. Loads on catalog components were compared to vendor supplied allowable loads. Detailed finite element stress analyses were used in cases not amenable to hand calculation. Weight and thermal loads were considered for normal operating loads. Thermal loads were included only if they increased the resultant stress. Seismic inertia and seismic anchor motion loads were combined by the square root of the sum of the squares method, and then added and subtracted to the normal operating loads to obtain the range of loads used in calculating the seismic stress. In cases where the support geometry or loading was too complex for hand analysis, detailed finite element stress analyses were performed. The resulting stresses were compared to allowable stresses defined in the SEP guidelines.

All supports on safety related piping of the SI-51 and SI-04 models were analyzed. Since this led to the analysis of some 50 supports, analyses of the SI-04 supports were not performed. The analyses are contained in Appendix D. The supports for the SI-51 and SI-158 piping were then ranked according to decreasing stress ratio. The stress ratio for a support is defined to be the maximum ratio of calculated to allowable stress for all components of the support. Hence the support with the highest stress ratio is the most highly loaded relative to its allowable load. The licensee was requested to similarly rank the supports of both systems and to identify the supports with the largest stress ratio. For each piping system, the five supports with the largest stress ratio according to the EG&G analyses and the five according to the licensee's analyses were merged into a list. The lists were reviewed and found to contain a representative sample of the types of components found in pipe supports. The calculations supporting the stress ratios appearing on both lists were then subjected to a detailed comparison. The purpose of the comparison was to determine if the criteria and methodology applied by the licensee were acceptable.

Results of the comparison between support calculations are presented for the SI-51 piping supports in Table 13, and for the SI-158 supports in Table 14. Several differences in stress ratio were found, as indicated and discussed in the tables. No application of unacceptable criteria or methodology was found. Supports identified as overloaded by the EG&G analysis had either been forwarded to the support design group for modification, or shown to be acceptable by analysis of an improved support configuration. As noted in Section 4 of this report, supports were added to the SI-51 piping to reduce loads on the feedwater pump nozzles. Loads used in the licensee's support analyses were taken from the analysis of the piping with the improved support configuration. In some cases, the presence of added supports reduced loads on nearby supports, so that some of the supports identified as unacceptable in the EG&G analysis were shown acceptable under the reduced loading in the licensee's analysis.

Based on detailed comparison of the results of 14 supporting analyses, the criteria and methodology used by the licensee in analyzing pipe supports were shown to be in keeping with the SEP guidelines and current industry practice and are acceptable.

6. CONCLUSION


Four confirmatory finite element analyses and one confirmatory hand calculation were performed for piping systems. Pipe supports of two of the systems were subjected to confirmatory analysis. Results of the confirmatory analyses were compared to corresponding results of the licensee's analyses. The confirmatory hand calculation results were compared to the results of a confirmatory finite element analysis. Based on the comparisons, the licensee's criteria and methodologies for analyzing piping and pipe supports were found in keeping with the SEP guidelines and current industry practice and are acceptable.

7. REFERENCES

1. Letter, H. Thompson (NRC) to K. Baskin (SCE), dated September 19, 1985, Subject: Long Term Service (LTS) Seismic Criteria and Methodology - San Onofre Nuclear Generating Station, Unit I.
2. American Society of Mechanical Engineers, ASME Boiler and Pressure Vessel Code, Section III, Division 1, "Nuclear Power Plant Components," Subsection NC, 1980 Edition, Winter 1980 Addenda.
3. Letter, W. Paulson (NRC) to R. Deitch (SCE), dated September 20, 1982, Subject: SEP Topic III-6, Seismic Design Considerations, Staff Guidelines for Seismic Evaluation Criteria for the SEP Group II Plants - Revision 1.


LEGEND

- / - NODE LOCATION
 - ◎ - HIGHLIGHT POINT LOCATION
 - - SPRING HANGER
 - - SHUDDER
 - - RIGID SUPPORT
 - - ANCHOR
 - - ELASTIC JOINT
 - - FLEXIBLE ANCHOR
 - - VALVE




ROTATION ABOUT Y-AXIS * 45.4 DEG.
 X-Z PLANE TILT * 45 DEG.

Figure 1. Isometric of the SI-51 computer model.



LEGEND

- / - NODE LOCATION
- - MASSPOINT LOCATION
- - SPRING HANGER
- - SHUDDER
- - RIGID SUPPORT
- - ANCHOR
- * - ELASTIC JOINT
- - FLEXIBLE ANCHOR
- - VALVE




ROTATION ABOUT Y-AXIS * 49.4 DEG.
X-Z PLANE TILT * 45 DEG.

Figure 2. Partial isometric of the SI-51 computer model.

* * LEGEND * *

- - - MODE LOCATION
- - - MASSPOINT LOCATION
- ~~~~ - SPRING HANGER
- - SHUDDER
- SP - RIGID SUPPORT
- - - ANCHOR
- * - ELASTIC JOINT
- - - FLEXIBLE ANCHOR
- - VALVE



Continued on
Figure 2



Continued on Figure 4

Figure 3. Partial isometric of the SI-51 computer model.

••LEGEND••

- NODE LOCATION
- - HANGPOINT LOCATION
- 4 \ \ \ / - SPRING HANGER
- H --- H - SHUBUR
- 4 --- | - RIGID SUPPORT
- ||| - ANCHOR
- * - ELASTIC OBJECT
- F - FLEXIBLE ANCHOR
- W O W - VALVE

Continued on Figure 5




ROTATION ABOUT Y-AXIS = 46.4 DEG.
X-Z PLANE TILT = 46 DEG.

Continued on
Figure 3

Figure 4. Partial isometric of the SI-51 computer model.

--LEGEND--


- / - NODE LOCATION
- - MASSPOINT LOCATION
- >---> - SPRING HANGER
- H---H- - SHUBBER
- <->- - RIGID SUPPORT
- |---| - ANCHOR
- * - ELASTIC JOINT
- ><->- - FLEXIBLE ANCHOR
- - VALVE



SONGS I SI-51 ANALYSIS (ENDPNT. HORIZ. S
NUPIPE MATHEMATICAL MODEL (V 1.6)

LEGEND

- / - NODE LOCATION
- - MASSPOINT LOCATION
- ~~~~ - SPRING HANGER
- - SHUDDER
- |— - RIGID SUPPORT
- +— - ANCHOR
- * - ELASTIC JOINT
- - FLEXIBLE ANCHOR
- o— - VALVE



ROTATION ABOUT Y-AXIS = 45.4 DEG.
X-Z PLANE TILT = 46 DEG.





Figure 6. Partial isometric of the SI-51 computer model.




23

SONGSI SAFETY INJECTION SYSTEM SI-04 W 1
NUPIPE MATHEMATICAL MODEL IV .81

LEGEND

- NODE LOCATION
- - MASSPOINT LOCATION
- △VVV - SPRING HANGER
- - SHUDDER
- - RIGID SUPPORT
- - ANCHOR
- * - ELASTIC JOINT
- - FLEXIBLE ANCHOR
- - VALVE



ROTATION ABOUT Y-AXIS * 45.4 DEG.
 X-Z PLANE TILT * 45 DEG.

Figure 7. Isometric of the SI-04 computer model.

* * LEGEND * *

- NODE LOCATION
 - - MASSPOINT LOCATION
 - - SPRING HANGER
 - H — - SHUDDER
 - - RIGID SUPPORT
 - - ANCHOR
 - * - ELASTIC JOINT
 - - FLEXIBLE ANCHOR
 - - VALVE


MUTATION ABOUT Y-AXIS * 45.4 DEG.
 X-Z PLANE TILT * 45 DEG.

Continued on
Figure 9

Figure 8. Partial isometric of the SI-04 computer model.


LEGEND

- / - NODE LOCATION
- - EQUIPMENT LOCATION
- ~~~~ - SPRING HANGER
- |||| - SHRUBBER
- |-| - RIGID SUPPORT
- || - ANCHOR
- * - BLAST JOINT
- |- - FLEXIBLE ANCHOR
- |-o- - VALVE



52


Point A



ROTATION ABOUT Y-AXIS + - 44.0 DEG.
X-Z PLANE TILT * - 46 DEG.


Figure 9. Partial isometric of the SI-04 computer model.

**SONGS I SI-158 PIPE STRESS CALCULATION X
NUPIPE MATHEMATICAL MODEL (V 1.0)**



* * LEGEND * *


- NODE LOCATION
 -  - MASSPOINT LOCATION
 -  - SPRING HANGER
 -  - SHUBBER
 -  - RIGID SUPPORT
 -  - ANCHOR
 -  - ELASTO JOINT
 -  - FLEXIBLE ANCHOR
 -  - VALVE



ROTATION ABOUT Y-AXIS = 46.4 DEG.
 X-Z PLANE TILT = 45 DEG.


Figure 10. Isometric of the SI-158 computer model.

Continued on Figure 12



LEGEND

- / - NODE LOCATION
- - MASSPOINT LOCATION
- △VVV - SPRING HANGER
- H - SHUDDER
- | - RIGID SUPPORT
- E- - ANCHOR
- * - ELASTIC JOINT
- E- - FLEXIBLE ANCHOR
- WOB - VALVE



ROTATION ABOUT Y-AXIS + 45.4 DEG.
X-Z PLANE TILT + 45 DEG.


Figure 11. Partial isometric of the SI-158 computer model.

**SONGS I SI-100 PIPE STRESS CALCULATION W
HUPIPE MATHEMATICAL MODEL. (V 1.6)**

• • LEGEND • •

- NODE LOCATION
 - - HASUPPORT LOCATION
 - 4\W\W - SPRING HANGER
 - H - SNUBBER
 - ← - RIGID SUPPORT
 - - ANCHOR
 - * - ELASTO JOINT
 - - FLEXIBLE ANCHOR
 - - VALVE


ROTATION ABOUT Y-AXIS γ 45.4 DEG.
 X-Z PLANE TILT ρ 45 DEG.




Continued on
Figure 11

Figure 12. Partial isometric of the SI-158 computer model.

Continued on
Figure 12



LEGEND	
/	- NODE LOCATION
○	- HANGPOINT LOCATION
~~~~~	- SPRING HANGER
H---	- SHUDDER
----	- RIGID SUPPORT
—	- ANCHOR
*	- ELASTIC JOINT
-E-	- FLEXIBLE ANCHOR
oval	- VALVE




ROTATION ABOUT Y-AXIS     * 45.4 DEG.  
X-Z PLANE TILT           * 45 DEG.

Figure 13. Partial isometric of the SI-158 computer model.

• • • E G E R D • •

- NODE LOCATION
  - - HASSPPOINT LOCATION
  - 4 \ \ \ \ - SPRING HANGER
  - 1 \ \ \ \ - SHUBBER
  - 4 — - RIGID SUPPORT
  - E - ANCHOR
  - * - ELASTO JINT
  - E - FLEXIBLE ANCHOR
  - - VALVE



NOTATION ABOUT Y-AXIS      + 45.4 DEG.  
 X-Z PLANE TILT      + 45 DEG.



Flow transmitter  
SIS-FI-912

FRANE NO. 2-00

Figure 14. Isometric of the SI-51 tubing computer model.

**LEGEND**

- / - NODE LOCATION
- - HANGPOINT LOCATION
- ~~~~ - SPRING HANGER
- - SHRUBBER
- - RIGID SUPPORT
- - ANCHOR
- * - ELASTIC JOINT
- - FLEXIBLE ANCHOR
- - VALVE



ROTATION ABOUT Y-AXIS * 46.4 DEG.  
X-Z PLANE TILT - 46 DEG.

Figure 15. Partial isometric of the SI-51 tubing computer model.




Figure 16. North-South response spectrum for Site 51.

I - TYPE




Figure 17. Vertical response spectrum for SI-51.




Figure 18. Fast-West response spectrum for S1-51.

# I TYPE




Figure 19. North-South response spectrum for SI-04.




Figure 20. Vertical response spectrum for SI-04.

# 1 TYPE I




Figure 21. East-West response spectrum for S1-04.

# 1 TYPE




Figure 22. North-South response spectrum for SI-158.




Figure 23. Vertical response spectrum for SI-158.




Figure 24. East-West response spectrum for SI-150.




Figure 25. North-South response spectrum for SI-51 tubing.




Figure 26. Vertical response spectrum for SI-51 tubing.




Figure 27. East-West response spectrum for SI-51 tubing.

TABLE 1. PIPE DATA AND MATERIAL SPECIFICATIONS--SES PROBLEM SI-51

Line number	6006-6-150IR 6007-6-150IR 6008-6-150IR	319-12-EG 320-12-EG	6004-14-150IR 6005-14-150IR	319-10-EG 320-10-EG
OD (inches)	6.625	12.75	14.0	10.75
Thickness (inches)	0.432	0.687	0.58	0.593
Weight ^a (lb/ft)	39.86	140.12	139.27	101.97
Material	A312, TP-316	A106-B	A312, TP-316	A106-B
E _{cold} (10 ⁶ psi)	28.3	27.9	28.3	27.9
S _b (psi)	18800	15000	18800	15000
Design temperature (°F)	120	340	120	340
Operating temperature (°F)	120	340	120	340
Design pressure (psi)	900	1350	900	1350
Operating pressure (psi)	900	1350	900	1350

a. Includes weight of pipe, contents, and insulation.

TABLE 2. PIPE DATA AND MATERIAL SPECIFICATIONS--SIS PROBLEM SI-04

Line number	6002-16-151R	318-14-GG	338-8-GG
OD (inches)	16.0	14.0	8.625
Thickness (inches)	0.375	0.375	0.322
Weight ^a (lb/ft)	141.68	122.38	50.24
Material	A312, TP-304	A53-B	A53-B
$E_{cold}$ ( $10^6$ psi)	28.3	27.9	27.9
$S_h$ (psi)	18600	15000	15000
Design temperature (°F)	120	340	95
Operating temperature (°F)	120	340	95
Design pressure (psi)	140	360	360
Operating pressure (psi)	140	360	360

a. Includes weight of pipe, contents, and insulation.

TABLE 3. PIPE DATA AND MATERIAL SPECIFICATIONS--SIS PROBLEM SI-158

Line number	6007-6-1501R	6007-6-2501R
OD (inches)	6.625	6.625
Thickness (inches)	0.432	0.718
Weight ^a (lb/ft)	39.86	60.46
Material	SA312, TP-316	SA312, TP-316
$E_{cold}$ ( $10^6$ psi)	28.3	28.3
$S_h$ (psi)	18800	18800
Design temperature (°F)	120	570
Operating temperature (°F)	120	570
Design pressure (psi)	900	900
Operating pressure (psi)	900	900

a. Includes weight of pipe, contents, and insulation.

TABLE 4. PIPE DATA AND MATERIAL SPECIFICATIONS--SIS PROBLEM SI-51 TUBING

OD (inches)	0.375
Thickness (inches)	0.049
Weight ^a (lb/ft)	0.2
Material	316 SST
$E_{cold}$ ( $10^5$ psi)	28.3
$S_h$ (psi)	18800
Design temperature (°F)	120
Operating temperature (°F)	120
Design pressure (psi)	900
Operating pressure (psi)	900

a. Includes weight of pipe, contents, and insulation.

TABLE 5. PIPING SYSTEM VALVE DESCRIPTIONS

<u>Model</u>	<u>Valve</u>	<u>Weight (lb_f)</u>	<u>Face-to-Face Dimension (in.)</u>
SI-51	HV851A & B	2960/2338 ^a	35
	HV852A & B	2160/2338	33
	12-600-222	1463/-	33
SI-04	862-12-C42	750/-	27.5
	HV-853A	2550/1275	33
	HV-854A	2210/1105	30
	14-300-488	1473/737	32.5
	861A-16-G42	1053/527	16
SI-158	MOV-850C	801/393	21
	867C-6-C58	259/-	17
SI-51 Tubing	870E-3/4"-T5	5/-	5
	SIS-FT-912 iso valve	9/0	2

a. The first number is the weight of the valve body and the second is the weight of the valve stem.

TABLE 6. SUMMARY OF FIRST TEN NATURAL FREQUENCIES AND PERIODS OF VIBRATION--SIS MODEL SI-51

Mode	W Rods		W/O Rods	
	f (Hz)	T (second)	f (Hz)	T (second)
1	4.739	0.211	4.455	0.225
2	5.518	0.181	5.147	0.194
3	5.794	0.173	5.794	0.173
4	7.731	0.129	6.111	0.164
5	8.298	0.121	7.645	0.131
6	8.355	0.120	8.271	0.121
7	9.127	0.110	8.380	0.119
8	9.805	0.102	8.805	0.114
9	10.697	0.094	9.465	0.106
10	11.037	0.091	10.464	0.096

TABLE 7. SUMMARY OF FIRST TEN NATURAL FREQUENCIES AND PERIODS OF VIBRATION--SIS MODEL SI-04

Mode	W Rods		W/O Rods	
	f (Hz)	T (second)	f (Hz)	T (second)
1	1.024	0.977	1.024	0.976
2	3.277	0.305	3.219	0.311
3	4.545	0.220	3.639	0.275
4	5.364	0.186	4.545	0.220
5	7.209	0.139	5.364	0.187
6	7.433	0.135	7.209	0.138
7	7.585	0.132	7.437	0.134
8	8.638	0.116	7.586	0.132
9	8.968	0.112	8.638	0.116
10	9.602	0.104	8.972	0.112

TABLE 8. SUMMARY OF FIRST TEN NATURAL FREQUENCIES AND PERIODS OF VIBRATION--SIS MODEL SI-158

<u>Mode</u>	<u>f (Hz)</u>	<u>T (second)</u>
1	6.288	0.159
2	11.141	0.090
3	13.236	0.076
4	14.010	0.071
5	15.529	0.064
6	16.197	0.062
7	18.456	0.054
8	19.290	0.052
9	20.911	0.048
10	23.716	0.042

TABLE 9. SUMMARY OF FIRST TEN NATURAL FREQUENCIES AND PERIODS OF  
VIBRATION--SIS MODEL SI-51 TUBING

<u>Mode</u>	<u>f</u> (Hz)	<u>T</u> (second)
1	5.791	0.173
2	9.046	0.110
3	9.202	0.109
4	11.587	0.086
5	12.268	0.082
6	13.815	0.072
7	15.480	0.064
8	18.422	0.054
9	18.584	0.054
10	23.364	0.043

TABLE 10. COMPARISON OF STRESS RESULTS FOR SI-51

Node/EP EG&G/Licensee	Component	SIF EG&G/Licensee	Inertial Stress: Equation 9			2(SAH) Stress: Equation 10		
			Stress (ksi)		% Difference Based on Max. Stress (62.5 ksi)	Stress (ksi)		% Difference Based on Max. Stress (17.2 ksi)
			EG&G	Impell		EG&G	Licensee	
10/7	Reducer-Irg	3.000	63.9	61.1	4	9.1	9.3	1
15/10	Reducer-sm	3.000	36.5	34.9	3	5.2	5.4	1
20/25	Straight pipe	1.000	12.9	12.2	1	1.5	1.6	1
22/30	Straight pipe	1.000	12.8	12.0	1	1.5	1.6	1
30/36	Tee-run	1.427/1.426	13.9	12.9	2	2.0	2.3	2
50/45	Tee-branch	1.427/1.426	15.4	10.6	8	3.0	3.1	1
	-North run	1.427/1.426	14.4	13.2	2	3.8	3.7	1
	-South run	1.427/1.426	12.5	12.6	0	3.2	3.2	0
55/50	Reducer-Irg	2.000	15.9	12.7	5	5.0	4.8	1
60/55	Reducer-sm	2.000	15.1	12.1	5	4.5	4.2	2
830/300	Straight pipe	1.000	11.3	9.2	3	1.8	1.7	1
80/62	Straight pipe	1.500	10.5	9.5	2	2.6	2.6	0
	at branch							
95/70b	Elbow	1.000	8.2	7.2	2	2.0	1.9	1
105/76a	Elbow	1.000	8.6	8.0	1	1.9	1.8	1
110/76b	Elbow	1.000	8.3	8.6	0	2.3	2.4	1
145/105a	Elbow	1.000	8.8	8.8	0	4.3	4.4	1
180/115	Straight pipe	1.000	11.1	11.0	0	10.1	9.4	4
845/305	Straight pipe	1.000	12.7	9.8	5	1.7	1.7	0
	near valve							
850/310a	Elbow	1.848	16.3	12.2	7	4.9	4.6	2
875/325a	Elbow	1.848	14.2	10.6	6	5.2	4.4	5
885/330a	Elbow	2.423/2.421	12.2	11.0	4	3.7	3.6	1
900/910a	Elbow	1.848	10.4	10.2	0	1.8	1.6	1
915/90ba	Elbow	1.848	8.0	7.4	1	0.3	0.1	1
250/156	Branch,	2.077	13.2	11.0	4	16.5	17.8	7
	West run							
700/449	Elbow	1.643	8.8	8.7	0	17.6	16.5	6
425/260	Reducer-sm	2.000	26.4	29.2	4	5.0	5.2	1
430/265	Reducer-Irg	2.000	27.0	28.9	3	5.2	5.8	3
435/350	Tee-Branch	1.427/1.426	29.9	27.5	4	5.2	7.7	14
	-North run	1.427/1.426	21.6	22.6	2	3.8	4.5	4
	-South run	1.427/1.426	35.1	30.4	8	5.3	7.4	12
450/395	Straight pipe	1.000	18.7	17.0	3	2.4	3.0	3
660/355	Tee-branch	1.427/1.426	26.8	23.8	5	2.9	4.8	11
	-South run	1.427/1.426	26.9	24.0	5	2.9	4.5	9
675/370	Elbow	1.848	15.5	15.6	0	3.0	3.5	3
680/380	Elbow	1.848	23.3	21.7	3	4.4	4.2	1
680/380	Reducer-sm	3.000	34.0	31.8	4	7.1	6.8	2
685/382	Reducer-Irg	3.000	50.4	54.0	7	12.6	11.6	6

TABLE II. COMPARISON OF STRESS RESULTS FOR SI-04

Node/BP E&G/Licensee	Component	SIF	Inertial Stress: Equation 9			2(SAH) Stress: Equation 10		
			Stress (ksi)		% Difference Based on Max. Stress (23.85 ksi)	Stress (ksi)		% Difference Based on Max. Stress (11.05 ksi)
			E&G	Licensee		E&G	Licensee	
60/70	Straight pipe	1.000	4.4	5.1	3	0.5	0.4	1
70/80	Straight pipe	1.000	5.4	4.7	3	0.7	0.6	1
75/90	Straight pipe	1.000	4.5	3.8	3	0.6	0.6	0
85/100	Straight pipe	1.000	7.4	7.5	0	1.6	1.5	1
100/110	Straight pipe	1.000	10.4	10.5	0	0.8	0.8	0
110/120	Straight pipe	1.000	8.0	7.9	0	0.7	0.7	0
120/130	Straight pipe	1.000	12.3	12.5	1	0.6	0.6	0
130/140	Straight pipe	1.000	5.2	3.3	8	1.4	1.4	0
135/145	Elbow	3.227/3.225	11.6	7.6	17	4.8	4.9	1
140/145	Elbow	3.227/3.225	14.2	11.0	13	5.0	5.0	0
145/150	Straight pipe	1.000	7.2	5.7	6	1.6	1.6	0
150/153	Straight pipe	1.000	8.8	7.2	7	1.9	2.0	1
155/155	Elbow	3.227/3.225	19.3	15.7	15	5.8	5.5	3
160/155	Elbow	3.227/3.225	15.4	12.4	13	4.1	4.2	1
175/165	Straight pipe	1.000	23.5	16.2	31	5.5	5.4	1
190/175	Straight pipe	1.000	14.2	14.3	2	6.1	6.0	1
200/190	Straight pipe	1.000	10.5	9.2	5	1.9	1.9	0
205/200	Straight pipe	1.000	13.4	12.4	4	1.9	2.1	2
215/210	Straight pipe	1.000	6.7	7.1	2	3.9	3.8	1
220/215	Elbow	3.227/3.225	11.1	12.0	4	11.2	10.9	3
225/215	Elbow	3.227/3.225	11.9	11.6	1	8.2	7.7	5
230/220	Elbow	3.227/3.225	15.0	13.4	7	8.6	8.3	3
235/220	Elbow	3.227/3.225	14.2	12.0	9	9.1	9.2	1
250/225	Elbow	3.227/3.225	14.7	13.8	4	7.5	8.0	5
255/225	Elbow	3.227/3.225	11.7	11.2	2	6.9	7.7	7
265/230	Elbow	3.227/3.225	10.1	5.4	20	8.2	7.2	9
270/230	Elbow	3.227/3.225	9.8	5.9	16	5.6	6.8	11
285/235	Elbow	4.229/4.232	13.5	8.1	23	7.3	6.1	11
290/235	Elbow	4.229/4.232	16.8	9.2	32	6.3	6.6	3
320/245	Tee-branch	2.539/2.539	13.4	9.4	17	4.6	5.0	4
	-North run		12.5	8.9	15	4.6	5.0	4
335/247	Reducer-ing	2.000	11.5	7.0	19	3.9	3.1	7
340/247	Reducer-sm	2.000	10.2	7.2	13	3.3	3.6	3
345/255	Elbow	3.051/3.041	16.9	11.0	24	6.2	6.1	1
350/255	Elbow	3.051/3.041	19.0	13.1	25	6.3	5.8	5
360/260	Tee-branch	2.317/2.316	13.5	9.9	15	3.8	3.9	1
	-East run		14.2	11.7	10	3.6	4.0	4
	-North run		14.2	12.5	7	1.9	2.0	1
370/270	Reducer-ing	2.000	19.2	24.2	21	5.0	6.9	17
375/270	Reducer-sm	2.000	20.5	13.1	30	5.0	3.2	16
385/285	Elbow	3.051/3.041	20.9	17.0	16	3.1	2.6	5
390/285	Elbow	3.051/3.041	20.2	14.5	24	3.2	1.6	14
395/290	Elbow	3.051/3.041	14.7	10.5	18	2.9	1.8	10

TABLE 12. COMPARISON OF STRESS RESULTS FOR SI-15B

Node/DP EG&G/Licensee	Component	SIF EG&G/Licensee	Inertial Stress: Equation 9			2(SAH) Stress: Equation 10		
			Stress (ksi)		% Difference Based on Max. Stress (13.1 ksi)	Stress (ksi)		% Difference Based on Max. Stress (6.75 ksi)
			EG&G	Licensee		EG&G	Licensee	
5/1000	Straight pipe	1.000	5.5	6.0	4	2.2	3.1	13
20/1030	Straight pipe	1.000	4.4	3.6	6	0.2	0.2	0
35/1090	Straight pipe	1.000	5.1	4.3	6	0.8	1.0	3
40/1100	Straight pipe	1.000	4.9	4.1	6	1.0	1.1	1
45/C108	Elbow	1.643	4.4	3.8	5	0.8	0.6	3
50/C10A	Elbow	1.643	4.2	3.6	5	0.6	0.6	0
55/C98	Elbow	1.643	4.1	3.3	6	1.0	1.5	7
60/C9A	Elbow	1.643	4.3	3.4	7	1.2	2.0	15
70/C8B	Elbow	1.643	4.2	3.4	6	1.6	1.2	6
75/C8A	Elbow	1.643	4.2	3.5	5	1.2	0.9	4
80/C7B	Elbow	1.643	4.2	3.6	5	0.8	1.0	3
85/C7A	Elbow	1.643	4.2	3.8	3	0.8	1.6	12
95/C6B	Elbow	1.643	4.3	4.0	2	1.2	1.1	1
100/C6A	Elbow	1.643	4.2	3.9	2	1.2	1.1	1
105/1270	Straight pipe	1.000	4.1	3.6	4	0.8	0.6	3
115/1290	Straight pipe	1.000	4.0	3.7	2	0.6	0.8	3
120/1320	Straight pipe	1.000	4.2	4.4	2	1.2	1.2	0
125/C5B	Elbow	1.000	4.3	4.4	1	1.2	1.2	0
130/C5A	Elbow	1.000	4.5	4.4	1	1.4	1.3	1
135/1360	Straight pipe	1.000	4.6	4.8	2	2.0	1.7	4
140/1350	Run & branch	1.500/2,100 ^a	5.2	6.2	8	3.4	4.2	12
145/C4B	Elbow	1.643	5.6	5.7	1	4.0	3.6	6
150/C4A	Elbow	1.643	5.9	6.4	4	4.6	4.2	6
155/1430	Straight pipe	1.000	5.5	6.2	5	3.0	2.6	6
160/1440	Straight pipe	1.000	5.5	5.9	3	3.0	2.6	6
165/1460	Straight pipe	1.000	4.9	5.3	3	1.8	1.9	1
195/C3B	Elbow	1.643	6.2	7.0	12	8.1	6.8	19
200/C3A	Elbow	1.643	5.7	6.1	18	7.0	6.5	7
205/V2C	Straight pipe	1.000	5.7	7.5	14	3.8	3.7	1
230/1700	Elbow	1.099	9.2	10.6	11	3.8	2.7	16
235/1704	Elbow	1.099	9.6	10.9	10	4.0	2.8	18
235/1705	Elbow	1.099	9.6	11.3	13	4.0	2.9	16
240/1706	Elbow	1.099	10.0	12.5	19	4.6	3.2	21
250/1717	Straight pipe	1.000	12.7	13.5	6	4.0	2.8	18

a. The EG&G analyst assumed a full penetration weld in place below the fillet weld per common nuclear grade weld practice. The Licensee's analyst conservatively assumed that only the visible weld could be credited. This led to the difference in SIF.

TABLE 13. COMPARISON OF STRESS RATIO RESULTS FOR SI-51 SUPPORTS

Support ID	Type	Node/DP	Component	Stress Ratio		
				EG&G	Licensee	Notes
SI-05-0320-H013	snubber	22/30	anchor bolt	1.6	--	1
SI-05-6005-H006	strut	260/157	clamp	0.3	0.9	2
SI-02-6005-H005	snubber	375/225	snubber	1.8	1.8	3
SI-06-6005-H004	snubber	380/230	clamp	1.8	1.0	4
SI-06-0319-H007	snubber	485/537	anchor bolt	2.0	0.9	5
SI-05-0320-H017	spring hanger	855/310	spring hanger	0.86	0.87	
SI-05-0320-H011	snubber	861-315	anchor bolt	0.64	0.96	6

1. The supports added to SI-51 made the snubber unnecessary and it was removed.
2. Based on the shape and dimensions recorded in the field, the EG&G analyst concluded the clamp was part of the snubber assembly originally installed. The licensee's analyst made note of the discrepancy, but used the load rating for the clamp associated with the strut assembly that replaced the snubber. This was conservative.
3. The support had been turned over to the licensee's design group for modification to increase load capacity.
4. The EG&G analyst used the published catalog load rating. The licensee's analyst contacted the manufacturer and obtained an increased load rating for the clamp.
5. Supports added to the piping in the vicinity of this support reduced the loads on it to acceptable levels.
6. Supports added to the piping in the vicinity of this support increased its loads.

TABLE 14. COMPARISON OF STRESS RATIO RESULTS FOR SI-158 SUPPORTS

Support ID	Type	Node/DP	Component	Stress Ratio		
				EG&G	Licensee	Notes
SI-01-6007-H005	strut	35/1090	clamp	0.23	0.21	
SI-01-6007-H301	guide	105/1270	baseplate	0.70	0.96	1
SI-01-6007-H00E	snubber	155/1430	baseplate	0.33	0.34	
SI-01-6007-H00D	snubber	160/1440	baseplate	0.52	0.39	2
SI-01-6007-H000	snubber	165/1460	anchor bolts	0.29	0.93	3
SI-01-6007-H008	spring hanger	180/1500	spring hanger	0.78	0.79	
SI-01-6007-H00A	spring hanger	240/1710	spring hanger	0.72	0.58	4

1. The EG&G analyst did a finite element analysis, the licensee's analyst a simple beam calculation. Both are acceptable.

2. The EG&G analyst did a simple beam calculation, the licensee's analyst a finite element analysis. Both are acceptable.

3. The licensee's analysis was based on factoring the results of a previous analysis to account for different loads. In the previous analysis support loads had been increased to account for the possibility of support dynamic response. Current criteria ensure support rigid response, so that support loads need not be increased.

4. Different hot loads were used. EG&G's hot load was based on design drawings, because the hot load hanger setting was not recorded during walkdown. The licensee's load was based on the current setting.

APPENDIX A

DESCRIPTION OF COMPUTER CODE

C

## APPENDIX A

### COMPUTER PROGRAM DESCRIPTION

The NUPIPE-II computer program performs linear elastic analysis of three-dimensional piping systems subject to thermal, deadweight, seismic, and other static and dynamic loads. The NUPIPE-II program is also designed to perform stress and fatigue analyses in accordance with the ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, 1974 Edition through the Summer 1975 Addenda; and the ANSI B31.1 Code, 1967 and Summer 1973 versions. NUPIPE-II may also be utilized to assure compliance with later piping code requirements provided the analyst takes into consideration any possible changes. Piping systems of more than one classification can be analyzed.

NUPIPE-II utilizes the finite element method of analysis with special features incorporated to accommodate specific requirements of piping system analysis. In accordance with the finite element method, the continuous piping is mathematically idealized as an assembly of elastic structural members connecting discrete nodal points. Nodal points are placed in such a manner as to isolate particular types of piping elements, such as straight runs of pipe, elbows, valves, etc., for which force-deformation characteristics can be categorized. Nodal points are also placed at all discontinuities, such as piping supports, concentrated weights, branch lines, and changes in cross-section. System loads such as weights, equivalent thermal forces, and earthquake inertia forces are applied at the nodal points. For the deadweight and dynamic time-history and response spectra analyses, distributed weight properties of the piping as well as concentrated weights, such as valves, pumps, or snubbers, can be considered. A lumped mass model of the piping system is used for all dynamic analyses. Both translational and rotational degrees-of-freedom may be considered.

For further information concerning NUPIPE-II capabilities or analytical procedures, contact Applied Mechanics Branch of EG&G Idaho, Inc.

APPENDIX B

MICROFICHE OF COMPUTER OUTPUT

NOTE: MICROFICHE OF COMPUTER OUTPUT  
(PAGES B-2 TO 5) ARE AVAILABLE  
IN THE PUBLIC DOCUMENT ROOM and  
LOCAL PUBLIC DOCUMENT ROOM

From Page B2 To

B5 - are

Micrfiche

Eqn 1 Calculation

$$1) M_a = [M_x^2 + M_y^2 + M_z^2]^{1/2} \quad (\text{axial moment})$$

$$2) M_b = [M_x^2 + M_y^2 + M_z^2]^{1/2} \quad (\text{torsional moment})$$

$$3) \text{Seismic stress} = \frac{75(\text{SF})(M_a + M_b)}{(1000)\pi}$$

4) Total = pressure + seismic

Eqn 10 calculation

$$1) M = [M_x^2 + M_y^2 + M_z^2]^{1/2}$$

$$2) \text{Stress} = \frac{(\text{SF})M}{(1000)\pi}$$

Calculation of stresses where SF is not  
SF couldn't be specified correctly.

$\lambda^2/\lambda'$	$\rho_w$	$t_n$	$\rho_y$	$\alpha_{y1}, \alpha_{y2}$	$\alpha_1, \alpha_2$	$\text{IXF}$	$\text{IXF}$	$\text{stress calc.}$
10	10.75	0.543	131612	0.001	0.001	171647	3.0	115.54
$t_s$	12.35	0.687	120461	0.001	0.001	160549	3.0	114.6
3.5	12.75	0.687	119111	0.001	0.001	193266	2.0	114.6
6.0	14.00	0.680	119111	0.001	0.001	176591	2.0	114.6
9.2	17.00	0.580	154074	0.001	0.001	204932	2.0	116.7
9.4	17.35	0.687	154074	0.001	0.001	215541	2.0	116.7
$t_{\text{so}}$	17.75	0.687	160781	0.001	0.001	41925	1.0	114.6
$t_{\text{sh}}$	19.75	0.543	174216	0.001	0.001	206670	1.0	115.54

ST-51	Reducer	Eg. 9	Stress	Ca/C	Stress		Tensile								
					MPa	MPa									
10	102.5	0.143	1136.2	1109.6	1007.01	618.256	881.976	2476.71	112395.9	1.0	45.54	6.12	60.48	66.6	
15	127.0	0.187	1155.3	1106.6	904.00	5782.04	7201.36	2477.61	9470.95	1.0	34.6	6.24	31.97	38.2	
25	173.0	0.233	1166.7	1165.6	2139.0	3101.2	1836.75	2680.82	2310.21	4235.44	2.0	74.6	6.24	9.26	15.5
40	240.0	0.300	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
60	360.0	0.400	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
90	540.0	0.500	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
120	720.0	0.600	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
150	900.0	0.700	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
170	112.5	0.800	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
172.5	122.5	0.857	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
175	127.0	0.911	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
177.5	132.5	0.957	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
180	137.0	1.000	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
182.5	142.5	1.043	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
185	147.0	1.087	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
187.5	152.5	1.131	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
190	157.0	1.174	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
192.5	162.5	1.217	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
195	167.0	1.261	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
197.5	172.5	1.304	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
200	177.0	1.347	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
202.5	182.5	1.391	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
205	187.0	1.434	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
207.5	192.5	1.477	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
210	197.0	1.520	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
212.5	202.5	1.563	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
215	207.0	1.606	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
217.5	212.5	1.649	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
220	217.0	1.692	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
222.5	222.5	1.735	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
225	227.0	1.778	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
227.5	232.5	1.821	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
230	237.0	1.864	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
232.5	242.5	1.907	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
235	247.0	1.950	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
237.5	252.5	1.993	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
240	257.0	2.036	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
242.5	262.5	2.079	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
245	267.0	2.122	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
247.5	272.5	2.165	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
250	277.0	2.208	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
252.5	282.5	2.251	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
255	287.0	2.294	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
257.5	292.5	2.337	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
260	297.0	2.380	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
262.5	302.5	2.423	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
265	307.0	2.466	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
267.5	312.5	2.509	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
270	317.0	2.552	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
272.5	322.5	2.595	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
275	327.0	2.638	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
277.5	332.5	2.681	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
280	337.0	2.724	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
282.5	342.5	2.767	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
285	347.0	2.810	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
287.5	352.5	2.853	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
290	357.0	2.896	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
292.5	362.5	2.939	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
295	367.0	2.982	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
297.5	372.5	3.025	1176.0	1176.0	1060.5	1011.0	1013.85	1607.79	2294.93	31110.5	2.0	72.6	2.15	7.60	15.7
300	377.0	3.068													


APPENDIX C

SMALL-BORE PIPING HAND CALCULATION

A small load piping calculation will be done for the SI-51 tubing. These results will be compared to those for a finite element analysis of the piping.

By inspection, the critical span is the terminating span at the connection to 6008-6" 1501R.

### N-S Dir



$W_1$  - small heart valve - assume 5 #

$W_2$  - out of plane span, 1.17' long

$$w = (0.2 \pm 1\%) (1.17') = 0.23 \pm$$

Span properties; 3/8" SST tubing

$$D_o = 7/8'' = 0.375''$$

$$t_m = 0.049''$$

$$I = \frac{1}{4} \pi \left[ \left( \frac{0.375}{2} \right)^4 - \left( \frac{0.375 - 0.049}{2} \right)^4 \right]$$

$$I = 6,817-4 \text{ in}^4$$

$$S = 2(6,817-4) / 0.375 = 3676-3 \text{ in}^3$$

acceleration =

$$a_{x0/\text{peak}} = 2.196 g$$

$$\text{eg. wt: } w = (0.2 \pm 1\%) (1.17 / 12 \text{ in}) (2.196 + 1g) = 0.053 \pm \text{#}/\text{in}$$

$$W_1 = (5) (3.196) = 15.980$$

$$W_2 = (.23) (3.196) = 0.735$$

SONG 91 5/22/56 58 piping Confirmatory MQR P2

Two HP 41C programs (see attachment) are used to solve the simply supported beam for:

$w_1$ :

	REF 1981	
LENTH?	.0530	RUN
MODULUS?	60.0000	RUN
X?	3.636-83	RUN
	8.5000	RUN
FB=	4,429.4211	RUN
X?		RUN
	29.0000	RUN
FB=	18,779.2984	RUN
X?		RUN
	47.0000	RUN
FB=	11,651.1611	RUN

$w_2$ :


	REF 1981	
A=?	38.8888	RUN
F=?	3.5000	RUN
S=?	15.9980	RUN
	3.636-83	RUN
R1=	14.2921	RUN
R2=	1.6973	RUN
SA=	33,387.3868	RUN
X=?		RUN
	29.0000	RUN
SA=	23,815.8784	RUN
X=?		RUN
	47.0000	RUN
SA=	18,673.4422	RUN

$w_2$ :

	REF 1981	
A=?	80.0000	RUN
F=?	29.0000	RUN
S=?	.7358	RUN
	3.636-83	RUN
R1=	8.4666	RUN
R2=	8.2664	RUN
SA=	3,737.1537	RUN
X=?		RUN
	8.5000	RUN
SA=	1,895.3744	RUN
X=?		RUN
	49.0000	RUN
SA=	1,971.451	RUN

E-W Dir

$w_1 = 5 \pm -\text{valve}$



acceleration:

$$-a_{z-w}/m_w = 1.934 g$$

equivalent  $w_2$ :

$$w = (0.2 \pm 1\%) (1\% / 12in) (1.934g)$$

$$w = 0.033 \pm 1\%$$

$$w_1 = 1\% (1.934) = 0.920 \pm 1\%$$

SONGS 5/30/76 SB Piping Conformatory M/R P3

using the same solution scheme:

w₁:


AED - E03  
WEIGHT/IN? .0338 RUN  
LENGTH? 94.0000 RUN  
MODULUS? 3.636-83 RUN  
X? 8.5000 RUN  
FB= 3,297.9579 RUN

FB= 18,824.3399

w₁:

AED - E03  
L=? 94.0000 RUN  
R=? 8.5000 RUN  
F=? 7.8000 CLX  
.0000 CLX  
S=? 9.9200 RUN  
3.636-83 RUN  
R1= 9.8230 RUN  
R2= 9.3970 RUN  
SA= 21,893.3221 RUN  
X=? 47.0000 RUN  
Sx= 11,535.1115

Vertical Def



acceleration:

$$a_v /_{max} = 1.698$$

equivalent wt:

$$w = (0.2)(1.2)(1.698) = 0.0293 \text{ #/in}$$

$$w_1 = (0.2)(1.5)(1.698) = 0.509 \text{ #}$$

SONGSC 5/20/26 SB Piping Conformatory MFR PY

Using the same solution scheme:

4

三

	XEQ 1033		XEQ 1033
WEIGHT/IN?		L=?	
	.8233	RUN	47.0000
LENGTH?		R=?	14.0000
	47.0000	RUN	RUN
MODULUS?		F=?	.5000
	3.636-93	RUN	RUN
X?		S=?	3.636-93
	14.0000	RUN	RUN
FB= 1,797.9373		R1= 0.3574	
X?		R2= 0.1516	RUN
	23.5000	RUN	RUN
FS= 3,149.1577		SA= 1,376.8621	RUN
X?			RUN
	23.5000		
SA= 373.3270			

### Load combinations

N-5 Dir

Location	9.5	29.0	40.0
w.	4429	10799	11661
w, & we)	73388	23815	18678
w ₂	342	777	2931
Total	38159	28751	77270
		1/mile	

E-w Dir

Location	7.5	47.0
W	3298	10024
W,	<u>21043</u>	<u>11595</u>
TOTAL	<u>24391</u>	<u>21619</u>
	14000	

SONGSI 5/70/86 SB Piping Conformatory MQR P5

Vertical Def.

Location	14.0	23.5
W	1798	2149
W ₁	1376	780
total	<u>3174</u>	<u>3129</u>
	limit	

Combined stress


SIF : For socket weld fittings  $i = 2.1$

$$\sigma = (0.75)(2.1) [38351^2 + 24391^2 + 3174^2]^{1/2}$$

$$\sigma = 71758 \text{ psi N.G.}$$

The piping is cold, so no thermal stress calculation was required.

55 solution -



given:  $l, a, F, I, S$

needed:  $R_1, R_2, F_b$

PRP "SS"

81+LBL "SS"

82 XEQ "INP"

83 RCL 82

84 RCL 85

85 *

86 RCL 88

87 /

88 "R1="

89 ARCL X

10 PROMPT

11 RCL 82

12 RCL 81

13 *

14 RCL 88

15 /

16 "R2="

17 ARCL X

18 PROMPT

19 RCL 82

20 RCL 85

21 *

22 RCL 81

23 *

24 RCL 88

25 /

26 RCL 84

27 /

28 "SA="

29 ARCL X

30 PROMPT

31 SF 91

RCL 01

X

RCL 00

$$M_x = \frac{Fbx}{l}, \quad x < a$$

$$\frac{F(l-x)}{l} \cdot x \geq a$$

Register

0  
1  
2  
3  
4  
5  
6

Controls

$L$   
 $a$   
 $F$   
 $=$   
 $S$   
 $b$   
 $X$

32+LBL 91

33 " X=? "

34 PROMPT

35 STO 95

36 RCL 81

37 X>Y?

38 GTO 82

39 RCL 88

40 RCL 86

41 -

42 RCL 82

43 *

44 RCL 81

45 *

46 RCL 88

47 /

48 GTO 83

49+LBL 92

50 RCL 82

51 RCL 85

52 *

53 RCL 86

54 *

55 RCL 89

56 /

57+LBL 93

58 RCL 84

59 /

60 "SX="

61 ARCL X

62 PROMPT

63 GTO 91

64 END

PRP "INP"

81+LBL "INP"

82 " L=? "

83 PROMPT

84 STO 88

85 " A=? "

86 PROMPT

87 STO 81

88 " F=? "

89 PROMPT

10 STO 82

11 " S=? "

12 PROMPT

13 STO 84

14 RCL 89

15 RCL 81

16 -

17 STO 85

18 END

DSS - Moment calculation for uniformly loaded beam.



$$M(x) = \frac{wx}{2} (l-x)$$

$$F_b = \frac{M(x)}{s}$$

81+LBL "DSS"  
82 "WEIGHT/in?" ← unit  
83 PROMPT wt.  
84 STO 81 )?  
85 "LENGTH?" ← beam 3  
86 PROMPT length  
87 STO 82  
88 "MODULUS?" ← s (units?)  
89 PROMPT  
10 STO 83  
11+LBL 81  
12 "X?" ← x  
13 PROMPT  
14 STO 84  
15 RCL 81  
16 *  
17 2  
18 /  
19 RCL 82  
20 RCL 84  
21 ←  
22 *  
23 RCL 83  
24 /  
25 "FB=" →  $f_b(x)$   
26 ARCL x  
27 PROMPT  
28 STO 81

APPENDIX D

PIPING SUPPORT CALCULATIONS

INCL 6/11/83

SONGS FOR ANAL

MUR PH

## Support summary sheet for I-51

Support	Node/O.P	Stress Ratio	Page
S1-05-0320-H013	22/30	1.60	D-5
-H014	25/75	0.67	D-5
S2-05-6004-H010	85/65	0.86	D-5
-H012	100/75	0.22	D-6-7
-H007	115/81	0.09	D-7-9
-H006	120/95	—	D-9
-H001	125/95	0.15	D-9-10
-H014	135/95	0.50	D-10-11
-H003	145/100	—	D-12
-H005	170/110	0.57	D-12-13
S1-02-6004 -H002	180/120	0.69	D-13-14
-H006	195/120	0.79	D-15
-H001	200/125	0.77	D-16
-H003	235/145	0.76	D-16-19
S1-02-6005 -H006	260/157	0.33	D-20
-H003	275/165	0.15	D-20-21
-H005	285/175	0.47	D-22
-H001	290/177	0.67	D-22-24
-H008	30 /196	0.19	D-25-26
-H002	315/195	0.80	D-27
-H008	320/205	0.44	D-28
—	340/210	—	D-29
—	345/215	—	D-30
S1-06-6005-H005	375/225	1.82	D-30-31
-H004	380/230	1.78	D-32-34
-H003	405/250	0.75	D-35
S1-06-0319 -H004	445/390	0.78	D-35-37
-H007	485/537	1.98	D-38
-H006	490/577	0.81	D-39
S1-06-0323 -H013	520/560	—	D-39
-H005	675/375	0.86	D-39
S1-02-6008 -H001	710/455	0.06	D-40-42
-H002	720/460	0.05	D-43
S1-02-6006 -H001	755/425	0.17	D-43
-H002	765/430	0.06	D-43
S1-02-6007 -H001	800/405	0.21	D-43
-H002	810/410	0.05	D-43
—	846/—	—	D-43
S1-05-0720 -H017	855/30	9.37	D-43
-H016	855/312	0.63	D-44-45
-H011	861/315	0.66	D-46
-H009	870/720	0.17	D-47

Support Summary Sheet for 22-51 (1960)

Loads	Page
Standard component tables	D-48-53
Lugs	D-55-59
Spring hangers	D-60
Sway struts	D-61-63
Snubbers	D-64-65
HP-41C Programs -	D-54, D-66

INEL

6/12/86 Songs &amp; Confirms, Inc.

## Support Summary Sheet for SI-158

Support	Node/D.P.	Stress Ratio	Page
SI-01-6007-H00L	20/1020	0.17	D-156-159
-H00K	35/1090	0.47	D-153-153
-H00J	40/1100	0.28	D-150-152
-H30I	105/1270	0.70	D-107-149
-H30H	115/1290	0.84	D-95-106
-H30G	120/1320	0.20	D-94
-H30F	135/1360	0.34	D-85-93
-H00E	155/1430	0.23	D-83-84
-H00D	160/1440	0.52	D-80-82
-H00C	165/1460	0.88	D-77-79
-H00B	180/1500	0.78	D-72-76
-H00A	240/1710	0.72	D-67-71
Loads			D-160-

INEL

ONGC Confm Support nod- 22-51 FCR 2/4/21 %

Node 221 d.p. 70 / SI-05-0320-H013 / Spring

Based on a review of the design and the calculations in the FCR, this support design is controlled by the anchor bolt capacity. As a first pass, assume that the bolt closest to the snubber E carries the full load. (9193#).

The bolt is a 1" Super Kwik, @ 6 $\frac{1}{2}$ " embedment.

$$F_a = 22943/4 = 5737$$

$$F_d = 19413/4 = 4853$$

$$\left( \frac{9193}{5737} \right) = 1.60 \text{ NC}$$

The reduced factor of safety cannot be applied because all bolts are in tension. A static analysis would not show sufficient load redistribution to pass the design!

---

Node 251 d.p. 75 / SI-05-0320-H014 / Spring hanger

Per the spring hanger table,  $\alpha = 0.67$

Node 851 d.p. 65 / SI-05-6524-H010 / Spring Hanger

Per the spring hanger Table,  $\alpha = .086$

Note 1001 dp 751 SI-05-6004-H012 / Smubbet

The assembly, from new bracket to pipe clamp,  
has been qualified in the smubber table. This leaves:

- a) base attach weld
- b) bracket attach weld

a) base: with legs are  $1\frac{1}{4}'' \times 4''$  on the pipe surface, 4 legs,  
a  $\frac{1}{4}''$  fillet weld as shown:



Area of weld:  
 $A = \frac{1}{4}(1\frac{1}{4} \times 2 \cdot 4)$   
 $A = 2.317 \text{ in}^2$

The load is at an angle, with the  
following direction cosines:

Smubber:  $\vec{s} = (0.7024, 0.6175, -0.7244)$

Pipe:  $\vec{P} = (0, 1.0, 0)$

The axial load is:

$$\vec{F}_{axial} = \vec{F}_{sm} (\vec{s} \cdot \vec{P})$$

$$F_{axial} = 5028 (0.6175) = 3085.16$$

$$F_{max} = \sqrt{\vec{F}_{sm}^2 - \vec{F}_{axial}^2} = 3971.16$$

For the lug calculation,  $\alpha = 0.22$  or

b. bracket attach weld

The weld pattern is a 5" sq. with  $\frac{1}{2}$ " fillet

$$A = \frac{1}{2}(5)(4) = 10^{\text{in}^2}$$

Since the column is II the pipes

$$F_a = F_{\text{allow}} / 10^{\text{in}^2} = 738 \text{ psi } \underline{\text{OK}}$$

$$\bar{F}_y = F_{\text{allow}} / 10^{\text{in}^2} = 573 \text{ psi } \underline{\text{OK}}$$

Node 115/dp. 81/ S-05-6004-H007 / guide

There are six elements to be analyzed

- 1) The horizontal W6x15 x 1 $\frac{1}{2}\frac{1}{4}$ " beam
- 2) The attachment weld to the vertical beam
- 3) The vertical W6x15 x 2 $\frac{1}{2}$ " beam
- 4) The attachment weld of the vertical beam to the W10x29 beam running N-S (secondary steel)
- 5) The N-S W10x29 beam (secondary steel)
- 6) Main beam EHP-323

see end of  
Appendix For  
listing of  
the program

## 1) Horizontal beam -

The load is 16.9 K vertical, applied mid-span.

7.87 RIN

$$L = 1'2\frac{1}{3}'' = 14.17'' \quad \text{area} = 4.43$$

11.29 RIN

$$a = L/2 = 7.07''$$

9.72 RIN

$$F = 16.9$$

$$S = 9.72$$

15.59

RIN

5.91

RIN

-2.83

RIN

2.84

RIN

2K:2 stresses are available - OK

The shear is


$$\bar{F}_s = 5.61 / 4.43 = 1.27 \text{ csc - OK}$$

Node 115

91

2) attachment weld, horizontal to vertical beam.

The weld pattern:



$\frac{1}{4}$ " fillet weld; This compares to  $t_w = \frac{1}{4}$ ,  $t_f = \frac{1}{4}$ . Since the weld section is nearly identical to the beam section, and the beam stresses were so low, the weld is acceptable based on comparison with the beam.

3) Vertical beam

The load is a horizontal 1.3 k applied  $31'11'' - 30'6'' = 17''$  from the top. The span is  $2'7'' - 3'' = 23''$ . This is in combination with an axial load of 5.61 K.

$L=?$	XEQ *FF*	$L = 23$
$A=?$	23.00 RUN	$a = 17$
$F=?$	17.00 RUN	$F = 67$
$S=?$	6.78 RUN	$s = 9.72$
$R1 = 2.29$	9.72 RUN	The fixed-fixed assumption gives a maximum bending stress of 2.8 KSI and a maximum shear of $4.41 / 4.43 = 1.0$ KSI. The axial stress is $5.61 / 9.72 = 0.58$ KSI.
$R2 = 4.41$	RUN	
$S1 = -91$	RUN	The beam is acceptable.
$SA = 2.72$	RUN	
$SL = -2.88$	RUN	
$X=?$	RUN	

4) attachment weld, vertical beam to secondary stud.

The attachment weld is identical to that above and the applied loads are as low. The weld is acceptable.

Node 115

- 5) The W-10x20 N-S secondary steel.

Since the E of the support is within 2' of the main steel (EHP-B23), local stresses are the only concern. The installation of gusset plates to support the flanges of this beam alleviates any concern in this area - acceptable.

## Node 120 / dp. 85 / S-I-05-6004-H006 / rod hanger

Rod hangers were given no credit for seismic analysis (piping done with  $\frac{1}{2}$ " w10 rod hangers).

This is not in the scope of the support analysis.

## Node 125 / dp. 90 / I-I-05-6004-H001 / lateral

There are 5 elements to be analyzed:

- 1) The vertical C5x6.7x1'2 $\frac{1}{2}$ " beams contacting the pipe
- 2) The attachment welds of these beams to the next element (3)
- 3) The horizontal C5x6.7x3'2 $\frac{1}{4}$ " beams attaching the vertical beams (2) to the column (5)
- 4) The attachment welds of item(3) to column E-3

- 1) The vertical C beams will be analyzed as fixed fixed with a mid span load

$$L = 1'2\frac{1}{2}'' = 14.5''$$

$$a = 1/2 = 7.25''$$

$$F = 6.1 \text{ ksc}$$

$$S = 3 \text{ in}^2 (\text{37}, \text{E=30}, \sigma=25, \rho=1.77)$$

$$\text{Area} = 1.97 \text{ in}^2$$

$L = 3.15$   
 $a = 3.05$   
 $F = 47.2$   
 $S = 3.00$   
 $\rho = 1.77$

The bending stress, 37 ksc, is acceptable.

$$\bar{\tau}_f = 3.1 / 1.97 = 1.6 \text{ ksc, ok.}$$

Node 125

2) The attachment weld is a  $\frac{1}{4}$  fillet on the inside of the C section, which has  $t_w = \frac{3}{16}$ "  $t_f = \frac{5}{16}$ ". Based on the low stresses calculated for the vertical C beams and the similarity of sections here and there, the weld is acceptable. Deficiencies noted in NCR-SOI-R-4227 do not affect this conclusion.

3) The horizontal C beams will be analyzed as a column. They are sufficiently short that buckling need not be considered.

$$F_t = F_d = 3.07 / 1.97 = 1.62 \text{ ksi, OK.}$$

4) The attachment weld to the column consists of two  $\frac{1}{4}$ " fillet welds 12.8" long loaded in shear.

$$A = (\frac{1}{4})(2)(12.8) = 6.4 \text{ in}^2$$

$$F_d = 6.1 / 6.7 = 0.9 \text{ ksi OK.}$$

Node 135 / dp. 95 / SI-05-6004-H014 / axial joint


There are 4 elements to be analyzed:

1) Lugs on the page

2) The strut itself

3) Attachment weld of lugs to column E-3

2) The lugs are loaded by the couple needed to resist the offset strut load, in addition to the strut load. The couple is obtained by:



Node 175 from the previous analysis:

$$\overline{DCOS}_{\text{proj}} = (0, 0, 1)$$

$$\overline{DCOS}_{\text{stout}} = (.102, 0.000, -0.995)$$

The stout load is 12.5 K.

$$\therefore F_{\text{scr}} = (0.995)(12.5) = 12.4 \text{ K}$$

The load  $\perp$  to the project,  $\bar{F}_\perp$ , is

$$\bar{F}_\perp = (.102)(12.5) = 1.3 \text{ K}$$

A moment equation gives:

$$2(9.90^\circ) \bar{F}_c = (9.9+16) F_{\text{scr}}$$

$$\bar{F}_c = \frac{(9.9+16) 12.4}{2(9.9)} = 16.3 \text{ K}$$

The total load on the leg is

$$\bar{F}_c + \bar{F}_{\text{scr}} = 12.4 + 16.3 = 28.7 \text{ K}$$

For the leg calculation  $a = 0.50$  OR

2) Stout Assy.

From the stout table  $a = 0.42$  OR

3) The attachment weld is a  $5/8''$  weld in a  $7/8'' \times 5/8''$  rectangular pattern. It is subjected to a 12.4 K normal and a 1.3 K shear load.

$$A_t = 2(5/8)[7/8 + 5/8] = 15.8 \text{ in}^2$$

$$\bar{F}_t = 12.4 / 15.8 = 0.8 \text{ K}$$

$$\bar{F}_s = 1.3 / 15.8 = 0.1 \text{ K}, \text{ O.K.}$$

Node 145 / dp 100 / SI-05-6004-H003 / Rod Hanger


This support has been upgraded to full vertical restraint. The new design is not accounted for analysis.

Node 170 / dp 110 / SI-02-6004-H005 / Snubber

There are 3 elements needing analysis:

- 1) Lugs on the pipe
- 2) The snubber assembly
- 3) attachment weld of snubber assembly to col. E-5
- 4) attachment lugs.

Based on the photographs, the lugs will be assumed to share the load and be configured as shown



$$7^{\circ} \bar{F}_{22} = 11.81^{\circ} F_z$$

$$\bar{F}_{22} = \frac{11.81}{7} (10.2) = 17.2 \text{ k}$$

$$\bar{F}_{21} = \bar{F}_{22} + F_z = 10.2 + 17.2 = 27.4 \text{ k}$$

Per the lug table,  $\mu = 0.17$  OK

2) Snubber - Per the snubber table  $\mu = 0.57$

Node 170

- 3) Attachment weld of snubber ass'y

From the ITT Grinnell catalog PH81, the bracket on a 201 shock suppressor has dimensions of  $4\frac{1}{2} \times 3$ ". (Note that the bracket was left when the PS.7-10 was substituted.)

$$P = 10.2 \text{ k}$$

$$A = 2(4\frac{1}{2} + 3) \frac{1}{4} = 3.7 \text{ in}^2$$

$$F_a = 10.2 / 3.7 = 2.7 \text{ k/in OK. (L27.9)}$$

Node 170 / DP 115 / SII-02-6004-14002 / 100% Stress

There are 5 elements needing evaluation.

- 1) The snubber ass'y (which is evaluated in the snubber table)
- 2) The attachment weld, snubber ass'y to plate
- 3) The attachment weld, plate to tube steel
- 4) The  $4\frac{1}{2} \times 14 \times 11$ " tube steel
- 5) The attachment weld, tube steel to  $W_17 \times 45$  beam

- 1) snubber ass'y - per the snubber table:

$$\alpha = 0.69$$

Node 130

- 2) the attachment weld, start way to late  
this weld is 2 parallel  $\frac{1}{4}$ " throat by  $4\frac{1}{2}$ " welds

$$F = 10.6$$

$$A = 2(1/4)(4\frac{1}{2}) = 2.3 \text{ in}^2$$

$$F_a = 10.6 / 2.3 = 4.6 \text{ kN} \quad \text{OK}$$

- 3) the attachment weld, plate to tube

this weld pattern is 2 parallel  $\frac{1}{4}$  fillet welds.

$$F = 10.6 K \quad 4" \text{ long}$$

$$A = 2(1/4)(4) = 2 \text{ in}^2$$

$$F_a = 10.6 / 2 = 5.3 \text{ kN}$$

$$F_a = 23.9 \text{ kN} - u = 222 \text{ OK}$$

- 4) Tube steel.

Since the tube steel is too short for concern  
about buckling, the area,  $7.59 \text{ in}^2$ , in  
comparison to the weld area ensures its  
adequacy. OK

- 5) attachment weld, tube steel to W18x45.

This weld is identical to the weld at the  
other end of the tube, and is adequate  
by comparison OK

INEL 6/11/73

SOP 102-1 Support Arms

MHR

Node 195 / dp 120 / II-02-6024-H006 / House. scnt

Three elements need analysis:

- 1) The stent assembly
- 2) The attachment weld to column 8-6
- 3) The stent ass'y -

For the stent ass'y table  $\alpha = 0.79$

- 2) The attachment weld, stent ass'y to col. 8-6

For a 2 1/2" x 2" stent ass'y, the base plate  
is 4 1/2" x 3". For a 3 1/2" fillet weld, all around,

$$A = \frac{3}{8} (2)(4\frac{1}{2} + 3) = 5.63 \text{ in}^2$$

$$P = 1.2 \text{ K}$$

$$F_s = 1.2 / 5.63 = 1.6 \text{ K} \therefore \text{OK}$$

Node 200 / dp 125 / EI-02-6004-H001 / strut

This support is identical to EI-02-6004-H002 and will be qualified by comparison. The max. load is 11.8 K, vs 10.6 K. The controlling component for H002 is the strut, with  $F/F = 0.69$ , for the strut.

$$F/F = (0.69) \frac{(11.8)}{(10.6)} = 0.77 < 1.0 \text{ OK}$$

Node 235 / dp 145 / EI-02-6004-H003 / vertical guide

There are 7 parts to be analyzed:

- 1) The bumper column - w 4x13x10 1/4" beam (E)
- 2) The cable C 3x4x1, C-C 1'-8" beam (54)
- 3) the std. components: 7/8" nuts, #140, 7/8" rod (12) eye nuts (EI-292, part 7), #66, welded beam
- 4) attach (A), #3, the washer plate (item 60)
- 5) attach weld to 4 4x4 Y 2 1/2" x 4"
- 6) 4 4x4x7/8" x 4" (item C)
- 7) attach weld, item C to support strut
- 8) attach weld, beam attach to beam

- 1) W4x13x10 1/4" beam

This beam is too short to buckle.

$$A = 7.57^{\prime\prime}^2 \quad (\text{AISC}, 8^{\text{th}})$$

$$\bar{F}_a = 7.0 / 7.8 \approx 0.8 \text{ KSC, negligible OK}$$

- 2) Cable C 3x4x1, CC 1' 8" beam

$L=?$		$L = 20''$
$A=?$		$A = 10''$
$F=?$		$F = 5.8 \text{ K}$
$S=?$		$S = 2 \times (1.1) = 2.2 \quad (\text{AISC}, 8^{\text{th}})$
$\beta=?$		

INEL

-51 Cont. Sup. Anal.

MFR 4/5/76

Node 235


$$F = 17.1 \text{ kip} < 40.6 \quad \text{OK - 0.72}$$

3) Standard components - load is 2.9K

item #	catalog #*	descri	rating	
25	-	7/8" nuts	qual. by prod	
12	140	7/8" rod	3.8	OK 0.76
7	290	eye nuts	3.8	OK 0.76
1	66	welded beam attach	7.7	OK 0.76

Catalog is ITT General Catalog PH71

The washer plate, has no load rating; it's a 4x4x1/2 plate @ 1" hole



$$F_b = \frac{[(0.5)(1.5)][\frac{1}{2}(1/2)]}{0.031} = 7.1 \text{ kip} < 40.6 \quad \text{OK - 0.17}$$

Perhaps an overkill, but remember the Bryant-Ryan skyway in K.C.


4) W 8 x 15 x 5' 9" beam

L=?		$L = 69''$
a=?	69.000 RUN	$a = 69/2 = 34.5$ (centerline)
F=?	34.500 RUN	$F = 2.9$
s=?	1.300 RUN	$S = 11.8$ (ASCE 5-7)
R=?	11.300 RUN	$F = 4.2 \text{ kip} < 40.6 \quad \text{OK - 0.10}$

$R_1 = 1.458$   
 $R_2 = 1.458$

Note 27

5) Attach weld, beam to clip

from P4-20, AISC, 8th

$$D = \frac{P}{C G L}$$

 $D = \text{min. reqd. throat, } 1\frac{1}{2}^{\frac{1}{2}}$  $P = \text{applied load, } L = 2\frac{1}{2} - 1\frac{1}{2} = 1\frac{1}{2}$  $C = \text{coefficient from Table 104 (P4-20) for } R = 2\frac{1}{2}/4 = 0.58$ 

$$\text{for } R = 0.58, \lambda = 0.25$$

$$xL = (0.25)(4) = 1^{\prime \prime}$$

$$aL = 4^{\prime \prime} - xL = 3^{\prime \prime}$$

$$a = 0.75^{\prime \prime}$$

$$C = 1.27$$

$$G = 0.86 \quad (\rho = 4-70)$$

$$D = \frac{1.5}{(1.27)(0.86)4^{\prime \prime}} = 0.743 \Rightarrow 1$$

$$D/2 = 1\frac{1}{16}/1\frac{1}{4} = 0.25^{\prime \prime} \quad \text{OK-0.25''}$$

6) &lt; 4x4 x 3/8" x 4

2 plates, area  $4 \times \frac{3}{8}^{\prime \prime}$  have  $A = 3^{\prime \prime}$ 

$$F_u = 2.9/3 = 1.0 \times 3 < 24.4 \quad \text{OK-204}$$

7) attach weld, clip to beam -

Based on item 5, weld is OK, int. hub shear

$$A = 2(1/4)[(2)(1/2) + 4] = 2.75$$

$$F_u = 2.9/2.75 = 1.05 < 24.4 \text{ kip} \quad \text{OK-204}$$

Node 235

- 1) attach. weld, beam attach to beam

from III br. P471 for = .6,  $\frac{7}{8}$  beam attach,  
the welds are  $2\frac{1}{2}$ "

$$A = (2\frac{1}{2})/2(1\frac{1}{4}) = 1.25"$$


$$\bar{F}_L = 2.4/1.25 = 23k < 23.9 \quad \underline{\text{OK O-10}}$$

Node 260 / OP 157 / II-02-5005-H006 / 1575

There are elements to be analyzed:

- 1) attachment base
- 2) pipe clamp - Flange pattern (assumed)  $16^{\circ} \times \frac{1}{2}$ ,  $1\frac{1}{2} \times 5$  stock
- 3) P.A. No. 2200-70 stand
- 4) attach. weld, end end to plate (the endures all loadings in the stand)

- 1) attach. base



- 2) Pipe clamp. Based on dimensions, this is a Flange-Pattern part No. 2030. (catalog listed, 2/20/70)

$$F = 37.6 \text{ kN}$$

$$\bar{F} = 1.8 < 7.6 \quad \underline{\text{OK O-15}}$$

Node 260

3) BP - No. 2200-30 stent

from stent calc., OK 0.49

4) from the BP catalog, the webs are  $7\frac{1}{8}$ " long

$$A = \frac{1}{4} (7\frac{1}{8}) = 1,906 \text{ in}^2$$

$$F_y = 14.8 / 1,906 = 7.8 \text{ ksi} < 229 \text{ OK - 0.33}$$

Node 275/dp 165 / II-02-6005-H003 / vertical guide

There are 4 elements to be analyzed:

- 1) The T5 4x4x 2 $\frac{1}{2}$  x 31.5" horizontal member
- 2) attachment web of horizontal to vertical members
- 3) W6 x 25 x 1 $\frac{1}{2}$  vertical members
- 4) attach. web of vertical member to structural stel.

The downwind skin design is acceptable by inspection.  
The load is transferred directly to structural stel.

1) T5 4x4x 2 $\frac{1}{2}$  x 31.5" long

$$L = 31.5"$$

$$z = 12"$$

$$F = 7.2$$

$$S = 5.35"$$

(AISC 8th, p 1-91)

A=?

31.585 RUN

F=?

12.000 RUN

S=?

3.200 RUN

R1= 2.161

R2= 1.829

S1= -2.751

S2= -2.998

$$F_y = 2.8 < 40.6 \text{ OK } 0.07$$

$$F_y = A = 5.09$$

$$\bar{F}_y = 7.2 / 5.09 = 0.6 \sim 0$$

INEL

E-57 Cont. Sup. Anal.

MPL 2/5/66

Node 2752) attachment weld  $\frac{1}{4}$ " fillet all aroundBased on TS 4x4x $\frac{1}{4}$  section  $S = 4.11 \text{ in}^3$   
( $A = 22.7 \text{ in}^2$ )

$$\bar{F} = 2.8 \frac{(57.75)}{(4.11)} = 7.65 < 27.9 \quad \text{OK } \underline{0.15}$$

3) W6x25 vertical member

From AISC,  $\sigma_{yf}^{(2)}$ ,  $A = 7.34 \text{ in}^2$ ,  $S = 16.7 \text{ in}^3$ 

$$F_a = 3.2 / 7.3 \approx 0$$

$$\bar{F}_a = (2.8) \frac{(57.75)}{(16.7)} = 0.9 \approx 0 \quad \text{OK}$$

4) weld, vertical member to civil steel -  
 $\frac{1}{4}$ " fillet on flange & web.

Consider the flanges only:

$$b_f = 6.03''$$

$$\frac{t_f}{b_f} = 0.455''$$

$$d = 6.38''$$

$$I = 2 \left\{ \frac{1}{2} (6.38 - 0.455)^2 (6.02) (0.455) \right\}$$

$$I = 48.6$$

$$\bar{F}_a = (2.8) (57.75) \left( \frac{\frac{1}{2}(6.38)}{48.6} \right) = 1.0 < 27.9 \text{ kip} \quad \text{OK } 0.04$$

Node 235 / DP175 / II-02-5005-H005 / strut

There are 2. elements to be analyzed

- 1.) Strut, Fig 211, size #2, cc - 3'6 1/8"
- 2) attach. weld to civil steel.

1) Strut

From the strut calc., OK 0.47

2 1) attach. weld: from the ITT Gr. PH 71 catalog,  
the weld is 3" long.

$$A = 2(3)(3/8) = 2.25 \text{ in}^2$$

$$\bar{F} = 555/225 = 2.5 \text{ k} < 27.4$$

OK 0.10

Node 270 / DP177 / II-02-5005-H001 / Lat. guide

There are 4 elements to be analyzed

- 1) The W6x25 vertical member
- 2) the attach. weld to the long member
- 3) the W6x25 horizontal member
- 4) the attach. to civil steel.

1) W6x25 vertical member

$$M = (1464 + 1078) 19.2 = 1464 \text{ k-in}$$

from ASCE 2nd,  $A = 7.34$ ,  $S = 16.7$

$$\bar{F}_b = \frac{1464}{16.7} = 8.8 < 40.6 \text{ k} \quad \underline{\text{OK - 0.23}}$$

$$\bar{F}_g = 19.2/234 = 2.6 < 27.4 \quad \underline{\text{OK - 0.11}}$$

Node 290

## 2) The connection weld

The weld is  $\frac{1}{8} = 5/16$ , all around, for eg. thickness of  $5/8"$  - this corresponds to  $\frac{1}{8} = 5/16$ ,  $\frac{1}{8} = 7/16$ . Since the weld has a much larger section, use lower stress

$$F = 0.8 < 23.9 \quad \text{OK } 0.37$$

3) The  $W_6 \times 25$  long. member.

Treat as a continuous member, & evaluate the intermediate weld only. The basic member will see the max moment applied by the next member, so OK for next, is OK for long. member. Also check for web crippling

Assume only flange welds contribute

$$d = 6.38$$

$$b_f = 6.08$$

$$\frac{I}{E} = \frac{2[4(6.38 - 0.25)]^2}{25.6} (6.08)(0.25)$$

$$F = \frac{(8.8)(16.7)(6.08/2)}{25.6} = 16.4 < 23.9 \quad \text{OK } 26.7$$

Web crippling ( $A = 54$ ,  $r = 2\frac{1}{2}$ ,  $P = 5-47$ )

$$A_{st} = \frac{\rho_{sf} - F_{uc} \pm (\frac{1}{8} + 5R)}{F_{sf}}$$

$$F_{uc} = \text{col } F_y = 36$$

$$F_{sf} = \text{anti } F_y = 36$$

$$R = 17/16 \quad (P1-24)$$

$$\rho_{sf} = \text{flange force}$$

$$\rho_{sf} = 4/3 (7.8 / 6.38) = 1.9$$

$$\frac{1}{8} = 5/16$$

$$5/16 = 7/16$$

$$A_{st} = \frac{1.9 - 7.8 (5/16) (7/16 - 5/16)}{16}$$

$$A_{st} = -1.75 < 0 \quad \text{no need for stiffener}$$

Node 290


1) The attachment to civil steel

load: from Rank, 5th, p 103,

The most reaction force for an S3 beam @ intermediate moment is  $M_0/2$

$$R = 146.4 / (2'4'' + 4' - 1'2'') = 2.9 \text{ k}$$

use table ~~XXXV~~ of AISC, 9th (p 4-50), for clips wld  
on long webs.



$$D = \frac{P}{C_C L} , = 16^{\circ} \text{ t needed}$$

$P$  = applied load ( $\frac{1}{2}$  total - 2 clips)

$$C_C = 0.86 \quad (\rho 4-78)$$

$$\alpha = 1.0 \text{ (constant)}$$

$$R = 317\frac{1}{2} = 0.857$$

$$C = 0.857$$

$$L = 3.5'$$

$$D = \frac{1.5}{(0.857)(0.86)(3.5)} = 0.56$$

$$t = 5/16, \quad \underline{OK} \quad 0.56/5 = \underline{0.11}$$

for disposal on civil steel,

$$A = 2(5/16)(7) = 1.125$$

$$F = 29/1.125 = 1.1 < 27.4 \quad \underline{OK} \quad \underline{0.05}$$

for the clips

$$A = 2(1/2)(7) = 7$$

$$F = 29/7 = 1.0 < 40.6 \quad \underline{OK} \quad \underline{0.03}$$

INEL

E-51 Conf. Sup. Anal


WPA 4/5/73

Node 310 / dp 193 / E-02-6005-Hoss / supressor

There are elements to be analyzed

- 1) The legs
- 2) The pipe clamp
- 3) The snubber
- 4) The clamps attached to coil steel

1) The legs -



$$F_a = \frac{17.6(4)}{90.74} = 0.6K$$

Based on review of the leg calc,  
these legs are negligibly loaded.

OK-0.0

2) The pipe clamp

from 4/20/74 PIA catalog,

for  $\theta = \arctan(4/100.74) = 2.5^\circ$

$$F = 45.4K \text{ at } 65^\circ$$

$$F = 17.6 < 45.4 \quad \underline{OK \quad 0.30}$$

3) The snubber

same catalog,  $F = 72.4K$

$$F = 17.6 < 72.4 \quad \underline{OK \quad 0.19}$$

Node 310

- 4) The attach to civil steel

If the box section is assumed to be built up of full pen welded  $\frac{1}{2}$ " plates,

$$A = 4(7)(\frac{1}{2}) = 14 \text{ in}^2$$

$$F = 126 / 14 = 9.0 \text{ k} < 23.9 \text{ OK } 0.04$$

Node 315 / dp 195 / II-02-6005-H-002 / strut

There are 6 elements to be analyzed:

- 1) the strut
- 2) attach weld to w6x15 horizontal member
- 3) w6x15 horiz. member
- 4) attach weld to vert. member
- 5) vert. w4x13 member
- 6) attach weld to civil steel.

- 1) the strut.

Per the strut strut calculation. OK - 0.80

- 2) attach weld to w6x15 horizontal member

$\frac{1}{4}$ " allowed on  $7\frac{1}{2} \times 3$  plate

$$A = 2(1/4)(4\frac{1}{2} + 3) = 3.75 \text{ in}^2$$

$$F = 9.4 / 3.75 = 2.5 \text{ k} \leq 23.9 \text{ OK } 0.11$$

- 3) w6x15 horiz. member

$$L = 28"$$

$$A = 14$$

$$F = 9.4$$

$$S = 9.72 \quad (\text{AISC}, \text{pg 28})$$

R=?	23.000	RUM
F=?	14.000	RUM
S=?	9.400	RUM
	9.720	RUM

$$F_b = 7.4 < 40.6 \text{ OK } 0.08$$

$$A = 4.43$$

$$F_y = 9.4 / 4.43 = 2.1 < 24.4 \text{ OK } 0.09$$

R1= 4.700  
R2= 4.700  
S1= -3.385

Node 315

4) attach. weld to W4x17 member

for W4x17,  $\frac{t_f}{t_w} = \frac{1}{4}$ ,  $\frac{t_w}{d} = \frac{3}{8}$ . Since the flange makes predominant contribution to  $I$ , use W4x13 I for weld section.  $I = 1.70$

$$\bar{F}_b = (3.4) \frac{(1.72)}{(1.70)} = 17.4 < 23.9 \text{ OK } 0.73$$

for W4x17,  $d = 4.16$ ,  $b_f = 4.06$

$$A = \frac{1}{4} (2(4.06) - 4.16) = 3.07 \text{ in}^2$$

$$\bar{F}_a = 4.7 / 3.07 = 1.53 \text{ K/in} < 23.9 \text{ OK } 0.66$$

$$\text{interaction } 0.73 + 0.66 = 0.79 < 1 \text{ OK}$$

5) W4x13 member

same stress as calculated for 4) above:

$$\bar{F}_b = 17.4 < 40.6 \text{ OK } 0.43$$

$$A = 2.87 \text{ in}^2 \quad \bar{F}_a = 4.7 / 2.87 = 1.6 < 40.6 \text{ OK } 0.07$$

$$\text{interaction } - \underline{0.46 \text{ OK}}$$

6) attach weld to end stud

This weld is unspayed by item 4). The only difference is that the web has a  $5/16''$  weld vs  $1/4''$  for item 4)

OK 0.79

TVEL

I-51 Conf. Sup. Fresh

MPC 4/3/23

Node 3301 dp 2051 I-06-6005-H028 / start

This support has 4 elements to analyse

- 1) Champs
- 2) stanch
- 3) clevis
- 4) stanch weld to civil steel

1) Champs -

for  $1\frac{1}{4} \times 5"$  stock, 3P (per photo) stanch loaded to  
7" od stanch, Q adjustment, have a  
BP 2200-30 stanch -

for  $1\frac{1}{4} \times 5"$  stock, 3 bolt, have BP = 2600  
For 14" -  $F = 326K$


$$F = 133 < 37.6 \quad \underline{OK \ 0.75}$$

2) stanch &amp; clevis

BP 2200-30 inc. endload stanch &amp; clevis:

Per the stanch table OK 0.44

3) stanch. weld to civil steel



$$A = 2(7\frac{1}{4})(7\frac{1}{4} + 5) = 7.89 \text{ in}^2$$

$$\bar{F}_a = 133(\cos 32.7^\circ) / 7.89 = 1.40 \text{ K.i}$$

$$I = 2 \left[ \frac{1}{3}(7\frac{1}{4}) \right]^2 (5)(5\frac{1}{16}) = 45.4$$

$$\bar{F}_o = \frac{133(\cos 32.7) (\frac{1}{3}(7\frac{1}{4}))}{45.4} = 0.6$$

$$F = F_a - \bar{F}_o = 20 \text{ K} < 27.6 \quad \underline{OK \ 0.08}$$

 $\bar{F}_r$  negligible OK

INEL

-51 Lignite Fuel

MPR 415-786

Node 3401 dp 2101 — Snubber

This support has elements to be analyzed:

- 1) large
- 2) clamp -
- 3) snubber arm
- 4)

can't find matching large  
clamps base will be missing

Node 3451 dep 251 - 1 rod hgt.

Analysis not necessary - paying delegate who will  
change contribution.

Node 375/dp 225/si-06-6005-14005/smash

For the smaller table  $F/F = 1.82$  NG.


Node 380 / dp 230 / 22-26-6075-4004 / snubber

This support has elements to be analyzed

- 1) eye
  - 2) snubbers very
  - 3) bracket stand wrist
  - 4) plate
  - 5) anchor bottle

1. Lungs.

conservative assumes W.C. has granted:



INEL

22-57 Cont. Type Anal

MCR 4/15/62

Node 380

2) Snubber assembly.

Per the snubber table, OK - 1.11

Since the snubber was oriented off the  $\perp$  to  
the pipe & load acting on the clamp needs  
checked:

$$\theta = \sin^{-1} \left[ \frac{2^{1/4}}{7^{1/4}} \right] = 50.5^\circ$$

per the Pres. Spec. table:	$\theta$	F
45		7435-
50.5		6907=
60		6070-

$$for \text{ faulted } F = 1.55 (6907) = 10706$$

$$\bar{F}/F = 10706 / 10707 = 1.00 \quad \underline{116}$$

Node 405 / dp 250 / SI-06-6005-11003 / vert guide

This support has 6 features to be analyzed:

- 1) W6x15x2'7" top horiz member
- 2) attach weld to vertical members
- 3) W6x15x2'4 web members
- 4) attach weld to baseplate
- 5) baseplate
- 6) anchor bolts.

The bottom horiz. member will be analyzed by analysis of top horiz. member

1) W6x15x2'7" top horiz member

for W6x15:       $D = 6.28$   
 $b_p \approx 4.03$       -  
 $t_w = 1/4$   
 $t_p = 3/8$   
 $A = 7.74$   
 $S = 10.2$   
 $k = 3/4$

$$L = 2'7" + 6.28" = 33.28"$$

$$A \sim \frac{1}{2}L = 16.64$$

$$F = 29.9$$

$$S = 10.2$$

$$\bar{F}_b = 12.0 < 49.6 \text{ kip } \underline{\text{OK}} \quad 0.70$$

$$\bar{F}_v = 14.7 / 7.74 = 1.8 < 24.4 \text{ kip } \underline{\text{OK}} \quad 0.13$$

Check for web crippling:

$$\Delta_{sc} \sim \frac{D_b F}{F_{yc}} = \frac{F_{yc} + (\frac{t_w}{4} + s_k)}{F_{yc}}$$

$$F_{yc} = F_{y1c} = 36 \text{ kip}$$

$$R = 0.75"$$

$$P_{sf} = (\frac{8}{3}) 29.9 \approx 79.2$$

$$\frac{t_w}{4} = 1/4$$

$$t_b = 1/16 \text{ assumed contact zone}$$

Node 40

$$A_{st} = \frac{29.2 - 36(1/4)(11/16 + 5/16)}{36}$$

$$A_{st} = 0.136 \text{ in}^2$$

the 2  $3/8 \times 2\frac{1}{2} \times 5\frac{1}{2}$ " plates have

$$A = (2)(7/8)(2\frac{1}{2}) = 1.375 > 0.136 \quad \underline{\text{OK 0.07}}$$

2 attach weld to vertical members.

The weld throat,  $1/4"$ , 151 width of weld to flange and  
and  $t_w = 3/8 = 0.375 = 1/4$  allows using the cold beam  
stress for the weld

$$\bar{f}_b = 120 < 27.9 \quad \underline{\text{OK 0.50}}$$

$$\bar{f}_y = 30.1 < 27.9 \quad \underline{\text{OK 0.13}}$$

3) vertical member -

same section as the horizontal member, same  
moment,

$$\bar{f}_b = 12 < 40.6 \quad \underline{\text{OK 0.3}}$$

$$\bar{f}_a = \bar{f}_{y(1/2)} = 21 < 40.6 \quad \underline{\text{OK 0.08}}$$

$$\text{Interaction: } 0.30 + 0.08 = 0.38 \quad \underline{\text{OK}}$$

4) Attach weld to baseplate

same as 3 above, but applied to (2)

$$\bar{f}_b = 120 < 27.9 \quad \underline{\text{OK 0.50}}$$

$$\bar{f}_a = \bar{f}_{y(1/2)} = 21 < 27.9 \quad \underline{\text{OK 0.13}}$$

$$\text{Interaction: } 0.50 + 0.13 = 0.63 \quad \underline{\text{OK}}$$

Node 405

5) Baseplate

treat as a beam, and use symmetry.



$$M_o = 14.7(6) = 89.2 \text{ k-in}$$

$$S = \frac{1}{12} [ \frac{1}{2}(14)(11)^2 ] = 2.33$$

$$F_b = 89.2 / 2.33 = 37.9$$

$$\bar{\tau}_b = F_b / (0.75)(0.75)(36) = 50.76 \quad \underline{OK \ 0.75}$$

$$\bar{\tau}_b = 14.7 / 12 = 1.3 < 24.4 = \underline{OK \ 0.05}$$

6) Anchor bolts:

1 1/4 CEG, min embed 6" -  $F = 19 \text{ k}$ 

$$F = 14.7/2 = 7.4 < 19 \quad \underline{OK \ 0.19}$$

Node 445 / dp 790 / S - 06 - 0319 - H007 / SPR HSR


Put the spring hanger cable - OK - 0.78

Node 485 / dp 577 / S - 06 - 0719 - H007 / saudier

There are features to be analyzed:

- 1) The hanger
- 2) The charge
- 3) The snubber array
- 4) clevis attached
- 5) the plate
- 6) The anchor bolts.

1) The hanger



2) The charge

for a PIC - 24-120, G load @ 981;  $F = 1.557(19404) = 21.5 \text{ kN}$

$$F = 19.0 < 21.5 \quad \text{OK } 0.98$$

3) The snubber array.

From the snubber table, OK - 0.25

Node 495

## 4) Clevis attach weld

The weld pattern, based on an earlier JT bracket, is a  $7'' \times 7'' \times 5/16''$  weld pattern.

$$A = \frac{5}{16}(7+7)(2) = 8.75 \text{ in}^2$$

$$I = 2\left(\frac{1}{2}(7)\right)^2(7)(5/16) = 88.6$$

$$S = 88.6 / (G)(7) = 19.7$$

$$\bar{F}_a = (19)(\cos 21.9) / 8.75 = 2.0 \text{ kN}$$


$$F_b = (19)(\sin 21.9)(4.7) / 19.7 = 1.73$$

$$F_y = (19)(\sin 21.9) \times 8.75 = 9.810$$

$$\bar{F} = \sqrt{(2.0)^2 + 1.73^2} = 3.8 < 23.9 \quad \underline{\text{OK } 0.16}$$

## 5) Tie plate

pull-out load - assume 15 - uniform central pressure



From Rilem, 53, p 982, fig 1c

$$a = 24$$

$$b = 12$$

$$a/b = 2$$

$$b/a = 0.5$$

$$a = b$$

$$a = b$$

$$a/b = 0.5 - 0.6$$

$$b/a = 0.58 - 0.6$$

$$b = a$$

$$\bar{F}_{max} = \bar{F}_d = \frac{a w}{\pi^2} = \frac{(0.6)(1.2)(210)}{(74)^2}$$

$$\bar{F}_d = 18.8 \text{ kN}$$

bending load: assume supported by one roller only:



$$R = [19(\sin 21.9)(4.7)] / 24$$

$$R = 0.3 \text{ kN}$$

$$M = (0.3)(12) = 3.6 \text{ in-k}$$

$$S = \frac{1}{48750} (12)(3.6)^3 = 13.5$$

$$\bar{F}_b = 3.5 / 13.5 = 0.26$$

$$F_b = 19.8 + 3.3 = 19.1 < 40.6 \quad \underline{\text{OK } 0.47}$$

INEL

II-81 Cont. Sup. Anal

MPCR 3/3/86

Node 95

Anchor bolts: for 1 1/4" CEB @ 5 3/4" embedment in 2800  
concrete  $F_E = \frac{1}{4}(19.0) = 4.8 \text{ k}$   
 $F_T = \frac{1}{4}(76.75) = 19.2 \text{ k}$

assume central bolt carry pull-out

$$F = 19.2/2 = 9.6 > 4.8 \quad \underline{\text{NG 1.98}}$$

need a detailed plate analysis, all bolts will be  
in tension, so  $F_D = 2$  is OK,

Node 490 / sp 537 / I-06-077-H026 / rubber

This support has features to be analyzed:

- 1) legs
- 2) clamp
- 3) snubber assy.
- 4) clevis attach
- 5) baseplate
- 6) anchor bolts.

### 1) legs

assume full axial load on 1x1x6 legs

$$F = (17.7K) \left[ \frac{5'4\frac{1}{2}''}{6'6\frac{1}{2}''} \right] = 14.5K$$

per the leg calc OK - 0.72

### 2. clamp

The clamp is a PSA-35 located at an angle of

$$\theta = \sin^{-1} \left[ \frac{5'4\frac{1}{2}''}{6'6\frac{1}{2}''} \right] = 55^\circ$$

from the PSA catalog,  $F = (1.55)(14.72) = 22.8K$

$$f/f = 17.7/22.8 = \underline{0.78}$$

### 3. snubber assy'

per the snubber table OK - 0.24

4,5,6 - Base attach - clevis attach, baseplate, anchor bolts,

Per FCR-X-41-747-5 stress ratio  
with a load of 19.0K is 0.87.

$$\therefore \text{OK: } 0.87 \left( \frac{17.7}{19.0} \right) = \underline{0.81}$$

INEL

I-51 Cont. Log. Anal

Copy 2 4/5/56

Node 520 / dp 500 / I=06-0327-H013/ 100' long

The piping was designed to function eccentrically w/o this support analysis not needed.

Node 575 / dp 375 / I=06-0719-H005/ 100' long

From the spring longer table, OK 0.86

Node 710 / dp 455 / I=02-6008-H001/ guide

This support is identical to support at node 720 (dp 400), except the loads differ:

	Loads Node 710	Loads Node 720
Horizontal	1.7	1.6
Vertical	2.5	1.4

The maximum increase in load gives a factor of 1.1

The maximum stress ratio @ node 720 is 0.06

$$\text{Therefore } \alpha = 1.1 (0.5) = 0.6$$

SONG55 -

Config

SI-51 Support Arol.

MPR 1/17/35

Node 720 / dp 460 / SI-02-6008-H002 / guide

There are 6 elements to be analyzed:

- 1) The horizontal W4x13x1'23/4" beam restraining uplift
- 2) attachment weld, item 2 to the vertical W4x17x2 1/4" side of the box
- 3) The vertical W4x17x0 1/2" beams transferring horizontal loads to item (2)
- 4) the vertical W4x17x2 1/4" beams comprising the sides of the box
- 5) attachment weld, item 4 to item 6
- 6) the 4" sch 40 pipe resisting down loading.  
(welds hold in place & do not see the load)

- 7) This W4x13x1'23/4" beam will be modeled Fixed-fixed with a central uplift load.

$L = ?$	$L = 1'23/4'' = 18.75''$
$a = ?$	$a = \frac{1}{2}L = 9.375''$
$F = ?$	$F = 1.4$
$S = ?$	$S = 5.46 \text{ in}^3, A = 7.83 \text{ in}^2 \quad (\text{ASCE}, \tau^{\text{eff}}, p 1-25)$
$S = ?$	$\bar{F}_D = 0.7 \cdot 1.83 = 0.2 \times 244 = 48.8 \text{ OK}$
$P_1 = 8.798$	$F_b = 0.5 \times S \cdot \bar{F}_D = 40.6 \text{ OK}$
$P_2 = 8.798$	
$S_1 = -0.473$	
$S_2 = 0.473$	
$S_L = -0.473$	

Node 720

- 2) Attach weld, element (2) to element (1)

The weld is a  $\frac{1}{16}$ " fillet on web & both flanges.  
This compares to a beam section with  $t_w = \frac{1}{4}$ ,  
 $t_f = \frac{3}{8}$ ". For bending, can assume  
flange controls section properties: use beam  
stress

$$F_b = 0.5 K_{SI} < 23.4 \quad \text{OK } 0.02$$

- 3) Vertical W4x13 beams used as compression members.

This element will be analyzed using 1.15.5.2 of  
AISC, 8th, p 5-47. This section makes provisions  
for local web buckling due to local compression  
loading from an attached beam in bending.

$$F_{yc} = F_{yse} = 36 \text{ KSI}$$

$$R = 17\frac{1}{16}$$

$$P_{bf} = 4/3 (1.6) = 2.1 \text{ KSI}$$

$$\frac{t}{t_w} = 0.28$$

$t_b = 1\frac{1}{32}$ " (estimated width of line of  
contact between piers and beam)

$$A_{st} = \frac{P_{bf} - F_{yc} \pm (\frac{t}{t_w} + 5) R}{F_{yse}}$$

$$A_{st} = \frac{(2.1) - (36)(0.28)(1\frac{1}{32} + 5(17\frac{1}{16}))}{36}$$

$$A_{st} = -1.1 \text{ in}^2$$

Since  $A_{st} < 0$ , no web stiffener is needed.

- 4) vertical W4x13 x 2'4" hot sides.

L=?

29.000 RUN

Analyze as a F-F beam,  $F_a = 0.3 \text{ KSI}$  (as element 3)  
with a transverse load of 1.8 K applied  
 $(31'' - 5\frac{1}{16}'') - (29' - 10\frac{3}{4}'') = 18.56''$  above the base.

R=?

18.600 RUN

$$L = 2'4'' = 28$$

$$a = 18.6''$$

$$F = 1.8 \text{ K}$$

$$S = 5.46''$$

 $\Sigma I = 0.429$  $\Sigma I = 1.199$  $\Sigma I = -9.814$  $\Sigma I = 9.315$  $\Sigma I = -1.215$

CONFIRM Confirm

I-51 Support And

MNR

1/17/85

Node 720

$$\bar{F}_v = 618 / 7.83 = 0.3 K \cdot I < 244$$

All stresses are very low - OK. 0.01

- 5) attachment wild, stem 4-to stem 6.

Same as stem 2, use beam stress:

$$\bar{F}_d = 1.07 < 27.9 \quad \text{OK} \quad 0.05^+$$

- 6) 4" and 40 pipe

The pipe is too short to buckle

$$\bar{F}_d = 1.47 / 7.17 = 0.4 \sim 0.0 \quad \text{OK}$$

INEL

SI-51 Cont. Sub Anal.

ENGR 4/11/86

Node 755 / DP 425 /	SI - 02-6006-H001	/ guide
765	430	-6006-H002
800	405	-6007-H001
810	410	-6007-H002

These 4 supports are identical to SI-02-6008-H002.  
 They will be evaluated by comparing loads, as was done for  
 node 710

Node	Load		Factor	F/F
	Horiz	Vert		
720	1.6	1.4	1.0	0.05
755	1.5	4.7	2.4	0.17 OK
765	1.8	0.9	1.2	0.06 OK
800	1.8	5.8	4.2	0.21 OK
810	1.6	1.2	1.0	0.05 OK

Node 846 / dp - / - / snubber

This snubber, attached to ground on the east end FW long-piping, has no design available.

Node 855 / dp 710 / SI-05-0320-H017 / spring hanger

Per the spring hanger table - OK 0.87

Nids 955 / dp 3121 - 05-0320-4016 LS nobor.

This support has features to be evaluated:

- 1) legs
- 2) clamps
- 3) anchor array
- 4) attach weld for clevis
- 5) plate
- 6) anchor bolts

1) legs -

legs are on number 2:  
Per. sec clamp has 15.5" & short

$$F_{leg} = [7.2 \sin(072)] \left[ \frac{6-15.5}{12} \right] = 9.5 \text{ k}$$

per the leg calculation - OK 0.25

2) clamps

The std. PSC clamp for the application @ 45°  
has  $F = 1.55(18) = 27.9$

$$F = 7.2 < 27.9 \quad \text{OK } \underline{0.26}$$

3) anchor array.

per the anchor table - OK 0.10

4) the plate -

assume a 33 plate @ center pt load:

$$F = 7.2 \sin 77^\circ = 5.3 \text{ k}$$

~~dimensions~~ 22" x 20"  
7" x 7" contact pressure

Note 555using Rankin, 5th, fig 1C p 326:

$$\begin{aligned} w &= 5.3 \\ a/b &= 7/20 = 0.35 \sim 0.4 \\ b/b &= 7/20 = 0.35 \sim 0.4 \\ a/b &= 22/20 = 1.10 \sim 1.0 \\ \beta &= 0.34 \end{aligned}$$

$$\bar{F}_b = \frac{\beta w}{2} = \frac{(0.34)(5.3)}{(2/4)^2} = 7.9 \text{ ksi}$$

$$\bar{F}_b = 7.9 < 40.6 \quad \underline{\text{OK}} \quad \underline{0.20}$$

g) The anchor bolts -

for 1" ccs, 4 1/2" min.

$$\begin{aligned} F &\sim 14,000/4 = 3.5 \text{ k} \\ \bar{F}_b &= 27.4/4 = 6.8 \text{ k} \end{aligned}$$

pull out load:  $\bar{F}_t = \frac{1}{4}(5.3) = 1.3 \text{ k}$

heading: assume heading moment taken by opposite bolts:

$$\bar{F} = (7.2 \cos 47.2) \frac{(4.7)}{((22^2+20^2)^{1/2})} = 0.8 \text{ k}$$

Total:  $\bar{F}_t = 1.3 + 0.8 = 2.1 < 7.5 \quad \underline{\text{OK}} \quad \underline{0.60}$

shear:  $\bar{F}_s = \frac{1}{4}(7.2 \sin 47.2) = 1.32 < 2.8 \quad \underline{\text{OK}} \quad \underline{0.19}$

integrity:  $(0.6^2 + 0.19^2)^{1/2} = 0.63 < 1 \quad \underline{\text{OK}} \quad \underline{0.33}$

INEL

II-51 Cont. Sup. Anal.

mgd2 4/6/86

Node 361 / dp 3151 = -05-0720-H011 / snubber

Three elements need analysis:

- 1) the clamp
- 2) the snubber
- 3) the attachment structure (claws, frame, baseplate)

1) The clamp -

use a 12" Ø PIA-35 clamp w

$$\theta = \sin^{-1} \left[ \frac{20'7\frac{1}{2}'' - 16'6''}{5'7''} \right] = 42.8''$$

from PIA catalog:  
 $F = (1.55)(12.0) = 27.9$

$$F/F = 6.2/27.9 = 0.22 \text{ ok}$$

2) The snubber -

per the snubber table, OK - 0.07

3) The attachment structure

Review of FCR X-41-763-5 showed it applicable, except that an  $F_{0.2}=2$  was used on the anchor bolt. Correction for this gives  $F/F = (0.749)(2) = 1.49$ , with a 14 kN snubber load.

$$F/F = (1.49) \left( \frac{6.2}{14.0} \right) = \underline{\underline{0.46}}$$

INEL

E-51 Cont. 100 Anal

20072 4/6/86

Node 8701 Sp 320 / E-05-0320-4009 / snubber

There are 3 elements to be evaluated:

- 1) clamp
- 2) snubber assembly
- 3) clavie attack weld

1) The clamp - the std -120 PSC clamp for the -35 snubber, at  $\theta = 90^\circ$ , has  $F = (1.5\pi) 50 = 77.5$

$$F = 12.5 < 77.5 \quad \underline{\text{OK } 0.16}$$

2) The snubber

Per the snubber table OK 0.17

3) The clavie attack weld:

for a  $7 \times 7^\circ \times 57/16$ " weld,

$$\frac{A}{S} = \frac{5/16(7+7)2}{\frac{1}{2}(7)(7(5/16))} = 8.75$$

$$S = \frac{1}{2}(7) = 9.84$$

The snubber is offset from  $\perp$  by  $\sin(7^\circ) = 0.124$ 

$$F_a = 12.6(\cos 72^\circ) / 8.75 = 1.2 < 40.6 \quad \underline{\text{OK } 0.03}$$

$$F_o = 12.6(\sin 32^\circ)(4.8) / 9.84 = 3.4 < 40.6 \quad \underline{\text{OK } 0.09}$$

$$\text{interaction: } 0.05 + 0.03 = \underline{\text{OK } 0.11}$$

SI-51 Support Loads (ABUR, 10/17/55; ADOG, 10/16/55)

node	dir	w=	T	$(S_{xx}^2 + S_{yy}^2)^{1/2}$	'Level A, a'	'Level O'
22	Y	—	—	9193	—	$\pm 9193$
100	Z	—	—	5023	—	$\pm 5023$
115	X	133	1176	5439	(133, 1304)	(-5266, 6748)
115	Y	3311	-131	7843	(2939, 3311)	(-5463, 1154)
120	Y	1784	182	4161	(1134, 1526)	(-2777, 5727)
125	X	247	-1476	4910	(-1189, 247)	(-6099, 5157)
175	Z	-312	-179	1225	(-312, -179)	(-1227, 1222)
145	Y	2482	263	7499	2745	(-5217, 10244)
170	X	—	—	12673	—	$\pm 12673$
180	Y	2393	-175	7663	2893	(-4945, 10556)
195	Z	-483	1524	8123	(-483, 1841)	(-9658, 4216)
200	Y	4143	-317	7717	4143	(-3301, 11960)
235	Y	1223	764	4238	1587	(-7015, 5325)
260	Z	-200	-1760	12691	-2060	(-14757, 12491)
275	Y	3648	249	6354	3897	(-3226, 12751)
285	Z	540	-252	4960	540	(-4672, 5500)
210	Z	28	1565	17623	1593	(-17595, 14216)
310	Z	—	—	13605	—	$\pm 13605$
315	Y	2890	237	6167	3177	(-1277, 1344)
320	Z	-232	-109	12916	-391	(-17207, 12674)
340	Z	—	—	16713	—	$\pm 16713$
345	Y	3774	-2172	7712	3774	(-8470, 13046)
375	Z	—	—	40189	—	$\pm 40189$
380	Z	—	—	18987	—	$\pm 18987$
405	Y	4141	689	24560	4110	(-20419, 24790)
485	Z	—	—	18970	—	$\pm 18970$
490	Z	—	—	17653	—	$\pm 17653$
520	Y	5550	-404	16504	5550	(-1227, 12056)
575	Z	—	—	10576	—	$\pm 10576$
610	Y	4155	-471	8910	4155	(-5224, 7965)
625	Z	—	—	17552	—	$\pm 17552$
710	Y	481	-72	1920	481	(-471, 2461)
710	Z	124	51	1525	125	(-1291, 712)

## II-51 Support Loads (cont'd)

node	dir	wt	T	$(\text{resistance})^{1/2}$	'Level A3'	'Level D'
720	Y	255	-59	1165	255	(-469, 1425)
720	Z	-36	7	1536	-36	-1572
755	Y	1419	142	3057	1611	(-1649, 4670)
755	Z	85	376	1119	421	(-1034, 1540)
765	Y	143	-8	784	143	(-649, 427)
765	Z	-28	-44	1704	-72	(-1776, 1676)
800	Y	1593	-150	4228	1593	(-2785, 5521)
800	Z	84	603	1095	687	(-1011, 1782)
810	Y	90	-103	1137	(-13, 90)	(-1150, 1227)
810	Z	-18	-107	1577	-125	(-1727, 1581)
840	Z	--	--	6362	--	$\pm 6362$
855	Z	--	--	7251	--	$\pm 7251$
861	Z	--	--	6206	--	$\pm 6206$
870	Z	--	--	12533	--	$\pm 12533$
886	X	713	670	16372	983	(16, 99, 17445)
886	Y	1348	-1154	3352	1348	(-310, 4750)

NUPIPE-III. NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION 1

85 / 10 / 16 .

2005-1551-HALEY515 THIS IS THE LAST PAGE

NUPIPE-III • NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM

27

VERSION I

SUPPORT REACTIONS FOR LOAD COMBINATION CASES  
SSSE + SANS 15855 TS 6 AND 6000 TANGERSI  
SONGS 1 15-151 ALBERTS

Hölde, „Die Eichholz-Satzung“ 14

卷之三

SI-SI support loads ABUR

PAGE 19

8510415. NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION 1.4.1  
SONGS 1 SI-SI ANALYSIS INPUT SRS (INPUT, HORIZ, SPECTRA)

SUPPORT REACTIONS FOR LOAD CASE NO. 2

THERMAL EXPANSION NORMAL OPERATION

NODE	TYPE	REACTION	DIRECTION
4	FORCE	+1087.	X COORD
4	FORCE	-194.	Y COORD
4	FORCE	-95.	Z COORD
4	MOMENT	8732.	X COORD
4	MOMENT	5751.	Y COORD
4	MOMENT	5751.	Z COORD
114	FORCE	-17.	X COORD
114	FORCE	-17.	Y COORD
114	FORCE	-14.	Z COORD
114	MOMENT	10.	X COORD
114	MOMENT	10.	Y COORD
114	MOMENT	10.	Z COORD
115	FORCE	-17.	X COORD
115	FORCE	-17.	Y COORD
115	FORCE	-14.	Z COORD
115	MOMENT	10.	X COORD
115	MOMENT	10.	Y COORD
115	MOMENT	10.	Z COORD
116	FORCE	-17.	X COORD
116	FORCE	-17.	Y COORD
116	FORCE	-14.	Z COORD
116	MOMENT	10.	X COORD
116	MOMENT	10.	Y COORD
116	MOMENT	10.	Z COORD
117	FORCE	-17.	X COORD
117	FORCE	-17.	Y COORD
117	FORCE	-14.	Z COORD
117	MOMENT	10.	X COORD
117	MOMENT	10.	Y COORD
117	MOMENT	10.	Z COORD
118	FORCE	-17.	X COORD
118	FORCE	-17.	Y COORD
118	FORCE	-14.	Z COORD
118	MOMENT	10.	X COORD
118	MOMENT	10.	Y COORD
118	MOMENT	10.	Z COORD
119	FORCE	-17.	X COORD
119	FORCE	-17.	Y COORD
119	FORCE	-14.	Z COORD
119	MOMENT	10.	X COORD
119	MOMENT	10.	Y COORD
119	MOMENT	10.	Z COORD
120	FORCE	-17.	X COORD
120	FORCE	-17.	Y COORD
120	FORCE	-14.	Z COORD
120	MOMENT	10.	X COORD
120	MOMENT	10.	Y COORD
120	MOMENT	10.	Z COORD
121	FORCE	-17.	X COORD
121	FORCE	-17.	Y COORD
121	FORCE	-14.	Z COORD
121	MOMENT	10.	X COORD
121	MOMENT	10.	Y COORD
121	MOMENT	10.	Z COORD
122	FORCE	-17.	X COORD
122	FORCE	-17.	Y COORD
122	FORCE	-14.	Z COORD
122	MOMENT	10.	X COORD
122	MOMENT	10.	Y COORD
122	MOMENT	10.	Z COORD
123	FORCE	-17.	X COORD
123	FORCE	-17.	Y COORD
123	FORCE	-14.	Z COORD
123	MOMENT	10.	X COORD
123	MOMENT	10.	Y COORD
123	MOMENT	10.	Z COORD
124	FORCE	-17.	X COORD
124	FORCE	-17.	Y COORD
124	FORCE	-14.	Z COORD
124	MOMENT	10.	X COORD
124	MOMENT	10.	Y COORD
124	MOMENT	10.	Z COORD
125	FORCE	-17.	X COORD
125	FORCE	-17.	Y COORD
125	FORCE	-14.	Z COORD
125	MOMENT	10.	X COORD
125	MOMENT	10.	Y COORD
125	MOMENT	10.	Z COORD
126	FORCE	-17.	X COORD
126	FORCE	-17.	Y COORD
126	FORCE	-14.	Z COORD
126	MOMENT	10.	X COORD
126	MOMENT	10.	Y COORD
126	MOMENT	10.	Z COORD
127	FORCE	-17.	X COORD
127	FORCE	-17.	Y COORD
127	FORCE	-14.	Z COORD
127	MOMENT	10.	X COORD
127	MOMENT	10.	Y COORD
127	MOMENT	10.	Z COORD
128	FORCE	-17.	X COORD
128	FORCE	-17.	Y COORD
128	FORCE	-14.	Z COORD
128	MOMENT	10.	X COORD
128	MOMENT	10.	Y COORD
128	MOMENT	10.	Z COORD

D-E2

II-51. Support Loads ~~ANOTHER~~ ABUR

200

05/16/15. NUCLEUS-III, NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION 1.9.1  
SONGS : SI-51 ANALYSIS (RELL SAMS (ENGR), HORIZ. SPECTRA)

SUPPLY SECTION FOR LONG CREEK NO. 1

#### **HIGH PLUS INTERNAL FORCES**

HP 41C  
code  
for load  
combinations

PRP "LCOM"  
 81 LBL "LCOM"  
 82 "WT?" ← WT  
 83 PROMPT  
 84 STO 81  
 85 STO 82  
 86 "T?" ← Thermal  
 87 PROMPT  
 88 ST+ 82  
 89 RCL 81  
 10 RCL 82  
 11 X>Y?  
 12 X<Y  
 13 STO 83  
 14 X<Y  
 15 STO 84  
 16 "A,MH="  
 17 ARCL 83  
 18 PROMPT → A, MH = Level A, B, min  
 19 "A, MX="  
 20 ARCL 84  
 21 PROMPT → A, MX = Level A, B, max  
 22 "SEIS?"  
 23 PROMPT  
 24 ST- 83  
 25 ST+ 84  
 26 "B,MH="  
 27 ARCL 83  
 28 PROMPT → B, MH = Level D, min  
 29 "B, MX="  
 30 ARCL 84  
 31 PROMPT → B, MX = Level D, max  
 32 END

Combines pipe support loads by:  
 Level A,B min = min (w, w+T)  
 max = max (w, w+T)  
 Total min = Level A,B min - 11E-3T  
 max = Level A,B max + 11E-3T

SORVETIC ratio SI-51 Support anal MPR 9/14/75

L455

The following data has been gathered from the support analyses:

Node / D.P.	Force	-// direction length	both sides welded?	— direction length	weld throat
100/175	121 K	4"	✓	1 1/4"	1/4"
175/195	23.7 K	4"	✓	1 1/4"	1/4"
170/110	13.7	2"	✓	2"	1/4"
	13.7	4"	✓	1 1/4	1/4"
200/157	91.4	4	✓	1 1/4	5/16
730/270	47.4	4	✓	1 1/4	5/16 (use 1/4)
495/577	47.0	6	✓	1"	5/16
790/577	14.5	6	✓	1"	5/16
746/					
855/312	9.5	6	✓	1"	1/4"

LUGS

ASME Code Case N-318-2 shall be used, (4/12/65), but only  
sigma stresses will be checked

## 1.0 Limitations

1.1 fillet webs ok

1.2 - must pt - cold piping

1.3  $B_1 \leq 0.5, B_2 \leq 0.5, \beta_1 \beta_2 \leq 0.075$ 

$$B_1 = L_1/r, B_2 = L_2/r$$

$L_1$  = width of plate  $r$  = mean, avg radius,  $L_2$  = length of plate

$$\text{for } P_o = \frac{14.0}{12.5} = 0.57 \quad (P = 900 \text{ psi})$$

$$r = \frac{(P_o - p)}{2} = \frac{6.710}{2} = 6.030$$

<u>Node</u>	$L_1$	$B_1$	$r$	$L_2$	$B_2$	$\beta_1 \beta_2$	
100	1 1/4	0.19	6.71	$\sqrt{2.65}$	0.59	0.111	NG
135	1 1/4	0.19	6.71	$\sqrt{1.68}$	0.59	0.111	NG
170	2	0.30	6.71	$\sqrt{2.65}$	0.30	0.59	NG
	1 1/4	0.19	6.71	$\sqrt{2.65}$	0.59	0.111	NG
260	1 1/4	0.19	6.71	$\sqrt{2.65}$	0.59	0.111	NG
380	1 1/4	0.19	6.71	$\sqrt{2.65}$	0.59	0.111	NG
485	1	0.17	6.03	$\sqrt{2.66}$	0.89	0.173	NG
490	1	0.17	6.03	$\sqrt{2.66}$	0.89	0.173	NG
855	1	0.17	6.03	$\sqrt{2.66}$	0.89	0.173	NG

100:  $\therefore L_2 = 0.57r = 3.75$ , but  $\beta_1 \beta_2 = 0.075 > 0.075$   
 $\therefore L_2 = 0.075r/3 = 2.65$

135: same as 100

170:  $\therefore L_2 = 0.075r/1.68 = 1.68$  for  $\sqrt{L^2}$   
 same as 100 for  $\sqrt{L^2}$

260: same as 100

380: " "

485:  $\therefore L_2 = 0.57r = 3.75, \beta_1 \beta_2 = 0.075$  ok

490: use 485 result

490:  $\therefore L_2 = 0.57r = 3.75, \beta_1 \beta_2 = 0.075$  NG.
$$\therefore L_2 = 0.075r/2.66 = (0.075)(6.03)/1.17 = 2.66$$

465

$$1.4 \quad \sqrt{r^2} = \sqrt{(6.71)(0.58)} = 1.97'' \rightarrow 14\pi/1.97 = 22 \text{ evenly}$$

*spaced around: OK*

$$1.5 \quad D_o/l = 14/0.58 = 25 < 100$$

$$\begin{aligned} 2.0 \quad r &= 6.71''/6.03'' \\ t &= 0.58''/0.69'' \\ D_s &= 14''/12.75'' \\ T &= r/l = 11.569/8.779 \\ L_1, L_2 &\text{ from } p2 \\ L_1, L_2 &\text{ from } p1 \end{aligned}$$

$$K_1 = 26 \text{ for full width}$$

$$M_L = M_N = M_T = Q_1 = W = 0$$

$$Q_2 \neq 0, \text{ load}$$

2.0

$$S_{m1} = Q_2 / 2L_2 L_0$$

$$L_b = \min(L_1, t) = \min(L, 0.58) \text{ from } 14'', \min(L, 0.69) \text{ from } 12''$$

<u>Node</u>	$R_2$	$L_2$	$L_b$	$S_{m1}$
100	12.1	2.65	0.58	3.94 K/cm
135	29.7	2.65	0.58	9.74
170	13.7	1.68	0.58	7.03
	13.7	2.65	0.58	4.46
260	31.4	2.65	0.58	10.21
330	47.4	2.65	0.58	15.12
485	41.0	2.66	0.69	11.17
490	14.5	2.66	0.69	3.95
555	9.5	2.66	0.69	2.06

$$S_{m1} = Q_2 / 2L_2 L_b = S_{m2}$$

$$S_{m1} \times 4 = S_{m2}$$

7.0 - for  $\sigma_p$  & special regions only.

$$(NC-9) \quad \frac{B_1 P_{avg} D_0}{2t_m} + B_2 \underbrace{\frac{M_A + M_B}{\pi}}_{\sigma_p} + S_{mL} \leq \min(2S_y, 2S_u)$$

$\sigma_p$  is the standard piping output stress. for straight pipes, the 0.75 is from of the equation (which will be used here), gives identical results

$$\text{for } T_p = 76 \text{ & } 120^\circ F, \quad S_m = 18,700 \text{ psi}$$

$$S_y = 27,576 \text{ psi}$$

$$\min(S_m, 2S_y) = 524 \text{ (i.e. } 3S_y)$$

Node	$\sigma_p$	$S_{mL}$	$\sigma_p + S_{mL}$	$< 524 \times 0.75?$	$S_{mL}$ at 18.8 KSC
100	8.8	3.44	12.7	OK - 0.22	OK 0.21
175	9.5	4.74	23.2	OK 0.41	OK 0.50
170	9.1	7.03	16.1	OK - 0.29	OK 0.17
170	9.1	4.76	13.6	OK - 0.24	OK 0.24
260	17.5	10.21	29.3	OK 0.57	OK 0.21
380	12.6	15.42	29.6	OK 0.52	OK 0.57
445	12.8	16.17	30.0	OK - 0.53	OK 0.57
490	14.3	2.95	18.3	OK 0.32	OK 0.21
505	13.5	2.06	15.6	OK 0.28	OK 0.11

$S_{mL}^{**} \leq 2.5 S_y \Rightarrow \text{since } S_{mL}^{**} = S_{mL} < 2.0 S_y, \text{ satisfied by the above}$

$$Q_1^{**}/2L_L \leq S_y :$$

since  $Q_1^{**} = Q_2$ , this is equivalent to

$$S_{mL} < S_y$$

3.2 - other require for fillet welds.

$$(7) \frac{2Q_2}{A_w} \leq 2\gamma \leq 56.4 \times 10^{-3}$$

$$Q_2^{\text{eff}} = Q_2, A_w = \text{fillet weld throat area}$$

$$A_w = \pi (n_1 L_1 + n_2 L_2)$$

$t$  - throat size

$n_1 = \# L_1$ , side welds

$n_2 = \# L_2$  "

$$(8) \{4 [Q_2^{\text{eff}} / A_w]^2\}^{1/2} \leq \gamma_y$$

Since  $Q_2^{\text{eff}} = Q_2$ , this reduces to

$$2Q_2/A_w \leq \gamma_y$$

If this is satisfied, (7) is automatically satisfied

node	$Q_2$	$n_1$	$L_1$	$n_2$	$L_2$	$A_w$	$2Q_2/A_w$	$\gamma_y = 17.8?$
100	12.1	1	6.25	2	2.65	6.55	3.7	OK - 0.20
115	23.7	1	1.25	2	2.65	6.55	3.6	OK - 0.47
171	12.7	1	3.0	2	1.68	5.36	5.11	OK - 0.27
	12.7	1	1.25	2	2.65	6.55	4.18	OK 0.22
260	31.4	1	1.25	2	2.65	6.55	9.59	OK 0.57
380	47.4	1	1.25	2	2.65	6.55	7.24	OK 0.39
495	41.0	1	1.00	2	3.35	7.70	10.65	OK 0.57
490	26.5	1	1.0	2	3.06	9.91	5.90	OK 0.31
455	9.5	1	1.0	2	3.35	7.70	2.47	OK 0.13

INEL 5/12/86

SONSSE Confir Anal

mjr

## Spring hanger table

Support No.	Model/DP	Type [Grinnell]	Loads Hot Max	Spring Ratio
SI-05-0320-H014	25135	Fig 8-268, #16, 'B'	6500 9500	0.67
SI-05-0004-H010	25165	" " #13"	4491 5200	0.86
SI-06-0319-H004	445/390	Fig 268, #17, 'B'	10100 13000	0.78
SI-06-0319-H005	675/375	" " #10, 'F'	1458 1690	0.86
SI-05-0320-H017	853/310	Fig 82, #17 'F'	4500 5200	0.87

$$\text{Force Ratio} = \frac{\text{hot load}}{\text{max load}}$$

Max Loads taken from ITT Grinnell PH71 catalog

2015 5/17/31

A'001 / D/P	Support No.	Length	Load	Span	Struct. Acc. size	Part No.	Part No.	Length	Allowable load (normal)	Comment
135/43	11 - 05 - 6004 - 11014	3' 8 1/4"	12520	2100 - 10	"	78	"	30000	OK - 0.82	
180/115	11 - 02 - 6004 - 11002	4' 10 1/4"	10556	c - 211 / #21	"	120	"	15400	(1) OK - 0.69	
145/120	11 - 02 - 6004 - 11006	5' 7 1/2"	9216	211 / #22	"	120	"	11610	OK - 0.79	
200/125	11 - 02 - 6004 - 11001	4' 10 1/4"	11840	c - 211 / #4	"	120	"	15400	(1) OK - 0.77	
260/165	11 - 02 - 6005 - 11004	4' "	14751	2200 - 30	"	78	"	30000	OK - 0.49	
255/175	11 - 02 - 6005 - 11003	4' 5 1/2"	5500	211 / #12	"	120	"	11610	OK - 0.71	
315/175	11 - 02 - 6005 - 11002	2' 4 1/2"	9301	c - 211 / #2	"	120	"	11610	OK - 0.80	
330/205	11 - 02 - 6005 - 11008	3' 9 "	13307	2200 - 30	"	78	"	30000	OK - 0.71	

MJR-15/96

SWAY STRESS NOTES

- 2) The given allowable for these stents is for a length of 10', where buckling would clearly govern. Because of this, a buckling calculation will be used to establish capacity. This is attached.

ML 8/12/55

SWAY STRUT ANALYSIS.

Stanch & nodes 180 & 200 are C-211, size 2 Channel sway  
stanch 4' 10" long loaded to 10556 and 16,  
respectively. The capacity of these supports will be  
assumed in terms of the buckling load, and shear of  
the plates.

Buckling - based on a primed-primed, 2" x 160 plate,  
4' 10" long.

$$2" \times 160 \text{ plate: } A = 2.140 \text{ in}^2$$
$$I = 1.162 \text{ in}^4$$

$$r = \sqrt{\frac{I}{A}} = \sqrt{\frac{1.162}{2.140}} = 0.728 \text{ in}$$

$$K = 40 \text{ (per cent, } \rho = 12\%, \alpha = 2\%, \beta = 3\%)$$

$$\frac{Kl}{r} = \frac{58}{0.728} = 79.625 < 200$$

Assume  $F_y = 36 \text{ k/c}$

$$c_c = \sqrt{\frac{2\pi^2(200\delta^3)}{(36k)}} \quad 1.5-1, \alpha = 5\%, \beta = 2$$

$$c_c = 126.1$$

$$Kl/r < c_c :$$

$$F_a = \left[ 1 - \frac{79.625^2}{2(126.1)^2} \right] 36$$
$$\frac{5}{3} = \frac{3(79.625)}{8(126.1)} = \frac{(79.625)^2}{8(126.1)^2}$$

$$F_a = 15.797$$

stanch & node 180, planar,  $\delta = 200$ , ok

Note: com 1.73 service factor.  $F_s = 1.73 / 1.5 = 1.1547$

$F_s < F_a$  & node 85

D = 1.3

Model No.	Length (ft)	Lead (lb)	Mark No.	Manuf.	Model No.	Allow. bearing load	Lead rating	Comment
22/10	15'	193	U-01	Pacific Scientific	P2A-3	4,5	1,700	OK
180/15	15'	5018	U-05	Pacific Scientific	P13-D	11.6	22,100	OK
170/10	38'	12673	U-01	Pacific Scientific	P15-10	11.6	22,100	OK-15%
410/14	24'	13605	U-01	Pac. Sci. Co.	P19-35	16.0	22,450	OK
310/10	34'	16113	U-01	Pac. Sci.	P19-35	16.0	22,450	OK
310/10	30'	110189	U-01	Pac. Sci.	P15-10	4.6	22,100	OK-1.82
380/210	22'	161191	U-01	Pac. Sci.	P15-10	4.6	17,114 (4)	OK
410/15	22'	118470	U-01	Pac. Sci.	P19-16	10.0	22,450	OK
410/15	6.5'	115153	U-01	Pac. Sci.	P15-11	10.0	22,140	OK
525/15	2.8'	10596	U-01	Pac. Sci.	P19-35	10.0	22,450	OK
625/10	41.0'	17552	U-01	Pac. Sci.	P19-35	10.0	22,450	OK
846/100	6.5'	6362	U-05	Pacific Scientific	P15-10	4.6	15,450 (2)	OK-OK
635/112	5.5'	7151	U-05	Pac. Sci.	P15-15	10.0	22,450	OK
661/	5.6'	6206	U-05	Pac. Sci.	P19-V	10.0	22,450	OK
847/118	7.2'	11551	U-01	Pac. Sci.	P19-V	10.0	22,450	OK

RECORDED BY H. S. STEPHENSON

II-51 Snubber Table Notes

- 1) The buckling load, away from simple compression factors (short columns), is controlled by the following relationships:

$$\frac{P_1}{P_2} = \frac{K_1/l_1^2}{K_2/l_2^2}$$

for the same number  $K_1 = K_2$ :


$$\frac{P_1}{P_2} = \left(\frac{l_2}{l_1}\right)^2$$

$$P_1 = (22100) \left( \frac{4.6}{5.2} \right)^2 =$$

- 2) Same as above:

$$P_1 = (22100) \left( \frac{4.6}{5.5} \right)^2 = 15459$$

55 solution -



given:  $l, a, F, I, s$

needed:  $R_1, R_2, f_b(x)$


Register	contents
0	$l$
1	$a$
2	$F$
3	$\underline{\underline{s}}$
4	$\underline{\underline{5}}$
5	$b$
6	$x$

PRP •SS•	•LBL R1	
81+LBL •SS•	81 * $x=2$	
82 XEQ •PUP•	82 PROMPT	
83 RCL 82	83 STO 86	
84 RCL 85	84 RCL 81	
85 *	85 XY?	
86 RCL 89	86 GTO 82	
87 /	87 RCL 88	
88 *R1= *	88 RCL 86	PRP •INP•
89 APCL X	89 -	
10 PROMPT	90 RCL 82	
11 RCL 82	91 * $L=2$	
12 RCL 81	92 RCL 81	
13 *	93 PROMPT	
14 RCL 88	94 STO 88	
15 /	95 * $A=2$	
16 *R2= *	96 PROMPT	
17 APCL X	97 STO 81	
18 PROMPT	98 * $F=2$	
19 RCL 82	99 PROMPT	
20 RCL 85	100 STO 82	
21 *	101 * $S=2$	
22 RCL 81	102 PROMPT	
23 *	103 STO 84	
24 RCL 88	104 RCL 89	
25 /	105 RCL 81	
26 RCL 84	106 -	
27 /	107 STO 85	
28 *R2= *	108 END	
29 APCL X		
30 PROMPT		
31 STO 81		

77-01-5007-HOCA

LOADS:

$$|W+P_d| = 1050 \text{ lb.}$$



CONSIDER LUGS:  $1/2'' \times 3/4'' \times 1''$  Long

$$\text{Stress: } \sigma_y = \frac{1050}{4(1/2)(1)} = 525 \text{ psi} < 14,400 \text{ psi}$$

CONSIDER SPRING HANGER & CLEVISES:

Assume Grinnell parts -

<u>Part</u>	<u>allowable load (lb.)</u>
290	1810
140	1810
66	1810
(2) S-267, TO C SIZE 7	1064

Actual loads are less than allowable.

CONSIDER 2x3x1/4 TUGGERS: (use largest beam)




$$A = 2.72 \text{ in}^2$$

$$I = 3.12 \text{ in}^4$$

shear:  $\sigma_v = \frac{525}{2.59} = 203 \text{ psi} < 14,400 \text{ psi}$

bending:  $\sigma_b = \frac{525(21)}{2.10} = 5250 \text{ psi} < 23,760 \text{ psi}$

CONSIDER PLATE A:



use "PLATE" program —

bending:  $\sigma_{b_{max}} = 12,832 \text{ psi}$  for plate "A"  $< 23,760 \text{ psi}$

$\sigma_{b_{max}} = 8,697 \text{ psi}$  for plate "B"  $< 23,760 \text{ psi}$

tension:  $\sigma_t = \frac{525}{[9 - 2(3/4)](3/4)} = 93 \text{ psi} < 21,600 \text{ psi}$

shear:  $\sigma_v = \frac{525}{4(11/2)(1/2)} = 175 \text{ psi} < 14,400 \text{ psi}$

CONSIDER BOLTS:

For plate "A" →

Tension:  $\rho = \frac{1102.5}{(7.5)(2)} = 735 \text{ lb/bolt}$

shear:  $\rho = \frac{525}{4} = 131 \text{ lb/bolt}$

For plate "B" →

$$\text{Tension: } \rho = \frac{2337}{(10/2)(2)} = 138 \text{ lb/bolt}$$

$$\text{Shear: } \rho = \frac{525}{4} = 131 \text{ lb/bolt}$$

These loads appear reasonable for the respective bolt sizes, however, allowables are unknown.

Consider welds:

Lug to pipe → 3/16" fillet, both sides

$$\text{Shear: } \sigma_y = \frac{525}{.707(3/16)(8)(1)} = 495 \text{ psi}$$

Clavis to tubing → 1/4" fillet, both sides

$$\text{Tension: } \sigma_t = \frac{525}{.707(1/4)(2)(11/4)} = 1188 \text{ psi}$$

Tubing to plate → 1/4" fillet, all around

$$\text{Shear: } \sigma_y = \frac{525}{.707(1/4)(6)} = 495 \text{ psi}$$

$$\text{Tension: } \sigma_b = \frac{525(21)}{.707(1/4)(6)(3)} = 3,465 \text{ psi}$$

Consider size clamp:

For 2 Grinnell HJ 40 clamp, allowable load  
= 3450 lbs > 1050 lbs.

∴ This support is acceptable.

PLATE "A"

03	2.25	2.25
04	3.75	3.75
05	2.25	2.25
06	3.75	3.75
07	7.5	7.5
08	7.5	7.5
09	3675	-3675
10	6.52E-10	6.52E-10
14	1.12E+06	1.12E+06

"	$\omega_{xx}$	-0.0007	.00003
"	$\omega_{yy}$	-0.0007	.00019
"	$\omega_{zy}$	-4.72E-15	3.53E-15
"	$M_{xx}$	1046.55	-97.86
"	$M_{yy}$	984.07	-223.60
"	$M_{xy}$	-3.70E-09	2.76E-09
"	$T_x$	11,163.23	-1043.79
"	$T_y$	10,495.73	-2335.04
"	$T_{xy}$	-3.95E-08	2.95E-08

TOTAL

12,207  
12,332  
5.90E-08

PLATE "B"

03	3.75	3.75
04	5.25	5.25
05	3.75	6.75
06	5.25	5.25
07	10.5	10.5
08	10.5	10.5
09	963	-963
10	1.12E-09	1.12E-09
14	3.32E+05	3.32E+05

$\omega_{xx}$	- .0007	.00007
$\omega_{yy}$	- .0006	.0003
$\omega_{xy}$	-1.14E-14	-2.64E-14



$M_{xx}$	284.50	-46.87
$M_{yy}$	272.44	-29.95
$M_{xy}$	-2.65E-09	-5.14E-09

TOTAL

$\sigma_x$	6,827.90	-1,124.87	7,952.73
$\sigma_y$	6,558.67	-2,158.73	8,697.40
$\sigma_{xy}$	-5.3E-08	-1.47E-07	2.10E-07

JZ-01-6007-H000

loads:  $|W + P_d + T| = 2040 \text{ lbs.}$



CONSIDER LUGS:  $5/8'' \times 1'' \times 1''$  long

shear:  $\sigma_v = \frac{2040}{4(1)(1)} = 510 \text{ psi} < 14,400 \text{ psi}$

CONSIDER CLAMP:

For a Grinnell HJ40 clamp with  $5/8''$  bolts,  
allowable load =  $3450 \text{ lbs} > 2040 \text{ lbs.}$

CONSIDER SPRING HANGERS & CLEVISES:


ASSUME Grinnell parts -

<u>Part</u>	<u>Allowable Load (lbs)</u>
290	2710
140	2710
(2) 82, TYPE A #9	2040 / 2040

Actual loads < allowances


CONSIDER A 3x3x 1/2 x 1'-5^{3/4}" :

Consider as - a Fixed-Fixed beam w/ loads applied at center -



Shear:  $\sigma_y = \frac{1020/2}{2.75} = 185 \text{ psi} < 14,400 \text{ psi}$

Bending:  $a = 2.75 \text{ in}^2$        $I_x = I_y = 2.32 \text{ in}^4$   
 $x_0 = y_0 = 0.932 \text{ in.}$        $r_0 = 0.584 \text{ in}$



$$I_u = 2.75(0.584)^2 = 0.938 \text{ in}^4$$

$$I_v = 2(2.32) - 0.938 = 3.502 \text{ in}^4$$

$$V_A = -1.318 \quad V_B = 1.478 \quad V_C = 1.478 \\ U_A = 0. \quad U_B = -2.796 \quad U_C = 2.796$$

$$M_u = \frac{-707(1020)(15\frac{3}{4})}{8} = -1420 \text{ in-lb}$$

$$M_v = \frac{707(1020)(15\frac{3}{4})}{8} = 1420 \text{ in-lb.}$$


$$\sigma_A = \frac{-1420(-1.318)}{0.938} = 1995 \text{ psi} < 21,600 \text{ psi}$$

$$\sigma_B = \frac{-1420(1.478)}{0.938} + \frac{1420(-2.796)}{3.502} = 3371 \text{ psi} < 21,600 \text{ psi}$$

$$\sigma_C = \frac{-1420(1.478)}{0.938} + \frac{1420(2.796)}{3.502} = -1104 \text{ psi} < 21,600 \text{ psi}$$

CONSIDER A 3x3x 1/2 x 3'-10"

consider as a Fixed-Fixed beam with loads applied as shown -



shear:  $\sigma_y = \frac{2(510)(21)^2[(3)(15) + 31]}{45^3} = 223 \text{ psi} < 14,400 \text{ psi}$

bending:  $M_{max} = \frac{2(510)(15)(21)^2}{45^3} = 6949 \text{ in-lb}$

$$M_u = -707(6949) = -4913 \text{ in-lb}$$

$$M_v = .707(6949) = 4913 \text{ in-lb}$$

$$\sigma_A = -\frac{4913/(-1.318)}{.938} = +6903 \text{ psi} < 21,600 \text{ psi}$$


$$\sigma_o = -\frac{4913/(1.473)}{.938} + \frac{4913/(2.795)}{3.502} = 11,664 \text{ psi} < 21,500 \text{ psi}$$

$$\sigma_c = -\frac{4913/(1.473)}{.938} + \frac{4913/(2.795)}{3.502} = -3819 \text{ psi} < 21,500 \text{ psi}$$

TORSION:  $J = \frac{1}{3} \left[ 3(1/2)^3 + (3-1/2)(1/2)^2 \right] = 0.229 \text{ in}^4$

$$\tau = \frac{Tc}{J} = \frac{2/2008)(1/2)}{0.229} = 3769 \text{ psi} < 14,400 \text{ psi}$$

CONSIDER PAGE PLATE:



$$419 \text{ lb} = \frac{2(510\text{Vz})}{0.75} + \frac{2008}{0.75}$$

-3-

$$\frac{2008}{0.75} = \frac{2(510\text{Vz})}{0.75} = 334 \text{ lb.}$$

FOR 1/2" R -

$$\text{shear: } \sigma_V = \frac{334}{(4\frac{1}{2} - \frac{3}{4})(\frac{1}{2})} = 445 \text{ psi} < 14,400 \text{ psi}$$

$$\text{TORSION: } T = \frac{2008(\frac{1}{2})(\frac{1}{2})}{4\frac{1}{2}(\frac{1}{2})^3} = 5355 \text{ psi} < 14,400 \text{ psi}$$

FOR 3/4" R -

$$\text{shear: } \sigma_V = \frac{419}{2(1\frac{3}{16})(\frac{3}{4})} = 160 \text{ psi} < 14,400 \text{ psi}$$

$$\text{TENSION: } \sigma_T = \frac{419}{(4\frac{3}{4} - 1)(\frac{3}{4})} = 150 \text{ psi} < 21,600 \text{ psi}$$

$$\text{BENDING: } \sigma_b = \frac{2008(3\frac{1}{4}\frac{1}{2})}{4\frac{3}{4}(\frac{3}{4})^2/12} = 4509 \text{ psi} < 27,000 \text{ psi}$$

CONJUGATE BOLTS:

For  $\frac{3}{16}$ " Fig. J-34 Philip's -

$$\text{shear} = 334 \text{ lb} < 16,516/5 = 3303 \text{ lb. allowable}$$

$$\text{tension} = \frac{2008}{4.25} = 472 \text{ lb.} < 17,675/5 = 3535 \text{ lb. allow}$$

For 1" A312 bolt -

$$\text{shear} = 419 \text{ lb.} < 26879/5 = 5375 \text{ lb. allowable}$$

$$\text{tension} = 472 \text{ lb.} < 14,000/5 = 2800 \text{ lb. allow.}$$

CONJUGATE WELDS:

$\Delta 3 \times 3 \times \frac{1}{2}$  to  $\Delta 3 \times 3 \times \frac{1}{2}$  -  $\frac{3}{16}$ " fillet

$$\text{shear: } \sigma_v = \frac{1020/2}{.707(\frac{3}{16})(12)} = 321 \text{ psi}$$

$$\text{bonding: } \sigma_b = \frac{1020(15\frac{3}{16})/2}{.707(\frac{3}{16})[\frac{4(3)(15)}{6} + (\frac{3}{2})^2]} = 2020 \text{ psi}$$

$$\text{torsion: } 2341 \text{ psi}$$

$\Delta 3 \times 3 \times \frac{1}{2}$  to anchor -  $\frac{3}{16}$ " fillet

$$\text{shear: } \sigma_v = \frac{\frac{2(510)(31)^2}{463}[3(15) - 31]}{.707(\frac{3}{16})(12)} = 786 \text{ psi}$$


$$\text{bonding: } \sigma_b = \frac{6949}{.707(\frac{3}{16})[\frac{4(3)(15) - (\frac{3}{2})^2}{6}]} = 6987 \text{ psi}$$

$$\text{torsion: } T = \frac{2(2007)}{.707(\frac{3}{16})[(\frac{3+1}{2})^2 - \frac{5(3+2)(2+2)}{12(3+2)}]} = 2693 \text{ psi}$$

$$\text{D-76} \quad \text{torsion: } 10,008 \text{ psi}$$

∴ This support is acceptable.

52-01-5007-H00C




CONSIDER JUGGERS AND CLEVISSES:

FOR PJA-3, allowable load = 6000 lbs. LEVEL A = 0  
 = 10,880 lbs. LEVEL B = 0

∴ Imposed load is below allowables

CONSIDER HORIZONTAL WIDE FLANGE:

conservatively consider WF as a cantilever beam  
 w/out bracing -




STRESS:  $\sigma_v = \frac{562}{4.56} = 123 \text{ psi} < 14,400 \text{ psi}$

STRESS:  $\sigma_b = \frac{562(21\frac{1}{4})}{10} = 1194 \text{ psi} < 37,750 \text{ psi}$

CONSIDER LUGS:  $3/4'' \times 1'' \times 2''$  long

$$\text{shear: } \sigma_v = \frac{1125}{4(1)(2)} = 141 \text{ psi} < 14,400 \text{ psi}$$

CONSIDER BASE PLATE:  $3/4'' \times 10'' \times 10''$



Bending: Conservatively consider plate to be simply supported beam with moment applied at center -

$$\sigma_b = \frac{11943 (3/4)/2}{7\frac{1}{2}(3/4)^3/12} = 16986 \text{ psi} < 22,760 \text{ psi}$$

$$\text{shear: } \sigma_v = \frac{562}{4(1\frac{1}{4})(\frac{3}{4})} = 150 \text{ psi} < 14,400 \text{ psi}$$

$$\text{tension: } \sigma_t = \frac{562}{[10 - 2(\frac{3}{4})](\frac{3}{4})} = 88 \text{ psi} < 21,600 \text{ psi}$$

CONSIDER BOLTS:

$$\text{tension: } P_t = \frac{11943}{7\frac{1}{2}(3)} = 796 \text{ lb/bolt}$$

$$\text{shear: } P_s = \frac{562}{4} = 143 \text{ lb/bolt}$$

Although the face of each bolt is greater than loads, reasonable to use  $3/4''$  bolts.

CONTINUED WELDS:

Clevis to WF → 1/4" fillet, all around

$$\text{Tension: } \sigma_t = \frac{562}{.707(1/4)(2.25)(4)} = 353 \text{ psi}$$

WF to plate → 1/4" fillet, all around

$$\text{Shear: } \sigma_y = \frac{562}{2(3.45)(.707)(1/4)} = 291 \text{ psi}$$

$$\text{Bending: } \sigma_b = \frac{11943}{.707(1/4)(6)(3.995)} = 1879 \text{ psi}$$


CONTINUED RIGID CLAMPS:

Assume 2 5" Grinnell HJ 40 rigid clamps:

allowable load = 3450 lbz. > 1125 lbz.

∴ This support is acceptable.

JF-01-5007-H000



$$\text{LOADS: } |W+P_d| + (\Sigma E^2 + \Lambda M^2)^{1/2} = 1008 \text{ lbs.}$$

CONSIDER INCLINED CLAMP, CLEVIS:

For Grinnell Fig. 201 assembly, the allowable load = 10,350 lbs. > 1008 lbs.


CONSIDER WELDS:

Clevis plate to base plate - 7/16" fillet all around

$$\text{STRESSES: } \sigma_y = \frac{1008 \text{ lbs}}{.707(\frac{7}{16})(10)} = 441 \text{ psi}$$


$$\text{TENSION: } \sigma_t = \left[ \frac{(1008 \text{ lbs}) (\frac{7}{16})}{5} + 1010 \sin \varphi \right] \cdot \frac{1}{.707(\frac{7}{16})(10)} \\ = 405 \text{ psi}$$

CONSIDER BASE PLATE + BOLTS:



First, consider main plate as if there was not a rigid connector in upper left corner:

Pending:




$$\sigma_b = \left[ \frac{3164 + \frac{261(7)}{4}}{4} \right] \frac{(1/2)(1/2)}{7(1/2)^2 / 12} = 12414 \text{ psi} < 23,760 \text{ psi}$$

TENSION:  $\sigma_t = \frac{974}{[4 - 2(\frac{7}{14})]^{1/2}} = 250 \text{ psi} < 21,500 \text{ psi}$

Shear:  $\sigma_v = \frac{974}{4(1)(1/2)} = 487 \text{ psi} < 14,400 \text{ psi}$

2. Second, consider bolt loads taking into account eccentric bolt pattern:



Since c.g. of bolt pattern is so close to point of loading, ignore eccentricity and consider safety factor in doing so.


Shear:  $\sigma_v = \frac{974}{4} = 244 \text{ lb/bolt}$

Tension:  $\sigma_t = \frac{261}{4} + \frac{3164}{2(7)} = 291 \text{ lb/bolt}$

For 3/4" Hilt Lube bolts the ultimate shear load is 13,257 lb. and the ultimate tensile load is 3155 lb.

Although the allowable loads for the 3/4" 3/4" bolts are unknown, the imposed loads are so small that they are deemed acceptable.

3. Consider joint of extension plate to main plate:



$$\sigma = \left[ \frac{244 + 291 + 291/244}{5} \right] \frac{1}{1.7(2)(3) + 1} / \frac{1}{5(1+3)} = 6956 \text{ psi}$$


∴ This support is acceptable.

EE-01-6007-HOOG

LOADS:

$$|W + P_d + T| + (SSE^2 + 1M^2)^{1/2}$$

$$= 862 \text{ lbs.}$$




CONSIDER INNUMBER CLAMP, CLEVIS:

ASSUME all PACIFIC JOURNAL PJIA-3 PARTS:

allowable load = 6000 lbs	LEVEL A+C
10,580 lbs	LEVEL C=D


CONSIDER BASE PLATE:



TENSION:  $\sigma_t = \frac{747}{[10 - 2(7/16)](7/16)} = 119 \text{ psi} < 21,600 \text{ psi}$

STRESS:  $\sigma_s = \frac{747}{4(1\frac{1}{8})(7/16)} = 181 \text{ psi} < 14,400 \text{ psi}$

Conclusion: Conservatively ignore nuts bolts and  
base plate is a simply supported  
beam with moment arm at one  
length of 1 ft -



$$\sigma_b = \frac{mc}{I} = \left[ \frac{431(26)}{4} + 1494 \right] \frac{(3/4)/2}{7(3/4)^3/12} = 6546 \text{ psi} < 23,750 \text{ psi}$$

CONSIDER BOLTS:

shear:  $\frac{747}{6} = 125 \text{ lb/bolt}$

TENSION: consider corner bolts only -

$$\frac{1494}{2(26)} = \frac{431}{4} = 136 \text{ lb/bolt}$$

∴ Although bolt type is unknown, these loads appear acceptable for 3/4" concrete anchors.

CONSIDER WELDS:

Clevis plate to base plate - 1/4" fillet all around

shear:  $\sigma_v = \frac{747}{.707(1/4)(10)} = 423 \text{ psi}$

TENSION:  $\sigma_t = \frac{431 + 1494/5}{.707(1/4)(10)} = 413 \text{ psi}$

∴ This support is acceptable.

JJ-01-6007-H20F

114" x 4" x 6" ICR2


LOADS:

$$Y\text{-dir. } |W + P_d + T| = 1036 \text{ lb/in}$$

$$|W + P_d + T| + (\Sigma E^2 + A M^2)^{1/2} = 1645 \text{ lb/in}$$

$$INC. \quad |W + P_d + T| = 103 \text{ lb/in.}$$

$$|W + P_d + T| + (\Sigma E^2 + A M^2)^{1/2} = 442 \text{ lb/in.}$$



Utilize computer program "FRAME" to find reactions in structural members: Analyze for worst load combinations

CONSIDER W4x12 MEMBERS:

$$A = 3.83 \text{ in}^2, \quad S = 3.46 \text{ in}^3$$

$$\text{TENSION: } \sigma_t = \frac{1825}{3.83} = 477 \text{ psi} < 21,600 \text{ psi}$$

$$\text{COMPRESSION: } C_c = 125$$

$$\frac{C_c}{F} = \frac{2(42)}{1.0} = 84 < 125$$

$$\sigma_a = \left[ \frac{1 - (84)^2}{2(125)^2} \right] 25,000 = 14,397 \text{ psi}$$

$$\frac{S}{3} + \frac{2(84)}{3(125)} - \frac{(84)^2}{3(125)^2}$$

$$\text{LEVEL D} = 23010 \text{ psi}$$

$$\sigma_a = \frac{334}{3.83} = 879 \text{ psi} < 14,397 \text{ psi}$$

$$\text{Shear: } \sigma_y = \frac{1152}{3.83} = 303 \text{ psi} < 14,400 \text{ psi}$$

$\sigma = 8576$

$$\text{Bending: } \sigma_b = \frac{2954}{5.46} = 530 \text{ psi} < 23,760 \text{ psi}$$

CONSIDER 114 x 4 x 6 I:

$$\text{Tension: } \sigma_t = \frac{176}{5.0} = 117 \text{ psi} < 21,600 \text{ psi}$$


$$\text{Shear: } \sigma_v = \frac{266}{5} = 53 \text{ psi} < 14,400 \text{ psi}$$

$$\text{Bending: } \sigma_b = \frac{789 (114/2)}{4(114)^3/12} = 757 \text{ psi} < 27000 \text{ psi}$$

CONSIDER PAIR PLATES:

Analyze plates as simply supported beam with loads applied at center:

Top plate:




$$\text{Bending: } \left[ 2954 + \frac{1711(20)}{4} \right] \frac{1/2}{17(1)^3/12} = 4418 \text{ psi} < 27000 \text{ psi}$$

$$\text{Tension: } \sigma_t = \frac{476}{[21 - 2(1^3/8)](1)} = 26 \text{ psi} < 21,600 \text{ psi}$$

$$\text{Shear: } \sigma_v = \frac{476}{4(2)(1)} = 60 \text{ psi} < 14,400 \text{ psi}$$

Bottom plate:



$$\text{Bending: } \left[ 1090 + \frac{1269(13)}{4} \right] \frac{1/2}{13(1/2)^2/12} = 9526 \text{ psi} < 27000 \text{ psi}$$

$$\text{Tension: } \sigma_t = \frac{1326}{\left[ 16 - 2 \left( \frac{13}{10} \right) \right] 1/2} = 184 \text{ psi} < 21,000 \text{ psi}$$

$$\text{Shear: } \sigma_v = \frac{1326}{4(1/2)(1/2)} = 111 \text{ psi} < 14,400 \text{ psi}$$

### CONSIDER ANCHOR BOLTS:

At top anchor:

$$\text{Shear: } \sigma_v = \frac{475}{4} = 116 \text{ lb/bolt}$$

$$\text{Tension: } \sigma_t = \frac{1711}{4} + \frac{3964}{2(17)} = 544 \text{ lb/bolt}$$

These loads appear reasonable for 1/4" concrete anchors.

At bottom anchor:

$$\text{Shear: } \sigma_v = \frac{1326}{4} = 332 \text{ lb/bolt}$$

$$\text{Tension: } \sigma_t = \frac{1269}{4} + \frac{1090}{2(13)} = 359 \text{ lb/bolt}$$

These loads appear reasonable for 3/4" concrete anchors.

### CONSIDER WELDS:

Welds to base plate: 7/16" fillet

$$\text{Tension: } \sigma_t = \frac{\frac{1711 - 3964}{3}}{7.07 \left( \frac{7}{16} \right) (4)} = 7432 \text{ psi}$$

D-87

$$\text{shear: } \sigma_v = \frac{1326}{.707(5/16)(2)(2^{3/4})} = 1819 \text{ psi}$$

204x15 to 204x15: 1/4" fillet

$$\text{shear: } \sigma_v = \frac{1724}{.707(1/4)(2)(2^{3/4})} = 1773 \text{ psi}$$

$$\text{TENSION: } \sigma_t = \frac{\frac{1162}{2} + \frac{2724}{4}}{.707(1/4)(4)} = 1789 \text{ psi}$$

2 1/4 x 4 x 6 to 204x15: 5/16" fillet

$$\text{shear: } \sigma_v = \frac{266}{.707(5/16)(3)} = 151 \text{ psi}$$

$$\text{TENSION: } \sigma_t = \frac{586 + 739/1^{1/4}}{.707(5/16)(3)} = 689 \text{ psi}$$

Total 840 psi

- ∴ This support appears acceptable. However, it should be noted that additional loading will be imposed by the other piping supported by this structure. This additional loading will probably not overstress the structure.

Revised loadings of (1442, 496) vs the original loads of (1647 and 496) required analysis. Since the revised load decreased to some % as the horizontal load increased in 1/3 times the horizontal, and would contribute more to the stress in the buckling element, the support has D-58 the same stress rules - OK.

卷之三

0.0006  
-2.00451, I = 10.6211, V = 10.715955 LCCN 11055

D-87

卷之三

Job title	Number of firms	Percentage of firms
Marketing manager	1,100	10.0
Sales manager	1,000	9.1
Production manager	900	8.3
Quality manager	800	7.4
Logistics manager	700	6.5
Human resources manager	600	5.5
Financial manager	500	4.6
Information systems manager	400	3.6
Research and development manager	300	2.7
Procurement manager	200	1.8
Other managers	1,000	9.1
Total	11,000	100.0

P-70



S. S. SINGH

ITEM	GENERAL INFORMATION		APPROVALS		GENERAL INFORMATION		APPROVALS	
	ITEM	DESCRIPTION	ITEM	DESCRIPTION	ITEM	DESCRIPTION	ITEM	DESCRIPTION
1	1	1	2	2	3	3	4	4
2	2	2	3	3	4	4	5	5
3	3	3	4	4	5	5	6	6
4	4	4	5	5	6	6	7	7
5	5	5	6	6	7	7	8	8
6	6	6	7	7	8	8	9	9
7	7	7	8	8	9	9	10	10
8	8	8	9	9	10	10	11	11
9	9	9	10	10	11	11	12	12
10	10	10	11	11	12	12	13	13
11	11	11	12	12	13	13	14	14
12	12	12	13	13	14	14	15	15
13	13	13	14	14	15	15	16	16
14	14	14	15	15	16	16	17	17
15	15	15	16	16	17	17	18	18
16	16	16	17	17	18	18	19	19
17	17	17	18	18	19	19	20	20
18	18	18	19	19	20	20	21	21
19	19	19	20	20	21	21	22	22
20	20	20	21	21	22	22	23	23
21	21	21	22	22	23	23	24	24
22	22	22	23	23	24	24	25	25
23	23	23	24	24	25	25	26	26
24	24	24	25	25	26	26	27	27
25	25	25	26	26	27	27	28	28
26	26	26	27	27	28	28	29	29
27	27	27	28	28	29	29	30	30
28	28	28	29	29	30	30	31	31
29	29	29	30	30	31	31	32	32
30	30	30	31	31	32	32	33	33
31	31	31	32	32	33	33	34	34
32	32	32	33	33	34	34	35	35
33	33	33	34	34	35	35	36	36
34	34	34	35	35	36	36	37	37
35	35	35	36	36	37	37	38	38
36	36	36	37	37	38	38	39	39
37	37	37	38	38	39	39	40	40
38	38	38	39	39	40	40	41	41
39	39	39	40	40	41	41	42	42
40	40	40	41	41	42	42	43	43
41	41	41	42	42	43	43	44	44
42	42	42	43	43	44	44	45	45
43	43	43	44	44	45	45	46	46
44	44	44	45	45	46	46	47	47
45	45	45	46	46	47	47	48	48
46	46	46	47	47	48	48	49	49
47	47	47	48	48	49	49	50	50
48	48	48	49	49	50	50	51	51
49	49	49	50	50	51	51	52	52
50	50	50	51	51	52	52	53	53
51	51	51	52	52	53	53	54	54
52	52	52	53	53	54	54	55	55
53	53	53	54	54	55	55	56	56
54	54	54	55	55	56	56	57	57
55	55	55	56	56	57	57	58	58
56	56	56	57	57	58	58	59	59
57	57	57	58	58	59	59	60	60
58	58	58	59	59	60	60	61	61
59	59	59	60	60	61	61	62	62
60	60	60	61	61	62	62	63	63
61	61	61	62	62	63	63	64	64
62	62	62	63	63	64	64	65	65
63	63	63	64	64	65	65	66	66
64	64	64	65	65	66	66	67	67
65	65	65	66	66	67	67	68	68
66	66	66	67	67	68	68	69	69
67	67	67	68	68	69	69	70	70
68	68	68	69	69	70	70	71	71
69	69	69	70	70	71	71	72	72
70	70	70	71	71	72	72	73	73
71	71	71	72	72	73	73	74	74
72	72	72	73	73	74	74	75	75
73	73	73	74	74	75	75	76	76
74	74	74	75	75	76	76	77	77
75	75	75	76	76	77	77	78	78
76	76	76	77	77	78	78	79	79
77	77	77	78	78	79	79	80	80
78	78	78	79	79	80	80	81	81
79	79	79	80	80	81	81	82	82
80	80	80	81	81	82	82	83	83
81	81	81	82	82	83	83	84	84
82	82	82	83	83	84	84	85	85
83	83	83	84	84	85	85	86	86
84	84	84	85	85	86	86	87	87
85	85	85	86	86	87	87	88	88
86	86	86	87	87	88	88	89	89
87	87	87	88	88	89	89	90	90
88	88	88	89	89	90	90	91	91
89	89	89	90	90	91	91	92	92
90	90	90	91	91	92	92	93	93
91	91	91	92	92	93	93	94	94
92	92	92	93	93	94	94	95	95
93	93	93	94	94	95	95	96	96
94	94	94	95	95	96	96	97	97
95	95	95	96	96	97	97	98	98
96	96	96	97	97	98	98	99	99
97	97	97	98	98	99	99	100	100
98	98	98	99	99	100	100	101	101
99	99	99	100	100	101	101	102	102
100	100	100	101	101	102	102	103	103
101	101	101	102	102	103	103	104	104
102	102	102	103	103	104	104	105	105
103	103	103	104	104	105	105	106	106
104	104	104	105	105	106	106	107	107
105	105	105	106	106	107	107	108	108
106	106	106	107	107	108	108	109	109
107	107	107	108	108	109	109	110	110
108	108	108	109	109	110	110	111	111
109	109	109	110	110	111	111	112	112
110	110	110	111	111	112	112	113	113
111	111	111	112	112	113	113	114	114
112	112	112	113	113	114	114	115	115
113	113	113	114	114	115	115	116	116
114	114	114	115	115	116	116	117	117
115	115	115	116	116	117	117	118	118
116	116	116	117	117	118	118	119	119
117	117	117	118	118	119	119	120	120
118	118	118	119	119	120	120	121	121
119	119	119	120	120	121	121	122	122
120	120	120	121	121	122	122	123	123
121	121	121	122	122	123	123	124	124
122	122	122	123	123	124	124	125	125
123	123	123	124	124	125	125	126	126
124	124	124	125	125	126	126	127	127
125	125	125	126	126	127	127	128	128
126	126	126	127	127	128	128	129	129
127	127	127	128	128	129	129	130	130
128	128	128	129	129	130	130	131	131
129	129	129	130	130	131	131	132	132
130	130	130	131	131	132	132	133	133
131	131	131	132	132	133	133	134	134
132	132	132	133	133	134	134	135	135
133	133	133	134	134	135	135	136	136
134	134	134	135	135	136	136	137	137
135	135	135	136	136	137	137	138	138
136	136	136	137	137	138	138	139	139
137	137	137	138	138	139	139	140	140
138	138	138	139	139	140	140	141	141
139	139	139	140	140	141	141	142	142
140	140	140	141	141	142	142	143	143
141	141	141	142	142	143	143	144	144
142	142	142	143	143	144	144	145	145
143	143	143	144	144	145	145	146	146
144	144	144	145	145	146	146	147	147
145	145	145	146	146	147	147	148	148
146	146	146	147	147	148	148	149	149
147	147	147	148	148	149	149	150	150
148	148	148	149	149	150	150	151	151
149	149	149	150	150	151	151	152	152
150	150	150	151	151	152	152	153	153
151	151	151	152	152	153	153	154	154
152	152	152	153	153	154	154	155	155
153	153	153	154	154	155	155	156	156
154	154	154	155	155	156	156	157	157
155	155	155	156	156	157	157	158	158
156	156	156	157	157	158	158	159	159
157	157	157	158	158	159	159	160	160
158	158	158	159	159	160	160	161	161
159	159	159	160	160	161	161	162	162
160	160	160	161	161	162	162	163	163
161	161	161	162	162	163	163	164	164
162	162	162	163	163	164	164	165	165
163	163	163	164	164	165	165	166	166
164	164	164	165	165	166	166	167	167
165	165	165	166	166	167	167	168	168
166	166	166	167	167	168	168	169	169
167	167	167	168	168	169	169	170	170
168	168	168	169	169	170	170	171	171
169	169	169	170	170	171			

0-92



SI-01-6007-H306

loads:

$$\underline{Y\text{-dir.}} \quad |W + P_d + T| = 626 \text{ lbz.}$$

$$|W + P_d + T| + (\Sigma E^2 + AM^2)^{1/2} = 705 \text{ lbz.}$$

$$\underline{\text{Lat. - dir.}} \quad |W + P_d + T| = 151 \text{ lbz.}$$

$$|W + P_d + T| + (\Sigma E^2 + AM^2)^{1/2} = 287 \text{ lbz.}$$

This support is essentially the same as  
SI-01-6007-H30F and the loads applied here  
are significantly less than those utilized  
in the analysis of SI-01-6007-H30F. Therefore,  
this support appears acceptable with the  
same comments as given for SI-01-6007-H30F.

JJ-01-6007-H30.4


LOADS:

V-Dir.  $|W + P_d + T| = 198 \text{ lb.}$

$$|W + P_d + T| + (2SE^2 + 1M^2)^{1/2} = 347 \text{ lb.}$$

Z-Dir.  $|W + P_d + T| = 106 \text{ lb.}$

$$|W + P_d + T| + (2SE^2 + 1M^2)^{1/2} = 272 \text{ lb.}$$



utilize computer program "FRAME" to find reactions in structural members: Analyze for worst load combinations

CONSIDER 54x7.7 MEMBER  $A = 2.26 \text{ in}^2, Z = 204 \text{ in}^3$

TENSION:  $\sigma_t = \frac{551}{2.26} = 244 \text{ psi} < 21,600 \text{ psi}$

COMPRESSION:  $C_c = 126$

$$\frac{C_c}{F} = \frac{2(18)}{0.581} = 61.96 < 126$$

$$F_2 = \frac{\left[1 - \frac{(51.95)^2}{2(126)}\right] 36,000}{\frac{5}{3} + \frac{2(51.95)}{3(126)} - \frac{(51.95)^2}{3(126)}} = 17,235 \text{ psi}$$

LIVE D = 32,402 psi

$$\sigma_2 = \frac{551}{2.26} = 245 \text{ psi} < 17,235 \text{ psi}$$

FLOR:  $\sigma_v = \frac{202}{2.26} = 147 \text{ psi} < 14,400 \text{ psi}$

Bending:  $\sigma_b = \frac{1549}{3.04} = 510 \text{ psi} < 23,760 \text{ psi}$

COLLIDER L 2x2x14:

Tension:  $\sigma_t = \frac{470}{.938} = 501 \text{ psi} < 21,600 \text{ psi}$

Compression:  $C_c = 126$

$$\frac{EI}{r} = \frac{2(25.5)}{.609} = 83.74 < 126$$


$$F_2 = \frac{\left[1 - \frac{(83.74)^2}{2(126)^2}\right] 36,000}{\frac{5}{3} + \frac{3(83.74)}{8(126)} - \frac{(83.74)^2}{8(126)^2}} = 14,926 \text{ psi}$$

Level A = 23,051 psi

$$\sigma_a = \frac{466}{.938} = 497 \text{ psi} < 14,926 \text{ psi}$$

Shear:  $\sigma_v = \text{negligible}$

Bending:  $A = .938 \text{ in}^2$        $I_x = I_y = 0.343 \text{ in}^4$   
 $x_0 = y_0 = 0.392 \text{ in}$        $r_u = 0.391 \text{ in}$



$$I_{uv} = A r_u^2 = .938(.391)^2 = 0.143 \text{ in}^4$$

$$I_{vv} = 2(.343) - .143 = 0.553 \text{ in}^4$$

$$V_A = -0.827 \quad V_B = 0.577 \quad V_C = 0.577 \\ U_A = 0 \quad U_B = -1.414 \quad U_C = 1.414$$

$$M_u = .707(12) = -12 \text{ in-lb}$$

$$M_v = .707(12) = 12 \text{ in-lb} \quad D-96$$

$$\sigma_A = \frac{-12(-.777)}{.143} = -76 \text{ psi} < 21,600 \text{ psi}$$

$$\sigma_B = \frac{-12(.577)}{.143} + \frac{12(-1.414)}{.553} = 86 \text{ psi} < 21,600 \text{ psi}$$

$$\sigma_C = \frac{-12(.577)}{.143} + \frac{12(1.414)}{.553} = -42 \text{ psi} < 21,600 \text{ psi}$$

CONSIDER X & Y SHEAR:

Tension:  $\sigma_t = \frac{253}{2.11} = 120 \text{ psi} < 21,600 \text{ psi}$

Compression: Negligible

Shear:  $\sigma_y = \frac{253}{2.11} = 120 \text{ psi} < 14,400 \text{ psi}$

Bending:  $I = 2.11 \text{ in}^2$        $I_x = I_y = 1.76$   
 $K_0 = 4_0 = 0.888$        $I_u = 0.587$

$$I_u = 2.11(0.587)^2 = 0.727 \text{ in}^4$$

$$I_v = 2(1.76) - .727 = 2.793 \text{ in}^4$$

$$V_A = -1.256 \quad V_B = 0.865 \quad V_C = .865 \\ U_A = 0 \quad U_B = -2.121 \quad U_C = 2.121$$

$$M_u = -707(584) = -413 \text{ in-lb}$$

$$M_v = 707(584) = 413 \text{ in-lb}$$

$$\sigma_A = \frac{-413(-1.256)}{.727} = -714 \text{ psi} < 21,600 \text{ psi}$$

$$\sigma_B = \frac{-413(.865)}{.727} + \frac{413(-2.121)}{2.793} = 800 \text{ psi} < 21,600 \text{ psi}$$

$$\sigma_C = \frac{-413(.865)}{.727} + \frac{413(2.121)}{2.793} = -188 \text{ psi} < 21,600 \text{ psi}$$

CONSIDER A 1/2 x 2 x 7 1/2 :

$$\text{Tension: } \sigma_t = \frac{202}{1/2(2)} = 202 \text{ psi} < 21,600 \text{ psi}$$


$$\text{Shear: } \sigma_v = \frac{120}{1/2(2)} = 120 \text{ psi} < 14,400 \text{ psi}$$

$$\text{Bending: } \sigma_b = \frac{276(1/2/2)}{2(1/2)^2/12} = 2712 \text{ psi} < 27,000 \text{ psi}$$

CONSIDER CAGE PLATES:

Analyze plates as if simply supported beams with loads applied at center

Top plate:




$$\text{Bending: } \left[ 1549 + \frac{553(1/2)}{4} \right] \frac{1/2/2/2}{4(1/2)^2/12} = 38543 \text{ psi}$$

$$F_b (\text{Level D}) = 1.23(75)(36,000) = 50,750 \text{ psi} > 38,543 \text{ psi}$$

$$\text{Tension: } \sigma_t = \frac{186}{[4 - 1/4](7/8)} = 180 \text{ psi} < 21,600 \text{ psi}$$

$$\text{Shear: } \sigma_v = \frac{186}{2(1/2)(7/8)} = 165 \text{ psi} < 14,400 \text{ psi}$$

Bottom plate:



D-98

$$\text{Bending: } \left[ 18 + \frac{313(9)}{4} \right] \frac{(1/2)(1/2)}{5(1/2)^2(1/2)} = 2934 \text{ psi} < 27,000 \text{ psi}$$

$$\text{Tension: } \sigma_t = \frac{745}{[5 - 1/2](1/2)} = 125 \text{ psi} < 21,600 \text{ psi}$$

$$\text{Shear: } \sigma_v = \frac{245}{2(1/2)(1/2)} = 230 \text{ psi} < 14,400 \text{ psi}$$

### CONJUGATE ANCHOR BOLTS:

At top anchor:

$$\text{Shear: } \sigma_v = \frac{185}{2} = 93 \text{ lb/bolt}$$

$$\text{Tension: } \sigma_t = \frac{555}{2} + \frac{549}{15} = 280 \text{ lb/bolt}$$

These loads appear reasonable for 1 1/4" concrete anchors.

$$\text{Minimum edge dist} = 15/8 - 1/8 = 1 1/2"$$

At bottom anchor:

$$\text{Shear: } \sigma_v = \frac{245}{2} = 123 \text{ lb/bolt}$$

$$\text{Tension: } \sigma_t = \frac{213}{2} + \frac{17}{5} = 162 \text{ lb/bolt}$$

These loads appear reasonable for 1/2" concrete anchors.

### CONJUGATE WELDS:

34 x 7.7 to base plate: 1/4" fillet 0-99

$$\text{Tension: } \sigma_t = \frac{\frac{552}{2} + \frac{1549}{5}}{.707(1/4)(25/8)} = 1431 \text{ psi}$$

$$\text{Shear: } \sigma_v = \frac{176}{.707(1/4)(2)(21/2)} = 210 \text{ psi}$$

$\frac{3}{8} \times 2 \times 1/4$  to base plate: 1/4" fillet

$$\text{Tension: } \sigma_t = \frac{218}{.707(1/4)(8)} = 325 \text{ psi}$$

$$\text{Shear: } \sigma_v = \frac{345}{.707(1/4)(8)} = 344 \text{ psi}$$

$$\text{Bending: } \sigma_b = \frac{17}{(.707)(1/4)\left[\frac{4(2)(2) + 12}{6}\right]} = 21 \text{ psi}$$

Total 500 psi

$\frac{3}{8} \times 3 \times 7/8$  to  $54 \times 7.7$ : 1/4" fillet

$$\text{Tension: } \sigma_t = \frac{253}{.707(1/4)(12)} = 119 \text{ psi}$$

$$\text{Shear: } \sigma_v = \frac{185}{.707(1/4)(12)} = 87 \text{ psi}$$

$$\text{Bending: } \sigma_b = \frac{474}{(.707)(1/4)\left[\frac{4(2)(2) - 12}{6}\right]} = 441 \text{ psi}$$

D-100 Total: 547 psi

E 12 x 2 x 7 1/2 to J4 x 7.7

-- Tension:  $\sigma_t = \frac{202}{.707(1/4)(5)} = 229 \text{ psi}$

Shear:  $\sigma_v = \frac{170}{.707(1/4)(5)} = 138 \text{ psi}$

Bending:  $\sigma_b = \frac{275/1/2}{.707(1/4)(2)} = 1561 \text{ psi}$

Total: 1929 psi

- This support appears acceptable with the most critical stresses occurring in the 3/8" base plate. Although a very conservative approach was taken for the plate analysis, it should be considered that loads due to adjacent piping will also be imposed upon this structure.

The loads have been revised:

	Vert.	Horiz.
old load	442	235
new load	147	272
% of old load	79%	116%

The calculation was reviewed, and the baseplate found to control the design. Since a frame analysis was used to run permutations of the possible load combinations, results were used to predict the effect of the load changes on the baseplate loads; and further, this was conservatively bounded by multiplying the ratio of increase by the maximum stress ratio:

$$F/F = (1.16)(0.72) = 0.84$$

0-101

SI-01-4-C07-H304

JOINT NO.	SECTION NO.	DISPLACEMENT		RESTRAINTS		ROTATIONS	
		X	Y	FIXED	FIXED	FIXED	FIXED
1	1	0.000	0.000				
2	2	5.000	0.000				
3	3	2.000	0.000				
4	4	0.000	0.000				
5	5	19.000	0.000				
6	6	13.500	0.000				
7	7	0.000	-25.000				
8	8	2.000	4.000				
9	9	3.000	9.000				
10	10	9.000	9.000				
11	11	15.000	0.000				
12	12	17.000	9.000				
13	13	15.000	4.000				

MEMBER TYPE	SECTION TYPE	GEOMETRIC CONFIGURATION		AFFECTED ELEMENT AXIS		POSITION RELATIVE TO AXIS		UNIT VECTOR FOR A AXIS	
		X	Y	A	B	C	D	E	F
1	2	2.000	0.000	0	6.000	1.7640	1.6410	0.2630	0.0000
2	2	0.000	2.000	0	3.4800	1.4600	1.3460	0.2230	0.0000
3	2	1.100	2.900	0.03	1.7600	1.3300	1.2130	0.2230	0.0000
4	2	1.000	2.931	0.06	0.0210	0.0210	0.0210	0.2630	0.0003
PROPERTIES	TYPE	LENGTH	SECTION TYPE	WEIGHT	LENGTH	SECTION TYPE	WEIGHT	LENGTH	WEIGHT
0	1	2	2	1.000	1.100	3	1.276	1	5.2117
1	1	3	3	0.600	3.771	4	4.000	1	4.5000
2	1	3	3	0.000	4.777	5	4.700	1	4.5000
3	1	3	3	4.000	2.169	6	4.263	1	4.274
4	1	4	4	4.000	2.169	6	4.263	2	4.274
5	1	4	4	4.000	2.169	6	4.263	2	4.274
6	1	4	4	4.000	2.169	6	4.263	2	4.274
7	1	4	4	4.000	2.169	6	4.263	2	4.274
TOTAL STRUCTURAL WEIGHT	46.577	CENTER OF GRAVITY X	13.21699	Y	7.1055	Z	0.0000		

TOTAL STIFFNESS MATRIX FOR 6 EQUATIONS EQUILIBRIUM,  
116 EQUATIONS EQUILIBRIUM,  
987 STORAGE LOCATIONS

## STATIC LOADS

JOINT	CENTRATED LOADS		LOADS APPLIED AROUND THE	
	X DIRECTION	Y DIRECTION	X AXIS	Y AXIS
12	0.	-4720E+03	0.	0.
13	-7350E+03	0.	0.	0.
14	0.	-4720E+03	0.	0.
15	-7350E+03	0.	0.	0.
JOINT	CENTRATED LOADS		ROTATION AROUND THE	
0.	0.	0.	0.	
16	0.	0.	0.	0.
17	-1627E-96	-7725E-64	0.	0.
18	-199E-06	-1356E-03	0.	0.
19	-1246E-04	-4247E-03	0.	0.
20	-1109E-03	-1427E-02	0.	0.
21	-1980E-02	-5604E-02	0.	0.
22	-2745E-01	-4625E-01	0.	0.
23	-4732E-01	-4623E-01	0.	0.
24	-2513E-01	-4179E-01	0.	0.
25	-6138E-01	-6327E-01	0.	0.
26	-5100E-01	-6164E-01	0.	0.
27	0.	0.	0.	0.
28	-8463E-04	-6550E-03	0.	0.
29	-0.	0.	0.	0.
30	ROTATION AROUND THE		ROTATION AROUND THE	
31	0.	0.	0.	0.
32	-1627E-03	-7725E-03	-1405E-03	-6162E-03
33	-199E-03	-1356E-03	-1146E-03	0.
34	-1246E-02	-4247E-02	-1146E-02	0.
35	-1109E-01	-1427E-01	-4572E-01	0.
36	-1980E-01	-5604E-01	-3690E-01	0.
37	-2745E-01	-4625E-01	-4220E-01	0.
38	-4732E-01	-4623E-01	-1116E-01	0.
39	-2513E-01	-4179E-01	-4340E-01	0.
40	-6138E-01	-6327E-01	-1220E-01	0.
41	-5100E-01	-6164E-01	-3906E-01	0.
42	0.	0.	-1130E-01	0.
43	-8463E-03	-6550E-03	-1663E-02	0.
44	-0.	0.	-7460E-02	0.
45	-1627E-03	-7725E-03	-4040E-03	0.
46	-199E-03	-1356E-03	-1959E-03	0.
47	-1246E-02	-4247E-02	-5395E-02	0.
48	-1109E-01	-1427E-01	-5166E-01	0.
49	-1980E-01	-5604E-01	-2619E-01	0.
50	-2745E-01	-4625E-01	-1928E-01	0.
51	-4732E-01	-4623E-01	-4141E-01	0.
52	-2513E-01	-4179E-01	-2307E-01	0.
53	-6138E-01	-6327E-01	-2603E-01	0.
54	-5100E-01	-6164E-01	-1410E-01	0.
55	0.	0.	-2619E-01	0.
56	-8463E-03	-6550E-03	-1928E-01	0.
57	-0.	0.	-4141E-01	0.
58	JOINT SUPPORT CONDITIONS		REACTIONS	
59	DISPLACEMENT IN THE X DIRECTION		X REACTION	
60	DISPLACEMENT IN THE Y DIRECTION		Y REACTION	
61	DISPLACEMENT IN THE Z DIRECTION		Z REACTION	
62	ROTATION AROUND THE X AXIS		X ROTATION	
63	ROTATION AROUND THE Y AXIS		Y ROTATION	
64	ROTATION AROUND THE Z AXIS		Z ROTATION	

D-103


SIGNIFICANT GANS

SUSTAINABLE

$\rho = 105$

SGU 1 JUN 1955

2015

SI-01-6007-H301



Load equation  $|N + P_d + T| + (SSE^2 + AM^2)^{1/2}$

Load Case	Load Description	Node	X-Force lb	Y-Force lb	Z-Force lb
1-1	-X	5	628.0	0	0
1-1	+X	53	915.0	0	0
1-1	+X	28	100	0	0
1-1	+X	21	100	0	0
1-2	-X	13	-556.0	0	0
1-2	-X	13	-1460.0	0	0
1-2	-X	13	-100	0	0
1-2	-X	13	-100	0	0
1-3	-Y	12	0	704.0	0
1-3	-Y	12	0	600	0
1-3	-Y	12	0	100.0	0
1-3	-Y	12	0	100.0	0
1-4	-Y	14	0	0	0
1-4	+Y	14	0	0	0
1-4	+Y	14	0	0	0
1-4	+Y	14	0	0	0

Computer program "Frame" to find numerical  
stress numbers.

D-107


## Frame Model



D-108

Consider Base Plates

Analyze plates as if simply supported beams with displacements allowed only in positive X-direction and loads applied at center.



$$\text{Top plate } A = 4(\frac{3}{8}) = 1.50 \text{ in}^2$$

$$S = \frac{1}{2}(4)(\frac{3}{8})^3 / (\frac{3}{8}) = 0.094 \text{ in}^3$$

$$l = 14$$

$$\text{Bottom plate } A = 6(\frac{1}{2}) = 3.00 \text{ in}^2$$

$$S = \frac{1}{2}(6)(\frac{1}{2})^3 / (\frac{1}{4}) = 0.250 \text{ in}^3$$

$$l = 6"$$

Consider bending in top plate

Load Case	X-Reaction lbs	Y-Reaction lbs	Moment Reac. in-lbs	Load Type
1	-2251	-532.7	-1425	+X
2	3252	688.2	587.8	-X
3	291.3	-585.4	-2733	+Y
4	-550.9	732.3	3871	-Y

Combine Load case 1&3

$$X\text{-React} = -2251 - 291.3 = -1959.7$$

$$\text{Moment React} = -1425 - 2733 = -4158$$

$$T_b = \left[ \frac{1959.7}{4} + 4158 \right] \frac{1}{0.094} = 117,201.6 \text{ psi}$$

Combine load cases 1 & 4

$$X\text{-React} = -2251 - 550.9 = -2801.9 \text{ lb}$$

$$\text{Moment} = -1425 + 3871 = 2446.5 \text{ in-lbs}$$

$$T_b = \left[ \frac{1959.7}{4} - 2446.5 \right] \frac{1}{0.094} = 130,347.3 \text{ psi}$$

Combine Load cases 2 & 3

$$\lambda \text{-React} = 3352 + 291.3 = 3643.3$$

$$\boxed{\frac{2145.2}{0.094}} \text{ Moment React} = 587.8 - 2733 = -2145.2$$

$$T_b = \frac{2145.2}{0.094} = 22,821.3$$

Combine load cases 2 & 4

$$\lambda \text{-React} = 3352 - 550.9 = 2901.1$$


$$\boxed{\frac{4459.8}{0.094}} \text{ Moment React} = 587.8 + 3871 = 4458.8$$

$$T_b = \frac{4458.8}{0.094} = 47,434.0 \text{ psi}$$

The combination of load cases 1 and 3 and the combination of load cases 1 and 4 give the largest bending stresses in the plate. Idealizing the base plate as a simply supported beam gave very high stresses so a finite element model and SUPERSAP were used to determine more realistic stresses.

The stresses for the plate were determined for two load cases. Load case 1 is the combination of cases 1 & 3 and load case 2 is the combination of cases 1 & 4 above.

Super Sap Model Input for Loads



Load Case 1

$$\text{Axial load} = 2251 - 291.3 = 1959.7 \text{ lbs}$$

$$\text{Moment} = -1425 - 2733 = -4158 \text{ lb-in}$$

$$\frac{1959.2}{4} = 489.9 \text{ lbs} \quad \frac{499.9}{2} = 249.9 \text{ lbs}$$

$$-\frac{4158}{3 \text{ lb}} = 1386 \text{ lbs}$$

Node	X-Force	Y-Force	Z-Force
56	0	0	1631.0
57	0	0	489.9
58	0	0	-896.1
59	0	0	489.9
60	0	0	245

$$56 \Rightarrow 245.0 + 1386 = 1631.0$$

$$57 \Rightarrow 489.9$$

$$58 \Rightarrow 489.9 - 1386 = -896.1$$

$$59 \Rightarrow 489.9$$

$$60 \Rightarrow 245$$

D-111

Load Case 2

$$\text{Axial load} = 2251 - 550.9 = 2801.9$$

$$\text{Moment} = -1425 + 3871 = 2446.0$$

$$\frac{2801.9}{4} = 700.5 \quad \frac{700.5}{2} = 350.2$$

$$\frac{2446.0}{3} \frac{\text{lbf-in}}{\text{in}} = 815.3 \text{ lbf (couple force)}$$

Node	X-Force	Y-Force	Z-Force
56	0	0	1165.5
57	0	0	700.5
58	0	0	-114.8
59	0	0	700.5
60	0	0	350.2

Node

$$56 \quad 350.2 + 815.3 = 1165.5$$

$$57 \quad 700.5 =$$

$$58 \quad 700.5 - 815.3 = -114.8$$

$$59 \quad 700.5$$

$$60 \quad 350.2$$

Loading the SUPERSAP model with the loads given on pages 3 and 4 give plate bending stresses to be approximately 35.5 KSI in the area just below the angle.

$$\text{Bending stress} = 35.5 \text{ KSI} \leq \frac{\text{allowable}}{\text{for level D.}} = \frac{50.76 \text{ KSI}}{0.75(36)(1.03)} = 35.5 \text{ KSI}$$

The upper base plate is subjected to larger loads than the lower base plate; therefore the lower base plate will not be checked for bending.

#### Check Anchor Bolts in lower base plate

$$X = 291.3 + 635.9 = 927.2 \quad Y = 319.6 + 689.2 = 1007.8 \text{ lbs}$$



$$M = 353.1 + 127.1 = 480.2 \text{ lb-in}$$

$$\text{Maximum tension} = \frac{927.2}{2} + \frac{190.2}{6} = \underline{543.6 \text{ lbs/bolt}}$$

$$\text{Maximum shear} = \frac{1007.8}{2} = \underline{503.9 \text{ lbs/bolt}}$$

#### Check Anchor Bolts in upper base plate

$$\text{Maximum tension (from supersap)} = -261.7 + 1367.0 + 731.2 + 185.5 + 247.7 = \underline{2972 \text{ lbs}}$$

$$\text{Maximum shear (from frame)} = \frac{732.3}{2} + \frac{689.2}{2} = \underline{710.3 \text{ lbs/bolt}}$$

### Check L3x3x4₂

Tension: (Ex + Gy member)

$$\text{Axial Force} = 550.4 + 2251 = 2801.4$$

$$f_t = \frac{2801.4}{2.75} = 1019 \text{ psi} \leq 21,000 = 0.6 (36)$$

### Compression:

$$C_c = 126.1 \text{ p. 5-77 AISC}$$

$$\frac{KJ}{r} = \frac{(2.0)(12)}{0.594} = 61.64 < 126.1$$

$$F_a = (7,270 \text{ p. 5-74 AISC})(1.68 \text{ lever}) = 32,470 \text{ psi}$$

$$\text{Axial force} = 3352 + 291.3 = 3643 \text{ lbs}$$

$$f_a = \frac{3643}{2.75} = 1325 \text{ psi}$$

$$f_a = 1325 \text{ psi} \leq F_a = 32470$$


### Bending:

$$\text{Area} = 2.75$$

$$Z_0 = y_0 = 0.932$$

$$I_z = I_y = 2.22$$

$$r_z = 0.594$$



$$I_u = A r^2 = 2.75 (0.594)^2 = 0.239 \text{ in}^4$$

$$I_u + I_y = I_z + I_y$$

$$I_y = 2(2.22) - 0.239 = 3.552 \text{ in}^4$$

$$Y_c = -3.15 - 1.0 = -4.15 \quad Z_c = 0.603$$

$$u_d = 0 \quad u_3 = -2.12 \quad u_4 = 2.12$$

$$M_{u4} = -757 (4459) = -3,352$$

$$M_u = 0.707 (4459) = -3,152$$

$$T_A = \frac{M_{u4}}{I_u} - \frac{M_u Y_c}{I_y} = \frac{-3,352 (-2.12)}{0.239} = \underline{\underline{24.22 \text{ ksi}}}$$

$$T_b = \frac{-3,152 (0.603)}{0.239} - \frac{3,552 (-2.12)}{3.552} = \underline{\underline{-26.07 \text{ ksi}}}$$

$$T_c = \frac{-3,152 (0.603)}{0.239} - \frac{3,552 (1.0)}{3.552} = \underline{\underline{-46.07 \text{ ksi}}}$$

$$f_{max} = 46.07 \text{ ksi} \leq f_{maximum} = 0.6(32.129) = 40.00 \text{ ksi}$$

Shear:

$$\text{Force} = 683.2 + 732 = 1420 \text{ lbs}$$
$$\sigma_x + \sigma_y$$

$$\text{shear area} = (3)(1/2) = 1.5 \text{ in}^2$$

$$f_y = \frac{1420}{1.5} \text{ in}^2 = 947 \text{ psi} \leq (0.4)(24)(1.89) = 27,072 \text{ psi}$$

$$f_y = 947 \text{ psi} \leq F_y = 27,000 \text{ psi}$$

Check  $\Delta \approx 2 \times 3/4$

Tension:

$$\text{Force} = (\sigma_x + \sigma_y \text{ member 6})$$

$$\text{Force} = 937 + 432 = 1369 \text{ lbs.}$$

$$f_z = \frac{1369}{1.36} = 1007 \text{ lbs} \leq F_z = 40,600 \text{ lbs}$$

Compression:

$$\text{Force} = (\sigma_x + \sigma_y \text{ member 6})$$

$$\text{Force} = 729 + 819 = 1548 \text{ lbs}$$

$$f_z = \frac{1548}{1.36} = 1138 \text{ psi}$$

$$C_c = 12.6 \text{ psi, 5-74 AISC}$$

$$\frac{\Delta}{r} = \frac{2.2(31)}{0.352} = 159.4 > 12.6$$

$$F_z = 5,972 (1.89) = 11,051 \text{ psi}$$
$$\text{A574 AISC}$$

$$f_z = 1138 \leq F_z = 11,051 \text{ psi}$$

Bending:

$$\text{Moment} = (\Theta z + \Theta Y \text{ member's})$$

$$\text{Moment} = 161.6 + 34.7 = 196.3$$

$$A = 1.36 \quad I_x = I_y = 0.479 \\ Z_0 = y_0 = 0.636 \quad r_u = 0.389$$

$$I_u = 1.36(0.389)^2 = 0.206$$

$$I_v = 2(0.479) - 0.206 = 0.752$$

$$Y_A = -0.899 \quad V_A = 0.515 \quad L = 0.515$$

$$U_A = 0.0 \quad U_B = -1.414 \quad U_C = 1.414$$

$$m_u = -0.707(196.3) = -138.9 \text{ lb-in}$$

$$m_v = 0.707(196.3) = 138.9 \text{ lb-in}$$

$$\bar{T}_4 = \frac{-138.9(-0.899)}{0.206} = 505.7 \text{ psi}$$

$$\bar{T}_8 = \frac{-138.9(0.515)}{0.206} + \frac{138.9(-1.414)}{0.752} = -605 \text{ psi}$$

$$\bar{T}_c = \frac{-138.9(0.515)}{0.206} + \frac{138.9(1.414)}{0.752} = -86 \text{ psi}$$

$$F_{min} = 0.6(26)(1.98) = 25,332$$

$$f_s \text{ max} = 602 \text{ psi} \leq F_{max} = 25,332$$

Shear:

$$\text{Force} = (\Theta z + \Theta Y \text{ member's})$$

$$\text{Force} = 5.9 + 2.1 = 7.9 \text{ kips}$$

$$\text{Shear area} = 2(24) = 48 \text{ in}^2$$

$$\bar{f}_v = \frac{7.9}{48} = 10.5 \text{ psi} < 4(26,332) / 48$$

$$\bar{f}_v = 10.5 + \bar{f}_s = 57,592 \text{ psi}$$

Check  $\Delta 3 \times 3 \times 3\frac{1}{2}$

Tension:

$$\text{Force} = \sigma Z + \sigma Y \text{ member 19}$$

$$\text{Force} = 629 + 691 = 1310 \text{ lbs}$$

$$\bar{\sigma}_t = \frac{1310}{2.01} = 651 \text{ psi} \quad \bar{\sigma}_z = 0.6(36,000)(1.84) = 20,320$$

$$\bar{\sigma}_x = 621 \text{ psi} \leq \bar{\sigma}_z = 20,320 \text{ psi}$$

Compression:

$$C_0 = 125 \text{ psi - } 6 \text{ Acs}$$

$$\frac{C_0}{F} = \frac{125/6}{9.537} = 40.9 - 52.2 \text{ psi}$$

$$F_x = 19,120 \text{ psi} (1.84) = 35,320 \text{ psi}$$

$$\text{Force} = (\sigma Z + \sigma Y \text{ members 12+19})$$

$$\text{Force} = 662 + 522 = 1,184 \text{ lbs}$$

$$\bar{\sigma}_x = \frac{1184}{2.01} = 581 \text{ psi}$$

$$\bar{\sigma}_x = 581 \leq F_x = 35,320$$

Shear:

$$\text{Force} = \sigma Z + \sigma Y \text{ member 19}$$

$$\text{Force} = 1966 + 209 = 2,175 \text{ lbs}$$

$$\text{Shear} = 2,175 = (3)(2\frac{1}{2}) = 1.25 \text{ in.}^2$$

$$\bar{\sigma}_y = \frac{2,175}{2.01/10^3} = 1,042 \text{ psi}$$

$$\bar{\sigma}_y = 0.6(36)(1.84) = 20,320 \text{ psi}$$

$$\bar{\sigma}_y = 1,042 \text{ psi} \leq F_y = 20,320 \text{ psi}$$

Bending:

$$\text{Element} = \theta K + \theta Y \quad \text{2 nodes & } r^2 \text{ member}$$
$$\text{Element} = 60494.421 = 3775 \text{ lb/in}$$

$$A = 2.01 \text{ in}^2 \quad I_x = I_y = 1.76 \text{ in}^4$$
$$x_0 = y_0 = 0.555 \quad r_u = 0.587 \text{ in}$$

$$I_u = 2(0.555)^2 = 0.727 \text{ in}^4$$

$$I_v = 2(1.76 - 0.727) = 2.793 \text{ in}^4$$

$$M_u = -1.205 \quad M_v = 0.727 \quad M_u = 0.727$$

$$M_u = 0.3 \quad M_v = -0.21 \quad M_u = 0.3$$

$$N_u = -0.050(3775) = -1888$$

$$N_v = 0.727(3775) = 2723$$

$$\bar{T}_u = \frac{-300/1.205}{0.727} = 3623$$

$$\bar{T}_v = -\frac{300/0.727}{0.727} - \frac{5.12/0.21}{2.793} = -4023$$

$$T_u = \frac{-300/1.205}{0.727} + \frac{-300/0.21}{2.793} = -324$$

$$\bar{T}_{\text{maximum}} = 4023 \leq F_{\text{minimum}} = 40,000$$

Check figure  $4\frac{1}{2} \times 2 \times 7\frac{1}{2}$

Tension: Force = 395 lbs

$$\sigma_t = \frac{395}{2(4)} = 395 \text{ psi}$$

$$\bar{\sigma}_t = 325 \text{ psi} \quad \bar{\sigma}_t = 40,300 \text{ psi}$$

Compression:

$$\text{Force} = 3558 \text{ lbs} \quad \bar{\sigma}_c = \frac{3558/4}{2(4)} = 351 \text{ psi}$$

$$\bar{\sigma} = \frac{1}{2}(3.14)^2 = 0.0208 \quad \sigma = \sqrt{\bar{\sigma}} = \sqrt{0.0208} = 0.453$$

$$F_{Ax} = \frac{0.75(50)}{0.125} = 103.3 \quad C_s = 126$$

$$F_a = (0.75)(23,466) = 17,622$$

$$F_a = 359 \leq 17,622 = F_a$$

Bending:

$$\text{Moment} = (\theta L + \theta \frac{L}{2} \text{ Node 2 member 3})$$

$$\text{Moment} = 1354 + 1575 = 2932 \text{ in-lb}$$

$$\tau_b = \frac{2932(1/4)}{0.02258} = 35,240$$

$$F_b = (0.75)(23,000)(1.59) = 50,760$$

$$\tau_b = 35,240 \leq F_b = 50,760$$

### Check welds

Welds are at least  $\frac{1}{4}$ " fillet weld and are all around unless noted otherwise.

$$\text{Weld Capacity per inch of weld} = 6.750(1/4)(23,240 \text{ in-lb}) = \underline{153.75 \text{ in}}$$

$$\text{Corner of } 2 \times 2 \times \frac{3}{8} \Rightarrow \text{length} = 2[2+2+\frac{3}{8}-\frac{3}{8}] = 9.5"$$

$$3 \times 3 \times \frac{3}{8} \Rightarrow \text{length} = 2[3+3+\frac{3}{8}-\frac{3}{8}] = 13.5"$$

$$3 \times 2 \times \frac{1}{2} \Rightarrow \text{length} = 2[3+3-\frac{1}{2}-\frac{1}{2}] = 14.0"$$

$$\text{Minimum weld strength} = 2.5(153.75 \text{ in}) = 383.75 \text{ lbs}$$

Maximum weld strength =  $40,760 \text{ lbs} \geq \text{to any member force.}$

# FRAME OUTPUT

Pages 14 thru 29

D-120

I 06 01 - 1979 - 10 - 15

卷之三

JULY 11 C C C 4 9 0 I b A T S  
GARDEN - 4.000 0.000  
1 2.000 0.001  
2 2.000 0.000  
3 2.000 0.000

FUNCTIONAL	WEIGHT	UNIT	REFERENCE VECTOR FOR A AXIS
A. ABSIS	0.0000	A.1	1.0000
B. 2.2500	-0.0000	A.2	0.0000
C. 0.7500	-0.0000	A.3	0.0000
D. 0.0000	-0.0000	A.4	0.0000
E. 0.0000	-0.0000	A.5	0.0000
F. 0.0000	-0.0000	A.6	0.0000
G. 0.0000	-0.0000	A.7	0.0000
H. 0.0000	-0.0000	A.8	0.0000
I. 0.0000	-0.0000	A.9	0.0000
J. 0.0000	-0.0000	A.10	0.0000
K. 0.0000	-0.0000	A.11	0.0000
L. 0.0000	-0.0000	A.12	0.0000

21272

0-121

## POSITIVE X LOADING

JOINT	FORCE & DISPLACEMENT	CONCENTRATED LOADS		MAX. STRESS	MAX. STRAIN
		X DIRECTION	Y DIRECTION		
8	-0.04100 + 0.00000	14.716 - 0.3	10.435 - 0.3	0.0	0.0
13	-0.04800 + 0.00000	28.511 - 0.3	15.234 - 0.3	0.0	0.0
20	-0.06000 + 0.00000	52.931 - 0.3	28.754 - 0.3	0.0	0.0
21	-0.06000 + 0.00000	56.666 - 0.3	32.378 - 0.3	0.0	0.0
1	-0.06000 + 0.00000	89.499 - 0.4	46.250 - 0.4	0.0	0.0
4	-0.06000 + 0.00000	42.020 - 0.3	21.010 - 0.3	0.0	0.0
5	-0.06000 + 0.00000	42.020 - 0.3	21.010 - 0.3	0.0	0.0
12	-0.06000 + 0.00000	21.241 - 0.3	10.946 - 0.3	0.0	0.0
13	-0.06000 + 0.00000	21.241 - 0.3	10.946 - 0.3	0.0	0.0
16	-0.06000 + 0.00000	21.241 - 0.3	10.946 - 0.3	0.0	0.0
6	-0.06000 + 0.00000	43.181 - 0.2	21.516 - 0.2	0.0	0.0
7	-0.06000 + 0.00000	43.181 - 0.2	21.516 - 0.2	0.0	0.0
10	-0.06000 + 0.00000	21.801 - 0.2	10.905 - 0.2	0.0	0.0
11	-0.06000 + 0.00000	45.025 - 0.2	23.514 - 0.2	0.0	0.0
9	-0.06000 + 0.00000	21.241 - 0.2	10.946 - 0.2	0.0	0.0
17	-0.06000 + 0.00000	21.241 - 0.2	10.946 - 0.2	0.0	0.0
18	-0.06000 + 0.00000	45.025 - 0.2	23.514 - 0.2	0.0	0.0
19	-0.06000 + 0.00000	45.025 - 0.2	23.514 - 0.2	0.0	0.0
14	-0.06000 + 0.00000	45.025 - 0.2	23.514 - 0.2	0.0	0.0
1	-0.06000 + 0.00000	13.916 - 0.2	0.0	0.0	0.0
4	-0.06000 + 0.00000	21.801 - 0.2	10.905 - 0.2	0.0	0.0
5	-0.06000 + 0.00000	45.025 - 0.2	23.514 - 0.2	0.0	0.0
12	-0.06000 + 0.00000	21.241 - 0.2	10.946 - 0.2	0.0	0.0
13	-0.06000 + 0.00000	21.241 - 0.2	10.946 - 0.2	0.0	0.0
16	-0.06000 + 0.00000	21.241 - 0.2	10.946 - 0.2	0.0	0.0
6	-0.06000 + 0.00000	43.181 - 0.2	21.516 - 0.2	0.0	0.0
7	-0.06000 + 0.00000	43.181 - 0.2	21.516 - 0.2	0.0	0.0
10	-0.06000 + 0.00000	21.801 - 0.2	10.905 - 0.2	0.0	0.0
11	-0.06000 + 0.00000	45.025 - 0.2	23.514 - 0.2	0.0	0.0
9	-0.06000 + 0.00000	21.241 - 0.2	10.946 - 0.2	0.0	0.0
17	-0.06000 + 0.00000	21.241 - 0.2	10.946 - 0.2	0.0	0.0
18	-0.06000 + 0.00000	45.025 - 0.2	23.514 - 0.2	0.0	0.0
19	-0.06000 + 0.00000	45.025 - 0.2	23.514 - 0.2	0.0	0.0
14	-0.06000 + 0.00000	45.025 - 0.2	23.514 - 0.2	0.0	0.0

MAXIMUM AVERAGE SHEAR FORCE  
IN AXIS

JOINT	AXIAL FORCE	LATERAL DISPLACEMENT		MAX. STRESS	MAX. STRAIN
		X DIRECTION	Y DIRECTION		
1	22.516 + 0.0	-2.32776 + 0.2	6.0	0.0	0.0
3	-2.32776 + 0.2	0.0	0.0	0.0	0.0
14	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
15	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
16	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
17	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
18	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
19	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
20	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
1	22.516 + 0.0	-2.32776 + 0.2	6.0	0.0	0.0
3	-2.32776 + 0.2	0.0	0.0	0.0	0.0
14	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
15	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
16	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
17	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
18	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
19	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
20	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
1	22.516 + 0.0	-2.32776 + 0.2	6.0	0.0	0.0
3	-2.32776 + 0.2	0.0	0.0	0.0	0.0
14	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
15	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
16	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
17	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
18	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
19	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0
20	-1.02351 + 0.2	0.0	-0.44665 + 0.3	0.0	0.0

D-122

JOINT NUMBER FLEXURE FLEXURE  
1 10X 10X 10X 10X 10X 10X

DISPLACEMENT FLEXURE FLEXURE

FLEXURE FLEXURE FLEXURE

ROTATION ABOUT THE Z AXIS  
DISPLACEMENT IN THE X DIRECTION  
DISPLACEMENT IN THE Y DIRECTION  
DISPLACEMENT ABOUT THE Z AXIS

D-123

5-1-6107-138  
24-72-24  
23-36-00  
23-36-00  
23-36-00  
23-36-00

卷之三

0-124

166 • JUNE 19, 2001 • E3 • 01518107

F. A. G. L. S.



REGULATORY LADING

D-126

ROTATION IN (deg) LINE 1 LINE 2 LINE 3  
DISPLACEMENT IN LINE 1 LINE 2 LINE 3  
DISPLACEMENT IN LINE 1 LINE 2 LINE 3  
ROTATION ABCD LINE 1 LINE 2 LINE 3

0-127

D-122

JOURNAL OF POLYMER SCIENCE: PART A

卷之三

C O O R D I N A T E S

DISPLACEMENT = VOLUME = SECTION

4110 4110 4110 4110 4110 4110 4110 4110

## **Intellipass Matrix from 120 locations worldwide**

D-129

POSITIVE ATTITUDE

DISPLACEMENTS  
DISPLACEMENTS

- 6 -

DISPLACEMENT IN THE VORTEX CLOUD

卷之三

P-132

DATA SHEET  
DISPACER  
ROTATION AND POSITION

023518+04  
023518+05  
023518+06

D-131

卷之三

4-1-51-6007-1301

卷之三

卷之三

G-132

$\{a_i\}_{i=1}^n$  is a sequence of real numbers such that  $a_1 > a_2 > \dots > a_n$ .

15 - 104-4 - 101-1

卷之三

173

## NEGATIVE Y LEADING

JOINT	FORCES AND MOMENTS	CONCENTRATED LOADS	APPLIED LOADS
1.5	0.	0.	0.
2.0	0.	-2750E+03	0.
2.1	0.	-1000E+03	0.

JOINT	X DIRECTION PLACEMENT	Y DIRECTION
0.	3492E+04	0.
1.5	-4823E+04	0.
1.6	-5854E+04	0.
1.7	-5809E+04	0.
1.8	-1244E+04	0.
1.9	-1401E+04	0.
2.0	-1412E+04	0.
2.1	-2373E+04	0.
2.2	-4392E+04	0.
2.3	-1460E+04	0.
2.4	-4111E+04	0.
2.5	-4122E+04	0.
2.6	-1046E+04	0.
2.7	0.	0.
2.8	-1789E+04	0.
2.9	-1516E+04	0.
3.0	-1167E+04	0.
3.1	-1516E+04	0.
3.2	-1167E+04	0.
3.3	-1516E+04	0.
3.4	-1167E+04	0.
3.5	-1516E+04	0.
3.6	-1167E+04	0.
3.7	-1516E+04	0.
3.8	-1167E+04	0.
3.9	-1516E+04	0.
4.0	-1167E+04	0.
4.1	-1516E+04	0.
4.2	-1167E+04	0.
4.3	-1516E+04	0.
4.4	-1167E+04	0.
4.5	-1516E+04	0.
4.6	-1167E+04	0.
4.7	-1516E+04	0.
4.8	-1167E+04	0.
4.9	-1516E+04	0.
5.0	-1167E+04	0.
5.1	-1516E+04	0.
5.2	-1167E+04	0.
5.3	-1516E+04	0.
5.4	-1167E+04	0.
5.5	-1516E+04	0.
5.6	-1167E+04	0.
5.7	-1516E+04	0.
5.8	-1167E+04	0.
5.9	-1516E+04	0.
6.0	-1167E+04	0.

JOINT	Z DIRECTION PLACEMENT	X DIRECTION	Y DIRECTION
0.	3492E+04	0.	0.
1.5	-4823E+04	0.	0.
1.6	-5854E+04	0.	0.
1.7	-5809E+04	0.	0.
1.8	-1244E+04	0.	0.
1.9	-1401E+04	0.	0.
2.0	-1412E+04	0.	0.
2.1	-2373E+04	0.	0.
2.2	-4392E+04	0.	0.
2.3	-1460E+04	0.	0.
2.4	-4111E+04	0.	0.
2.5	-4122E+04	0.	0.
2.6	-1046E+04	0.	0.
2.7	0.	0.	0.
2.8	-1789E+04	0.	0.
2.9	-1516E+04	0.	0.
3.0	-1167E+04	0.	0.
3.1	-1516E+04	0.	0.
3.2	-1167E+04	0.	0.
3.3	-1516E+04	0.	0.
3.4	-1167E+04	0.	0.
3.5	-1516E+04	0.	0.
3.6	-1167E+04	0.	0.
3.7	-1516E+04	0.	0.
3.8	-1167E+04	0.	0.
3.9	-1516E+04	0.	0.
4.0	-1167E+04	0.	0.
4.1	-1516E+04	0.	0.
4.2	-1167E+04	0.	0.
4.3	-1516E+04	0.	0.
4.4	-1167E+04	0.	0.
4.5	-1516E+04	0.	0.
4.6	-1167E+04	0.	0.
4.7	-1516E+04	0.	0.
4.8	-1167E+04	0.	0.
4.9	-1516E+04	0.	0.
5.0	-1167E+04	0.	0.

JOINT	Z DIRECTION PLACEMENT	X DIRECTION	Y DIRECTION
0.	3492E+04	0.	0.
1.5	-4823E+04	0.	0.
1.6	-5854E+04	0.	0.
1.7	-5809E+04	0.	0.
1.8	-1244E+04	0.	0.
1.9	-1401E+04	0.	0.
2.0	-1412E+04	0.	0.
2.1	-2373E+04	0.	0.
2.2	-4392E+04	0.	0.
2.3	-1460E+04	0.	0.
2.4	-4111E+04	0.	0.
2.5	-4122E+04	0.	0.
2.6	-1046E+04	0.	0.
2.7	0.	0.	0.
2.8	-1789E+04	0.	0.
2.9	-1516E+04	0.	0.
3.0	-1167E+04	0.	0.
3.1	-1516E+04	0.	0.
3.2	-1167E+04	0.	0.
3.3	-1516E+04	0.	0.
3.4	-1167E+04	0.	0.
3.5	-1516E+04	0.	0.
3.6	-1167E+04	0.	0.
3.7	-1516E+04	0.	0.
3.8	-1167E+04	0.	0.
3.9	-1516E+04	0.	0.
4.0	-1167E+04	0.	0.
4.1	-1516E+04	0.	0.
4.2	-1167E+04	0.	0.
4.3	-1516E+04	0.	0.
4.4	-1167E+04	0.	0.
4.5	-1516E+04	0.	0.
4.6	-1167E+04	0.	0.
4.7	-1516E+04	0.	0.
4.8	-1167E+04	0.	0.
4.9	-1516E+04	0.	0.
5.0	-1167E+04	0.	0.

D-134

JOINT 1 leading  
PLATE 1  
PLATE 2  
PLATE 3  
PLATE 4  
PLATE 5

PLATE 6  
PLATE 7  
PLATE 8  
PLATE 9  
PLATE 10PLATE 11  
PLATE 12  
PLATE 13  
PLATE 14  
PLATE 15PLATE 16  
PLATE 17  
PLATE 18  
PLATE 19  
PLATE 20PLATE 21  
PLATE 22  
PLATE 23  
PLATE 24  
PLATE 25PLATE 26  
PLATE 27  
PLATE 28  
PLATE 29  
PLATE 30PLATE 31  
PLATE 32  
PLATE 33  
PLATE 34  
PLATE 35PLATE 36  
PLATE 37  
PLATE 38  
PLATE 39  
PLATE 40PLATE 41  
PLATE 42  
PLATE 43  
PLATE 44  
PLATE 45PLATE 46  
PLATE 47  
PLATE 48  
PLATE 49  
PLATE 50PLATE 51  
PLATE 52  
PLATE 53  
PLATE 54  
PLATE 55PLATE 56  
PLATE 57  
PLATE 58  
PLATE 59  
PLATE 60PLATE 61  
PLATE 62  
PLATE 63  
PLATE 64  
PLATE 65PLATE 66  
PLATE 67  
PLATE 68  
PLATE 69  
PLATE 70PLATE 71  
PLATE 72  
PLATE 73  
PLATE 74  
PLATE 75PLATE 76  
PLATE 77  
PLATE 78  
PLATE 79  
PLATE 80PLATE 81  
PLATE 82  
PLATE 83  
PLATE 84  
PLATE 85PLATE 86  
PLATE 87  
PLATE 88  
PLATE 89  
PLATE 90PLATE 91  
PLATE 92  
PLATE 93  
PLATE 94  
PLATE 95PLATE 96  
PLATE 97  
PLATE 98  
PLATE 99  
PLATE 100PLATE 101  
PLATE 102  
PLATE 103  
PLATE 104  
PLATE 105PLATE 106  
PLATE 107  
PLATE 108  
PLATE 109  
PLATE 110PLATE 111  
PLATE 112  
PLATE 113  
PLATE 114  
PLATE 115PLATE 116  
PLATE 117  
PLATE 118  
PLATE 119  
PLATE 120PLATE 121  
PLATE 122  
PLATE 123  
PLATE 124  
PLATE 125PLATE 126  
PLATE 127  
PLATE 128  
PLATE 129  
PLATE 130PLATE 131  
PLATE 132  
PLATE 133  
PLATE 134  
PLATE 135PLATE 136  
PLATE 137  
PLATE 138  
PLATE 139  
PLATE 140PLATE 141  
PLATE 142  
PLATE 143  
PLATE 144  
PLATE 145PLATE 146  
PLATE 147  
PLATE 148  
PLATE 149  
PLATE 150PLATE 151  
PLATE 152  
PLATE 153  
PLATE 154  
PLATE 155PLATE 156  
PLATE 157  
PLATE 158  
PLATE 159  
PLATE 160PLATE 161  
PLATE 162  
PLATE 163  
PLATE 164  
PLATE 165PLATE 166  
PLATE 167  
PLATE 168  
PLATE 169  
PLATE 170PLATE 171  
PLATE 172  
PLATE 173  
PLATE 174  
PLATE 175PLATE 176  
PLATE 177  
PLATE 178  
PLATE 179  
PLATE 180PLATE 181  
PLATE 182  
PLATE 183  
PLATE 184  
PLATE 185PLATE 186  
PLATE 187  
PLATE 188  
PLATE 189  
PLATE 190PLATE 191  
PLATE 192  
PLATE 193  
PLATE 194  
PLATE 195PLATE 196  
PLATE 197  
PLATE 198  
PLATE 199  
PLATE 200PLATE 201  
PLATE 202  
PLATE 203  
PLATE 204  
PLATE 205PLATE 206  
PLATE 207  
PLATE 208  
PLATE 209  
PLATE 210PLATE 211  
PLATE 212  
PLATE 213  
PLATE 214  
PLATE 215PLATE 216  
PLATE 217  
PLATE 218  
PLATE 219  
PLATE 220PLATE 221  
PLATE 222  
PLATE 223  
PLATE 224  
PLATE 225PLATE 226  
PLATE 227  
PLATE 228  
PLATE 229  
PLATE 230PLATE 231  
PLATE 232  
PLATE 233  
PLATE 234  
PLATE 235PLATE 236  
PLATE 237  
PLATE 238  
PLATE 239  
PLATE 240PLATE 241  
PLATE 242  
PLATE 243  
PLATE 244  
PLATE 245PLATE 246  
PLATE 247  
PLATE 248  
PLATE 249  
PLATE 250PLATE 251  
PLATE 252  
PLATE 253  
PLATE 254  
PLATE 255PLATE 256  
PLATE 257  
PLATE 258  
PLATE 259  
PLATE 260PLATE 261  
PLATE 262  
PLATE 263  
PLATE 264  
PLATE 265PLATE 266  
PLATE 267  
PLATE 268  
PLATE 269  
PLATE 270PLATE 271  
PLATE 272  
PLATE 273  
PLATE 274  
PLATE 275PLATE 276  
PLATE 277  
PLATE 278  
PLATE 279  
PLATE 280PLATE 281  
PLATE 282  
PLATE 283  
PLATE 284  
PLATE 285PLATE 286  
PLATE 287  
PLATE 288  
PLATE 289  
PLATE 290PLATE 291  
PLATE 292  
PLATE 293  
PLATE 294  
PLATE 295PLATE 296  
PLATE 297  
PLATE 298  
PLATE 299  
PLATE 300PLATE 301  
PLATE 302  
PLATE 303  
PLATE 304  
PLATE 305PLATE 306  
PLATE 307  
PLATE 308  
PLATE 309  
PLATE 310PLATE 311  
PLATE 312  
PLATE 313  
PLATE 314  
PLATE 315PLATE 316  
PLATE 317  
PLATE 318  
PLATE 319  
PLATE 320PLATE 321  
PLATE 322  
PLATE 323  
PLATE 324  
PLATE 325PLATE 326  
PLATE 327  
PLATE 328  
PLATE 329  
PLATE 330PLATE 331  
PLATE 332  
PLATE 333  
PLATE 334  
PLATE 335PLATE 336  
PLATE 337  
PLATE 338  
PLATE 339  
PLATE 340PLATE 341  
PLATE 342  
PLATE 343  
PLATE 344  
PLATE 345PLATE 346  
PLATE 347  
PLATE 348  
PLATE 349  
PLATE 350PLATE 351  
PLATE 352  
PLATE 353  
PLATE 354  
PLATE 355PLATE 356  
PLATE 357  
PLATE 358  
PLATE 359  
PLATE 360PLATE 361  
PLATE 362  
PLATE 363  
PLATE 364  
PLATE 365PLATE 366  
PLATE 367  
PLATE 368  
PLATE 369  
PLATE 370PLATE 371  
PLATE 372  
PLATE 373  
PLATE 374  
PLATE 375PLATE 376  
PLATE 377  
PLATE 378  
PLATE 379  
PLATE 380PLATE 381  
PLATE 382  
PLATE 383  
PLATE 384  
PLATE 385PLATE 386  
PLATE 387  
PLATE 388  
PLATE 389  
PLATE 390PLATE 391  
PLATE 392  
PLATE 393  
PLATE 394  
PLATE 395PLATE 396  
PLATE 397  
PLATE 398  
PLATE 399  
PLATE 400PLATE 401  
PLATE 402  
PLATE 403  
PLATE 404  
PLATE 405PLATE 406  
PLATE 407  
PLATE 408  
PLATE 409  
PLATE 410PLATE 411  
PLATE 412  
PLATE 413  
PLATE 414  
PLATE 415PLATE 416  
PLATE 417  
PLATE 418  
PLATE 419  
PLATE 420PLATE 421  
PLATE 422  
PLATE 423  
PLATE 424  
PLATE 425PLATE 426  
PLATE 427  
PLATE 428  
PLATE 429  
PLATE 430PLATE 431  
PLATE 432  
PLATE 433  
PLATE 434  
PLATE 435PLATE 436  
PLATE 437  
PLATE 438  
PLATE 439  
PLATE 440PLATE 441  
PLATE 442  
PLATE 443  
PLATE 444  
PLATE 445PLATE 446  
PLATE 447  
PLATE 448  
PLATE 449  
PLATE 450PLATE 451  
PLATE 452  
PLATE 453  
PLATE 454  
PLATE 455PLATE 456  
PLATE 457  
PLATE 458  
PLATE 459  
PLATE 460PLATE 461  
PLATE 462  
PLATE 463  
PLATE 464  
PLATE 465PLATE 466  
PLATE 467  
PLATE 468  
PLATE 469  
PLATE 470PLATE 471  
PLATE 472  
PLATE 473  
PLATE 474  
PLATE 475

ROTATION ANGLE  
DISPLACEMENT  
ROTATION ANGLE

D-135


J. L. M. VAN DER HORST

• 137 •

D-136

# SUPERSAP OUTPUT

Pages 31 thru 42



Y-AXIS

D-138

Write fault error writing device= PRN  
Abort. Retry. Ignore? A

[C:\] >>TYPE CLINT1.L

***** SUPERSAP ANALYSIS VERSION: 7.1  
RELEASED: 7/30/95

DATE: June 11, 1986

TIME: 08:08:30

INPUT FILE.....CLINT1

### BASE PLATE WITH GUSSET

#### ***** CONTROL INFORMATION

NUMBER OF NODE POINTS	(NUMNP)	=	63
NUMBER OF ELEMENT TYPES	(NELTYP)	=	2
NUMBER OF LOAD CASES	(LL)	=	2
NUMBER OF FREQUENCIES	(NF)	=	0
GEOMETRIC STIFFNESS FLAG	(GEOSTF)	=	0
ANALYSIS CODE	(NDYN)	=	0
SOLUTION MODE	(MODEX)	=	0
NUMBER OF ITERATION VECTORS	(NAD)	=	0
EQUATIONS PER BLOCK	(KEDB)	=	0
TAFE10 GAVE FLAG	(NIOSV)	=	0
NODAL DEFLECTION PRINTING	(DEFPCH)	=	0
OVERALL MATRIX PRINTING	(GENPRT)	=	0
ELEMENT MATRIX PRINTING	(ELPRT)	=	0
WEIGHT AND C.G. FLAG	(IWTCG)	=	0
BANDWIDTH MINIMIZATION FLAG	(MINBND)	=	0
FILE FORMAT FLAG	(IPLT)	=	0
NUMBER OF RESPONSE SPECTRA	(NRSC)	=	0
GRAVITATIONAL CONSTANT	(GRAV)	=	3.8640E+02
TOTAL BLANK COMMON	(MTOT)	=	23000

#### BANDWIDTH MINIMIZATION SPECIFIED

#### ***** NODAL DATA

NODE NO.	BOUNDARY CONDITION CODES						NODAL POINT COORDINATES			
	DX	DY	DZ	RX	RY	RZ	X	Y	Z	T
1	0	1	1	0	0	0	0.000E+00	0.000E+00	0.000E+00	0.000E+00
2	0	0	0	0	0	0	1.000E+00	0.000E+00	0.000E+00	0.000E+00
3	0	0	0	0	0	0	2.000E+00	0.000E+00	0.000E+00	0.000E+00
4	0	0	0	0	0	0	3.000E+00	0.000E+00	0.000E+00	0.000E+00
5	0	1	1	0	0	0	4.000E+00	0.000E+00	0.000E+00	0.000E+00
6	0	0	0	0	0	0	0.000E+00	1.500E+00	0.000E+00	0.000E+00
7	0	0	0	0	0	0	1.000E+00	1.500E+00	0.000E+00	0.000E+00
8	0	0	0	0	0	0	2.000E+00	1.500E+00	0.000E+00	0.000E+00
9	0	0	0	0	0	0	3.000E+00	1.500E+00	0.000E+00	0.000E+00
10	0	0	0	0	0	0	4.000E+00	1.500E+00	0.000E+00	0.000E+00
11	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
12	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
13	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
14	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
15	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
16	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
17	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
18	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
19	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
20	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
21	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
22	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
23	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
24	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
25	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
26	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
27	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
28	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
29	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
30	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
31	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
32	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
33	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
34	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
35	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
36	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
37	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
38	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
39	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
40	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
41	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
42	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
43	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
44	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
45	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
46	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
47	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
48	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
49	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
50	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
51	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
52	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
53	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
54	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
55	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
56	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
57	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
58	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
59	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
60	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
61	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
62	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
63	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
64	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
65	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
66	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
67	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
68	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
69	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
70	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
71	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
72	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
73	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
74	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
75	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
76	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
77	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
78	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
79	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
80	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
81	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
82	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
83	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
84	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
85	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
86	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
87	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
88	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
89	0	0	0	0	0	0	3.000E+00	2.000E+00	0.000E+00	0.000E+00
90	0	0	0	0	0	0	4.000E+00	2.000E+00	0.000E+00	0.000E+00
91	0	0	0	0	0	0	0.000E+00	2.000E+00	0.000E+00	0.000E+00
92	0	0	0	0	0	0	1.000E+00	2.000E+00	0.000E+00	0.000E+00
93	0	0	0	0	0	0	2.000E+00	2.000E+00	0.000E+00	0.000E+00
94	0	0	0	0	0	0	3.000E+0			

21	0	0	0	0	0	0	0.000E+00	7.000E+00	.000E+00
22	0	0	0	0	0	0	1.000E+00	7.000E+00	.000E+00
23	0	0	0	0	0	0	2.000E+00	7.000E+00	.000E+00
24	0	0	0	0	0	0	3.000E+00	7.000E+00	.000E+00
25	0	0	0	0	0	0	4.000E+00	7.000E+00	.000E+00
26	0	0	0	0	0	0	0.000E+00	8.500E+00	.000E+00
27	0	0	0	0	0	0	1.000E+00	8.500E+00	.000E+00
28	0	0	0	0	0	0	2.000E+00	8.500E+00	.000E+00
29	0	0	0	0	0	0	3.000E+00	8.500E+00	.000E+00
30	0	0	0	0	0	0	4.000E+00	8.500E+00	.000E+00
31	0	0	0	0	0	0	0.000E+00	1.000E+01	.000E+00
32	0	0	0	0	0	0	1.000E+00	1.000E+01	.000E+00
33	0	0	0	0	0	0	2.000E+00	1.000E+01	.000E+00
34	0	0	0	0	0	0	3.000E+00	1.000E+01	.000E+00
35	0	0	0	0	0	0	4.000E+00	1.000E+01	.000E+00
36	0	0	0	0	0	0	0.000E+00	1.200E+01	.000E+00
37	0	0	0	0	0	0	1.000E+00	1.200E+01	.000E+00
38	0	0	0	0	0	0	2.000E+00	1.200E+01	.000E+00
39	0	0	0	0	0	0	3.000E+00	1.200E+01	.000E+00
40	0	0	0	0	0	0	4.000E+00	1.200E+01	.000E+00
41	0	0	0	0	0	0	0.000E+00	1.400E+01	.000E+00
42	0	0	0	0	0	0	1.000E+00	1.400E+01	.000E+00
43	0	0	0	0	0	0	2.000E+00	1.400E+01	.000E+00
44	0	0	0	0	0	0	3.000E+00	1.400E+01	.000E+00
45	0	0	0	0	0	0	4.000E+00	1.400E+01	.000E+00
46	0	0	0	0	0	0	0.000E+00	1.550E+01	.000E+00
47	0	0	0	0	0	0	1.000E+00	1.550E+01	.000E+00
48	0	0	0	0	0	0	2.000E+00	1.550E+01	.000E+00
49	0	0	0	0	0	0	3.000E+00	1.550E+01	.000E+00
50	0	0	0	0	0	0	4.000E+00	1.550E+01	.000E+00
51	0	1	1	0	0	0	0.000E+00	1.700E+01	.000E+00
52	0	0	0	0	0	0	1.000E+00	1.700E+01	.000E+00
53	0	0	0	0	0	0	2.000E+00	1.700E+01	.000E+00
54	0	0	0	0	0	0	3.000E+00	1.700E+01	.000E+00
55	0	1	1	0	0	0	4.000E+00	1.700E+01	.000E+00
56	0	0	0	0	0	0	3.000E+00	7.000E+00	2.000E+00
57	0	0	0	0	0	0	3.000E+00	8.500E+00	2.000E+00
58	0	0	0	0	0	0	3.000E+00	1.000E+01	2.000E+00
59	0	0	0	0	0	0	2.000E+00	1.000E+01	2.000E+00
60	0	0	0	0	0	0	1.000E+00	1.000E+01	2.000E+00
61	0	0	0	0	0	0	2.000E+00	1.200E+01	2.000E+00
62	0	0	0	0	0	0	2.000E+00	1.400E+01	2.000E+00
63	0	0	0	0	0	0	2.000E+00	1.500E+01	2.000E+00

***** THIN PLATE/SHELL ELEMENTS

NUMBER OF ELEMENTS =

47

NUMBER OF MATERIALS =

1

***** MATERIAL PROPERTIES

MATERIAL I.D. NUMBER =

1

WEIGHT DENSITY =

2.1E-006-01

MASS DENSITY =

7.1E-195E-04

CASE 1 ALPHA(x)	CASE 2 ALPHA(y)	CASE 3	CASE 4	CASE 5	CASE 6	CASE 7
3.137E+07 .000E+00	4.550E+06 .000E+00	0.000E+00	3.137E+07 .000E+00	0.000E+00	1.115E+07 .000E+00	

***** ELEMENT LOAD MULTIPLIERS

CASE A

CASE B

CASE C

CASE D

0-140

TEMP .000E+00 .000E+00 .000E+00 .000E+00  
 X-DIR .000E+00 .000E+00 .000E+00 .000E+00  
 Y-DIR .000E+00 .000E+00 .000E+00 .000E+00  
 Z-DIR .000E+00 .000E+00 .000E+00 .000E+00

***** ELEMENT CONNECTIVITY DATA

ELEM NO.	NODE I	NODE J	NODE K	NODE L	MAT'L O	AVERAGE INDEX	NORMAL THICKNESS	TEMP. PRESSURE.	TEMP. DIFFERENCE	TEMP. GRADIENT
1	1	2	7	6	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
2	6	7	12	11	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
3	11	12	17	16	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
4	16	17	22	21	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
5	21	22	27	26	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
6	26	27	32	31	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
7	31	32	37	36	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
8	36	37	42	41	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
9	41	42	47	46	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
10	46	47	52	51	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
11	51	52	57	56	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
12	56	57	62	61	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
13	61	62	67	66	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
14	66	67	72	71	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
15	71	72	77	76	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
16	76	77	82	81	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
17	81	82	87	86	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
18	86	87	92	91	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
19	91	92	97	96	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
20	96	97	102	101	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
21	101	102	107	106	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
22	106	107	112	111	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
23	111	112	117	116	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
24	116	117	122	121	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
25	121	122	127	126	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
26	126	127	132	131	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
27	131	132	137	136	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
28	136	137	142	141	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
29	141	142	147	146	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
30	146	147	152	151	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
31	151	152	157	156	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
32	156	157	162	161	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
33	161	162	167	166	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
34	166	167	172	171	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
35	171	172	177	176	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
36	176	177	182	181	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
37	181	182	187	186	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
38	186	187	192	191	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
39	191	192	197	196	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
40	196	197	202	201	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
41	201	202	207	206	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
42	206	207	212	211	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
43	211	212	217	216	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
44	216	217	222	221	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
45	221	222	227	226	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
46	226	227	232	231	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
47	231	232	237	236	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
48	236	237	242	241	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
49	241	242	247	246	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
50	246	247	252	251	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
51	251	252	257	256	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
52	256	257	262	261	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
53	261	262	267	266	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
54	266	267	272	271	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
55	271	272	277	276	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
56	276	277	282	281	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
57	281	282	287	286	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
58	286	287	292	291	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
59	291	292	297	296	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
60	296	297	302	301	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
61	301	302	307	306	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
62	306	307	312	311	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
63	311	312	317	316	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
64	316	317	322	321	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
65	321	322	327	326	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
66	326	327	332	331	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
67	331	332	337	336	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
68	336	337	342	341	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
69	341	342	347	346	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
70	346	347	352	351	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
71	351	352	357	356	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
72	356	357	362	361	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
73	361	362	367	366	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
74	366	367	372	371	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
75	371	372	377	376	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
76	376	377	382	381	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
77	381	382	387	386	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
78	386	387	392	391	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
79	391	392	397	396	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
80	396	397	402	401	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
81	401	402	407	406	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
82	406	407	412	411	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
83	411	412	417	416	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
84	416	417	422	421	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
85	421	422	427	426	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
86	426	427	432	431	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
87	431	432	437	436	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
88	436	437	442	441	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
89	441	442	447	446	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
90	446	447	452	451	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
91	451	452	457	456	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
92	456	457	462	461	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
93	461	462	467	466	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
94	466	467	472	471	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
95	471	472	477	476	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
96	476	477	482	481	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
97	481	482	487	486	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
98	486	487	492	491	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
99	491	492	497	496	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
100	496	497	502	501	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
101	501	502	507	506	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
102	506	507	512	511	0	1	3.750E-01	.000E+00	.000E+00	.000E+00
10										

VALUE A      VALUE B      VALUE C      VALUE D

.000E+00      .000E+00      .000E+00      .000E+00

35

***** ELEMENT CONNECTIVITY DATA

ELEMENT NUMBER	NODE N	DIRECTION I	DIRECTION J	DIRECTION K	NODES L	CODES KD KR	SPECIFIED TRANSLATION	SPECIFIED ROTATION	BENDING RATE
1	1	1	4	3	2	7 1 0	.0000E+00	.0000E+00	1.000E+10
2	2	2	4	4	3	8 1 0	.0000E+00	.0000E+00	1.000E+10
3	3	4	5	5	4	9 1 0	.0000E+00	.0000E+00	1.000E+10
4	4	4	5	6	5	10 1 0	.0000E+00	.0000E+00	1.000E+10
5	5	0	0	7	6	11 1 0	.0000E+00	.0000E+00	1.000E+10
6	6	0	0	7	7	7 1 0	.0000E+00	.0000E+00	1.000E+10
7	7	0	0	7	8	8 1 0	.0000E+00	.0000E+00	1.000E+10
8	8	0	0	7	9	9 1 0	.0000E+00	.0000E+00	1.000E+10
9	9	0	0	7	10	10 1 0	.0000E+00	.0000E+00	1.000E+10
10	10	10	10	10	11	11 1 0	.0000E+00	.0000E+00	1.000E+10
11	46	46	46	46	47	7 1 0	.0000E+00	.0000E+00	1.000E+10
12	47	47	47	47	48	8 1 0	.0000E+00	.0000E+00	1.000E+10
13	48	48	48	48	49	9 1 0	.0000E+00	.0000E+00	1.000E+10
14	49	49	49	49	50	10 1 0	.0000E+00	.0000E+00	1.000E+10
15	50	50	50	50	51	11 1 0	.0000E+00	.0000E+00	1.000E+10
16	51	51	51	51	52	7 1 0	.0000E+00	.0000E+00	1.000E+10
17	52	52	52	52	53	8 1 0	.0000E+00	.0000E+00	1.000E+10
18	53	53	53	53	54	9 1 0	.0000E+00	.0000E+00	1.000E+10
19	54	54	54	54	55	10 1 0	.0000E+00	.0000E+00	1.000E+10
20	55	55	55	55	56	7 1 0	.0000E+00	.0000E+00	1.000E+10

***** BANDWIDTH MINIMIZATION

MINBND (BANDWIDTH CONTROL PARAMETER) =

1 *

***** EQUATION NUMBERS AFTER MINIMIZATION

OLD NODE	NEW NODE	DX	DY	DZ	RX	RY	RZ
1	47	273	0	0	274	275	276
54	513	314	314	314	316	317	318
59	343	344	344	344	346	347	348
60	561	362	362	362	364	365	366
61	567	0	0	0	568	569	570
66	267	268	268	268	270	271	272
67	307	308	308	308	310	311	312
68	337	378	378	378	380	381	382
69	349	380	380	380	382	383	384
70	555	755	755	755	758	759	760
71	261	262	262	262	264	265	266
72	501	302	302	302	304	305	306
73	519	320	320	320	322	323	324
74	525	326	326	326	328	329	330
75	521	327	327	327	329	330	331
76	556	756	756	756	758	759	760
77	272	1004	1004	1004	1006	1007	1008
78	293	1005	1005	1005	1007	1008	1009
79	290	1006	1006	1006	1008	1009	1010
80	291	1005	1005	1005	1007	1008	1009
81	292	1006	1006	1006	1008	1009	1010
82	294	1007	1007	1007	1009	1010	1011
83	295	1008	1008	1008	1010	1011	1012
84	296	1009	1009	1009	1011	1012	1013
85	297	1010	1010	1010	1012	1013	1014
86	298	1011	1011	1011	1013	1014	1015
87	299	1012	1012	1012	1014	1015	1016
88	300	1013	1013	1013	1015	1016	1017
89	301	1014	1014	1014	1016	1017	1018
90	302	1015	1015	1015	1017	1018	1019
91	303	1016	1016	1016	1018	1019	1020
92	304	1017	1017	1017	1019	1020	1021
93	305	1018	1018	1018	1020	1021	1022
94	306	1019	1019	1019	1021	1022	1023
95	307	1020	1020	1020	1022	1023	1024
96	308	1021	1021	1021	1023	1024	1025
97	309	1022	1022	1022	1024	1025	1026
98	310	1023	1023	1023	1025	1026	1027
99	311	1024	1024	1024	1026	1027	1028
100	312	1025	1025	1025	1027	1028	1029
101	313	1026	1026	1026	1028	1029	1030
102	314	1027	1027	1027	1029	1030	1031
103	315	1028	1028	1028	1030	1031	1032
104	316	1029	1029	1029	1031	1032	1033
105	317	1030	1030	1030	1032	1033	1034
106	318	1031	1031	1031	1033	1034	1035
107	319	1032	1032	1032	1034	1035	1036
108	320	1033	1033	1033	1035	1036	1037
109	321	1034	1034	1034	1036	1037	1038
110	322	1035	1035	1035	1037	1038	1039
111	323	1036	1036	1036	1038	1039	1040
112	324	1037	1037	1037	1039	1040	1041
113	325	1038	1038	1038	1040	1041	1042
114	326	1039	1039	1039	1041	1042	1043
115	327	1040	1040	1040	1042	1043	1044
116	328	1041	1041	1041	1043	1044	1045
117	329	1042	1042	1042	1044	1045	1046
118	330	1043	1043	1043	1045	1046	1047
119	331	1044	1044	1044	1046	1047	1048
120	332	1045	1045	1045	1047	1048	1049
121	333	1046	1046	1046	1048	1049	1050
122	334	1047	1047	1047	1049	1050	1051
123	335	1048	1048	1048	1050	1051	1052
124	336	1049	1049	1049	1051	1052	1053
125	337	1050	1050	1050	1052	1053	1054
126	338	1051	1051	1051	1053	1054	1055
127	339	1052	1052	1052	1054	1055	1056
128	340	1053	1053	1053	1055	1056	1057
129	341	1054	1054	1054	1056	1057	1058
130	342	1055	1055	1055	1057	1058	1059
131	343	1056	1056	1056	1058	1059	1060
132	344	1057	1057	1057	1059	1060	1061
133	345	1058	1058	1058	1060	1061	1062
134	346	1059	1059	1059	1061	1062	1063
135	347	1060	1060	1060	1062	1063	1064
136	348	1061	1061	1061	1063	1064	1065
137	349	1062	1062	1062	1064	1065	1066
138	350	1063	1063	1063	1065	1066	1067
139	351	1064	1064	1064	1066	1067	1068
140	352	1065	1065	1065	1067	1068	1069
141	353	1066	1066	1066	1068	1069	1070
142	354	1067	1067	1067	1069	1070	1071
143	355	1068	1068	1068	1070	1071	1072
144	356	1069	1069	1069	1071	1072	1073
145	357	1070	1070	1070	1072	1073	1074
146	358	1071	1071	1071	1073	1074	1075
147	359	1072	1072	1072	1074	1075	1076
148	360	1073	1073	1073	1075	1076	1077
149	361	1074	1074	1074	1076	1077	1078
150	362	1075	1075	1075	1077	1078	1079
151	363	1076	1076	1076	1078	1079	1080
152	364	1077	1077	1077	1079	1080	1081
153	365	1078	1078	1078	1080	1081	1082
154	366	1079	1079	1079	1081	1082	1083
155	367	1080	1080	1080	1082	1083	1084
156	368	1081	1081	1081	1083	1084	1085
157	369	1082	1082	1082	1084	1085	1086
158	370	1083	1083	1083	1085	1086	1087
159	371	1084	1084	1084	1086	1087	1088
160	372	1085	1085	1085	1087	1088	1089
161	373	1086	1086	1086	1088	1089	1090
162	374	1087	1087	1087	1089	1090	1091
163	375	1088	1088	1088	1090	1091	1092
164	376	1089	1089	1089	1091	1092	1093
165	377	1090	1090	1090	1092	1093	1094
166	378	1091	1091	1091	1093	1094	1095
167	379	1092	1092	1092	1094	1095	1096
168	380	1093	1093	1093	1095	1096	1097
169	381	1094	1094	1094	1096	1097	1098
170	382	1095	1095	1095	1097	1098	1099
171	383	1096	1096	1096	1098	1099	1100
172	384	1097	1097	1097	1099	1100	1101
173	385	1098	1098	1098	1100	1101	1102
174	386	1099	1099	1099	1101	1102	1103
175	387	1100	1100				

29	37	213	214	215	216	217	218
30	38	219	220	221	222	223	224
31	26	147	148	149	150	151	152
32	27	153	154	155	156	157	158
33	28	159	160	161	162	163	164
34	30	171	172	173	174	175	176
35	31	177	178	179	180	181	182
36	18	99	100	101	102	103	104
37	19	105	106	107	108	109	110
38	22	123	124	125	126	127	128
39	24	135	136	137	138	139	140
40	25	141	142	143	144	145	146
41	12	63	64	65	66	67	68
42	13	69	70	71	72	73	74
43	15	81	82	83	84	85	86
44	16	87	88	89	90	91	92
45	17	93	94	95	96	97	98
46	6	27	28	29	30	31	32
47	7	33	34	35	36	37	38
48	9	46	48	47	48	49	50
49	10	51	52	53	54	55	56
50	11	57	58	59	60	61	62
51	1	1	0	0	0	0	4
52	2	5	6	7	8	9	10
53	3	11	12	13	14	15	16
54	4	17	18	19	20	21	22
55	5	23	0	0	24	25	26
56	6	207	208	209	210	211	212
57	7	201	202	203	204	205	206
58	29	165	166	167	168	169	170
59	23	129	130	131	132	133	134
60	21	117	118	119	120	121	122
61	20	111	112	113	114	115	116
62	14	75	76	77	78	79	80
63	8	39	40	41	42	43	44

BANDWIDTH BEFORE RESEQUENCING =

200

BANDWIDTH AFTER RESEQUENCING =

60

## ***** NODAL LOADS (STATIC) OR MASSES (DYNAMIC)

NODE NUMBER	LOAD CASE	X-AXIS FORCE	Y-AXIS FORCE	Z-AXIS FORCE	X-AXIS MOMENT	Y-AXIS MOMENT	Z-AXIS MOMENT
56	1	.0000E+00	.0000E+00	1.651E+03	.0000E+00	.0000E+00	.0000E+00
57	1	.0000E+00	.0000E+00	4.891E+02	.0000E+00	.0000E+00	.0000E+00
58	1	.0000E+00	.0000E+00	-6.451E+02	.0000E+00	.0000E+00	.0000E+00
59	1	.0000E+00	.0000E+00	4.899E+02	.0000E+00	.0000E+00	.0000E+00
60	1	.0000E+00	.0000E+00	2.450E+02	.0000E+00	.0000E+00	.0000E+00
56	2	.0000E+00	.0000E+00	1.168E+03	.0000E+00	.0000E+00	.0000E+00
57	2	.0000E+00	.0000E+00	7.005E+02	.0000E+00	.0000E+00	.0000E+00
58	2	.0000E+00	.0000E+00	-1.148E+02	.0000E+00	.0000E+00	.0000E+00
59	2	.0000E+00	.0000E+00	7.005E+02	.0000E+00	.0000E+00	.0000E+00
60	2	.0000E+00	.0000E+10	3.502E+02	.0000E+00	.0000E+00	.0000E+00

## ***** ELEMENT LOAD MULTIPLIERS

LOAD CASE	CASE A	CASE B	CASE C	CASE D
1	.0000E+00	.0000E+00	.0000E+00	.0000E+00
2	.0000E+00	.0000E+00	.0000E+00	.0000E+00

## ***** STIFFNESS MATRIX PARAMETERS

NON-ZERO NON-DIAGONAL ELEMENT = D-147 COEFF =

MAXIMUM/MINIMUM = 3.438E+04  
 AVERAGE DIAGONAL ELEMENT = 5.1471E+08  
 DENSITY OF THE MATRIX = 9.7054E+00

!!!! WARNING: MODEL MAY LACK SUFFICIENT BOUNDARY  
CONSTRAINT OR HAVE STIFFNESS COMPATIBILITY PROBLEM. SEE NODE AND/OR ELEMENTS ASSOCIATED WITH DOF:

667

***** STATIC ANALYSIS

LOAD CASE = 1

DISPLACEMENTS/ROTATIONS (DEGREES) OF UNRESTRAINED NODES

NODE NUMBER	X- TRANSLATION	Y- TRANSLATION	Z- TRANSLATION	X- ROTATION	Y- ROTATION	Z- ROTATION
1	7.5513E-05	.0000E+00	.0000E+00	-8.3270E-02	-7.5470E-03	.0000E+00
2	7.4615E-05	3.0517E-06	-3.9594E-08	-7.9535E-02	4.4196E-03	.0000E+00
3	7.2321E-05	1.3882E-05	-5.5844E-08	-9.2985E-02	2.5934E-03	.0000E+00
4	6.8430E-05	1.5813E-05	-4.8831E-08	-9.7218E-02	-1.1254E-03	.0000E+00
5	6.3944E-05	.0000E+00	.0000E+00	-1.1112E-01	1.3236E-02	.0000E+00
6	6.6940E-05	1.4999E-06	-1.9985E-08	1.1684E-01	-1.3256E-02	.0000E+00
7	6.7131E-05	8.0463E-06	1.1384E-07	1.3462E-01	6.1206E-03	.0000E+00
8	6.7755E-05	1.4468E-05	6.0398E-08	1.3059E-01	3.4324E-03	.0000E+00
9	6.8597E-05	1.8300E-05	1.5410E-07	1.3607E-01	-3.8463E-03	.0000E+00
10	6.7541E-05	2.0522E-05	1.9799E-08	1.7983E-01	2.4630E-02	.0000E+00
11	5.7904E-05	-5.9457E-07	7.0921E-03	4.1799E-01	-5.3506E-02	.0000E+00
12	5.8336E-05	7.9346E-06	8.0348E-03	4.4637E-01	-4.6975E-02	.0000E+00
13	5.8039E-05	1.5965E-05	8.8589E-03	4.9001E-01	-4.7492E-02	.0000E+00
14	5.7671E-05	2.3855E-05	9.7226E-03	5.3440E-01	-4.8040E-02	.0000E+00
15	5.6549E-05	3.3111E-05	1.0441E-02	5.7752E-01	-5.8397E-02	.0000E+00
16	5.7536E-05	-5.4195E-06	2.3276E-02	4.5537E-01	-8.8704E-02	.0000E+00
17	5.8301E-05	7.0626E-06	2.5030E-02	4.7064E-01	-1.1902E-01	.0000E+00
18	3.8791E-05	2.1810E-05	2.7244E-02	5.0498E-01	-1.3942E-01	.0000E+00
19	3.4713E-05	3.2992E-05	2.9694E-02	5.4319E-01	-1.4667E-01	.0000E+00
20	3.0019E-05	4.6564E-05	3.2286E-02	5.7229E-01	-1.7079E-01	.0000E+00
21	1.0457E-05	-8.2026E-06	3.2969E-02	7.5868E-02	-7.5139E-02	.0000E+00
22	1.0965E-05	2.7003E-06	3.4752E-02	5.3917E-02	-1.3805E-01	.0000E+00
23	1.2523E-05	1.7921E-05	3.7571E-02	1.7758E-02	-2.0027E-01	.0000E+00
24	1.4051E-05	6.4847E-05	4.0732E-02	-1.0175E-02	-1.5021E-01	-8.2065E-03
25	1.3814E-05	3.3323E-05	4.3195E-02	-3.3827E-02	-1.8297E-01	.0000E+00
26	-1.8224E-05	-4.9731E-06	3.1759E-02	-1.8242E-01	-4.0510E-02	.0000E+00
27	-2.0584E-05	-3.4255E-06	3.2702E-02	-1.9144E-01	-6.1819E-02	.0000E+00
28	1.4579E-06	-1.5520E-06	3.3771E-02	-2.4750E-01	-5.0274E-02	.0000E+00
29	1.8184E-05	-2.0326E-06	3.4828E-02	-3.0059E-01	-8.5198E-02	-9.2211E-04
30	3.3180E-05	-1.8027E-06	3.7006E-02	-3.4764E-01	-1.5011E-01	.0000E+00
31	3.3332E-06	5.7971E-07	3.5957E-02	-1.8483E-01	-1.3052E-02	.0000E+00
32	2.1467E-06	-7.5195E-06	2.8499E-02	-2.7226E-01	-7.2807E-02	.0000E+00
33	6.6379E-06	-2.9818E-05	2.7145E-02	-3.7257E-01	-3.7391E-02	4.8028E-04
34	1.9920E-05	-6.2273E-05	2.7955E-02	-2.6711E-01	-4.4097E-02	3.5423E-03
35	2.4578E-05	-3.7201E-05	2.6775E-02	-1.9849E-01	-5.6492E-02	.0000E+00
36	3.8632E-05	4.7670E-07	1.8061E-02	-2.9294E-01	-3.7872E-02	.0000E+00
37	3.9945E-05	-2.0388E-05	1.8849E-02	-2.9089E-01	-3.1449E-02	.0000E+00
38	4.1877E-05	-5.8857E-05	1.7149E-02	-3.7259E-01	-2.3718E-02	-2.5914E-04
39	3.5791E-05	-4.5567E-05	1.7531E-02	-3.0811E-01	-2.0752E-02	.0000E+00
40	3.1781E-05	-4.79984E-05	1.7325E-02	-3.2709E-01	-1.8492E-02	.0000E+00
41	3.1897E-05	-2.5751E-05	5.4718E-03	-3.4958E-01	-3.5776E-02	.0000E+00
42	3.1585E-05	-1.1960E-05	3.5570E-03	-3.7180E-01	-3.4111E-02	.0000E+00
43	3.1774E-05	-1.0507E-05	3.1152E-03	-3.1621E-01	-1.3551E-02	.0000E+00
44	3.1079E-05	-2.7705E-05	3.8844E-03	-3.2745E-01	3.7302E-02	.0000E+00
45	3.1062E-05	-7.5584E-05	3.0723E-03	-3.5587E-01	4.1147E-02	.0000E+00
46	3.1647E-05	-1.3320E-05	-3.9453E-03	-3.6337E-01	-1.0773E-02	.0000E+00
47	3.1771E-05	-1.1338E-05	3.0128E-03	-3.5525E-01	-4.7474E-02	.0000E+00

49	6.7034E-05	-1.3217E-05	1.3771E-07	-1.3141E-01	-3.0252E-03	.0000E+00
50	6.4717E-05	-2.1531E-05	-4.3229E-09	-1.1785E-01	1.2375E-02	.0000E+00
51	7.0901E-05	.0000E+00	.0000E+00	7.7458E-02	-5.7282E-03	.0000E+00
52	7.0284E-05	5.0085E-07	-5.7655E-08	7.3018E-02	4.1526E-03	.0000E+00
53	7.3275E-05	-4.6900E-07	-5.2957E-08	8.0059E-02	5.5229E-04	.0000E+00
54	7.4915E-05	-7.0858E-08	-5.9822E-08	7.5066E-02	-3.5310E-03	.0000E+00
55	7.0702E-05	.0000E+00	.0000E+00	8.2799E-02	7.8392E-03	.0000E+00
56	-5.8815E-03	8.7603E-03	4.1320E-02	.0000E+00	-9.7532E-02	-4.9195E-02
57	-2.6934E-03	8.8224E-03	3.4630E-02	.0000E+00	-5.9517E-02	-4.9043E-02
58	-1.3760E-03	9.0114E-03	2.7836E-02	-2.6341E-01	-5.8446E-02	-5.3867E-02
59	-1.3540E-03	9.8431E-03	2.7172E-02	-2.9225E-01	-5.6261E-02	-2.9844E-02
60	-1.3402E-03	1.0179E-02	2.6524E-02	-2.9661E-01	.0000E+00	-1.3583E-02
61	-7.2988E-04	9.9061E-03	1.7116E-02	.0000E+00	-2.0548E-02	-1.1807E-02
62	-3.8531E-04	9.8051E-03	7.1377E-03	.0000E+00	-1.3910E-02	-9.1500E-03
63	-2.3707E-04	9.7494E-03	2.2417E-03	.0000E+00	-1.0683E-02	-8.3267E-03

## ***** STATIC ANALYSIS

LOAD CASE =

## DISPLACEMENTS/ROTATIONS (DEGREES) OF UNRESTRAINED NODES

NODE NUMBER	X- TRANSLATION	Y- TRANSLATION	Z- TRANSLATION	X- ROTATION	Y- ROTATION	Z- ROTATION
1	2.3013E-04	.0000E+00	.0000E+00	-1.0087E-01	-6.9391E-03	.0000E+00
2	2.2547E-04	2.7920E-05	-4.7779E-08	-9.8000E-02	5.5043E-03	.0000E+00
3	2.1783E-04	4.0426E-05	-5.9134E-08	-1.1308E-01	3.3815E-03	.0000E+00
4	2.0738E-04	4.1554E-05	-5.9749E-08	-1.1895E-01	-1.4011E-03	.0000E+00
5	1.9637E-04	.0000E+00	.0000E+00	-1.3623E-01	1.6323E-02	.0000E+00
6	2.0803E-04	1.5211E-05	-2.6177E-08	1.3922E-01	-1.3872E-02	.0000E+00
7	2.0738E-04	2.9342E-05	1.3870E-07	1.6247E-01	7.5409E-03	.0000E+00
8	2.0981E-04	4.2955E-05	7.3145E-03	1.8314E-01	4.4464E-03	.0000E+00
9	2.1229E-04	4.7352E-05	1.8876E-07	2.0320E-01	-4.5715E-03	.0000E+00
10	2.0975E-04	4.3657E-05	2.4792E-08	2.2123E-01	3.0486E-02	.0000E+00
11	1.9321E-04	1.7400E-05	8.4995E-03	5.0304E-01	-8.4833E-02	.0000E+00
12	1.9333E-04	3.2275E-05	9.7175E-03	5.4146E-01	-6.0949E-02	.0000E+00
13	1.9280E-04	4.5695E-05	1.0787E-02	5.9721E-01	-6.1532E-02	.0000E+00
14	1.9263E-04	6.0336E-05	1.1908E-02	8.5493E-01	-6.2751E-02	.0000E+00
15	1.8931E-04	7.6542E-05	1.2852E-02	7.1124E-01	-5.5461E-02	.0000E+00
16	1.5802E-04	1.4213E-05	2.8081E-02	5.5495E-01	-1.1931E-01	.0000E+00
17	1.5857E-04	3.5893E-05	3.0404E-02	5.7641E-01	-1.7550E-01	.0000E+00
18	1.5844E-04	8.0972E-05	3.5268E-02	6.2131E-01	-1.8337E-01	.0000E+00
19	1.5133E-04	8.1016E-05	3.6483E-02	8.7255E-01	-1.9124E-01	.0000E+00
20	1.4324E-04	1.0531E-04	3.9873E-02	7.1377E-01	-2.2071E-01	.0000E+00
21	1.1106E-04	1.4620E-05	4.0102E-02	1.0567E-01	-1.9728E-01	.0000E+00
22	1.1112E-04	3.3408E-05	4.2358E-02	8.7943E-02	-1.6263E-01	.0000E+00
23	1.1230E-04	8.1304E-05	4.6262E-02	3.9377E-02	-2.3053E-01	.0000E+00
24	1.1200E-04	1.3807E-04	5.0494E-02	9.9955E-03	-2.1119E-01	-7.2156E-03
25	1.1557E-04	9.3081E-05	5.3775E-02	-1.5227E-02	-2.2542E-01	.0000E+00
26	9.1919E-05	2.7161E-05	3.9074E-02	-1.8070E-01	-6.9154E-02	.0000E+00
27	9.0254E-05	2.6186E-05	4.0572E-02	-2.1244E-01	-4.5674E-02	.0000E+00
28	9.1905E-05	3.3088E-05	4.2223E-02	-2.7754E-01	-8.1547E-02	.0000E+00
29	1.1222E-04	8.3568E-05	4.3977E-02	-3.7680E-01	-1.3932E-01	-2.2787E-02
30	1.3949E-04	1.7503E-05	4.7022E-02	-3.8952E-01	-2.1755E-01	.0000E+00
31	1.0315E-04	1.8140E-05	5.2215E-02	-3.2275E-01	-5.2513E-01	.0000E+00
32	1.0647E-04	1.8837E-05	5.7715E-02	-3.7380E-01	-8.3613E-02	4.0411E-03
33	1.1501E-04	-1.1749E-05	5.4537E-02	-3.5513E-01	-8.3094E-02	1.7717E-02
34	1.7285E-04	-3.7527E-05	5.3047E-02	-3.1477E-01	-8.3772E-02	7.1530E-03
35	1.5048E-04	-3.7547E-05	5.7347E-02	-3.5875E-01	-3.3772E-01	.0000E+00
36	1.6745E-04	1.6750E-05	5.0057E-02	-3.3467E-01	-8.3877E-02	.0000E+00
37	1.7250E-04	-2.7125E-05	5.1094E-02	-3.7662E-01	-5.7110E-02	.0000E+00
38	1.6416E-04	-3.5715E-05	5.2028E-02	-3.7777E-01	-4.3771E-02	2.1821E-04
39	1.7085E-04	-3.5634E-05	5.2037E-02	-3.7777E-01	-5.3771E-02	1.0000E-05
40	1.7633E-04	-3.5261E-05	5.2037E-02	-4.1775E-01	-4.7714E-02	1.0000E-05

41	-1.172E-04	-1.400E-05	8.0457E-03	-5.172E-01	-7.162E-02	-1.000E+00
42	2.2009E-04	-3.4248E-05	8.0659E-03	-7.9115E-01	-7.5593E-02	0.000E+00
43	2.1137E-04	-6.5220E-05	9.0472E-03	-4.0686E-01	-2.0541E-02	-1.0551E-03
44	2.0577E-04	-6.1199E-05	9.7442E-03	-4.2250E-01	4.1752E-02	-1.000E+00
45	2.0415E-04	-6.8958E-05	8.1160E-03	-4.3362E-01	4.5497E-02	-1.000E+00
46	2.3389E-04	-1.4322E-05	-1.4557E-03	-1.3272E-01	-1.3317E-02	-1.000E+00
47	2.3307E-04	-2.6473E-05	1.5179E-07	-1.5974E-01	8.7831E-03	-1.000E+00
48	2.3146E-04	-2.9151E-05	4.5825E-03	-1.7579E-01	-2.0178E-03	-1.5344E-03
49	2.2904E-04	-4.4426E-05	1.8332E-07	-1.7202E-01	-3.3457E-03	-1.000E+00
50	2.2578E-04	-4.7614E-05	-1.8071E-09	-1.5684E-01	1.4722E-02	-1.000E+00
51	2.4888E-04	.0000E+00	.0000E+00	9.8292E-02	-8.3257E-03	-1.000E+00
52	2.4390E-04	-2.1942E-03	-4.7906E-08	9.5309E-02	5.5363E-03	-1.000E+00
53	2.3878E-04	-3.1157E-05	-6.8396E-08	1.0347E-01	1.1000E-03	-1.000E+00
54	2.3129E-04	-3.5238E-05	-5.2179E-08	9.9493E-02	-4.3175E-03	-1.000E+00
55	2.1997E-04	.0000E+00	.0000E+00	1.0903E-01	1.0589E-02	-1.000E+00
56	-6.0584E-03	9.3827E-03	5.1109E-02	.0000E+00	-1.6621E-01	-5.2373E-02
57	-4.7268E-03	1.0013E-02	4.3721E-02	.0000E+00	-1.3524E-01	-5.9463E-02
58	-2.6699E-03	1.0351E-02	3.4082E-02	-2.9849E-01	-8.6540E-02	-1.1019E-01
59	-2.6367E-03	1.2302E-02	3.4677E-02	-3.7505E-01	-6.9184E-02	-7.3964E-02
60	-2.6155E-03	1.3152E-02	3.5345E-02	-3.8567E-01	.0000E+00	-3.5587E-02
61	-1.2582E-03	1.2534E-02	2.1962E-02	.0000E+00	-3.5504E-02	-2.2903E-02
62	-6.1831E-04	1.2492E-02	9.1994E-03	.0000E+00	-2.5467E-02	-1.7095E-02
63	-3.4156E-04	1.2452E-02	2.9223E-03	.0000E+00	-1.9546E-02	-1.5583E-02

***** THIN PLATE/SHELL ELEMENT STRESSES

ELEMENT NO.	CASE (MODE)	MEMBRANE STRESS COMPONENTS			BENDING STRESS COMPONENTS		
		SM11	SM22	SM12	SB11	SB22	SB12
1	1	-6.501E+00	1.249E+01	2.172E+01	-8.890E+03	-1.392E+04	9.108E+02
1	2	-2.444E+01	1.535E+02	8.675E+01	-3.223E+03	-1.674E+04	1.140E+03
2	1	2.906E+00	-2.043E+01	1.772E+01	-4.379E+03	-2.077E+04	-3.539E+03
2	2	1.580E+01	5.425E+01	5.256E+01	-5.291E+03	-2.509E+04	-4.537E+03
3	1	5.492E+00	-3.951E+01	4.6229E+00	-1.048E+03	-1.763E+03	-1.748E+03
3	2	1.169E+01	6.631E+00	8.942E+00	-1.521E+03	-2.457E+03	-2.388E+03
4	1	3.154E+00	-5.100E+01	-2.121E+01	1.351E+03	1.925E+04	-2.590E+02
4	2	4.822E+00	-1.362E+01	-3.757E+01	1.549E+03	2.291E+04	-4.504E+02
5	1	-4.891E+00	-2.947E+01	-2.454E+01	8.734E+02	1.537E+04	2.552E+03
5	2	-2.132E+01	8.349E+00	-2.712E+01	7.695E+02	1.866E+04	2.957E+03
6	1	-2.083E+00	1.348E+01	-5.453E+00	7.951E+02	5.913E+03	9.109E+02
6	2	2.812E+00	-2.207E+01	8.335E+01	5.910E+02	8.537E+03	8.800E+03
7	1	-1.315E+01	-9.799E+01	4.511E+01	7.549E+01	1.127E+03	-5.332E+02
7	2	-1.307E+01	-4.646E+02	1.053E+02	-1.172E+02	1.703E+03	-1.526E+02
8	1	1.731E+01	4.461E+01	-1.944E+01	4.123E+02	8.027E+02	-1.410E+02
8	2	3.737E+01	-1.977E+02	-6.633E+01	4.822E+02	8.749E+02	-1.454E+02
9	1	-2.188E+00	8.542E+01	-1.730E+01	-2.931E+03	-1.256E+04	3.836E+03
9	2	1.122E+01	4.588E+01	-9.575E+01	-3.719E+03	-1.595E+04	3.046E+03
10	1	-5.002E+00	8.737E+01	-4.055E+00	-2.814E+03	-1.235E+04	4.826E+03
10	2	-3.222E+01	1.726E+02	-9.412E+01	-3.178E+03	-1.570E+04	-1.167E+03
11	1	-2.406E+01	4.553E+01	2.472E+01	-5.009E+03	-1.539E+04	7.047E+03
11	2	-7.332E+01	1.739E+01	4.799E+01	-6.158E+03	-1.938E+04	8.540E+03
12	1	3.997E+00	1.472E+01	1.503E+01	-8.968E+03	-2.271E+04	-1.110E+03
12	2	4.036E+01	7.366E+01	7.346E+01	-9.412E+03	-2.735E+04	-1.587E+03

D-142

13	2	3.280E+01	1.395E+02	2.781E+01	-1.841E+03	-1.953E+03	-3.180E+03
14	1	1.237E+01	-5.611E+01	1.755E+01	2.747E+03	2.222E+04	-2.471E+03
14	2	1.978E+01	-9.883E+00	3.582E+01	2.983E+03	2.637E+04	-3.154E+03
15	1	-7.252E-01	-2.477E+02	5.774E+00	2.704E+03	1.703E+04	5.689E+03
15	2	-5.986E+01	-3.605E+02	3.877E+01	3.051E+03	2.027E+04	5.709E+03
16	1	2.447E+01	-3.055E+02	-7.901E+01	1.441E+03	3.782E+03	4.716E+02
16	2	2.467E+01	-5.067E+02	8.516E+00	2.018E+03	6.308E+03	-1.241E+02
17	1	1.470E+00	-3.034E+02	-1.354E+02	4.398E+02	1.047E+03	5.598E+02
17	2	2.950E+01	-9.259E+02	-1.789E+02	5.226E+02	1.915E+03	1.356E+03
18	1	1.673E+01	3.442E+02	-1.463E+02	2.995E+03	1.872E+03	-1.178E+03
18	2	8.611E+01	1.953E+02	-3.496E+02	3.847E+03	2.475E+03	-1.228E+03
19	1	-3.228E+01	3.506E+02	7.428E+01	-1.301E+03	-1.200E+04	3.152E+03
19	2	-2.523E+01	4.182E+02	-6.445E+01	-1.330E+03	-1.531E+04	4.400E+03
20	1	6.552E+00	-4.417E+01	8.902E+01	-4.811E+03	-1.458E+04	-1.961E+02
20	2	-9.894E+01	-5.248E+00	1.091E+00	-6.231E+03	-1.874E+04	-3.077E+02
21	1	-3.653E+01	2.076E+01	1.499E+01	-5.846E+03	-1.779E+04	4.528E+02
21	2	-1.007E+02	4.902E+01	1.905E+01	-7.147E+03	-2.171E+04	5.656E+02
22	1	3.101E+01	7.560E+01	-1.305E+01	-7.789E+03	-2.477E+04	-2.725E+03
22	2	3.101E+01	1.674E+02	-3.709E+01	-9.542E+03	-3.025E+04	-3.524E+03
23	1	-3.508E+01	9.795E+01	-1.144E+01	-5.902E+02	-7.407E+02	-3.461E+03
23	2	-4.245E+01	2.403E+02	-2.114E+01	-8.875E+02	-1.255E+03	-4.513E+03
24	1	2.620E+01	2.104E+02	1.932E+02	1.037E+04	2.780E+04	-2.914E+03
24	2	1.069E+01	4.193E+02	3.029E+02	1.176E+04	5.304E+04	-3.891E+03
25	1	1.567E+01	-8.300E+02	2.333E+02	6.579E+03	1.953E+04	9.419E+03
25	2	-4.652E+01	-1.103E+03	4.860E+02	6.435E+03	2.288E+04	1.133E+04
26	1	1.961E+02	-7.967E+02	-1.580E+02	-2.253E+03	-9.416E+02	-1.295E+02
26	2	1.478E+02	-1.590E+03	-1.523E+01	-2.831E+03	2.779E+02	-1.136E+02
27	1	3.592E+01	-6.364E+01	3.552E+01	2.902E+02	1.464E+03	1.165E+03
27	2	9.169E+01	-5.631E+02	1.266E+02	5.500E+02	5.134E+03	2.168E+03
28	1	-6.200E+01	3.918E+02	1.241E+02	3.609E+03	1.698E+03	2.739E+03
28	2	-9.127E+01	2.727E+02	3.089E+02	3.425E+03	2.364E+03	3.884E+03
29	1	1.146E+00	4.105E+02	-5.497E+01	-1.470E+03	-1.219E+04	-2.078E+03
29	2	4.033E+01	5.229E+02	9.684E+01	-1.354E+03	-1.575E+04	-1.195E+03
30	1	-1.572E+01	-2.490E+01	-1.094E+02	-4.741E+03	-1.485E+04	1.681E+01
30	2	-1.557E+02	2.886E+01	-7.245E+01	-6.106E+03	-1.919E+04	-2.206E+01
31	1	-1.657E+01	2.175E+02	-5.140E+01	-5.540E+03	-1.839E+04	-2.177E+02
31	2	-4.215E+01	5.157E+02	-1.565E+02	-4.335E+03	-2.230E+04	-2.590E+02
32	1	2.150E+01	1.818E+02	-1.700E+01	-5.375E+03	-2.584E+04	-2.121E+02
32	2	4.837E+01	4.094E+02	-5.595E+01	-5.571E+03	-2.177E+04	-2.171E+02
33	1	-3.366E+01	1.722E+02	-1.067E+01	-1.590E+03	-1.722E+02	-4.557E+02
33	2	-5.378E+01	3.474E+02	-1.301E+01	-2.717E+03	-5.642E+02	-6.173E+02
34	1	4.041E+01	1.477E+02	-1.305E+02	7.146E+03	1.545E+04	2.277E+02
34	2	7.157E+01	3.747E+02	-5.111E+01	3.825E+03	1.655E+04	2.177E+02

07/17

35	2	1.785E+01	-1.426E+03	-2.949E+02	2.752E+03	2.570E+04	-2.749E+03
36	1	6.569E+00	-9.220E+02	1.156E+02	-4.541E+03	-3.919E+03	4.791E+03
36	2	7.029E+00	-1.860E+03	1.700E+02	-5.158E+03	-3.086E+03	5.450E+03
37	1	1.936E+01	3.426E+01	1.795E+02	3.971E+02	1.747E+03	8.739E+02
37	2	3.539E+01	-2.837E+02	3.055E+02	9.129E+02	4.623E+03	8.456E+02
38	1	-2.304E+01	2.299E+02	2.101E+01	5.079E+02	5.757E+02	2.599E+03
38	2	-3.326E+01	1.347E+02	5.896E+01	8.015E+02	8.111E+02	4.040E+03
39	1	1.589E+01	2.758E+02	2.372E+01	-3.189E+03	-1.364E+04	-2.874E+03
39	2	4.448E+01	3.321E+02	1.059E+02	-4.236E+03	-1.795E+04	-3.316E+03
40	1	-1.584E+01	2.629E+02	4.460E+01	-2.858E+03	-1.376E+04	8.690E+02
40	2	-5.134E+01	5.337E+02	1.655E+02	-3.780E+03	-1.813E+04	1.073E+03
41	1	8.807E+02	3.087E+03	2.030E+03	-3.592E+02	-2.276E+03	-1.420E+03
41	2	1.355E+03	3.032E+03	3.233E+03	-6.170E+02	-1.760E+03	-1.573E+03
42	1	8.482E+02	-1.320E+03	-1.277E+03	-5.102E+02	-8.435E+02	-2.394E+03
42	2	1.766E+03	-1.018E+03	-1.056E+03	-1.999E+03	-6.398E+02	-3.729E+03
43	1	-1.202E+02	1.973E+01	2.731E+01	1.360E+03	-4.740E+01	-2.906E+03
43	2	8.540E+00	5.400E+02	-1.947E+02	2.017E+03	-1.408E+02	-6.458E+03
44	1	-2.493E+01	3.671E+02	3.156E+02	7.459E+02	-1.164E+03	-1.331E+03
44	2	-1.874E+01	4.586E+02	4.941E+02	1.849E+03	-2.371E+03	-3.432E+03
45	1	2.557E+02	3.208E+01	-5.997E+02	5.491E-02	8.612E+00	-7.122E+02
45	2	1.120E+03	1.284E+02	-1.052E+03	1.484E+03	-2.551E+02	-1.433E+03
46	1	-2.847E+02	5.629E+02	-8.963E+02	8.077E+01	8.402E+01	-4.064E+02
46	2	1.216E+02	6.771E+02	-1.547E+03	8.431E+01	-1.740E+02	-7.332E+02
47	1	-5.028E+02	-2.549E+02	1.303E+03	8.424E+01	8.700E+02	-3.213E+02
47	2	-4.114E+02	-2.516E+01	1.265E+03	1.378E+02	8.264E+02	-5.848E+02

***** BOUNDARY ELEMENT FORCES/MOMENTS

ELEMENT NO.	CASE (MODE)	FORCE	MOMENT
1	1	.0000E+00	.0000E+00
1	2	.0000E+00	.0000E+00
2	1	-3.9534E+02	.0000E+00
2	2	-4.7774E+02	.0000E+00
3	1	-5.0644E+02	.0000E+00
3	2	-6.9134E+02	.0000E+00
4	1	-4.8621E+02	.0000E+00
4	2	-5.7749E+02	.0000E+00
5	1	.0000E+00	.0000E+00
5	2	.0000E+00	.0000E+00
6	1	-1.7955E+02	.0000E+00
6	2	-2.6172E+02	.0000E+00
7	1	1.1704E+02	.0000E+00
7	2	1.7571E+02	.0000E+00

D-148

6	1	7.3145E+02	.0000E+00
9	1	+1.5440E+03	.0000E+00
9	2	+1.8875E+03	.0000E+00
10	1	1.9379E+02	.0000E+00
10	2	2.4792E+02	.0000E+00
46	11	-9.9439E+01	.0000E+00
46	11	-1.4557E+02	.0000E+00
47	12	1.2138E+03	.0000E+00
47	12	1.5178E+03	.0000E+00
48	13	5.6027E+01	.0000E+00
48	13	4.3625E+02	.0000E+00
49	14	+1.3771E+03	.0000E+00
49	14	+1.8332E+03	.0000E+00
50	15	-4.3229E+01	.0000E+00
50	15	-2.8071E+01	.0000E+00
51	15	.0000E+00	.0000E+00
51	15	.0000E+00	.0000E+00
52	17	-3.7835E+02	.0000E+00
52	17	-4.7808E+02	.0000E+00
53	18	-5.2657E+02	.0000E+00
53	18	-6.8746E+02	.0000E+00
54	19	-5.9822E+02	.0000E+00
54	19	-5.2179E+02	.0000E+00
55	20	.0000E+00	.0000E+00
55	20	.0000E+00	.0000E+00

***** TEMPORARY FILE STORAGE (MEGABYTES)

UNIT NO.	7 :	.023
UNIT NO.	8 :	.033
UNIT NO.	9 :	.029
UNIT NO.	10 :	.023
UNIT NO.	11 :	.164
UNIT NO.	12 :	.009
UNIT NO.	13 :	.205
UNIT NO.	14 :	.050
UNIT NO.	15 :	.023
UNIT NO.	17 :	.000
TOTAL :		.659

***** END OF FILE

CC: ALBGR1


0-149

JT-01-6007-H00J

LOADS:

$$|W + P_d| + (\Sigma E^2 + \Lambda M^2)^{1/2}$$

$$= 583 \text{ lbs.}$$




COLLIDER JACKETED, CLAMP, CLEVIJES:

ASSUME all Grinnell parts: (due to lack of info.)

<u>Part</u>	<u>Allowable Load (lbs.)</u>
200	10,350
295	2,365
66	3,770

∴ All parts are acceptable

COLLIDER VERTICAL UNION FLANGE:



TENSION:  $F_t = 21,600 \text{ psi}$ , LEVEL D = 40,608 psi

$$\sigma_t = \frac{262}{3.73} = 68 \text{ psi} < 21,600 \text{ psi}$$

0-150

COMPRESSION:

$$C_c = 126$$

$$\frac{F_L}{F} = \frac{0.0(34)}{1.00} = 0.8 < 126$$

$$F_a = \frac{\left[1 - \frac{(68)^2}{2(126)^2}\right] 36,000}{\frac{2}{3} + \frac{2(68)}{3(126)} - \frac{(68)^2}{3(126)^2}} = 16,631 \text{ psi}$$

$$\text{LEVEL A} = 31,266 \text{ psi}$$

$$\sigma_a = \frac{262}{3.83} = 68 \text{ psi} < 16,631 \text{ psi}$$

Tear:  $F_t = 14,400 \text{ psi}$  , LEVEL A = 27,573 psi

$$\sigma_t = \frac{521}{3.83} = 136 \text{ psi}$$

Bending:  $F_b = .66(36,000) = 23,760 \text{ psi}$

$$\text{LEVEL A} = 44,669 \text{ psi}$$

$$\sigma_b = \frac{521(34)}{5.45} = 3244 \text{ psi} < 23,760 \text{ psi}$$

COLLISION WEAK:

Clevis to wide flange - 1/4" fillet all around

Tension:  $\sigma_t = \frac{521}{.707(1/4)(4)} = 727 \text{ psi}$

Tear:  $\sigma_t = \frac{262}{.707(1/4)(4)} = 371 \text{ psi}$

D-151

wide flange to existing 12x12 beam - 1/4" fillet all around

$$\text{Tension: } \sigma_t = \frac{262}{.707(1/4)(21)} = 71 \text{ psi}$$

$$\text{Shear: } \sigma_v = \frac{521}{.707(1/4)(21)} = 140 \text{ psi}$$

$$\text{Bending: } \sigma_b = \frac{521(34)}{.707(1/4)[2(4)(4) - \frac{(4)^2}{3}]} = 2684 \text{ psi}$$

$$\text{TOTAL: } \overline{2895 \text{ psi}}$$

∴ This support is acceptable


EE-01-6007-H002

LOADS:

$$|W + P_d| = 685 \text{ lb.}$$

$$|W + P_d + T| = 731 \text{ lb.}$$

$$|W + P_d + T| + (\sigma E^2 + A M c)^{1/2} = 1236 \text{ ksi.}$$



CHECK WIDE FLANGES:  $A = 3.83$ ,  $J = 5.45$

$$\text{shear: } F_v = .4(35) = 14.4 \text{ ksi}$$

$$\text{LEVEL A} = 27.07 \text{ ksi}$$

$$\sigma_v = \frac{731}{3.83} = 191 \text{ psi} < 14,400 \text{ psi}$$

$$\sigma_v = \frac{1236}{3.83} = 321 \text{ psi} < 27,070 \text{ psi} \quad \text{LEVEL A}$$

$$\text{Pending: } F_a = .6(35) = 23.75 \text{ ksi}, \quad \text{LEVEL A} = 44.67 \text{ ksi}$$

$$\sigma_b = \frac{1236(12\frac{3}{4})}{5.45} = 2956 \text{ psi} < 23,760 \text{ psi}$$

$$\text{TENSION: } F_t = .6(35) = 21.6 \text{ ksi}, \quad \text{LEVEL A} = 40.61 \text{ ksi}$$

$$\sigma_t = \frac{1236}{3.83} = 320 \text{ psi} < 21,600 \text{ psi}$$

$$\text{COMPRESSION: } C_c = \sqrt{\frac{2\pi^2(724,000)}{25,000}} = 125$$


$$\frac{CL}{T} = \frac{1.0(37)}{1.00} = 37.0 < 125$$

D-153

$$\sigma_2 = \frac{\left[1 - \frac{63.0^2}{2(125)^2}\right] (36,000)}{\frac{7}{3} + \frac{2(63.0)}{8(125)} - \frac{(63.0)^2}{8(125)^2}} = 17133 \text{ psi}$$

LEVEL D = 32210 psi

$$\sigma_a = \frac{1266}{3.83} = 330 \text{ psi} < 17133 \text{ psi}$$

CHECK  $1'' \times 4''$  R: 1" H.L. 

shear:  $F_t = 14.4 \text{ ksi}$

LEVEL D = 27.07 ksi

$$\sigma_v = \frac{1266}{1(1/16)} = 920 \text{ psi} < 14,400 \text{ psi}$$

TENSION (tear out):  $F_t = 21.6 \text{ ksi}$ , LEVEL D = 40.61 ksi

$$\sigma_t = \frac{1266}{(1)(4 - \frac{1}{1/32})} = 418 \text{ psi} < 21,600 \text{ psi}$$

COMPRESSION:  $c_c = 125$ ,  $r = \sqrt{3(1^2/12)/(\pi/4)} = 0.042$

$$\frac{c_f}{r} = \frac{2(24)}{0.042} = 1143 > 125 \text{ (use 200)}$$

$$F_u = \frac{12\pi^2 E}{25(2L/r)^2} = \frac{12\pi^2 (29 \times 10^6)}{25(200)^2} = 3733 \text{ psi}$$

LEVEL D = 7019 psi

$$\sigma_z = \frac{1266}{2(1)} = 633 \text{ psi} < 3733 \text{ psi}$$

CHECK CLAMP & CLEVIS:

ASSUME Grinnell parts:

<u>Part No.</u>	<u>maximum load (lbs.)</u>
295	5390
66	7090

All parts are acceptable.

CHECK WELDS:

CLEVIS TO 6x6" R → 1/4" Filler L ≈ 3 3/4"

$$\sigma_t = \frac{1266}{.707(1/4)(2)(2\frac{3}{4})} = 1910 \text{ psi}$$

2 wide Flanges → 1/4" Filler

$$\sigma_t = \frac{1266}{.707(1/4)(2)(2\frac{3}{4})} = 1902 \text{ psi}$$

$$\sigma_t = \frac{1266}{.707(1/4)(2)(2\frac{3}{4})} = 1202 \text{ psi}$$


$$\sigma_b = \frac{1266}{(.57X4 - 1/4)(2\frac{3}{4})(1/4)} = 8856 \text{ psi}$$

∴ this support is acceptable.

SUPPORT CALCULATIONSJZ-01-6007-HCOL

$$\text{LOADS: } |W + P_d + T| = 442 \text{ lb/in}$$

$$|W + P_d + T| + (JZ\epsilon^2 - 1M^2)^{1/2} = 747 \text{ lb/in.}$$

COLLIMED VERTICAL TUBE:

$$\text{TENSION: } F_t = .3(35,000) = 31,500 \text{ psi}$$

$$\text{LEVEL A} = 40,608 \text{ psi}$$

$$\sigma_t = \frac{747}{3.59} = 208 \text{ psi} < 31,500 \text{ psi}$$

$$\text{COMPRESSION: } C_c = \sqrt{\frac{3\pi^2 (29 \times 10^6)}{36,000}} = 136$$

$$\frac{E}{r} = \frac{2(38 1/2)}{1.51} = 51.0 < 126$$

$$F_2 = \left[ \frac{1 - (51.0)^2}{2(126)^2} \right] 36,000 = 18,259 \text{ psi}$$


$$\frac{r}{z} + \frac{c(J1)}{z(126)} = \frac{(J1)^2}{z(126)^3}$$

$$\text{LEVEL A} = 34,326 \text{ psi}$$

$$\sigma_2 = \frac{747}{3.59} = 208 \text{ psi} < 18,259 \text{ psi}$$

COLLIMED HOLLOW CYLICAL Z:

Considering this number of 25 in. thick - Face = Face  
bottom in. in contact with 100% of contact -



Steel:  $F_y = .4(36,000) = 14,400 \text{ psi}$ , Level D = 27,072 psi

$$\sigma_y = \frac{747}{1.19} = 629 \text{ psi} < 14,400 \text{ psi}$$

Bending:  $F_b = .5(36,000) = 31,600 \text{ psi}$ , Level D = 40,508 psi

$$a = 1.19 \text{ in}^2$$

$$z_0 = 40 = 0.717 \text{ in.}$$

$$I_x = I_y = 0.703 \text{ in}^4$$

$$r_0 = 0.941 \text{ in.}$$

$$I_u = ar_0^2 = 1.19(0.941)^2 = 1.054 \text{ in}^4$$

$$I_u + I_v = I_x - I_y \quad I_v = 2(0.703) - 1.054 = 0.352 \text{ in}^4$$

$$v_A = -1.014$$

$$u_A = 0$$

$$v_B = 0.754$$

$$u_B = -1.762$$

$$v_C = +0.754$$

$$u_C = 1.762$$

$$M_u = -.707(747)(7\frac{5}{8})/8 = -503 \text{ in-lb}$$


$$M_v = .707(747)(7\frac{5}{8})/8 = 503 \text{ in-lb}$$

$$\tau_A = \frac{M_u v_A}{I_u} + \frac{M_v u_A}{I_v} = \frac{-503(-1.014)}{1.054} = 484 \text{ psi} < 31,600 \text{ psi}$$

$$\sigma_d = \frac{-503(1.754)}{1.054} + \frac{503(-1.762)}{0.352} = -2466 \text{ psi} < 31,600 \text{ psi}$$

$$\tau_C = \frac{-503(1.754)}{1.054} + \frac{503(1.762)}{0.352} = 2288 \text{ psi} < 31,600 \text{ psi}$$


CONSIDER VERTICAL & I:



TENSION:  $\sigma_t = \frac{374}{1.19} = 314 \text{ psi} < 21,600 \text{ psi}$

Comment: calculations performed for horizontal  
 $\Delta 2\frac{1}{2} \times 2\frac{1}{2} \times \frac{1}{4}$  would apply here also.

CONSIDER CHANNEL:



Shear:  $\sigma_v = \frac{374/2}{3.09} = 242 \text{ psi} < 14,400 \text{ psi}$

Comment: consider half of beam as cantilever -

$$\sigma_b = \frac{374(75/3) + 748}{0.564} = 7046 \text{ psi} < 40,603 \text{ psi}$$

LEVEL D

$$\sigma_b = \frac{442(1/2)(75/3) + 442(75/3)/3}{.564} = 4,137 \text{ psi} < 21,600 \text{ psi}$$

CONSIDER WELDS:

Tube to existing beam: 1/4" fillet

$$\text{Tension: } \sigma_t = \frac{747}{.707(1/4)(4)(3)} = 352 \text{ psi}$$

Horizontal L to vertical L: 1/4" fillet

$$\text{Shear: } \sigma_v = \frac{747}{.707(1/4)(2)(2^{1/2})} = 845 \text{ psi}$$

$$\text{Bending: } \sigma_b = \frac{748}{.707(1/4)\left[\frac{4(2^{1/2})(2^{1/2}) - (2^{1/2})^2}{6}\right]} = 813 \text{ psi}$$

(See "Design of welded structures", Blockley)

Vertical L to channel: 1/4" fillet

Bending: same as above calculation

$$\text{Tension: } \sigma_t = \frac{374}{.707(1/4)(4)(2^{1/2})} = 212 \text{ psi}$$

Channel to vertical tubing: 7/16" fillet

$$\text{Tension: } \sigma_t = \frac{747}{.707(7/16)(2)(4)} = 704 \text{ psi}$$

$$\text{Bending: } \sigma_b = \frac{748(2)}{.707(7/16)(4)(4)} = 705 \text{ psi}$$

∴ This support is acceptable

85/11/25.

**KUPIRE-TIL NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION**  
**SERIES 1 ST-150 PIPE STRESS CALCULATION W INPELL SAPS**

**SUPPORT REACTIONS FOR LOAD CASE NO. 1**

**WEIGHT PLUS EXTERNAL FORCES**

NOPE	TYPE	REACTION FLBS OR IN-LBS)	DIRECTION
5	FORCE	-9.	X COORE
5	FORCE	188.	Y COORE
5	MOMENT	-1.	Z COORE
5	MOMENT	15.	X COORE
5	MOMENT	72.	Y COORE
5	MOMENT	-5732.	Z COORE
20	FORCE	408.	Y COORE
35	FORCE	686.	Y COORE
85	FORCE	465.	Y COORE
85	FORCE	1.	INCLINED
95	FORCE	210.	Y COORE
95	FORCE	-41.	INCLINED
105	FORCE	196.	Y COORE
105	FORCE	36.	Z COORE
115	FORCE	198.	Y COORE
115	FORCE	-4.	Z COORE
120	FORCE	209.	Y COORE
120	FORCE	-25.	Z COORE
135	FORCE	10.	Y COORE
135	FORCE	-2.	INCLINED
250	FORCE	39.	Y COORE
250	FORCE	-231.	Y COORE
250	FORCE	19.	Z COORE
250	MOMENT	2916.	X COORE
250	MOMENT	-565.	Y COORE
250	MOMENT	1978.	Z COORE

D91-O

PS/11/25.

**NUPPIPE-TIL, NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM -- VERSION 1**  
**SPNCS 1 ST-158 PIPE STRESS CALCULATION W IMPELL SAYS**

SUPPORT REACTIONS FOR LEAD CASE NO. 2

THERMAL EXPANSION PLUS ANCHOR MOVEMENTS

NODE	TYPE	REACTION (LBS OR IN-LBS)	DIRECTION
5	FORCE	-178.	X COORD
5	FORCE	-11.	Y COORD
5	FORCE	-46.	Z COORD
5	MOMENT	579.	X COORD
5	MOMENT	-5555.	Y COORD
5	MOMENT	161.	Z COORD
20	FORCE	34.	Y COORD
35	FORCE	45.	Y COORD
85	FORCE	-145.	Y COORD
85	FORCE	54.	INCLINED
95	FORCE	-82.	Y COORD
95	FORCE	49.	INCLINED
105	FORCE	6.	Y COORD
105	FORCE	-61.	Z COORD
115	FORCE	-69.	Y COORD
115	FORCE	-102.	Z COORD
120	FORCE	427.	Y COORD
120	FORCE	176.	Z COORD
135	FORCE	-1036.	Y COORD
135	FORCE	-100.	INCLINED
250	FORCE	156.	X COORD
250	FORCE	667.	Y COORD
250	FORCE	-124.	Z COORD
250	MOMENT	-11195.	X COORD
250	MOMENT	-7393.	Y COORD
250	MOMENT	-58093.	Z COORD

191-0

## NUPIPE-III. NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION 1

SONGS 1 SI-158 PIPE STRESS CALCULATION w IMPELL SANS

SUPPORT REACTIONS FOR LOAD COMBINATION CASE NO. 24

SEISMIC PLUS IMPSAHS

NODE	TYPE	REACTIONS (LBS OR IN-LBS)	DIRECTION
5	FORCE	679.	X COORD
5	FORCE	127.	Y COORD
5	FORCE	327.	Z COORD
5	HOMEREN	952.	X COORD
5	HOMEREN	21449.	Y COORD
5	HOMEREN	7365.	Z COORD
20	FORCE	305.	Y COORD
35	FORCE	535.	Y COORD
40	FORCE	663.	Y COORD
45	FORCE	403.	Y COORD
45	FORCE	306.	INCLINED
95	FORCE	100.	Y COORD
95	FORCE	373.	Y COORD
105	FORCE	83.	INCLINED
105	FORCE	602.	Y COORD
115	FORCE	149.	Y COORD
115	FORCE	166.	Y COORD
120	FORCE	169.	Y COORD
120	FORCE	137.	Y COORD
135	FORCE	446.	Y COORD
135	FORCE	393.	INCLINED
155	FORCE	862.	INCLINED
160	FORCE	1010.	INCLINED
165	FORCE	1124.	Y COORD
250	FORCE	1653.	X COORD
250	FORCE	705.	Y COORD
250	FORCE	1733.	Z COORD
250	HOMEREN	81452.	X COORD
250	HOMEREN	77906.	Y COORD
250	HOMEREN	72249.	Z COORD

0-162

Distribution Copies:

Docket File 50-206

NRC PDR

Local PDR

PAD#1 r/f

PAD#1 p/f

TNovak, Actg Div Dir

GLear

RDudley

EMcKenna

PShuttleworth

NThompson, DHFT

OELD

LHarmon

EJordan

BGrimes

JPartlow

EButcher, TSCB

TBarnhart (4)

WJones

FOB, DPLA

Tech Branch that had input in package

ACRS (10)

OPA

LFMB (w/cy of TAC w/Amd No. & date issued)