Commonwealth Edison Company Zion Generating Station 101 Shiloh Boulevard Zion, IL 60099-2797 Tel 847-746-2084

ComEd

November 21, 1997

U.S. Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

Enclosed is Licensee Event Report (LER) number \$2.97-005, Docket No. 50-000304 that is being submitted pursuant to 10CFR50.73(a)(2)(i)(B) which requires a 30 day written report when any operation occurs that is prohibited by the plant's Technical Specifications.

Attachment A provides commitments associated with this correspondence.

Very truly yours,

R. Starkey

Station Manager

Zion Generating Station

RS/jb

Enclosures:

Licensee Event Report

Regulatory Commitment List

XC:

NRC Region III Administrator NRC Zion Resident Inspector Illinois Department of Nuclear Safety IDNS Resident Inspector IEDZY.

9711260213 971121 PDR ADOCK 05000304



ATTACHMENT A

REGULATORY COMMITMENTS

The following identifies those actions committed to by ComEd in this document. Any other actions discussed is this submittal represent intended or planned actions by ComEd. They are described to the NRC for the NRC's information and are not regulatory commitments.

Regulatory Commitments	Tracking Number
The IST Group Lead will include in their review for acceptance criteria a second check to ensure the periodicity requirements for each component are met.	30418097SCAQ00009-01
The IST Group Lead will put into place a mechanism to ensure their review of applicable PTs and Technical Staff Surveillances is conducted prior to the critical date for the component tested.	30418097SCAQ00009-02
The Shift Operations Supervisor will ensure the PTs which require IST review will be provided to the IST Group Lead prior to the critical date.	30418097SCAQ00009-03
The System Engineering Supervisor will ensure the Technical Staff Surveillances which contain IST components will be provided to the IST Group Lead prior to the critical date.	30418097SCAQ00009-04
The IST group will pursue acquiring a scheduling/monitoring tool that will keep track of IST surveillances on the component level.	30418097SCAQ00009-05