



Georgia Power

the southern electric system

D. O. Foster
Vice President
Vogtle Project

06 JUN 24 A 9:43

June 19, 1986

United States Nuclear Regulatory Commission
Region II
Suite 2900
101 Marietta Street, Northwest
Atlanta, Georgia 30323

File: X7BG03-M118
Log: GN-955

Reference: Vogtle Electric Generating Plant - Unit 1; 50-424;
125V DC Station Batteries


Attention: Mr. J. Nelson Grace

On May 20, 1986, Mr. R. E. Folker, Vogtle Project Quality Assurance Engineer, informed Mr. E. F. Christnot of the USNRC - Region II of a potentially reportable condition concerning the 125V DC Station Batteries. During a monthly inspection of the batteries, a black substance was observed to be flaking off the positive straps of the Class 1E Batteries.

Georgia Power Company is evaluating this condition and expects to inform the NRC of the results of the evaluation of this condition by July 18, 1986.

This response contains no proprietary information and may be placed in the NRC Public Document Room.

Yours truly,


D. O. Foster

xc: U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

J. H. Miller
J. P. O'Reilly
G. F. Head
R. E. Conway
J. T. Beckham
R. H. Pinson
P. D. Rice
B. M. Guthrie
D. E. Dutton

R. A. Thomas
D. R. Altman
P. R. Bemis
J. A. Bailey
O. Batum
G. Bockhold
C. E. Belflower
J. F. D'Amico
E. D. Groover

L. T. Gucwa
C. W. Hayes
G. A. McCarley
D. S. Read
Sr. Resident (NRC)
C. S. McCall (OPC)
J. E. Joiner (TSLA)
D. C. Teper (GANE)
NORMS