

June 27, 1986

Docket No. 50-412

Mr. J. J. Carey, Vice President  
Duquesne Light Company  
Nuclear Group  
Post Office Box 4  
Shippingport, PA 15077

DISTRIBUTION

Docket File

NRC PDR  
Local PDR  
PAD#2 Rdg  
T. Novak  
OELD  
E. Jordan  
B. Grimes  
J. Partlow

P. Tam  
D. Miller  
ACRS (10)  
N. Thompson, DHFT  
D. Lasher  
EICSB  
Gray File

Dear Mr. Carey:

Subject: Request for Additional Information, Beaver Valley Unit 2,  
Response to Items 2.2.1, 2.2.2, 4.3, 4.5.2 and 4.5.3 of Generic  
Letter 83-28

By letter dated March 30, 1984, Duquesne Light Company responded to the subject Generic Letter. Our review of your submittal is ongoing. However, we determined that additional information is needed to complete our review of the subject items. Details may be found in the enclosure. Please respond within 45 days of receipt of this letter.

This information request affects fewer than 10 respondents; therefore OMB clearance is not required under P.L. 96-511.

Sincerely,

/s/

Peter S. Tam, Project Manager  
PWR Project Directorate #2  
Division of PWR Licensing-A  
Office of Nuclear Reactor Regulation

cc: See next page

~~LA:PAD#2  
DMiller  
6/7/86~~

PM:PAD#2  
PTam:hc  
6/23/86

EICSB  
DLasher  
6/25/86

AD:PAD#2  
DMcDonald  
6/29/86

8607090029 860627  
PDR ADOCK 05000412  
A PDR

Mr. J. J. Carey  
Duquesne Light Company

Beaver Valley 2 Power Station

cc:  
Gerald Charnoff, Esq.  
Jay E. Silberg, Esq.  
Shaw, Pittman, Potts & Trowbridge  
1800 M Street, N.W.  
Washington, DC 20036

Mr. R. E. Martin, Manager  
Regulatory Affairs  
Duquesne Light Company  
Beaver Valley Two Project  
P. O. Box 328  
Shippingport, Pennsylvania 15077

Mr. C. W. Ewing, Quality Assurance  
Manager  
Quality Assurance Department  
Duquesne Light Company  
P. O. Box 186  
Shippingport, Pennsylvania 15077

Zori Ferkin  
Assistant Counsel  
Governor Energy Council  
1625 N. Front Street  
Harrisburg, PA 15105

Director, Pennsylvania Emergency  
Management Agency  
Room B-151  
Transportation & Safety Building  
Harrisburg, Pennsylvania 17120

Mr. T. J. Lex  
Westinghouse Electric Corporation  
Power Systems  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Mr. Thomas Gerusky  
Bureau of Radiation Protection  
PA Department of Environmental  
Resources  
P. O. Box 2063  
Harrisburg, Pennsylvania 17120

Mr. P. RaySircar  
Stone & Webster Engineering Corporation  
P. O. Box 2325  
Boston, Massachusetts 02107

BVPS-2 Records Management Supervisor  
Duquesne Light Company  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. W. Troskoski  
U. S. NRC  
P. O. 181  
Shippingport, Pennsylvania 15077

John A. Lee, Esq.  
Duquesne Light Company  
1 Oxford Centre  
301 Grant Street  
Pittsburgh, Pennsylvania 15279

Mr. Thomas E. Murley, Regional Admin.  
U. S. NRC, Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 15229

REQUEST FOR ADDITIONAL INFORMATION  
BEAVER VALLEY UNIT 2  
GENERIC LETTER 83-28

(1) Item 2.2.1 - Incomplete

Applicant responded to items 2.2.1.1 to 2.2.1.6 but still needs to provide additional information in response to items 2.2.1.2 and 2.2.1.4. For Item 2.2.1.2, applicant should describe how new safety-related items are entered; how changes in classification of listed items are made; how listed items are verified; how unauthorized changes to the information system are prevented; and how the information system will be maintained and distributed to users as a single, unambiguous and consistent version. For Item 2.2.1.4, the applicant should describe the means by which the plant and corporate management assure themselves that these procedures are being correctly and consistently applied.

(2) Item 2.2.2 - Incomplete

Applicant needs to present his evaluation of NUTAC program and describe how it will be implemented at Beaver Valley Unit 2. Accordingly, the applicant will need to supplement his response to address the concerns associated with implementation at Beaver Valley Unit 2 of measures to improve the NPRDS and SEE-IN programs outlined in the NUTAC report.

(3) Item 4.3 - Incomplete

Applicant needs to commit to and implement the WOG design or its equivalent for automatically actuating the shunt trip attachment on the reactor trip breakers and address the plant-specific concerns put forth in the NRC SER on the WOG design.

(4) Item 4.3 Technical Specifications - Incomplete

Applicant should submit proposed technical specification in accordance with the guidance provided in Generic Letter 85-09.

(5) Item 4.5.2 - Incomplete

Applicant should verify that on-line testing of the RTS will be performed on a regular basis as per technical specifications, which includes independent on-line testing of the diverse trip features.

(6) Item 4.5.3 - Incomplete

Need a description of the specific implementation plan for Beaver Valley Unit 2 after NRC reviewed the technical report WCAP-10271 and supplement 1.