

APR 2 1986

✓ Florida Power and Light Company  
ATTN: Mr. C. O. Woody  
Group Vice President  
Nuclear Energy Department  
P. O. Box 14000  
Juno Beach, FL 33408

Gentlemen:

SUBJECT: CONFIRMATION OF ACTION - DOCKET NOS. 50-250 AND 50-251

This letter refers to the telephone conversation on April 2, 1986, between Messrs. V. W. Panciera and R. Brewer of this office and Messrs. J. Dickey and D. Chaney of your staff, concerning the results of your evaluation of emergency diesel generator loading. This evaluation, which was performed at your initiative, revealed potential overloading of Turkey Point diesel generators.

Based upon the matters discussed, it is our understanding that you will take or have taken the following actions prior to restart of Units 3 and 4:

1. Total loads on emergency diesel generators will be reduced to no more than 2845 kilowatts per diesel generator and procedures will be changed, and operators trained on these changes prior to assuming duties, to assure operation within this limitation.
2. A written safety evaluation performed pursuant to 10 CFR 50.59 of the reduced diesel generator loading demonstrates that, with Unit 4 in a cold shutdown condition:

Unit 3 can be operated safely, in accordance with Technical Specifications, and within the bounds of currently approved accident analysis for the full range of accident break spectra.

Unit 4 can be safely maintained in cold shutdown.

This evaluation will be formally submitted to the NRC prior to Unit 3 entering mode 2.

3. A safety evaluation of diesel generator loading for concurrent operation of Units 3 and 4 will be completed and approved by the NRC prior to restart of Unit 4.

8604100228 860402  
PDR ADOCK 05000250  
P PDR

APR 2 1986

If your understanding of our discussion is different from that stated above, please inform this office promptly.

Sincerely,

Original Signed by  
Roger D. Walker /for

J. Nelson Grace  
Regional Administrator

CAL 50-250, 251-86-01

cc: ✓ C. M. Wethy, Vice President  
✓ C. J. Baker, Plant Manager  
✓ L. W. Bladow, Plant QA  
✓ J. Arias, Jr., Regulatory and Compliance Supervisor

bcc: Document Control Desk  
State of Florida  
✓ NRC Resident Inspector  
✓ A. McDonald

RII

TEConlon:aw  
04/✓/86  
4/1 Memo

RII

ARHerdt  
04/✓/86

RII

RDWalker  
04/2/86

RII

AFGibson  
04/✓/86

RII

GJenkins  
04/2/86

HQ

AMcDonald  
04/7/86

Telecom Elrod/  
McDonald on 4/1  
McDonald concurred  
in substance of letter