

COMMONWEALTH EDISON COMPANY  
CALCULATION TITLE PAGE

CALCULATION NO.: L-001337

PAGE NO.: 1

SAFETY RELATED       REGULATORY RELATED       NON-SAFETY RELATED

CALCULATION TITLE: Containment Liner Leak Chase Channel Assessment

STATION/UNIT: LaSalle County/ Unit 1

SYSTEM ABBREVIATION: NA

EQUIPMENT NO.: (IF APPL.) NA

PROJECT NO.: (IF APPL.) 10248-012

REV: 0 STATUS: Approved QA SERIAL NO. OR CHRON NO. DATE:

PREPARED BY: A. C. Eberhardt/ *A. C. Eberhardt* DATE: 10/28/97

REVISION SUMMARY: Initial Issue

ELECTRONIC CALCULATION DATA FILES REVISED: NA  
(Name ext/size/date/hour: min/verification method/remarks)

DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION YES  NO

REVIEWED BY: R. Namperumal/ *R. Namperumal* DATE: 10-30-97

REVIEW METHOD: Detailed COMMENTS (C, NC OR CI): CI

APPROVED BY: S. M. KAZMI *S. M. Kazmi* DATE: 11-3-97

9712020014 971126  
PDR ADOCK 05000373  
PDR

**COMMONWEALTH EDISON COMPANY**  
**CALCULATION TABLE OF CONTENTS**

PROJECT NO. 10248-012		
CALCULATION NO. L-001337	REV. NO. 0	PAGE NO. 2
DESCRIPTION	PAGE NO.	SUB-PAGE NO.
TITLE PAGE	1	
REVISION SUMMARY	1	
TABLE OF CONTENTS	2	
PURPOSE/OBJECTIVE	3	
METHODOLOGY AND ACCEPTANCE CRITERIA	3	
ASSUMPTIONS	3	
DESIGN INPUT	3-4	
REFERENCES	4	
CALCULATIONS	5 to 25.1	5.1,5.2,12.1,13.1,18.1,25.1
SUMMARY AND CONCLUSIONS	26	
ATTACHMENTS	A1 - A7, B1 - B7, C1 - C8, D1 - D39	

This Calculation has been prepared using Mathcad Plus 5, S&L Program Number 03.7.548-5.0

#### Purpose and Objective

To perform a design assessment of 2" and 3" containment liner leak chase channels in the suppression pool and drywell. Discrepancies between design material yield strength and specified minimum material yield strength are addressed. In addition, the margin between specified yield and ultimate tensile strength as determined from vendor supplied certified material test reports (CMTRs) will be verified. Results are given in terms of margin factor which is defined as the ratio of allowable stress divided by actual stress. This calculation is performed in response to PIF # L1997-06237.

#### Methodology and Acceptance Criteria

This calculation shall be performed in accordance with the applicable documents listed as Design Inputs below. The acceptance criteria used for this assessment is given in Subsection 4.3.2 of the LaSalle Design Assessment Report (DAR) (D.I. 32). Applicable load combinations are defined in Table 4.3-2 of the DAR. Allowable stresses for load combinations 1 through 3 are per the 1969 AISC Specification. However, it has been demonstrated in previous calculations (see D.I. 33) that the governing load combinations involve either hydro-dynamic loads or jet impingement loads. For these load combinations, the allowable stress is limited to 0.95 fy. As permitted in Ref. 3, Sect. III.2.a, a 10% increase in minimum specified yield strength will be used to account for strain rate effects associated with impact loads. The allowable stress used for weld assessment is 21 ksi for all load combinations.

#### Assumptions

There are no unverified or unconservative assumptions used in this calculation.

#### Design inputs (Check where applicable "APP" )

APP

- 1)  DC-SE-01-LS, Rev. 7, Structural Project Design Criteria
- 2)  AISC's Manual of Steel Construction, Eighth Edition
- 3)  AISC's Manual of Steel Construction, Seventh Edition
- 4a)  ACI-318 Building Code Requirements for Reinforced Concrete Structures, 1983
- 4b)  ACI-349 Building Code Requirements for NSR Concrete Structures, 1980
- 5)  AISI's Cold Formed Steel Design Manual, 1983
- 6)  DC-SE-02-LS, Rev. 0, Seismic Response Spectra
- 7)  DC-SE-03-LS through DC-SE-09-LS, All Rev. 0, Hydrodynamic Response Spectra
- 8)  Calculation 802-100.2, Rev. 0, Pages 25-37, Peak g-values for Pipe Supports
- 9)  Calculation 802-100.2, Rev. 8, Pages 41-44, Peak g-values for Pipe Supports in the Drywell
- 10)  Calculation 802-100.2, Rev. 8, Page 40, Peak g-values for Electrical Supports in the Drywell
- 11)  Calculation 795, Rev. 0, Pages 42-43, Peak g-values for Cable Trays and Conduits
- 12)  DIT No. LS-EPED-0C77-01 and Calculation No. GDS-3.6.6, Rev. 1, Reduced Conduit Weights
- 13)  S&L's SD&D Report No. 78, Rev. 4, Concrete Masonry Wall Design
- 14)  S&L's SDS-E5.0, Rev. 1, Loads, Load Combinations, and Allowables
- 15)  S&L's SDS-E11.0, Rev. 2 Hilti Kwik Bolt Design
- 16)  S&L's SDS-E11.0, Rev. 3 Hilti Kwik Bolt II Design
- 17)  S&L's SDS-E30.0, Rev. 0 Cable Tray Design

- 18)  S&L's SDS-E31.0, Rev. 2 Cable Tray Support Design  
 19)  S&L's SDS-E33.0, Rev. 3 Conduit and Conduit Support Design  
 20)  S&L's SDS-E37.0, Rev. 5 Pipe Support Design  
 21)  S&L's SDS-E41.0, Rev. 2 Weld Design  
 22)  S&L's SDS-E44.0, Rev. 0 Embedment Plate Design  
 23)  Calculation 802-104.4, Rev. 9, Pages 4-5, Design Equations for Embedment Plates  
 24)  LaSalle County Station Updated Final Safety Report, Rev. 11  
 25)  LaSalle County Station Drawing S-384, Rev. U  
 26)  S&L's GDS-3.6.3, Rev. 3  
 27)  S&L's Project Instruction LSNS-22, Rev. 3  
 28)  NUREG ICR-2913, "Two Phase Jet Loads" Published Jan. 1983 by SANDIA National Laboratories  
 29)  S&L's Project Instruction LSNS-16, Appendix I, Rev. 0  
 30)  CBI Shop Drawings (See specific references below for Revision nos.)  
 31)  SRV & LOCA Loads on Downcomer Bracing and Gusset Plates, NSLD Calc. 3C7-1179-002)  
 32)  LaSalle County Station Mark II Design Assessment Report, Rev. 10  
 33)  LaSalle Calculation 164, "Suppression Pool Liner Assessment & Anchorage Assessment"  
 34)  LaSalle Calculation 3C7-1075-001, "Loa s due to Loss-of Coolant Accident in LaSalle Containment,"  
     Rev. 6  
 35)  LaSalle Specification J-2534, "Primary Containment Steel Liner Work", Amd. 3, 9-14-81

#### References

1. PIF # L1997-06237
2. Staad-III Structural Analysis, S&L Program # 03.7.065-20.2)
3. USNRC Standard Review Plan 3.6.2, Rev. 1, July 1981

GLOBAL UNIT DEFINITIONS :

$$\text{kip} = 1000 \text{-lbf} \quad \text{psf} = \frac{\text{lbf}}{\text{ft}^2} \quad \text{ksf} = \frac{\text{kip}}{\text{ft}^2} \quad \text{ksi} = \frac{\text{kip}}{\text{in}^2} \quad \text{ORIGIN} = 1$$

$$\text{lbs} = 1 \text{-lbf}$$

$$\text{lb} = 1 \text{-lbf}$$

**Calculations****General Description**

A total of three cases are considered to cover all variations in configuration, material properties, and governing load combinations. These three cases are described below as part of the calculation index.

**Calculation Index**

The calculation is divided into three sections to consider the following cases:

Pages 5 to 11, 2"x1"x 3/16" stainless steel channel subject to all loads in the suppression pool.

Pages 12 to 17, 3x4.1 channel subjected to jet impingement loads in the drywell and hydro-dynamic LOCA and SRV loads in the suppression pool.

Pages 18 to 24, 3x4.1 channel with one leg shortened by 1/2" to accommodate a thickened embed plate. This configuration is analyzed for hydro-dynamic LOCA and SRV loads in the suppression pool.

**Case 1: 2"x1"x 3/16" Stainless Steel Channel****Preparation of Input to Staad Computer Model**

This model includes the 2" channel as well as the half coupling and test plug connection detail shown in Section D-D on CBI dwg. 34, Rev. 3. This model covers all 2" channels on the wall and basemat. Joint coordinates are center line coordinates. Additional joints are provided so that stresses can be determined at the end of the fillets at each corner of the channel. Member properties of the channel web and flanges are based on a thickness  $tw$  of 3/16" and an effective width of 3.0". This is based on the criteria given in D.I. 20, Fig. 37.6.6-4 where  $ba$  is the side dimension of a square with an area equivalent to that of the 1/4" half coupling which has a diameter of 7/8".

$$d = \frac{7}{8} \text{ in}$$

$$tw = \frac{3}{16} \text{ in}$$

Equivalent square:  $ba = \left( \frac{\pi \cdot d^2}{4} \right)^{.5}$

$$ba = 0.78 \text{ in}$$

Calc. For	
Safety-Related	Non-Safety-Related

Calc. No. L - 001237	
Rev.	Date
Page 5.1	of

Client	
Project	
Proj. No.	10243-012 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

STAAD MODEL FOR CASE 1 - L 2" x 1" x 3/16"

WITH TES. COUPLING

Channel Properties

$$d = 2"$$


$$b_f = 1"$$

$$t_f = t_w = 3/16"$$

$$k = 0.261" \text{ conservative}$$

test coupling, see next page.

SEE NEXT 2 PAGES FOR  
ADDITIONAL MODEL  
DETAILS



JOINT COORD.

1	0	5
2	0	.7394
3	0	.9063
4	.1669	.9063
5	.16456	.9063
6	.1.8125	.9063
7	.1.8125	.7394
8	.1.8125	0
9	0.5475	.9063
10	1.264	.9063
11	0.5475	2.33
12	1.264	2.33

Member Incidences

1	12
2	2 3
3	3 4
4	4 9
5	5 6
6	6 7
7	7 8
8	9 10
9	10 5
10	9 11
11	11 12
12	12 10

Calc. No.:	
Safety-Related	Non-Safety-Related

Calc. No. L-071227
Rev. Date
Page 5.2 of


Client	
Project	
Proj. No.	10248-012 Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

$\frac{1}{4}$ " $\phi$  3,000 lb half coupling

A, B & C Dimensions From CATALOG W-6B

Bonney Forge  
Allentown, PA



$$A = 1\frac{1}{8}''$$

$$B = \frac{7}{8}''$$

$$C = 0.555''$$

$$D = B - \frac{B-C}{2}$$

$$= \frac{7}{8} - \frac{\frac{7}{8} - 0.555}{2} = 0.915''$$

$$D/2 = 0.4575''$$

DIM "A" including  $\frac{1}{4}$ " PLUG

$$= A + \frac{C}{2} = 1\frac{1}{8} + \frac{0.555}{2} = 1.40$$

use 1.42"

Effective width       $b = ba + 12 \cdot tw$

$$b = 3.0 \text{ in}$$

#### C 2 x 1 x 3/16" Properties of Flange and Web

$$b = 3.0 \text{ in}$$

$$t = \frac{3}{16} \text{ in}$$

$$AY = b \cdot t$$

$$IZ = \frac{b \cdot t^3}{12}$$

$$AY = 0.5625 \text{ in}^2$$

$$IZ = 0.00165 \text{ in}^4$$

Note that Ax is calculated in the Staad program using the values of YD and ZD. Arbitrary values of IX, IY, and AZ are input to Staad but are not used in the analysis.

#### Member Properties of 1/4" Dia. 3000 lb. half coupling

From Catalog W-6B Bonney Forge, Allentown, PA

$$A = 1.125 \text{ in}$$

$$B = \frac{7}{8} \text{ in}$$

$$C = .555 \text{ in}$$

Wall thickness

$$t = \frac{B - C}{2} \quad t = 0.16 \text{ in}$$

$$b = B$$

$$\text{use} \quad t = 0.17 \text{ in}$$

$$b = 0.875 \text{ in}$$

$$AY = b \cdot t$$

$$IZ = \frac{b \cdot t^3}{12}$$

$$AY = 0.1488 \text{ in}^2$$

$$IZ = 0.0003582 \text{ in}^4$$

Note that Ax is calculated in the Staad program using the values of YD and ZD. Arbitrary values of IX, IY, and AZ are input to Staad but are not used in the analysis.

Loads:

The previous Calculation No. 164 (D.I. 33) identified the following critical loads: Maximum Accident Pressure = 45 psi (Ref. 32, Table 1.1-1) and LOCA Poolswell Impact.

As shown in Table 2 of D.I. 34, loads due to pool swell impact act on structures above the suppression pool located between El. 700'-2" (High water level in the suppression pool) and El. 718'-8" (Max. height of poolswell). The maximum value of pool swell impact pressure (= 643 psi) is used in this analysis.

**Member Loads**

Member loads due to poolswell act on members 1 and 2. The magnitude is equal to the pressure times the member width.

$$\text{Uniform load, members 1 and 2: } GX = (643 + 45) \cdot 3.0 \cdot \frac{\text{lbf}}{\text{in}}$$

$$GX = 2064 \cdot \frac{\text{lbf}}{\text{in}}$$

**Poolswell impact pressure on circular half coupling and plug:**

From D.I. 34, Table 3, the maximum value of pool swell impact pressure acting on circular pipe sections is 48.88 psi.

$$\text{Uniform load, member 10: } GX = (48.88 + 45) \cdot 0.875 \cdot \frac{\text{lbf}}{\text{in}}$$

$$GX = 82.14 \cdot \frac{\text{lbf}}{\text{in}}$$

**Member loads on Members subjected to Accident Pressure = 45 psi**

$$\text{Uniform load, mems. 3 to 7 & 9: } GX_1 = 45 \cdot 3.0 \cdot \frac{\text{lbf}}{\text{in}}$$

$$GX_1 = 135.0 \cdot \frac{\text{lbf}}{\text{in}}$$

Uniform load, members 11 & 12:       $GX2 = 45.0875 \cdot \frac{\text{lbf}}{\text{in}}$

$$GX2 = 39.4 \cdot \frac{\text{lbf}}{\text{in}}$$

Uniform load, member 8:

Load on member 8 is equal to balance of load not acting on member 11.

$$GY = GX1 - GX2$$

$$GY = 95.6 \cdot \frac{\text{lbf}}{\text{in}}$$

#### Joint Loads

Member loads do not represent 100% of the pressure load acting on the channel because member length is based on center to center dimensions. Therefore, length times member width will not completely represent the total surface area subjected to pressure loads. For this reason, Joint loads are used to apply the additional load that acts on the missing surface area. Joint loads due to poolswell are applied to Joint 3. The magnitude is equal to the pressure times the missing surface area of the channel flange.

Flange length = 1"

Length modeled in Staad = .9063"

Effective width = 3.0"

Missing surface area:

$$A = (1 - .9063) \cdot \text{in} \cdot 3.0 \cdot \text{in}$$

$$A = 0.28 \cdot \text{in}^2$$

Pressure load = 688 psi

$$FX = 688 \cdot \text{psi} \cdot A$$

$$FX = 193.4 \cdot \text{lbf}$$

Evaluate joint force at Joints 3 & 6 due to LOCA pressure = 45 psi

FY = 45 psi A

FY = 12.65 lbf

Thermal Load:

As stated in the previous Calculation No. 164 (D.I. 33) the channel is analyzed with and without the effects of temperature. The temperature change for the poolswell load condition is 76 deg. F.

Variations in Material Properties

Review of Vendor-supplied CMTRs shows that ASTM A276 Type 304 material has been supplied with two types of finishes. Hot-finished material has a yield of 30 ksi and an ultimate of 75 ksi, whereas cold-finished material has a yield of 45 ksi and an ultimate of 90 ksi. CMTRs are reviewed to determine the appropriate design yield strength for each channel configuration.

Material Yield Strength

The following documents related to Vendor Specification 2534 are provided in Attachment 4 of the calculations:

1. Stores and Metal Verification Summary & Supplement Sheets, File # 5.1 CCM
2. Material Heat Number Sheet, File No. 8.16-2, Document #18
3. Certified Material Test Reports, File No. 5.2

These documents identify the following material heats for 2x1x3/16" channels:

Heat No.	Min. Specified Yield Strength
23755	30,000 psi
F30188	30,000 psi
30660	45,000 psi
30706	45,000 psi
30844	45,000 psi
40523	30,000 psi
42379	30,000 psi

For the cases shown above, design yield strength is controlled by min. specified yield strength = 30 ksi. As permitted in Ref. 3, Section III.2.a, a 10% increase in min. specified design yield strength is used to account for strain rate effects associated with dynamic effects of LOCA loads such as jet impingement and poolswell impact loads

Therefore, the allowable stress is:

$$F_b = 0.95 \cdot 1.1 \cdot 30.0 \text{ ksi}$$

$$F_b = 31.35 \text{ ksi}$$

Results of Staad III Analysis:

Results of the analysis are shown in Attachment A.

Maximum member stress occurs in member 1 = 29.00 ksi. (See Page A7)

$$\text{Mar11} = \frac{F_b}{29.00 \text{ ksi}}$$

$$\text{Mar11} = 1.08$$

Check weld based on reactions at Joints 1 and 8 (Max. reaction occurs at joint 1).

$$\text{Weld force: } f_w = \frac{(1.434^2 + .4467^2)^{.5}}{3 \text{ in}} \cdot \text{kip}$$

$$f_w = 0.50 \cdot \frac{\text{kip}}{\text{in}}$$

$$\text{Weld Allowable: } F_w = 0.707 \cdot 21 \text{ ksi} \cdot \frac{3}{16} \text{ in}$$

$$F_w = 2.78 \cdot \frac{\text{kip}}{\text{in}}$$

$$\text{Mar12} = \frac{F_w}{f_w}$$

$$\text{Mar12} = 5.56$$

Check 3/16" weld between Channel and coupling for test plug:

Diameter of circular weld =  $B = 0.875 \text{ in}$  Assume 1/2 of weld length is effective for Member no. 11 and 12, each.

Therefore, weld length =  $L = 3.14159 \cdot \frac{B}{2}$

$$L = 1.37 \text{ in}$$

Weld allowable =  $F_{w1} = F_w \cdot L$

$$F_{w1} = 3.83 \text{ kip}$$

Actual force in weld (Member 12 governs):  $f_w = (.0743^2 - .0499^2)^{.5} \text{ kip}$

$$f_w = 0.09 \text{ kip}$$

$$\text{Mar13} = \frac{F_{w1}}{f_w}$$

$$\text{Mar13} = 42.75$$

Inspection of this large margin shows that the half coupling and its attachment weld can easily resist the pool hydrodynamic loads.

Case 2: 3x4.1 Channel Subjected to Jet Impingement LoadsPreparation of Input to Staad Computer Model

This model covers the following two configurations:

1. Leak Test Assembly 39-EE located in the suppression pool (see CBI Dwg. No. 39, Rev. 5)
2. All 3" ASTM A36 leak chase channels in the drywell.

Joint coordinates are center line coordinates. Additional joints are provided so that stresses can be determined at the end of the fillets at each corner of the channel. Member properties of the channel web and flanges are based on an effective width of 1.00". Test couplings are not modeled for channels in the drywell because the design evaluation of the drywell channels is governed by jet impingement loads which are defined in D.I. #35, Sketch JF-1A on Page 2-2-7. The presence of a test coupling is not significant in the evaluation of "EE" assemblies because it is attached to a vertical channel which is not a highly loaded member in the assembly.

Member PropertiesC3x4.1 Flange Properties (Members 1, 2, 6, 7)

$$b = 1 \text{ in}$$

$$t = 0.273 \text{ in}$$

$$AY = b \cdot t$$

$$IZ = \frac{b \cdot t^3}{12}$$

$$IZ = 0.0016955 \cdot \text{in}^4$$

$$AY = 0.273 \cdot \text{in}^2$$

Note that Ax is calculated in the Staad program using the values of YD and ZD. Arbitrary values of IX, IY, and AZ are input to Staad but are not used in the analysis.

C3x4.1 Web Properties (Members 3, 4, 5)

$$b = 1 \text{ in}$$

$$t = 0.170 \text{ in}$$

$$A = b \cdot t$$

$$IZ = \frac{b \cdot t^3}{12}$$

$$IZ = 0.0004094 \cdot \text{in}^4$$

$$A = 0.1700 \cdot \text{in}^2$$

Note that Ax is calculated in the Staad program using the values of YD and ZD. Arbitrary values of IX, IY, and AZ are input to Staad but are not used in the analysis.

Safety-Related

Non-Safety-Related

Rev. 0 Date

Page 12.1 of

Client	
Project	
Proj. No. 10248-012	Equip. No.


Prepared by \_\_\_\_\_ Date \_\_\_\_\_

Reviewed by \_\_\_\_\_ Date \_\_\_\_\_

Approved by \_\_\_\_\_ Date \_\_\_\_\_

## STARD MODEL Y

$$K - \frac{t_f}{2} = 0.551$$



## JOINT COORDINATES

1	0	0
2	0	0.774
3	0	1.325
4	0.551	1.325
5	2.176	1.325
6	2.127	1.325
7	2.727	0.774
8	2.727	0

$$(bf - \frac{tw}{2})$$

## Channel Properties

$$d = 3"$$

$$t_f = 0.273$$

$$tw = 0.17$$

$$k = 1/16"$$

## Member Incidences

1	1	2
2	2	3
3	3	4
4	4	5
5	5	6
6	6	7
7	7	8

Loads:

## Critical Assembly for C3x4.1 Evaluation

Review of CBI Dwgs. 32 Rev. 4 and 39 Rev. 5 indicates that all 3" leak test channels in the suppression pool have the inside leg of the channel shortened by 1/2" to accommodate attachment to the thickened liner embed plate. See Section A-A on Dwg. 32, Section D-D on Dwg. 39 and the related table which give the "C" dimension of 1/2". The only exception to this is Leak Test Ass'y EE on Dwg. 39 which has a "C" dimension of 0". This assembly is analyzed as a separate case since its specific configuration is more severe than those channels that have a C dimension = 1/2".

The previous Calculation No. 164 (D.I. 33) identified the following critical loads: Maximum Accident Pressure = 45 psi (Ref. 32, Table 1.1-1) and LOCA Poolswell Impact.

Review of CBI Dwgs. 34 through 37, Rev. 3, 7, 3, 6, respectively, shows that Ass'y EE is used at 8 locations: Four at El. 679'-0" and four at El. 726'-0". (Dwgs 1D through 1G, Revs. 8, 7, 4, 6, respectively.) These elevations will be used to reduce the poolswell impact loads on these critical channels.

As shown in Table 2 of D.I. 34, loads due to pool swell impact act on structures above the suppression pool located between El. 700'-2" (High water level in the suppression pool) and El. 718'-8" (Max. height of poolswell).


Based on Table 2, none of the "EE" assemblies lie in the zone subject to Poolswell Impact forces.

Other forces acting on the Ass'y EE leak test channels are tabulated in the load combination table given on page 26 of Calc. 164 (Ref. 33). After pool swell impact, the next most critical load combination is #8 which is jet impingement load. This load case governs the design of A36 channels in the drywell. Jet loads in the suppression pool are much smaller than in the drywell. The jet pressure on the basemat is a maximum of 33 psi and reduces to zero at El. 700'-2" (See Fig. 4 in D.I. 34). The related joint and member loads for the jet impingement load in the drywell are described below.

After pool swell impact, the next most critical load combination for channels in the suppression pool is Case #7 which applies a vertical pressure of 197.03 psi and horz. pressure of 161.13 psi

Results of the Ass'y EE analysis for Load Combinations 7 are presented below. Results for the other 3" channels which have a "C" dimension = 1/2" and which are located in the poolswell impact zone are evaluated later using another Staad III model (See Case 3 below).

Review of CBI Dwgs. 288 through 291 and 294 through 297, Rev. 3, 3, 3, 4, 3, 3, 2, 3, respectively, shows that 3x4.1 channels (ASTM A36) have been used as leak chase channels in the drywell. Channels in the drywell are not subject to hydrodynamic impact loads, therefore the critical load for these channels is jet impingement. See load combination #8 in the load combination table given on page 26 of Calc. 164 (Ref. 33).



Calc. For	
Safety-Related	Non-Safety-Related

Calc. No. L-001337	
Rev.	Date
Page 13.1	of


Client	
Project	
Proj. No.	Equip. No.

Prepared by	Date
Reviewed by	Date
Approved by	Date

STAAD ANALYSIS - LOAD CASE 1 - UNIFORM PRESSURE LOAD  
 (LOAD COMBINATION #7 in CALC #164, D.I. #33)  
 REVISED L.C. WHEN POOL SWELL  
 DOES NOT APPLY

$$\Delta ESS \quad LOCA \quad SRV \quad Pa \\ 11.5 + 14.25 + 70.84 + 19.54 + 45 = 161.13 \text{ psf}$$

$$\begin{array}{l} \Delta 11.5 \\ ESS 4.36 \\ LOCA 116.56 \\ SRV 19.46 \\ Pa 45.0 \\ \hline 197.03 \text{ psf} \end{array}$$



$$\begin{array}{l} \Delta 11.5 \\ ESS 4.36 \\ LOCA 45.00 ? \text{ no drag load} \\ SRV 17.94 \\ Pa 45.0 \\ \hline 123.8 \text{ psf} \end{array}$$

**Member Loads**

Member loads due to Load Combination #7 applies a vertical pressure of 197.03 psi and horz. pressure of 161.13 psi.. The magnitude of the member load is equal to the pressure because the member width is 1". The vertical pressure is applied to members 1 & 2 and the horz. pressure is applied to Members 3 to 5.

The load on members 6 and 7 is the same as on members 1 and 2 minus the drag loads. From Calc. 164, Page 21, the LOCA drag load is 71.56 psi and the SRV drag load is 1.67 PSI.

$$\text{Net Load on Members 6 \& 7: } GX = (197.03 - 71.56 - 1.67) \cdot \text{psi}$$

$$GX = 123.80 \cdot \text{psi}$$

**Jet Impingement loads on Members 3, 4, and 5**

As shown on Pages 26 and 27 of Calc. 164, Load Case 8 is the jet impingement pressure load of 467 lbs/in acting on members 3, 4, and 5 which represent the channel web.

Note: See Page 25 for further discussion of jet loads in the containment drywell area.

**Joint Loads**

Member loads do not represent 100% of the pressure load acting on the channel because member length is based on center to center dimensions. Therefore length times member width will not completely represent the total surface area subjected to pressure loads. For this reason, Joint loads are used to apply the additional load that acts on the missing surface area. Joint loads for Load Combination 7 are applied to Joints 3 and 6. The magnitude is equal to the pressure times the missing surface area of the channel flange and web.

Flange length = 1.41"

Length modeled in Staad = 1.325"

Web length = 3"

Length modeled in Staad = 2.727

Effective width = 1.0"

Missing surface area:

$$Af = (1.41 - 1.325) \cdot 1.0 \cdot \text{in}$$

$$Aw = (3 - 2.727) \cdot 1.0 \cdot \text{in}^2$$

$$Af = 0.0850 \cdot \text{in}^2$$

Aw is distributed to joints 3 and 6, therefore:

$$Aw = \frac{Aw}{2}$$

$$Aw = 0.14 \cdot \text{in}^2$$

Pressure load for Jt. 3 in X & Y directions = 197.03 psi & -161.13 psi, respectively

$$FX = 197.03 \text{ psi} \cdot Af$$

$$FY = -161.13 \text{ psi} \cdot Aw$$

$$FX = 16.75 \text{ lbf}$$

$$FY = -21.99 \text{ lbf}$$

Pressure load for Jt. 6 in X & Y directions = -123.8 psi & -161.13 psi, respectively

$$FX = -123.8 \text{ psi} \cdot Af$$

$$FY = -161.13 \text{ psi} \cdot Aw$$

$$FX = -10.523 \text{ lbf}$$

$$FY = -21.99 \text{ lbf}$$

Evaluate Joint Force at Joints 3 & 6 due to Jet Pressure = -467 psi

$$FY = -467 \text{ psi} \cdot Aw$$

$$FY = -63.75 \text{ lbf}$$

#### Termal Load:

As stated in the previous Calculation No. 164 (D.I. 33) the channel is analyzed with and without the effects of temperature. The temperature change for the poolswell load condition is 76 deg. F, and the change for Jet Impingement Load is 30 deg. F. The 30 deg. change is accomplished by using a load factor of 0.4 in Load Combination 5.

Material Yield Strength

The following documents related to Vendor Specification 2534 are provided in Attachment 4 of the calculations:

1. Stores and Metal Verification Summary & Supplement Sheets, File # 5.1 CCM
2. Material Heat Number Sheet, File No. 8.16-2, Document #18
3. Certified Material Test Reports, File No. 5.2

These documents identify the following material heats for the 3x4.1 channels in Assembly 39-EE in the suppression pool:

Heat No.	Min. Specified Yield Strength	Actual Ultimate Strength Per CMTR
40076	30,000 psi	85,350
40489	45,000 psi	89,200

For the cases shown above, design yield strength is equal to the min. specified yield strength = 30 ksi. As permitted in Ref. 3, Section III.2.a, a 10% increase in the design yield strength is used to account for strain rate effects associated with dynamic effects of LOCA loads such as jet impingement and poolswell impact loads. Therefore, the allowable stress for channels in the suppression pool is:

$$F_{b1} = 0.95 \cdot 1.1 \cdot 30.0 \text{ ksi}$$

$$F_{b1} = 31.35 \text{ ksi}$$

The CBI CMTR documents identify the following material heats for the ASTM A36 3x4.1 channels in drywell:

Heat No.	Min. Specified Yield Strength	Actual Tensile Strength Per CMTR
93063	36,000 psi	68,100 psi
94541	36,000 psi	72,300 psi

Design yield strength is equal to the min. specified yield strength = 36 ksi. In addition, a 10% increase in min. specified design yield strength is used as permitted to account for strain rate effects associated with jet impingement loads. Therefore, the allowable bending stress for channels in the drywell is:

$$F_{b2} = 0.95 \cdot 1.1 \cdot 36.0 \text{ ksi}$$

$$F_{b2} = 37.62 \text{ ksi}$$

Results of Staad III Analysis:

Results of the analysis are shown in Attachment B

For the 3x4.1 channels in Assembly 39-EE in the suppression pool, the maximum member stress due to hydrodynamic load (L.C. #1) occurs in member 4 (12.57 ksi), and Fb1 is the allowable stress. For A36 channels in the drywell, the maximum member stress due to jet impingement occurs in member 4 (35.77 ksi), and Fb2 is the allowable stress.

Assembly 39-EE

ASTM A-36 Channels in Drywell

$$\text{Mar21} = \frac{\text{Fb1}}{12.57 \text{ ksi}}$$

$$\text{Mar21a} = \frac{\text{Fb2}}{35.77 \text{ ksi}}$$

$$\text{Mar21} = 2.49$$

$$\text{Mar21a} = 1.05$$

Check weld based on reactions at Joints 1 and 8 (Max. reaction occurs in L.C. #5).

Weld force:  $f_w = (.2038^2 + .7005^2)^{.5} \text{ kip}$

$$f_w = 0.73 \text{ kip}$$

Weld Allowable:  $F_w = 0.707 \cdot 21 \text{ ksi} \cdot \frac{3}{16} \text{ in}^2$

$$F_w = 2.78 \text{ kip}$$

$$\text{Mar22} = \frac{F_w}{f_w}$$

$$\text{Mar22} = 3.82$$

Case 3: 3x4.1 Channel With Short LegPreparation of Input to Staad Computer Model

This model covers all 3x4.1 channels billed on CBI Dwg. Nos. 32 (Rev. 4) and 39 (Rev. 5) other than those identified as Leak Test Assembly 39-EE (See Case 2). All Case 3 channels have one leg shortened by 1/2" as shown on Dwgs. 32 (Section A-A) and 39 (Section D-D).

Joint coordinates are center line coordinates. Additional joints are provided so that stresses can be determined at the end of the fillets at each corner of the channel. Member properties of the channel web and flanges are based on an effective width of 1.00". Test couplings are not modeled for this configuration because Ass'y A (Dwg. 32) and Detail E (Dwg. 39) show that test couplings on these assemblies are always mounted on a vertical leg of the assembly. The vertical leg is not the critical member for pool hydrodynamic loads because these impact loads primarily act in the vertical direction. Thus, the presence of a test coupling in the suppression pool is only significant when it is attached to a horizontal chord.

Member Properties

Member properties are the same as those used in the Case 2 model.

Material Yield Strength

The following documents related to Vendor Specification 2534 are provided in Attachment 4 of the calculations:

1. Stores and Metal Verification Summary & Supplement Sheets, File # 5.1 CCM
2. Material Heat Number Sheet, File No. 8.16-2, Document #18
3. Certified Material Test Reports, File No. 5.2

These documents identify the following material heats for the 3x4.1 channels billed on CBI Dwgs. 32 and 39:

Heat No.	Min. Specified Yield Strength	Actual Ultimate Strength per CMTR
30284	45,000 psi	91,400
40079	30,000 psi	85,350
40489	45,000 psi	89,200


Safety-Related	Non-Safety-Related
----------------	--------------------

Prepared by	Date
Reviewed by	Date
Approved by	Date

## STAAD MODEL

$$d - \frac{t_f}{2} = 2.727$$

$$K - \frac{t_f}{2} = 0.551$$



## JOINT COORDINATES

1	0	0.5
2	0	0.774
3	0	1.325
4	0.551	1.325
5	2.176	1.325
6	2.127	1.325
7	2.727	0.774
8	2.727	0

Channel Properties

$$d = 3"$$

$$b_f = 1.41"$$

$$t_f = 0.273$$

$$t_w = 0.17$$

$$K = 1/16"$$

## Member Incidences

1	1	2
2	2	3
3	3	4
4	4	5
5	5	6
6	6	7
7	7	8

Heat number 40079 has the lowest yield strength ( $F_y = 30$  ksi), so the allowable stress is:

$$F_{b1} = 0.95 \cdot 1.1 \cdot 30.0 \text{ ksi}$$

$$F_{b1} = 31.35 \text{ ksi}$$

Loads:

Critical Assembly for C3x4.1 Evaluation:

Review of the above specified CMTRs shows that channels from heat no. 40079 have a yield strength of 30 ksi. Based on previous calculations, it is necessary to reexamine the poolswell impact loads acting on the channels from heat no. 40079.

As shown in Table 2 of D.I. 34, loads due to poolswell impact act on structures above the suppression pool located between El. 700'-2" (High water level in the suppression pool) and El. 718'-8" (Max. height of poolswell). Therefore, CBI dwgs. 34 through 37 (Revision Nos. 3, 7, 4, 6, respectively) were reviewed to identify all '32'- and '39'-Series channel assemblies that fall within the poolswell zone. The following four assemblies were found to be subjected to significant poolswell impact loads: 39-A, 39-M, 39-N, 39-FF. Of these four, only Assembly 39-M had horizontal channels from heat no. 40079.

The center line elevation of 39-M is 703'-6" (See CBI dwgs. 1E and 1F, Revs. 7 & 4, respectively). Due to the poolswell phenomenon, the most critical load condition occurs when the lower flange of the bottom channel is impacted due to poolswell. This elevation corresponds to 702'-11 1/4". However, conservatively, poolswell for this case will be based on El. 704'-0". From Table 2 of D.I. 34, the poolswell impact at 704'-0" is 421.9 psi (A value of 422 psi will be used in this calculation. LOCA pressure is added to yield a total applied pressure of 422 + 45 = 467 psi).

Other forces acting on Ass'y 39-M are tabulated in the load combination table given on page 26 of Calc. 164 (Ref. 33). As stated earlier, jet impingement load is not a governing load in the suppression pool. Therefore, after pool swell impact, the next most critical load combination for channels in the suppression pool is Case #7 which applies a vertical pressure of 197.03 psi and horz. pressure of 161.13 psi.

The Staad model for this third configuration is analyzed for a total of nine load cases as described below:

Case 1. This case represents poolswell impact on the lower flange of the upper channel of Ass'y 39-FF.

Case 2. This case represents poolswell impact on the lower flange of the lower channel of Ass'y 39-FF. This case combined with thermal load produces the highest stresses and is used to qualify all channel assemblies built using heat numbers other than 40079.

Case 3. This case represents poolswell impact on the lower flange of the lower channel of Ass'y 39-M.

Case 4. This case represents Case #7 which applies a vertical pressure of 197.03 psi and horz. pressure of 161.13 psi.

Case 5. This case represents thermal effects due to accident temperature.

Cases 6, 7, 8, and 9 are the same as cases 1, 2, 3, and 4 combined with the appropriate thermal effects.

### Member Loads

#### Load Case 1

Member loads due to poolswell + accident pressure acting on members 1 and 2. The magnitude is equal to the pressure times the member width.

$$\text{Uniform load, Members 1 and 2: } GX = (643 + 45) \cdot 1.0 \cdot \frac{\text{lbf}}{\text{in}}$$

$$GX = 688 \cdot \frac{\text{lbf}}{\text{in}}$$

**Member loads on Members subjected to Accident Pressure = 45 psi**

$$\text{Uniform load, Members 3 to 7: } GX1 = 45 \cdot 1.00 \cdot \frac{\text{lbf}}{\text{in}}$$

$$GX1 = 45.00 \cdot \frac{\text{lbf}}{\text{in}}$$

### Joint Loads

Joint loads are applied to Joints 3 and 6 to account for the additional poolswell load or accident pressure that acts on surface area not represented by member length times width. The magnitude is equal to the pressure times the missing surface area of the channel flange and web.

Flange length = 1.41"  
Length modeled in Staad = 1.325"

Web length = 3"  
Length modeled in Staad = 2.727

Effective width = 1.0"

Missing surface area:

$$Af = (1.41 - 1.325) \cdot \text{in} \cdot 1.0 \cdot \text{in} \quad Aw = (3 - 2.727) \cdot 1 \cdot \text{in}^2$$

$$Af = 0.0850 \cdot \text{in}^2$$

$Aw$  is distributed to joints 3 and 6, therefore:

$$Aw = \frac{Aw}{2} \quad Aw = 0.14 \cdot \text{in}^2$$

Pressure load for Jt. 3 in X & Y directions = 688 psi & -45 psi, respectively

$$FX = 688 \cdot \text{psi} \cdot Af$$

$$FY = -45 \cdot \text{psi} \cdot Aw$$

$$FX = 58.48 \cdot \text{lbf}$$

$$FY = -6.14 \cdot \text{lbf}$$

Pressure load for Jt. 6 in X & Y directions = -45 psi

$$FX = -45 \cdot \text{psi} \cdot Af$$

$$FY = -45 \cdot \text{psi} \cdot Aw$$

$$FX = -3.825 \cdot \text{lbf}$$

$$FY = -6.14 \cdot \text{lbf}$$

### Load Case 2

Load Case 2 is the same as Load case 1 except that poolswell impact pressure acts on Members 6 and 7 and Joint 6 instead of members 1 and 2 and Joint 3. Therefore, the loads for these members and joints are just the reverse case of Load Case 1.

### Load Case 3

Load Case 3 represents poolswell impact on the lower flange of the lower channel of Ass'y 39-M. Member loads due to poolswell + accident pressure act on members 6 and 7. The magnitude is equal to the pressure times the member width. As stated earlier, the center line elevation of 39-M is 703'-6" (See CBI dwgs. 1E and 1F, Revs. 7 & 4, respectively). Due to the poolswell phenomenon, the most critical load condition occurs when the lower flange of the bottom channel is impacted due to poolswell. This elevation corresponds to 702'-11 1/4". However, conservatively, poolswell for this case will be based on El. 704'-0". From Table 2 of D.I. 34, the poolswell impact at 704'-0" is 421.9 psi (A value of 422 psi will be used in this calculation. LOCA pressure is added to yield a total applied pressure of 422 + 45 = 467 psi).

Uniform load, Members 6 and 7:  $GX = (422 + 45) \cdot 1.0 \frac{\text{lbf}}{\text{in}}$

$$GX = 467 \cdot \frac{\text{lbf}}{\text{in}}$$

**Member loads on members subjected to Accident Pressure = 45 psi**

Uniform load, Members 1 to 5:  $GX1 = 45 \cdot 1.00 \frac{\text{lbf}}{\text{in}}$

$$GX1 = 45.00 \cdot \frac{\text{lbf}}{\text{in}}$$

#### **Joint Loads:**

Joint loads are the same as for load case 2 except for Joint 6. Pressure load for Jt. 3 in the -X direction = 467 psi:

$$FX = 467 \text{ psi} \cdot Af$$

$$FX = 39.69 \cdot \text{lbf}$$

#### **Load Case 4: Alternate Load Case 7 (Calculation 164)**

As shown on Pages 26 of Calc. 164, there is an alternate Load Combination #7 which applies a vertical pressure of 197.03 psi and horz. pressure of 161.13 psi.. The magnitudes of the member loads and the joint loads are the same as Case 2 given on page 14 of this calculation except that the loads for these members and joints are just the reverse case, i.e., the maximum pressure load (197.03 psi) acts on Members 6 and 7 and Joint 6 instead of Members 1 and 2 and Joint 3.

Load Case 5: Thermal Load

As stated in the previous Calculation No. 164 (D.I. 33) the channel is analyzed with and without the effects of temperature. Since jet impingement load in the suppression pool is not a governing load condition, the temperature change corresponding to the poolswell load condition of 76 deg. F is used in the analysis.

Loads Cases 6, 7, 8 and 9:

These cases are the same as Cases 1, 2, 3, and 4 combined with thermal effects.

Results of Staad III Analysis:

Results of the analysis are shown in Attachment C. Review of member stresses shown on Page C7 shows that design of channels made from Heat No. 40079 is governed by Load Combination 8 ( $f_8 = 26.17$  ksi), and design of all other 3x4.1 channels covered in Case 3 is governed by Load Combination 7 ( $f_7 = 39.04$  ksi).

$$f_8 = 26.17 \text{ ksi}$$

$$f_7 = 39.04 \text{ ksi}$$

Procedure for Adjusting Design Yield Stress

The CMTR for heat no. 40489 reports a yield of 51.6 ksi and an ultimate of 89.2 ksi. The yield meets the ASTM specified minimum of 45 ksi for cold-finished material, but the ultimate value is 0.8 ksi less than the minimum value of 90 ksi. In order to maintain the ASTM specified stress margin of 45 ksi between yield and ultimate, the design yield stress is adjusted to meet the following criteria:

$$F_y \text{ max} \leq F_u - 45 \text{ ksi.}$$

Allowable Stress:

As stated previously, the 3x4.1 channel covered under this Case 3 analysis were manufactured from the following three heat numbers:

Heat No.	Min. Specified Yield Strength	Ultimate Strength from CMTR	
30384	45,000 psi	91,400	> 90,000 O.K.
40079	30,000 psi	85,350	> 75,000 O.K.
40489	45,000 psi	89,200	Revised $F_y = 89,200 - 45,000 = 44,200$

The heat number corresponding to Load Cases 3, 4, 8, and 9 is 40079, so  $F_y8 = 30.0$  ksi.

Due to the adjusted design yield strength, Heat No. 40489 has the next lowest effective yield strength and controls for Load Case 7, so  $F_y7 = 44.2$  ksi

The corresponding allowable stresses are:

$$F_{b8} = 0.95 \cdot 1.1 \cdot 30.0 \text{ ksi}$$

$$F_{b7} = 0.95 \cdot 1.1 \cdot 44.2 \text{ ksi}$$

$$F_{b8} = 31.35 \text{ ksi}$$

$$F_{b7} = 46.19 \text{ ksi}$$

The resulting design margins are:

$$\text{Mar31} = \frac{F_{b8}}{f_8}$$

$$\text{Mar31a} = \frac{F_{b7}}{f_7}$$

$$\text{Mar31} = 1.20$$

$$\text{Mar31a} = 1.18$$

Check weld based on reactions at Joints 1 and 8 (Max. reaction occurs in L.C. #2 at Jt. 8):

$$\text{Weld force: } f_w = .5924^2 + .1064^2 .5 \text{ kip}$$

$$f_w = 0.60 \text{ kip}$$

$$\text{Weld Allowable: } F_w = 0.70721 \text{ ksi} \cdot \frac{3}{16} \text{ in}^2$$

$$F_w = 2.78 \text{ kip}$$

$$\text{Mar32} = \frac{F_w}{f_w}$$

$$\text{Mar32} = 4.63$$

Discussion of Jet Impingement Loads on Liner Leak Chase Channels Inside Containment Drywell

In the previous calculation (D.I. 33), the main purpose of the analysis was to analyze channels subject to hydrodynamic impact loads in the suppression pool. The jet impingement forces were not part of the governing load case in the suppression pool. This calculation includes qualification of ASTM A36 channels in the drywell, so a study is included here to document that jet loads act on the web of the leak chase channels and do not apply significant loading to the channel flanges.

The UFSAR (D.I. 24), Section 3.6, Table 3.6-8 provides a list of postulated pipe breaks inside the containment. Two types of breaks are postulated: Circumferential and Longitudinal. Circumferential breaks cause jets to develop parallel to the axis to the pipe, whereas Longitudinal breaks cause jets which act perpendicular to the axis of the pipe. Review of Figs. 3.6-1 through 3.6-15 shows that large bore high pressure piping inside the containment is close to the liner only at the containment wall penetration locations and these are always horizontal pipe runs. Vertical pipe runs are always away from the containment liner plate. Therefore, a jet force would apply a significant force to the channel flanges only if there is a postulated longitudinal pipe break at or very close to the containment wall pipe penetration.

Figs. 3.6-1 through 3.6-15 and Table 3.6-8 can be used to determine the approximate location of all longitudinal breaks inside the containment. Based on this information, the closest longitudinal breaks to the liner channels are the break numbers C214 and C214S shown in Figs. 3.6-3 and 3.6-6, respectively. Per Table 3.6-8, the pipewhip restraints which have been designed to restrain the pipe from whipping due to the postulated breaks at C214 and C214S are R-72 and R-88, respectively. These restraints are shown on LaSalle Dwg S-384, Rev. U (D.I. 25). Using the dimensions shown on the plan view, the radial distance from the RPV center line to these restraints is:

$$D_1 = [(27 \text{ ft} + 7.125 \text{ in})^2 - (3 \text{ ft} + 8 \text{ in})^2]^{.5}$$

$$D_1 = 27.84 \text{ ft}$$

The elbow at which the break occurs is located further from the liner than the restraint. Therefore, the location of the restraint conservatively can be used as the break location. The sketch on the following page shows that the distance from the pipe break to the drywell liner is greater than 19.5 ft. According to NUREG ICR-2913 (D.I. 28), pipe break forces are not significant at distances greater than 8 pipe diameters from the pipe break location. For the Main Steam line with a diameter of 26 in, this distance is:

$$DIA = 26 \text{ in}$$


$$D8 = 8 \cdot DIA$$

$$D8 = 17.33 \text{ ft}$$

The distance to the liner is 19.5 ft which is greater than D8. Therefore, it can be concluded that none of the longitudinal or circumferential breaks inside the containment will apply a significant jet loads on the flanges of the ASTM A36 liner leak chase channels in the containment drywell.

Client	Safety-Related	Non-Safety-Related
Project		
Proj. No. 10248-12	Equip. No.	

Prepared by	Date
Reviewed by	Date
Approved by	Date



**SUMMARY AND CONCLUSIONS**

In response to PIF # L1997-06237, three channel configurations have been evaluated in the suppression pool and the drywell. This assessment has been performed using minimum specified material yield strength as determined from vendor supplied certified material test reports (CMTRs). In addition, the design yield strength is reduced, if necessary, to maintain a minimum of 45 ksi between yield and ultimate. Results are given in terms of the margin factor which is defined as the ratio of allowable stress divided by actual stress.

All margin factors are greater than 1.0 thus demonstrating that all leak chase channels have been found to meet the acceptance criteria and are thus able to serve as part on the containment pressure boundary.

Margin factors are summarized below.

	<u>Channel Section</u>	<u>Weld</u>
<b>Case 1:</b>		
C 2 x 1 x 3/16	Mar11 = 1.08	Mar12 = 5.56
<b>Case 2:</b>		
Assembly 39-EE	Mar21 = 2.49	Mar22 = 3.82
Drywell Channels	Mar21a = 1.05	
<b>Case 3:</b>		
C3x4.1, Heat No. 40079	Mar31 = 1.20	Mar32 = 4.63
All other C3x4.1 in Suppression Pool	Mar31a = 1.18	

```
*****
*          S T A A D - III
*          Revision 20.2
*          Proprietary Program of
*          Research Engineers, Inc.
*          Date= OCT 21, 1997
*          Time= 9: 5:13
*
*          USER ID: SARGENT & LUNDY ENGRS
*****
```

1. STAAD PLANE 2X1X3/16 CHANNEL & TEST PLUG
2. INPUT WIDTH 72
3. UNIT INCHES POUND
4. JOINT COORDINATES
5. 1 0. 0.; 2 0. .7394; 3 0. .9063; 4 .1669 .9063; 5 1.6456 .9063
6. 6 1.8125 .9063; 7 1.8125 .7394; 8 1.8125 0.
7. 9 0.5475 .9093; 10 1.264 .9063; 11 .5475 2.33; 12 1.264 2.33
8. MEMBER INCIDENCES
9. 1 1 2; 2 2 3; 3 3 4; 4 4 9; 5 5 6; 6 6 7; 7 7 8
10. 8 9 10; 9 10 5; 10 9 11; 11 11 12; 12 10 12
11. MEMBER PROPERTY AMERICAN
12. 1 TO 9 PRI IX .1 IY 8.E-4 IZ 1.65E-3 AY .5625 AZ .3 YD .1875 ZD 3.00
13. 10 11 12 PRI IX .1 IY 4E-4 IZ 3.582E-4 AY .1488 AZ .1 YD .17 ZD .875
14. MEMBER RELEASE
15. 10 12 START MZ
16. CONSTANTS
17. E STEEL ALL
18. POISSON STEEL ALL
19. DENSITY STEEL ALL
20. BETA 0. ALL
21. \* STAINLESS STEEL
22. ALPHA 99E-7 ALL
23. SUPPORTS
24. 1 8 PINNED
25. LOAD 1 LC 4,5,7
26. JOINT LOAD
27. 3 FX 193.4 FY -12.65
28. 6 FX -12.65 FY -12.65
29. MEMBER LOAD
30. 1 2 UNI GX 2064.
31. 3 4 5 9 UNI GY -135.
32. 6 7 UNI GX -135.
33. 8 UNI GY -95.6
34. 10 UNI GX 82.14
35. 11 UNI GY -39.4
36. 12 UNI GX -39.4
37. LOAD 2 THERMAL
38. TEMP LOAD
39. 3 4 5 8 9 11 TEMP 76.
40. LOAD COMB 3
41. 1 1. 2 1.

2X1X3/16 CHANNEL & TEST PLUG

-- PAGE NO. 2

42. LOAD LIST ALL
43. PERFORM ANALYSIS

PROBLEM STATISTICS

---

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 12/ 12/ 2  
ORIGINAL/FINAL BAND-WIDTH = 5/ 2  
TOTAL PRIMARY LOAD CASES = 2, TOTAL DEGREES OF FREEDOM = 32  
SIZE OF STIFFNESS MATRIX = 288 DOUBLE PREC. WORDS  
REQRD/AVAIL. DISK SPACE = 12.02/ 1069.5 MB, EXMEM = 1.02 MB

++ PROCESSING ELEMENT STIFFNESS MATRIX.	9: 5:14
++ PROCESSING GLOBAL STIFFNESS MATRIX.	9: 5:14
++ PROCESSING TRIANGULAR FACTORIZATION.	9: 5:14
++ CALCULATING JOINT DISPLACEMENTS.	9: 5:14
++ CALCULATING MEMBER FORCES.	9: 5:14

44. PRINT JOINT DISP LIST 3 6

2X1X3/16 CHANNEL &amp; TEST PLUG

-- PAGE NO. 3

JOINT DISPLACEMENT (INCH RADIANS) STRUCTURE TYPE = PLANE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
3	1	0.00652	0.00002	0.00000	0.00000	0.00000	-0.00293
	2	-0.00068	0.00000	0.00000	0.00000	0.00000	0.00056
	3	0.00585	0.00002	0.00000	0.00000	0.00000	-0.00237
6	1	0.00645	-0.00004	0.00000	0.00000	0.00000	-0.00358
	2	0.00068	0.00000	0.00000	0.00000	0.00000	-0.00056
	3	0.00713	-0.00004	0.00000	0.00000	0.00000	-0.00414

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

45. PRINT MEMBER FORCES LIST 1 4 7 9 10 ;2

2X1X3/16 CHANNEL &amp; TEST PLUG

-- PAGE NO. 4

MEMBER END FORCES STRUCTURE TYPE = PLANE

ALL UNITS ARE -- POUN INCH

MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
1	1	1	-446.67	1434.44	0.00	0.00	0.00	0.00
		2	446.67	91.68	0.00	0.00	0.00	496.42
2	1	1	0.00	-32.51	0.00	0.00	0.00	0.00
		2	0.00	32.51	0.00	0.00	0.00	-24.04
3	1	1	-446.67	1401.93	0.00	0.00	0.00	0.00
		2	446.67	124.19	0.00	0.00	0.00	472.38
4	1	4	625.78	-486.80	0.00	0.00	0.00	-373.83
		9	-625.38	538.18	0.00	0.00	0.00	178.77
	2	4	32.51	-0.26	0.00	0.00	0.00	29.46
		9	-32.51	0.26	0.00	0.00	0.00	-29.56
	3	4	658.29	-487.06	0.00	0.00	0.00	-344.36
		9	-657.89	538.44	0.00	0.00	0.00	149.21
7	1	7	716.66	654.98	0.00	0.00	0.00	447.39
		8	-716.66	-555.17	0.00	0.00	0.00	0.00
	2	7	0.00	32.51	0.00	0.00	0.00	24.04
		8	0.00	-32.51	0.00	0.00	0.00	0.00
	3	7	716.66	687.50	0.00	0.00	0.00	471.43
		8	-716.66	-587.68	0.00	0.00	0.00	0.00
9	1	10	690.17	-629.97	0.00	0.00	0.00	192.75
		5	-690.17	681.48	0.00	0.00	0.00	-442.97
	2	10	32.51	0.00	0.00	0.00	0.00	29.46
		5	-32.51	0.00	0.00	0.00	0.00	-29.46
	3	10	722.68	-629.97	0.00	0.00	0.00	222.21
		5	-722.68	681.48	0.00	0.00	0.00	-472.43
10	1	9	-46.06	66.85	0.00	0.00	0.00	0.00
		11	46.06	49.85	0.00	0.00	0.00	12.08
	2	9	0.00	0.00	0.00	0.00	0.00	0.00
		11	0.00	0.00	0.00	0.00	0.00	-0.01
	3	9	-46.06	66.84	0.00	0.00	0.00	0.00
		11	46.06	49.85	0.00	0.00	0.00	12.07
12	1	10	74.29	-6.25	0.00	0.00	0.00	0.00
		12	-74.29	-49.85	0.00	0.00	0.00	31.04
	2	10	0.00	0.00	0.00	0.00	0.00	0.00
		12	0.00	0.00	0.00	0.00	0.00	0.01
	3	10	74.29	-6.24	0.00	0.00	0.00	0.00
		12	-74.29	-49.85	0.00	0.00	0.00	31.05

2X1X3/16 CHANNEL & TEST PLUG

-- PAGE NO. 5

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

46. PRINT SUPPORT REACTIONS

2X1X3/16 CHANNEL &amp; TEST PLUG

-- PAGE NO. 6

SUPPORT REACTIONS -UNIT POUN INCH STRUCTURE TYPE = PLANE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
1	1	-1434.44	-446.67	0.00	0.00	0.00	0.00
	2	32.51	0.00	0.00	0.00	0.00	0.00
	3	-1401.93	-446.67	0.00	0.00	0.00	0.00
2	1	-555.17	716.66	0.00	0.00	0.00	0.00
	2	-32.51	0.00	0.00	0.00	0.00	0.00
	3	-587.68	716.66	0.00	0.00	0.00	0.00

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

47. PRINT MEMBER STRESSES LIST 1 4 7 9

2X1X3/16 CHANNEL &amp; TEST PLUG

-- PAGE NO. /FINAL

## MEMBER STRESSES

-----  
ALL UNITS ARE POUN/SQ INCH

MEMB	LD	SECT	AXIAL	BEND-Y	BEND-Z	COMBINED	SHEAR-Y	SHEAR-Z
1	1	.0	794.1 T	0.0	0.0	794.1	2550.1	0.0
		1.00	794.1 T	0.0	28205.6	28999.7	163.0	0.0
2	.	0.0	0.0 T	0.0	0.0	0.0	57.8	0.0
		1.00	0.0 T	0.0	1365.8	1365.8	57.8	0.0
3	.	0	794.1 T	0.0	0.0	794.1	2492.3	0.0
		1.00	794.1 T	0.0	26839.8	27633.9	220.8	0.0
4	1	.0	1112.5 C	0.0	21240.2	22352.8	865.4	0.0
		1.00	1111.8 C	0.0	10157.3	11269.0	956.8	0.0
2	.	0	57.8 C	0.0	1674.1	1731.9	0.5	0.0
		1.00	57.8 C	0.0	1679.6	1737.4	0.5	0.0
3	.	0	1170.3 C	0.0	19566.2	20736.4	865.9	0.0
		1.00	1169.6 C	0.0	8477.6	9647.2	957.2	0.0
7	1	.0	1274.1 C	0.0	25420.0	26694.1	1164.4	0.0
		1.00	1274.1 C	0.0	0.0	1274.1	987.0	0.0
2	.	0.0	0.0 C	0.0	1365.8	1365.8	57.8	0.0
		1.00	0.0 C	0.0	0.0	0.0	57.8	0.0
3	.	0	1274.1 C	0.0	26785.8	28059.9	1222.2	0.0
		1.00	1274.1 C	0.0	0.0	1274.1	1044.8	0.0
9	1	.0	1227.0 C	0.0	10951.5	12178.4	1119.9	0.0
		1.00	1227.0 C	0.0	25168.7	26395.7	1211.5	0.0
2	.	0	57.8 C	0.0	1674.1	1731.9	0.0	0.0
		1.00	57.8 C	0.0	1674.1	1731.9	0.0	0.0
3	.	0	1284.8 C	0.0	12625.6	13910.3	1119.9	0.0
		1.00	1284.8 C	0.0	26842.8	28127.6	1211.5	0.0

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

48. FINISH

\*\*\*\*\* END OF STAAD-III \*\*\*\*\*

\*\*\*\* DATE= OCT 22,1997 TIME= 9: 5:15 \*\*\*\*

\*\*\*\*\*  
\* For questions on STAAD-III, contact:  
\* Research Engineers, Inc at  
\* Ph: (714) 974-2500 Fax: (714) 921-2543 \*  
\*\*\*\*\*

PAGE NO. 1

```
*****
*          S T A A D - III
*          Revision 20.2
*          Proprietary Program of
*          Research Engineers, Inc.
*          Date= SEP 30, 1997
*          Time= 10:42:16
*
*          USER ID: SARGENT & LUNDY ENGRS
*****
```

1. STAAD PLANE 3X4.19 CHANNEL
2. INPUT WIDTH 72
3. UNIT INCHES POUND
4. JOINT COORDINATES
5. 1 0. 0.; 2 0. .774; 3 0. 1.325; 4 0.551 1.325; 5 2.176 1.3.<sup>75</sup>
6. 6 2.727 1.325; 7 2.727 0.774; 8 2.727 0.
7. MEMBER INCIDENCES
8. 1 1 2; 2 2 3; 3 3 4; 4 4 5; 5 5 6; 6 6 7; 7 7 8
9. MEMBER PROPERTY AMERICAN
10. 1 2 PRI IX .1 IY .0016955 IZ .0016955 AY .273 AZ .2 YD .273 ZD 1
11. 3 4 5 PRI IX .1 IY .0004094 IZ .0004094 AY .170 AZ .2 YD .170 ZD 1
12. 6 7 PRI IX .1 IY .0016955 IZ .0016955 AY .273 AZ .2 YD .273 ZD 1
13. CONSTANTS
14. % STEEL ALL
15. POISSON STEEL ALL
16. DENSITY STEEL ALL
17. BETA 0. ALL
18. \* STAINLESS STEEL
19. ALPHA 99E-7 ALL
20. SUPPORTS
21. 1 8 PINNED
22. LOAD 1 LC 4,5,7
23. JOINT LOAD
24. 3 FX 16.75 FY -21.99
25. 6 FX -10.523 FY -21.99
26. MEMBER LOAD
27. 1 2 UNI GX 197.03
28. 3 4 5 UNI GY -161.13
29. 6 7 UNI GX -123.8
30. LOAD 2 JET IMPINGEMENT
31. JOINT LOAD
32. 3 FY -63.75
33. 6 FY -63.75
34. MEMBER LOAD
35. 3 4 5 UNI GY -467.0
36. LOAD 3 THERMAL
37. TEMP LOAD
38. 3 4 5 TEMP 76.
39. LOAD COMB 4
40. 1 1. 3 1.
41. LOAD COMB 5 JET IMPINGEMT + THERMAL

3X4.19 CHANNEL

-- PAGE NO. 2

42. 2 1. 3 0.40
43. LOAD LIST ALL
44. PERFORM ANALYSIS

## PROBLEM STATISTICS

-----

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 8/ 7/ 2  
ORIGINAL/FINAL BAND-WIDTH = 1/ 1  
TOTAL PRIMARY LOAD CASES = 3, TOTAL DEGREES OF FREEDOM = 20  
SIZE OF STIFFNESS MATRIX = 120 DOUBLE PREC. WORDS  
REQD/AVAIL. DISK SPACE = 12.01/ 1070.8 MB, EXMEM = 1.02 MB

++ PROCESSING ELEMENT STIFFNESS MATRIX. 10:42:17  
++ PROCESSING GLOBAL STIFFNESS MATRIX. 10:42:17  
++ PROCESSING TRIANGULAR FACTORIZATION. 10:42:18  
++ CALCULATING JOINT DISPLACEMENTS. 10:42:18  
++ CALCULATING MEMBER FORCES. 10:42:18

45. PRINT JOINT DISP LIST 3 6

3Y4.19 CHANNEL

-- PAGE NO. 3

## JOINT DISPLACEMENT (INCH RADIANS) STRUCTURE TYPE = PLANE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
3	1	0.00245	-0.00004	0.00000	0.00000	0.00000	-0.00200
	2	0.00006	-0.00012	0.00000	0.00000	0.00000	-0.00251
	3	-0.00102	0.00000	0.00000	0.00000	0.00000	0.00072
	4	0.00143	-0.00004	0.00000	0.00000	0.00000	-0.00129
	5	-0.00035	-0.00012	0.00000	0.00000	0.00000	-0.00223
6	1	0.00235	-0.00004	0.00000	0.00000	0.00000	-0.00081
	2	-0.00006	-0.00012	0.00000	0.00000	0.00000	0.00251
	3	0.00102	0.00000	0.00000	0.00000	0.00000	-0.00072
	4	0.00337	-0.00004	0.00000	0.00000	0.00000	-0.00152
	5	0.00035	-0.00012	0.00000	0.00000	0.00000	0.00223

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

46. PRINT MEMBER FORCES LIST 1 4 7

3X4.19 CHANNEL

-- PAGE NO. 4

MEMBER END FORCES STRUCTURE TYPE = PLANE

ALL UNITS ARE -- POUN INCH

MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
1	1	1	215.09	86.47	0.00	0.00	0.00	0.00
		2	-215.09	66.03	0.00	0.00	0.00	7.91
2	1	1	700.50	-201.91	0.00	0.00	0.00	0.00
		2	-700.50	201.91	0.00	0.00	0.00	-156.28
3	1	1	0.00	-4.70	0.00	0.00	0.00	0.00
		2	0.00	4.70	0.00	0.00	0.00	-3.64
4	1	1	215.09	81.76	0.00	0.00	0.00	0.00
		2	-215.09	70.74	0.00	0.00	0.00	4.27
5	1	1	700.50	-203.79	0.00	0.00	0.00	0.00
		2	-700.50	203.79	0.00	0.00	0.00	-157.74
4	1	4	191.35	104.32	0.00	0.00	0.00	-23.55
		5	-191.35	157.52	0.00	0.00	0.00	-19.67
2	4	4	201.91	379.44	0.00	0.00	0.00	-12.43
		5	-201.91	379.44	0.00	0.00	0.00	12.43
3	4	4	4.70	0.00	0.00	0.00	0.00	6.23
		5	-4.70	0.00	0.00	0.00	0.00	-6.23
4	4	4	196.05	104.32	0.00	0.00	0.00	-17.32
		5	-196.05	157.52	0.00	0.00	0.00	-25.90
5	4	4	203.79	379.44	0.00	0.00	0.00	-9.93
		5	-203.79	379.44	0.00	0.00	0.00	9.93
7	1	7	268.29	112.61	0.00	0.00	0.00	50.08
		8	-268.29	-16.79	0.00	0.00	0.00	0.00
2	7	7	700.50	201.91	0.00	0.00	0.00	156.28
		8	-700.50	-201.91	0.00	0.00	0.00	0.00
3	7	7	0.00	4.70	0.00	0.00	0.00	3.64
		8	0.00	-4.70	0.00	0.00	0.00	0.00
4	7	7	268.29	117.31	0.00	0.00	0.00	53.72
		8	-268.29	-21.49	0.00	0.00	0.00	0.00
5	7	7	700.50	203.79	0.00	0.00	0.00	157.74
		8	-700.50	-203.79	0.00	0.00	0.00	0.00

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

47. SECTION 0. .5 1. MEMB 4  
 48. PRINT SUPPORT REACTIONS

3X4.19 CHANNEL

-- PAGE NO. 5

SUPPORT REACTIONS -UNIT POUN INCH STRUCTURE TYPE = PLANE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
	1	-86.47	215.09	0.00	0.00	0.00	0.00
	2	201.91	700.50	0.00	0.00	0.00	0.00
	3	4.70	0.00	0.00	0.00	0.00	0.00
	4	-81.76	215.09	0.00	0.00	0.00	0.00
	5	203.70	700.50	0.00	0.00	0.00	0.00
8	1	-16.79	268.29	0.00	0.00	0.00	0.00
	2	-201.91	700.50	0.00	0.00	0.00	0.00
	3	-4.70	0.00	0.00	0.00	0.00	0.00
	4	-21.49	268.29	0.00	0.00	0.00	0.00
	5	-203.79	700.50	0.00	0.00	0.00	0.00

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

49. \* UNIT INCH KIP

50. PRINT MEMBER STRESSES LIST 1 4 7

3X4.19 CHANNEL

-- PAGE NO. 6

## MEMBER STRESSES

ALL UNITS ARE POUN/SQ INCH

MEMB	LD	SECT	AXIAL	BEND-Y	BEND-Z	COMBINED	SHEAR-Y	SHEAR-Z
1	1	.0	787.9 C	0.0	0.0	787.9	316.7	0.0
		1.00	787.9 C	0.0	636.7	1424.5	241.9	0.0
2	.0	2565.9 C	0.0	0.0	0.0	2566.0	739.6	0.0
	1.00	2565.9 C	0.0	12581.7	15147.7	739.6	0.0	
3	.0	0.0 T	0.0	0.0	0.0	0.0	17.2	0.0
	1.00	0.0 T	0.0	293.1	293.1	17.2	0.0	
4	.0	787.9 C	0.0	0.0	0.0	787.9	299.5	0.0
	1.00	787.9 C	0.0	343.6	1131.4	259.1	0.0	
5	.0	2565.9 C	0.0	0.0	0.0	2566.0	746.5	0.0
	1.00	2565.9 C	0.0	12699.0	15264.9	746.5	0.0	
4	1	.0	1125.6 C	0.0	4890.4	6015.9	613.6	0.0
		0.50	1125.6 C	0.0	11445.9	12571.5	156.5	0.0
	1.00	1125.6 C	0.0	4083.4	5209.0	926.6	0.0	
2	.0	1187.7 C	0.0	2579.8	3767.5	2232.0	0.0	
	0.50	1187.7 C	0.0	34583.8	35771.6	0.0	0.0	
	1.00	1187.7 C	0.0	2579.8	3767.5	2232.0	0.0	
3	.0	27.7 C	0.0	1294.0	1321.6	0.0	0.0	
	0.50	27.7 C	0.0	1294.0	1321.6	0.0	0.0	
	1.00	27.7 C	0.0	1294.0	1321.6	0.0	0.0	
4	.0	1153.2 C	0.0	3596.4	4749.6	613.6	0.0	
	0.50	1153.2 C	0.0	10151.9	11305.2	156.5	0.0	
	1.00	1153.2 C	0.0	377.4	6530.6	926.6	0.0	
5	.0	1198.8 C	0.0	2062.2	3261.0	2232.0	0.0	
	0.50	1198.8 C	0.0	34066.3	35265.1	0.0	0.0	
	1.00	1198.8 C	0.0	2062.2	3261.0	2232.0	0.0	
7	1	.0	982.7 C	0.0	4031.6	5014.3	412.5	0.0
		1.00	982.7 C	0.0	0.0	982.7	61.5	0.0
2	.0	2566.0 C	0.0	12581.7	15147.7	739.6	0.0	
	1.00	2566.0 C	0.0	0.0	2566.0	739.6	0.0	
3	.0	0.0 C	0.0	293.1	293.1	17.2	0.0	
	1.00	0.0 C	0.0	0.0	0.0	17.2	0.0	
4	.0	982.7 C	0.0	4324.7	5307.4	429.7	0.0	
	1.00	982.7 C	0.0	0.0	982.7	78.7	0.0	
5	.0	2566.0 C	0.0	12699.0	15264.9	746.5	0.0	
	1.00	2566.0 C	0.0	0.0	2566.0	745.5	0.0	

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

51. \* PARAMETERS  
 52. \* CODE AISC  
 53. \* CHECK CODE 1 TO 12 14 TO 22  
 54. FINISH

\*\*\*\*\* END OF STAAD-III \*\*\*\*\*

FINAL

\*\*\*\*\* DATE= SEP 30, 1997 . TIME= 10:42:19 \*\*\*\*\*

\*\*\*\*\*  
\* For questions on STAAD-III, contact:  
\* Research Engineers, Inc at  
\* Ph: (714) 974-2500 Fax: (714) 921-2543  
\*\*\*\*\*

PAGE NO. 1

```
*****
*          S T A A D - III
*          Revision 20.2
*          Proprietary Program of
*          Research Engineers, Inc.
*          Date= OCT 28, 1997
*          Time= 13:37: 2
*
*          USER ID: SARGENT & LUNDY ENGRS
*****
```

1. STAAD PLANE 3X4.19 CHANNEL
2. INPUT WIDTH 72
3. UNIT INCHES FOUND
4. JOINT COORDINATES
5. 1 0. .5; 2 0. .774; 3 0. 1.325; 4 0.551 1.325; 5 2.176 1.325
6. 6 2.727 1.325; 7 2.727 0.774; 8 2.727 0.
7. MEMBER INCIDENCES
8. 1 1 2; 2 2 3; 3 3 4; 4 4 5; 5 5 6; 6 6 7; 7 7 8
9. MEMBER PROPERTY AMERICAN
10. 1 2 PRI IX .1 IY .0016955 IZ .0016955 AY .273 AZ .2 YD .273 ZD 1
11. 3 4 5 PRI IX .1 IY .0004094 IZ .0004094 AY .170 AZ .2 YD .170 ZD 1
12. 6 7 PRI IX .1 IY .0016955 IZ .0016955 AY .273 AZ .2 YD .273 ZD 1
13. CONSTANTS
14. E STEEL ALL
15. POISSON STEEL ALL
16. DENSITY STEEL ALL
17. BETA 0. ALL
18. \* STAINLESS STEEL
19. ALPHA 99E-7 ALL
20. SUPPORTS
21. 1 δ PINNED
22. LOAD 1 LC 4,5,7 UPPER CHANNEL
23. JOINT LOAD
24. 3 FX 58.48 FY -6.1425
25. 6 FX -3.825 FY -6.1425
26. MEMBER LOAD
27. 1 2 UNI GX 688.
28. 3 4 5 UNI GY -45.
29. 6 7 UNI GX -45
30. LOAD 2 LC 4,5,7 LOWER CHANNEL
31. JOINT LOAD
32. 3 FX 3.825 FY -6.1425
33. 6 FX -58.48 FY -6.1425
34. MEMBER LOAD
35. 1 2 UNI GX 45.
36. 3 4 5 UNI GY -45.
37. 6 7 UNI GX -688.
38. LOAD 3 LC 4,5,7 CHANNEL AT EL. 703'-0"
39. JOINT LOAD
40. 3 FX 3.825 FY -6.1425
41. 6 FX -39.69 FY -6.1425

3X4.19 CHANNEL

-- PAGE NO. 2

42. MEMBER LOAD
43. 1 2 UNI GX 45.
44. 3 4 5 UNI GY -45.
45. 6 7 UNI GX -467.
46. LOAD 4 LC 4,5,7 PRESSURE LOAD = 197.03 PSI
47. JOINT LOAD
48. 3 FX 10.523 FY -21.99
49. 6 FX -16.75 FY -21.99
50. MEMBER LOAD
51. 1 2 UNI GX 123.8
52. 3 4 5 UNI GY -161.13
53. 6 7 UNI GX -197.03
54. LOAD 5 THERMAL
55. TEMP LOAD
56. 1 TO 7 TEMP 76.
57. LOAD COMB 6
58. 1 1. 5 1.
59. LOAD COMB 7
60. 2 1. 5 1.
61. LOAD COMB 8 CHANNEL AT EL. 703'-0"
62. 3 1. 5 1
63. LOAD COMB 9 PRESSURE LOAD + THERMAL
64. 4 1. 5 1.0
65. LOAD LIST ALI
66. PERFORM ANALYSIS

## PROBLEM STATISTICS

-----  
NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 8/ 7/ 2  
ORIGINAL/FINAL BAND-WIDTH = 1/ 1  
TOTAL PRIMARY LOAD CASES = 5, TOTAL DEGREES OF FREEDOM = 20  
SIZE OF STIFFNESS MATRIX = 120 DOUBLE PREC. WORDS  
REQRD/AVAIL. DISK SPACE = 12.01/ 1069.0 MB, EXMEM = 1.02 MB

++ PROCESSING ELEMENT STIFFNESS MATRIX.	13:37: 4
++ PROCESSING GLOBAL STIFFNESS MATRIX.	13:37: 4
++ PROCESSING TRIANGULAR FACTORIZATION.	13:37: 4
++ CALCULATING JOINT DISPLACEMENTS.	13:37: 4
++ CALCULATING MEMBER FORCES.	13:37: 4

67. PRINT JOINT DISP LIST 3 6

3X4.19 CHANNEL

-- PAGE NO. 3

## JOINT DISPLACEMENT (INCH RADIANS) STRUCTURE TYPE = PLANE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
3	1	0.00769	0.00001	0.00000	0.00000	0.00000	-0.00811
	2	-0.01168	-0.00003	0.00000	0.00000	0.00000	0.01242
	3	-0.00765	-0.00002	0.00000	0.00000	0.00000	0.00809
	4	-0.00095	-0.00003	0.00000	0.00000	0.00000	0.00050
	5	-0.00083	0.00062	0.00000	0.00000	0.00000	0.00097
	6	0.00687	0.00063	0.00000	0.00000	0.00000	-0.00714
	7	-0.01250	0.00060	0.00000	0.00000	0.00000	0.01339
	8	-0.00848	0.00060	0.00000	0.00000	0.00000	0.00905
	9	-0.00177	0.00059	0.00000	0.00000	0.00000	0.00147
6	1	0.00760	-0.00003	0.00000	0.00000	0.00000	-0.00425
	2	-0.01189	0.00002	0.00000	0.00000	0.00000	0.00594
	3	-0.00780	0.00001	0.00000	0.00000	0.00000	0.00395
	4	-0.00106	-0.00004	0.00000	0.00000	0.00000	0.00111
	5	0.00122	0.00100	0.00000	0.00000	0.00000	-0.00083
	6	0.00882	0.00097	0.00000	0.00000	0.00000	-0.00508
	7	-0.01067	0.00101	0.00000	0.00000	0.00000	0.00511
	8	-0.00658	0.00100	0.00000	0.00000	0.00000	0.00312
	9	0.00016	0.00096	0.00000	0.00000	0.00000	0.00028

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

68. PRINT MEMBER FORCES LIST 1 4 7

3X4.19 CHANNEL

-- PAGE NO. 4

MEMBER END FORCES STRUCTURE TYPE = PLANE

ALL UNITS ARE -- POUN INCH

MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
1	1	1	-49.48	463.69	0.00	0.00	0.00	0.00
		2	49.48	-275.18	0.00	0.00	0.00	101.22
2	1	1	241.35	-336.75	0.00	0.00	0.00	0.00
		2	-241.35	349.08	0.00	0.00	0.00	-93.96
3	1	1	181.49	-225.46	0.00	0.00	0.00	0.00
		2	-181.49	237.79	0.00	0.00	0.00	-63.46
4	1	1	257.07	-92.13	0.00	0.00	0.00	0.00
		2	-257.07	126.06	0.00	0.00	0.00	-29.89
5	1	1	-1.34	-7.29	0.00	0.00	0.00	0.00
		2	1.34	7.29	0.00	0.00	0.00	-2.00
6	1	1	-50.82	456.40	0.00	0.00	0.00	0.00
		2	50.82	-267.89	0.00	0.00	0.00	99.23
7	1	1	240.02	-344.03	0.00	0.00	0.00	0.00
		2	-240.02	356.36	0.00	0.00	0.00	-95.95
8	1	1	180.16	-232.74	0.00	0.00	0.00	0.00
		2	-180.16	245.07	0.00	0.00	0.00	-65.46
9	1	1	255.74	-99.42	0.00	0.00	0.00	0.00
		2	-255.74	133.34	0.00	0.00	0.00	-31.89
4	1	4	162.39	-80.42	0.00	0.00	0.00	-110.93
		5	-162.39	153.54	0.00	0.00	0.00	-79.17
2	4	4	377.70	210.42	0.00	0.00	0.00	170.36
		5	-377.70	-137.27	0.00	0.00	0.00	112.15
3	4	4	266.41	150.55	0.00	0.00	0.00	111.53
		5	-266.41	-77.43	0.00	0.00	0.00	73.71
4	4	4	204.79	146.30	0.00	0.00	0.00	13.07
		5	-204.79	115.54	0.00	0.00	0.00	11.92
5	4	4	7.29	-1.34	0.00	0.00	0.00	6.75
		5	-7.29	1.34	0.00	0.00	0.00	-8.92
6	4	4	169.68	-81.75	0.00	0.00	0.00	-104.18
		5	-169.68	154.88	0.00	0.00	0.00	-88.08
7	4	4	384.99	209.08	0.00	0.00	0.00	177.11
		5	-384.99	-135.96	0.00	0.00	0.00	103.24
8	4	4	273.69	149.22	0.00	0.00	0.00	118.28
		5	-273.69	-76.09	0.00	0.00	0.00	64.79
9	4	4	212.08	144.96	0.00	0.00	0.00	19.82
		5	-212.08	116.87	0.00	0.00	0.00	3.00
7	1	7	184.48	133.77	0.00	0.00	0.00	90.06
		8	-184.48	-98.94	0.00	0.00	0.00	0.00
2	7	7	-106.35	-59.87	0.00	0.00	0.00	-252.42
		8	106.35	592.38	0.00	0.00	0.00	0.00
3	7	7	-46.49	-30.60	0.00	0.00	0.00	-163.57
		8	46.49	392.06	0.00	0.00	0.00	0.00

3X4.19 CHANNEL

-- PAGE NO. 5

MEMBER END FORCES STRUCTURE TYPE = PLANE

ALL UNITS ARE -- POUN INCH

MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
4	7		226.31	79.48	0.00	0.00	0.00	2.50
	8		-226.31	73.02	0.00	0.00	0.00	0.00
5	7		1.34	7.29	0.00	0.00	0.00	5.64
	8		-1.34	-7.29	0.00	0.00	0.00	0.00
6	7		185.82	141.66	0.00	0.00	0.00	95.70
	8		-185.82	-106.23	0.00	0.00	0.00	0.00
7	7		-105.02	-52.58	0.00	0.00	0.00	-246.78
	8		105.02	585.10	0.00	0.00	0.00	0.00
8	7		-45.16	-23.32	0.00	0.00	0.00	-157.93
	8		45.16	384.77	0.00	0.00	0.00	0.00
9	7		227.65	86.76	0.00	0.00	0.00	8.14
	8		-227.65	65.74	0.00	0.00	0.00	0.00

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

69. SECTION 0. .5 1. MEMB 4

70. PRINT SUPPORT REACTIONS

3X4.19 CHANNEL

-- PAGE NO. 6

SUPPORT REACTIONS -UNIT POUN INCH STRUCTURE TYPE = PLANE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
	1	-463.69	-49.48	0.00	0.00	0.00	0.00
	2	336.75	241.35	0.00	0.00	0.00	0.00
	3	225.46	181.49	0.00	0.00	0.00	0.00
	4	92.13	257.07	0.00	0.00	0.00	0.00
	5	7.29	-1.34	0.00	0.00	0.00	0.00
	6	-456.40	-50.82	0.00	0.00	0.00	0.00
	7	344.03	240.02	0.00	0.00	0.00	0.00
	8	232.74	180.16	0.00	0.00	0.00	0.00
	9	99.42	255.74	0.00	0.00	0.00	0.00
8	1	-98.94	184.48	0.00	0.00	0.00	0.00
	2	592.38	-106.35	0.00	0.00	0.00	0.00
	3	392.06	-46.49	0.00	0.00	0.00	0.00
	4	73.02	226.31	0.00	0.00	0.00	0.00
	5	-7.29	1.34	0.00	0.00	0.00	0.00
	6	-106.23	185.82	0.00	0.00	0.00	0.00
	7	585.10	-105.02	0.00	0.00	0.00	0.00
	8	384.77	-45.16	0.00	0.00	0.00	0.00
	9	65.74	227.65	0.00	0.00	0.00	0.00

\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

71. PRINT MEMBER STRESSES LIST 1 4 7

3X4.19 CHANNEL

-- PAGE NO. 7

## MEMBER STRESSES

-----  
ALL UNITS ARE POUN/SQ INCH

MEMB	LD	SECT	AXIAL	BEND-Y	BEND-Z	COMBINED	SHEAR-Y	SHEAR-Z
1	1	.0	181.2 T	0.0	0.0	181.3	1698.5	0.0
		1.00	181.2 T	0.0	8149.3	8330.5	1008.0	0.0
2	.0	884.1 C	0.0	0.0	884.1	1233.5	0.0	
	1.00	884.1 C	0.0	7564.3	8448.4	1278.7	0.0	
3	.0	664.8 C	0.0	0.0	664.8	825.8	0.0	
	1.00	664.8 C	0.0	5109.3	5774.1	871.0	0.0	
4	.0	941.7 C	0.0	0.0	941.7	337.5	0.0	
	1.00	941.7 C	0.0	2406.5	3348.2	461.7	0.0	
5	.0	4.9 T	0.0	0.0	4.9	26.7	0.0	
	1.00	4.9 T	0.0	160.7	165.6	26.7	0.0	
6	.0	186.1 T	0.0	0.0	186.2	1671.8	0.0	
	1.00	186.1 T	0.0	7988.6	8174.7	981.3	0.0	
7	.0	879.2 C	0.0	0.0	879.2	1260.2	0.0	
	1.00	879.2 C	0.0	7725.0	8604.2	1305.4	0.0	
8	.0	659.9 C	0.0	0.0	659.9	852.5	0.0	
	1.00	659.9 C	0.0	5270.0	5929.9	897.7	0.0	
9	.0	936.8 C	0.0	0.0	936.8	364.2	0.0	
	1.00	936.8 C	0.0	2567.2	3504.0	488.4	0.0	
4	1	.0	955.3 C	0.0	23030.8	23986.0	473.1	0.0
	0.50	955.3 C	0.0	6380.9	7336.1	688.1	0.0	
	1.00	955.3 C	0.0	16436.8	17392.1	903.2	0.0	
2	.0	2221.8 C	0.0	35370.3	37592.1	1237.7	0.0	
	0.50	2221.8 C	0.0	2958.5	5180.3	1022.7	0.0	
	1.00	2221.8 C	0.0	2285.5	25507.3	807.6	0.0	
3	.0	1567.1 C	0.0	23155.8	24722.8	885.6	0.0	
	0.50	1567.1 C	0.0	842.4	2409.5	670.5	0.0	
	1.00	1567.1 C	0.0	15303.2	16870.2	455.5	0.0	
4	.0	1204.7 C	0.0	2713.9	3918.6	860.6	0.0	
	0.50	1204.7 C	0.0	10923.0	12127.6	90.5	0.0	
	1.00	1204.7 C	0.0	2475.0	3679.7	679.6	0.0	
5	.0	42.9 C	0.0	1400.6	1443.5	7.9	0.0	
	0.50	42.9 C	0.0	1626.0	1668.8	7.9	0.0	
	1.00	42.9 C	0.0	1851.3	1894.2	7.9	0.0	
6	.0	558.1 C	0.0	21630.1	22628.3	480.9	0.0	
	0.50	998.1 C	0.0	4754.9	5753.0	696.0	0.0	
	1.00	998.1 C	0.0	18288.1	19286.2	911.1	0.0	
7	.0	2264.6 C	0.0	36771.0	39035.6	1229.9	0.0	
	0.50	2264.6 C	0.0	4584.5	6849.1	1014.8	0.0	
	1.00	2264.6 C	0.0	21434.2	23698.9	799.7	0.0	
8	.0	1609.9 C	0.0	24556.4	26166.3	877.8	0.0	
	0.50	1609.9 C	0.0	2468.4	4078.3	662.7	0.0	
	1.00	1609.9 C	0.0	13451.9	15061.8	447.6	0.0	
9	.0	1247.5 C	0.0	4114.6	5362.1	852.7	0.0	
	0.50	1247.5 C	0.0	9297.0	10544.5	82.5	0.0	
	1.00	1247.5 C	0.0	623.7	1871.2	687.5	0.0	
7	1	.0	675.8 C	0.0	7250.6	7926.3	490.0	0.0
		1.00	675.8 C	0.0	0.0	675.8	362.4	0.0

3X4.19 CHANNEL

-- PAGE NO. 8 / FINAL

## MEMBER STRESSES

ALL UNITS ARE POUN/SQ INCH

MEMB	LD	SECT	AXIAL	BEND-Y	BEND-Z	COMBINED	SHEAR-Y	SHEAR-Z
2	.0	389.6 T	0.0	20321.7	20711.3	219.3	0.0	
	1.00	389.6 T	0.0	0.0	389.6	2169.9	0.0	
3	.0	170.3 T	0.0	13168.5	13338.8	112.1	0.0	
	1.00	170.3 T	0.0	0.0	170.3	1436.1	0.0	
4	.0	829.0 C	0.0	201.1	1030.1	291.1	0.0	
	1.00	829.0 C	0.0	0.0	829.0	267.5	0.0	
5	.0	4.9 C	0.0	454.0	458.8	26.7	0.0	
	1.00	4.9 C	0.0	0.0	4.9	26.7	0.0	
6	.0	680.6 C	0.0	7704.5	8385.2	516.7	0.0	
	1.00	680.6 C	0.0	0.0	680.7	389.1	0.0	
7	.0	384.7 T	0.0	19867.8	20252.5	192.6	0.0	
	1.00	384.7 T	0.0	0.0	384.7	2143.2	0.0	
8	.0	165.4 T	0.0	12714.6	12880.0	85.4	0.0	
	1.00	165.4 T	0.0	0.0	165.4	1409.4	0.0	
9	.0	833.9 C	0.0	655.1	1489.0	317.8	0.0	
	1.00	833.9 C	0.0	0.0	833.9	240.8	0.0	











\*\*\*\*\* END OF LATEST ANALYSIS RESULT \*\*\*\*\*

72. FINISH



\*\*\*\*\* END OF STAAD-III \*\*\*\*\*

\*\*\*\* DATE= OCT 28,1997 TIME= 13:37: 5 \*\*\*\*


\*\*\*\*\*
 \* For questions on STAAD-III, contact:
 \* Research Engineers, Inc at
 \* Ph: (714) 974-2500 Fax: (714) 921-2543
 \*\*\*\*



MARK	DIM "A"	DIM "B"
12 <sup>R</sup>	22'-10 $\frac{7}{16}$	22'-10 $\frac{23}{32}$
15 <sup>R</sup>	16'-1 $\frac{5}{8}$	16'-2 $\frac{1}{2}$
16 <sup>R</sup>	7'-10 $\frac{1}{2}$	8'-0 $\frac{9}{16}$
20 <sup>R</sup>	18'-7 $\frac{1}{2}$	18'-7 $\frac{5}{8}$




SEAM IN  
PC 30 & 31



25'-4 27

32



DETAIL # 17


# ANSTEC APERTURE CARD

10'-0

Also Available on  
Aperture Card


9'-10 13/32

DETAIL # 19



DETAIL # 24

38100 -


FIN RAD  
4 1/2TYR SHOP SPLICE  
FOR CHANNELS

Calculation L-001337

Project No. 10248-012

ATTACHMENT D

Page 1 Of 39 R/O

A  
B  
C  
D  
E  
F  
G  
H  
I  
J  
K  
L  
M  
N  
O  
P  
Q  
R  
S  
T  
U  
V  
W  
X  
Y  
Z

ASSY (A)

- SECTION B-B

► INDICATES CHANGE FROM PREVIOUS ISSUE

SHIP PC	MARK	AMOUNT PC	DESCRIPTION	LENGTH		SPEC	#	AB LN
				FT	IN			
2	23-1		CHANNEL $2\frac{1}{2} \times 1 \times \frac{1}{4}$ (SK)	17	5 1/8	A36	D2	8/5
4	23-2		CHANNEL $2\frac{1}{2} \times 1 \times \frac{1}{4}$ (ROLL HARD WAY)	19	9 1/8	do	D2	8/6
4	23-3		CHANNEL $2 \times 1 \times \frac{3}{16}$	1	4 1/2	do	D2	8/20
4	23-4		CHANNEL $2 \times 1 \times \frac{3}{16}$	1	4 1/2	do	D2	8/20
8	23-5		LSK $\times \frac{1}{4}$ ( $4 \times L 2\frac{1}{2} \times 2\frac{1}{2} \times \frac{1}{4} \times 10' - 4\frac{1}{2}'$ )	18	10 1/2	A36	D2	8/6
4	23-6		L 5 $\times 2\frac{1}{2} \times \frac{1}{4}$ ( $L 5 \times 3 \times \frac{1}{2}$ )	18	10 1/2	A36	D2	
			FIN RAD = 12' 0 1/4	SHR	20 10 1/2			
6	23-7		CHANNEL C $3 \times 5.0$	1	3	A36	D2	8/6
4	23-8		L 5 $\times 2\frac{1}{2} \times \frac{1}{4}$ ( $L 5 \times 3 \times \frac{1}{2}$ )	20	10 1/2	A36	D2	
			FIN RAD = 13' 3 1/2	SHR	22 10 1/2			
4	23-9		CHANNEL $2 \times 1 \times \frac{3}{16}$	1	2 5/8	A36	D2	8/20
4	23-10		CHANNEL $2 \times 1 \times \frac{3}{16}$	1	2 5/8	do	D2	8/20
6	23-11		CHANNEL $2\frac{1}{2} \times 1 \times \frac{1}{4}$ (ROLL HARD WAY)	15	11 1/2	do	D2	8/6
4	23-12		CHANNEL $2 \times 1 \times \frac{3}{16}$	22	10 1/2	do	D2	8/8
4	23-13		CHANNEL $2 \times 1 \times \frac{3}{16}$	20	11 1/2	do	D2	8/6
4	23-14		CHANNEL $2 \times 1 \times \frac{3}{16}$	13	9 1/2	do	D2	8/10
4	23-15		CHANNEL $2 \times 1 \times \frac{3}{16}$	16	2 1/2	A36	D2	8/11
4	23-16		CHANNEL $2\frac{1}{2} \times 1 \times \frac{1}{4}$	8	0 1/2	A36	D2	8/12
4	23-17		CHANNEL $2 \times 1 \times \frac{3}{16}$	23	7 1/2	do	D2	8/13
8	23-18		CHANNEL $2 \times 1 \times \frac{3}{16}$	9	1	A36	D2	8/14
4	23-19		CHANNEL $2 \times 1 \times \frac{3}{16}$	10	0	do	D2	8/15
4	23-20		CHANNEL $2 \times 1 \times \frac{3}{16}$	18	7 1/2	do	D2	8/16
2	23-21		CHANNEL $2 \times 1 \times \frac{3}{16}$	20	5	do	D2	8/7
2	23-22		CHANNEL $2 \times 1 \times \frac{3}{16}$	18	4	do	D2	8/9
12	23-23		L $2\frac{1}{2} \times 1\frac{1}{2} \times \frac{1}{4}$	21	10 1/4	A36	D2	8/5
			FIN RAD = 41' 9	SHR	23 10 1/4			
3	23-24		R SK $\times \frac{1}{4}$ ( $\frac{1}{8} \times 2 \times 0' - 4\frac{1}{4}' 9\frac{1}{2}$ )			A36	D2	8/1
4	23-25		R $2 \times \frac{1}{4}$	0	3	do	D2	8/6
4	23-26		R $3\frac{1}{2} \times \frac{1}{4}$	0	5 1/2	A36	D2	
15	23-27		$\frac{1}{4}" \phi$ 3000# HALF CPLG (SCR'D)			A36	D2	10/3
15	23-28		$\frac{1}{4}" \phi$ 3000# SQUARE HEAD PLUG			A36	D2	10/8
18	23-A		COLUMN BASE LEAK TEST SYSTEM					
23-29	18		R $50^{\circ}$ OD $\times \frac{1}{4} \times 47"$ ID			A36	D2	8/11
23-30	18		R $\frac{3}{4} \times \frac{1}{4}$ ROLL TO CYLINDER (ROLL RAD = 1 1/2)	12	2 3/4	do	D2	8/6
23-31	18		R $\frac{3}{4} \times \frac{1}{4}$ ROLL TO CYLINDER (ROLL RAD = 2 1)	13	1 1/4	do	D2	8/6
23-27	18		$\frac{1}{4}" \phi$ 3000# HALF CPLG (SCR'D)			A36	D2	10/5
23-28	18		$\frac{1}{4}" \phi$ 3000# SQUARE HEAD PLUG			A36	D2	10/9
18	23-B		COLUMN BASE LEAK TEST SYSTEM					
23-32	18		R $20\frac{1}{2}^{\circ}$ OD $\times \frac{1}{4} \times 17\frac{1}{2}$ ID			A36	D2	10/8
23-33	18		R $\frac{3}{4} \times \frac{1}{4}$ ROLL TO CYLINDER (ROLL RAD = A 1/2)	4	6 1/8	do	D2	10/11
23-34	18		R $\frac{3}{4} \times \frac{1}{4}$ ROLL TO CYLINDER (ROLL RAD = 10 1/4)	5	5 1/8	do	D2	10/12
23-35	18		$\frac{1}{4}" \phi$ 3000# HALF CPLG (SCR'D)			A36	D2	10/12
23-36	18		$\frac{1}{4}" \phi$ 3000# SQUARE HEAD PLUG			A36	D2	

WORK THIS FLYING WITH DANG AFK 29 1975

LA SALLE COUNTY STATION, UNIT 1  
COMINTECH EDISON COMPANY  
971202 00 PM - 1

Chicago Bridge &amp; Iron Company

GBI


SHOP DETAILS FOR LEAK  
TEST SYSTEM IN BOTTOM OF  
SUPPRESSION CHAMBER

PART NUMBER 160496

1. The original date 11-19-73  
66-10-11

73-6336

C-2 Rev 7

THIS DRAWING IS THE PROPERTY OF CHICAGO BRIDGE & IRON COMPANY AND IS TO BE  
USED ONLY IN CONNECTION WITH PERFORMANCE OF WORK BY THE CHICAGO BRIDGE &  
IRON COMPANY. REPRODUCTION IN WHOLE OR IN PART FOR ANY OTHER PURPOSES  
IS EXPRESSLY PROHIBITED.

► INDICATES CHANGE FROM PREVIOUS ISSUE

MATERIAL HEAT  
NUMBER SHEET

## Material Types:

1. Welded Assemblies
2. Non-Welded Co/Je Matl.
3. Non Code Matl.

Piece-Mark	Serial No.	Material Heat No.	Matl. Type	Piece-Mark	Serial No.	Material Heat No.	Matl. Type
23-3	4Pcs	40161				Calculation L-001337	
23-4	4Pcs	40161				Project No. 10248-012	
23-5	8Pcs	14592				ATTACHMENT D	
23-6	4Pcs	74800				Page 2 of 39 R/c	
23-8	4Pcs	74800					
23-9	4Pcs	40161					
23-10	4Pcs	40161					
23-22	2Pcs	23755					
23-21	2Pcs	23755					
23-15	4Pcs	23755					
23-18	2Pcs	F30188					
23-18	6Pcs	42379					
23-13	4Pcs	40161					
23-19	4Pcs	F30188					
23-17	4Pcs	40161					
23-12	4Pcs	40161					
23-23	12Pcs	68940					
23-2	4Pcs	30844					
23-11	6Pcs	30844					
23-1	2Pcs	30844					
23-14	4Pcs	30706					
23-20	4Pcs	30706					
23-16	4Pcs	30706					

Data taken from records in accordance with applicable CB&I QA Manual.  
CBI Shop QA

Date 10/8/74

BY \_\_\_\_\_  
CHKD \_\_\_\_\_  
DATE \_\_\_\_\_

Reviewed (for material covered by code):

Authorized Inspector (Shop)

1/1

Date

9-1

Contract No. 73-6336

No. 23  
Sh 1 of 1

QUALITY ASSURANCE DOCUMENT INDEX

Specification 2534.24 Page — of —

File Number 5.3 Document Title CMTR'S

Calculation L-001337  
Project No. 10248-012  
ATTACHMENT D  
Page 3 of 39 R/O

Contractor Name CB&I

Document Listing:

CMTR'S

[A large rectangular box containing the document listing.]

Engineer Signoff \_\_\_\_\_ Paper Count 53



**REYNOLDS ALUMINUM SUPPLY COMPANY**  
METALS AND BUILDING PRODUCTS

4500 FIFTH AVENUE, S. - P. O. BOX 10785 - BIRMINGHAM, ALABAMA 35202 - 205/591-2341

September 31, 1974

Chicago Bridge  
P. O. Box 774  
Kankakee, Illinois 60901

Attention: Art Johnson

Please use this letter as authorization to mark material on P.O.  
# C73-6336-12A as follows:

6 pcs.	Ht. # F30188
22 pcs.	Ht. # 23755
39 pcs.	Ht. # 17797
7 pcs.	Ht. # 42379

Very truly yours,

REYNOLDS ALUMINUM SUPPLY CO.

Bob Littleton

BL:rf

cc: File

## REYNOLD ALUMINUM SUPPLY COMPANY

Calculation L-001337  
 Project No. 10248-012  
 ATTACHMENT D  
 Page 5 of 39 R/C

CERTIFICATE OF TEST  
STAINLESS STEELCustomer Chicago Bridge

Date 8-19-74  
 Customer Order No. 73-6336-12A

Address \_\_\_\_\_

Consignee \_\_\_\_\_ Consignee Order No. \_\_\_\_\_

Address \_\_\_\_\_

Invoice No. 07-07219Date of Shipment 8-2-74Specification ASTM-A-240Grade 304

## MATERIAL

ITEM	HEAT NUMBER	NUMBER OF PIECES	SIZE	CONDITION
1.	F 30188	6	2 X 1 X 3/16 X 120	23-18, 23-
2.	23755	11	2 X 1 X 3/16 X 120	23-21, 23-15, 23-2
3.	23755	11	2 X 1 X 3/16 X 120	
4.	17797	39	2 X 1 X 3/16 X 120	
5.	42379	7	2 X 1 X 3/16 X 120	23-18

## CHEMICAL ANALYSES

ITEM	C	MN	P	S	SI	CR	NI	CU	TI	CB	MO
1.	.046	1.62	.021	.011	.56	18.18	8.79				
2.	.04	1.65	.026	.016	.70	18.30	8.60				
3.	.04	1.65	.026	.016	.70	18.30	8.60				
4.	.033	1.62	.025	.014	.25	18.15	9.10				
5.	.05	1.47	.019	.011	.51	18.22	8.60				

## PHYSICAL PROPERTIES

ITEM	TENSILE STRENGTH	YIELD STRENGTH	% ELONGATION	HARDNESS	REMARKS
1.	87,200	39,000	50	686	
2.	80,800	39,700	59.1	RB 82	
3.	80,800	34,700	59.1	R 882	
4.	85,200	38,200	62	B78-79	
5.	86,700	38,100	56.5	RB 82	


We certify that the chemical analyses and physical test results applying on the above order number are correct and true to the best of our knowledge and belief.

Sworn and subscribed to before me

Reynolds Aluminum Supply Company

R.C. 001337

Diane Smith 11



**ITT Harper Inc.**   
 8200 Lehigh Avenue, Morton Grove, IL 60053  
 (312) 966-6000

Calculation L-001337  
 Project No. 10248-012  
 ATTACHMENT D  
 Page 6 of 39 R/O

CERTIFIED TEST REPORT

Date: 6/14/74  
 MMH Register No. 005439

Customer: METAL GOODS SERVICE CENTER  
 DIV ALCAN ALUM  
 11400 W. ADDISON STREET  
 FRANKLIN PARK, ILL. 60131

Address:

MMH Drawing No.

Purchase Order No. 24-31055


Weight and Pieces	Shape	Description of Item			Material
		Size	Length		
1090 LBS 13 PCS	CHANNEL	2 1/2 x 1 x 1/4"	18/24"		304 STAINLESS STEEL
					CBT C-73-6336
					MMH 24-91055
					DATE SHIPPED 6-20-74
					SPECIFICATIONS ASTM A2
					ITEM T304 SS Chan

Chemical Analysis								2 1/2 x 1 x 1/4	18/
Heat Number	C	S	P	CU	MO	CR	Ni	Mn	Bran
30844	.064	.028	.021	.21	.29	18.65	9.91	.22	1.38
									7/23/

Mechanical Properties						
Heat Number	Tensile Strength	Yield Strength	Elongation	R of A	Hardness	
30844	88,300	50,000	49%	69		

We hereby certify that the above figures are correct as contained in the records of this company.

Louis Paul, Q.C. MGR.



**ITT Harper Inc.**   
 8200 Lehigh Avenue, Morton Grove, Ill. 60053  
 (312) 568-8000

Calculation L-001337  
 Project No. 10248-012  
 ATTACHMENT D  
 Page 7 of 39 R/e

CERTIFIED TEST REPORT

Date: 6/4/74  
 MMH Register No. 005090

CHANGED  
ITEM

Customer:  
 METAL GOODS SERVICE  
 DIV ALCAN ALUM  
 P.O. BOX 427  
 FRANKLIN PARK, ILL. 60131

MMH Drawing No.

Address:

MMH Work Order No.

Chase Order No. 24-90807

Description of Item

Weight and Pieces	Shape	Size	Length	Material
8045 LBS 110 PCS	CHANNEL	2 x 1 x 1/4"	R/L	Chicago Bridge & Iron 304 STAINLESS STEEL
				C 73-6337-55
				OUR NUMBER 24-90985

DATE SHIPPED 6-7-74

SPECIFICATIONS ASTM A 236

ITEM I.304 S/S Channel

23-16  
23-20

Chemical Analysis

Heat Number	C	S	P	CU	MO	CR	NI	SI	MN	2 x 1 x 1/4
30599	.080	.012	.022	.43	.25	18.38	9.65	.45	1.45	Cindy Zwicker 6-76-74 10/24/74
30706	.064	.021	.023	.31	.34	18.69	10.03	.24	1.43	Elsp
30013	.049	.018	.023	.26	.28	18.68	9.90	.34	1.45	

Mechanical Properties


Heat Number	Tensile Strength	Yield Strength	% Elongation	R of A	Hardness	PCS	LBS
30599	90,600	51,700	50	68		57	305
30706	91,000	50,800	48	67		59	402
30013	89,200	49,300	51	70		2	13

We hereby certify that the above figures are correct as contained in the records of this company.

*Louis Prud'homme, Q.C.MGR.*

13  
10

8





MATERIAL HEAT  
NUMBER SHEET

Material Types:  
 1. Welded Assemblies  
 2. Non-Welded Code Matl.  
 3. Non Code Matl.

Piece-Mark	Serial No.	Material Heat No.	Matl. Type	Piece-Mark	Serial No.	Material Heat No.	Matl. Type
38-2	9PCS	30660					
38-3	10PCS	30660					
38-4	9PCS	30660					
38-8	36PCS	30660					
38-15	10PCS	30660					
						Calculation L-001337	
						Project No. 10248-012	
						ATTACHMENT D	
						Page 10 of 39 R/O	

Data taken from records in accordance with applicable CB&I QA Manual.  
 CBI Shop QA *Coldstanke*

Date 1/21/75

REV

BY  
CHK'D  
DATE

Reviewed (for material covered by code):

Authorized Inspector (Shop)

*N/A* **17-7**Contract No.  
73-6336No. 38  
Sh 3 of —



MEL CO. INC.  
 600 E. 10th Avenue, Morton Grove, IL 60053  
 (708)963-0060  
 DUN P.O. NO. C736331-31  
 DR NUMBER 94-91053  
 DATE SHIPPED 11/29/74  
 SPECIFICATIONS ASTM A 274  
 ITEM T304 Channel  
 2x1x3/16 18/24 R/L  
 123077-44  
 60131

600 E. 10th Avenue, Morton Grove, IL 60053  
 (708)963-0060

Calculation L-001337  
 Project No. 10248-012  
 ATTACHMENT D  
 Page 12 of 39 R/C

VERIFIED TEST REPORT

Date: 11/12/74

MMH Register No. 005727

MMH Drawing No. 8484

MMH Work Order No. AA 686

Weight and Pieces	Shape	Description of Item	Length	Material
3610 LBS 64 PCS	CHANNEL	2x1x3/16	20' R/L	304 STAINLESS STEEL

SPEC: ASTM-A-274

Chemical Analysis

Heat Number	C ✓	S ✓	P ✓	CU	NI	CR ✓	NI ✓	SI ✓	NH ✓
40523	.073	.020	.023	.36	.20	18.40	10.02	.31	1.36

Mechanical Properties

Heat Number	Tensile Strength	Yield Strength	Elongation	R of A.	Hardness
40523	23,600	15,110	12.0	75.0	

We hereby certify that the above figures are correct as contained in the records of this company.

By John D. Pezzard Q.C. Manager  
Name and Title



ITT Harper Inc.

8200 Lehigh Avenue  
(312) 966-6000

OUR NUMBER

3-5-74

DATE SHIPPED

SPECIFICATIONS 60CSASTM-A-236

ITEM ① T304 SS Channel

2 x 1 x 3/16

Date: 3/14/74

CERTIFIED TEST REPORT

HMH Register No.

Brauer  
4-5-74Customer: METAL GOODS SERVICE CENTER  
DIV. ALCAN ALUMINUM  
11400 W. ADDISON STREET

Address: FRANKLIN PARK, ILLINOIS 60131

Calculation L-001337

Project No. 10248-012

ATTACHMENT D

Page 13 of 39 R/o

HMH Drawing No.

HMH Work Order No.

Purchase Order No. 24-30675

		Description of Item			
Weight and Pieces	Shape	Size	Length	Material	
3315 LBS 61 PCS	CHANNEL	2 x 1 x 3/16	19' L/L	304 STAINLESS STEEL	
920 LBS 11 PCS	CHANNEL	3 x 1 3/8 x 3/16	15-24 R/L	304 STAINLESS STEEL	

## Chemical Analysis

Heat Number	C	S	P	CU	MO	CR	NI	SI	MN	LBS	PCS
30660	.066	.023	.023	.30	.29	13.84	0.71	.57	1.41	2730	51
30549	.52	.014	.025	.23	.27	13.56	1.91	.46	1.60	585	10
40079	.014	.014	.021	.20	.19	12.55	0.63	.53	1.83	22	1

## Mechanical Properties



Heat Number	Tensile Strength	Yield Strength	Elongation	R of A	Hardness
30660	20,850	55,180	42	42.6	
30549	36,400	43,750	46.8	69	
40079	35,350	40,200	52.5	71	

We hereby certify that the above figures are correct as contained in the records of this company.

By

John Tan

Name and Title





SHOP NOTE! THIS WELD MUST  
BE LEAK TIGHT @ 4 CORNERS 40.2  
ON EACH ASSY

LEAK TEST ASSY  
INSIDE ELEV. VIEW

40.2

ASSY	TEST CPLGP (3)	HORIRAL DIM 'A'	VERT P. DIM 'B'	C	LEAK TEST FOR ASSY
A	YES	1'-1 1/2	1'-1 1/2	1/2	79-A
B	NO	1'-1 1/2	1'-6 1/4	1/2	81-B
C	NO	1'-4 1/16	2'-10 1/4	1/2	82-A
D	NO	1'-1 1/2	1'-4 1/4	1/2	90-B
E	NO	1'-8 1/2	2'-4 1/2	1/2	89-A
F	NO	1'-11 3/16	2'-4 1/4	1/2	91-B
G	NO	1'-10 7/8	2'-1 1/4	1/2	88-A
H	NO	1'-1 13/16	2'-1 1/2	1/2	85-A
J	NO	1'-11 1/2	2'-1 1/2	1/2	88-B
K	NO	1'-1 1/2	1'-1 1/4	1/2	83B & 89-B
M	YES	1'-10 7/8	1'-1 1/2	1/2	85-B
P	NO	1'-10 3/16	2'-1 1/4	1/2	89-A
R	NO	1'-3	1'-1 1/2	1/2	81-A
S	NO	1'-1 1/2	1'-7 1/4	1/2	87-B
T	NO	1'-1 1/2	1'-9 1/4	1/2	86-B
W	NO	1'-7 1/8	2'-4 1/4	1/2	87-A
Y	NO	1'-10 7/8	1'-1 1/4	1/2	86-A
AA	NO	1'-8 5/8	1'-1 1/2	1/2	82-B
BB	NO	1'-7 7/8	2'-10 1/2	1/2	92-A
CC	NO	1'-6 11/32	2'-4 1/2	1/2	91-A
DD	YES	1'-2 1/2	1'-2 1/2	1/2	75-B
EE	YES	11	11	0	75-A
FF	NO	1'-5 1/2	1'-11 1/2	1/2	76-A

40.2



REF. NO.	DESCRIPTION	QT.	IN.	SPECIFICATION
-A	LEAK TEST ASS'Y			
-1	C 3X4.19 W/HOLE MBE	1	1 1/2	A276 D 102 F 304 D 102
-2	C 3X4.19 MBE	1	1 1/2	A276 D 102 F 304 D 102
-3	1/4" Ø 3,000# SCRWD HALF CPLG			
-4	1/8" Ø 3,000# SQ HEAD SCRWD PLUG			
-B	LEAK TEST ASS'Y			
-2	C 3X4.19 MBE	1	1 1/2	A276 D 102 F 304 D 102
-1	C 3X4.19 MBE	1	6 1/4	" D 102
-C	LEAK TEST ASS'Y			
-6	2 C 3X4.19 MBE	1	4 1/4	A276 D 102 F 304 D 102
-7	2 C 3X4.19 MBE	2	10 1/4	A276 D 102 F 304 D 102
-D	LEAK TEST ASS'Y			
-2	8 C 3X4.19 MBE	1	1 1/2	A276 D 102 F 304 D 102
-3	8 C 3X4.19 MBE	1	4 1/4	" D 102
-E	LEAK TEST ASS'Y			
-7	2 C 3X4.19 MBE	1	8 1/2	A276 D 102 F 304 D 102
-10	2 C 3X4.19 MBE	2	9 1/2	A276 D 102 F 304 D 102
-F	LEAK TEST ASS'Y			
-11	2 C 3X4.19 MBE	1	1 1/2	A276 D 102 F 304 D 102
-12	2 C 3X4.19 MBE	2	4 1/4	" D 102
-G	LEAK TEST ASS'Y			
-13	2 C 3X4.19 MBE	1	10 1/8	A276 D 102 F 304 D 102
-22	2 C 3X4.19 MBE	2	1 1/8	" D 102
-H	LEAK TEST ASS'Y			
-11	4 C 3X4.19 MBE	1	1 1/2	A276 D 102 F 304 D 102
-14	4 C 3X4.19 MBE	2	1 1/2	" D 102
-J	LEAK TEST ASS'Y			
-13	2 C 3X4.19 MBE	1	1 1/2	A276 D 102 F 304 D 102
-14	2 C 3X4.19 MBE	2	1 1/2	" D 102
-K	LEAK TEST ASS'Y			
-2	14 C 3X4.19 MBE	1	1 1/2	A276 D 102 F 304 D 102
-15	14 C 3X4.19 MBE	1	1 1/4	" D 102
-M	LEAK TEST ASS'Y			
-13	4 C 3X4.19 MBE	1	10 1/8	A276 D 102 F 304 D 102
-1	2 C 3X4.19 W/HOLE MBE	1	1 1/2	" D 102
-2	2 C 3X4.19 MBE	1	1 1/2	" D 102
-3	2 1/4" Ø 3,000# SCRWD HALF CPLG			A182 D 102 F 304 D 102
-4	2 1/8" Ø 3,000# SQ HEAD SCRWD PLUG			" D 102
-N	LEAK TEST ASS'Y			
-16	1 C 3X4.19 MBE	1	10 1/8	A276 D 102 F 304 D 102
-33	1 C 3X4.19 MBE	1	1 1/2	" D 102
-17	1 C 3X4.19 W/HOLE MBE	2	1 1/2	" D 102
-3	1 1/4" Ø 3,000# SCRWD HALF CPLG			A182 D 102 F 304 D 102
-4	1 1/8" Ø 3,000# SQ HEAD SCRWD PLUG			" D 102
-34	1 C 3X4.19 MBE	1	4 5/8	A276 D 102 F 304 D 102
-35	1 C 3X4.19 MBE	1	0 3/8	" D 102

REF. NO.	NAME	ACROSS	DESCRIPTION	LENGTH	SPEC'D.
1	39-P		LEAK TEST ASS'Y		
51-5	39-16	2	C 3X4.19 MBE	1 10 3/16	A276 D 102 F 304 D 102
51-5	39-22	2	C 3X4.19 MBE	2 7 1/4	" D 102
1	39-R		LEAK TEST ASS'Y		
	39-18	2	C 3X4.19 MBE	1 3	A276 D 102 F 304 D 102
	39-2	2	C 3X4.19 MBE	1 1 1/2	" D 102
3	39-S		LEAK TEST ASS'Y		
51-6	39-2	6	C 3X4.19 MBE	1 1 1/2	A276 D 102 F 304 D 102
51-5	39-19	6	C 3X4.19 MBE	1 7 1/4	" D 102
2	39-T		LEAK TEST ASS'Y		
51-6	39-2	4	C 3X4.19 MBE	1 1 1/2	A276 D 102 F 304 D 102
51-5	39-20	4	C 3X4.19 MBE	1 9 1/4	" D 102
1	39-W		LEAK TEST ASS'Y		
51-5	39-21	2	C 3X4.19 MBE	1 7 1/8	A276 D 102 F 304 D 102
51-5	39-12	2	C 3X4.19 MBE	2 4 1/4	" D 102
3	39-Y		LEAK TEST ASS'Y		
40-2	39-13	6	C 3X4.19 MBE	1 10 7/8	A276 D 102 F 304 D 102
40-2	39-15	6	C 3X4.19 MBE	1 1 1/4	" D 102
1	39-AA		LEAK TEST ASS'Y		
51-5	39-23	2	C 3X4.19 MBE	1 8 5/8	A276 D 102 F 304 D 102
51-6	39-2	2	C 3X4.19 MBE	1 1 1/2	" D 102
1	39-BB		LEAK TEST ASS'Y		
51-5	39-24	2	C 3X4.19 MBE	1 7 7/8	A276 D 102 F 304 D 102
40-2	39-25	2	C 3X4.19 MBE	2 10 1/2	" D 102
1	39-CC		LEAK TEST ASS'Y		
51-2	40-26	2	C 3X4.19 MBE	1 6 1/3	A276 D 102 F 304 D 102
51-2	39-10	2	C 3X4.19 MBE	2 4 1/2	" D 102
18	39-DD		LEAK TEST ASS'Y		
40-2	39-28	18	C 3X4.19 W/HOLE MBE	1 2 1/2	A276 D 102 F 304 D 102
40-2	39-27	59	C 3X4.19 MBE	1 2 1/2	" D 102
	39-3	18	1/4" Ø 3,000# SCRWD HALF CPLG		A182 D 102 F 304 D 102
	31-4	18	1/8" Ø 3,000# SQ. HEAD SCRWD PLUG		" D 102
8	39-EE		LEAK TEST ASS'Y		
40-2	39-30	8	C 3X4.19 W/HOLE MBE	0 11	A276 D 102 F 304 D 102
40-2	39-17	29	C 3X4.19 MBE	0 11	" D 102
	39-3	8	1/8" Ø 3,000# SCRWD HALF CPLG		A182 D 102 F 304 D 102
	39-4	8	1/8" Ø 3,000# SQ. HEAD SCRWD PLUG		" D 102
30	39-FF		LEAK TEST ASS'Y		
61-L	39-31	60	C 3X4.19 MBE	1 5 1/2	A276 D 102 F 304 D 102
51-6	39-32	60	C 3X4.19 MBE	1 11 1/2	" D 102

RECEIVED

FEB 7 1975

SARGENT

&  
LUNDY

GENERAL NOTES:

1. SEE DWG. #36 THRU #37 FOR FIELD LOCATION OF LEAK TEST ASSYS.
2. FOR NOTES ON LEAK TEST ASSYS. SEE DWG. #34.

LA SALLE COUNTY STATION, UNIT 1  
COMMONWEALTH EDISON COMPANY

Chicago Bridge & Iron Company



SUPP. CHAMB. LEAK TEST

ASS'Y DETAILS Aperture Card

PER SEL DWG. 5-326, REV K

Part No. 160496


On PWH Date 7-8-77

73-6336

Replacing L-160496

Date 39 Rev K

This drawing is the property of Chicago Bridge & Iron Company and is to be used only in connection with performance of work by this Chicago Bridge & Iron Company. Reproduction in whole or in part for any other purpose is



APPROVED PER NUCLEAR Q.A. MANUAL  
RELEASED FOR USE  
R. B. BURGESS 11-1-70  
Updated by L.S. REV E DATE 1-24-75

► INDICATES CHANGE FROM PREVIOUS ISSUE

MATERIAL HEAT  
NUMBER SHEET

## Material Types:

1. Welded Assemblies
2. Non-Welded Code Matl.
3. Non Code Matl.

Piece-Mark	Serial No.	Material Heat No.	Matl. Type	Piece-Mark	Serial No.	Material Heat No.	Matl. Type
39 A	32 ASSY'S.	LEAK TEST ASSY					
✓ 39-1	32 PCS.	40489				Calculation L-001337	
✓ 39-2	96 PCS.	40489				Project No. 10248-012	
✓ 39-3	32 PCS.	JR				ATTACHMENT D	
✓ 39-4	32 PCS.	KY				Page 15 Of 39	R/C
39 B	2 ASSY'S.	LEAK TEST ASSY					
✓ 39-2	4 PCS	40489					
✓ 39-5	4 PCS	40489					
39 C	1 ASSY	LEAK TEST ASSY					
✓ 39-6	2 PCS	40489					
✓ 39-7	2 PCS.	40489					
39 D	4 ASSY'S.	LEAK TEST ASSY					
✓ 39-2	8 PCS	40489					
39-3	8 PCS.	40489					
39 E	1 ASSY	LEAK TEST ASSY					
✓ 39-9	2 PCS.	40489					
✓ 39-10	2 PCS.	40489					
39 F-F	30 ASSY'S.	LEAK TEST ASSY					
✓ 39-31	60 PCS.	40489					
✓ 39-32	60 PCS.	40489					

Data taken from records in accordance with applicable CB&I QA Manual.  
CBI Shop QA *[Signature]*

Date

1/7/75

REV	BY	CHKD	DATE
-----	----	------	------

Reviewed (for material covered by code):  
Authorized Inspector: *[Signature]*

N/12

Date

18-1

Contract No.  
53-6356No. 39  
Sh 1 of 1



MATERIAL HEAT  
NUMBER SHEET

Material Types:  
 1. Welded Assemblies  
 2. Non-Welded Code Matl.  
 3. Non Code Matl.

Piece-Mark	Serial No.	Material Heat No.	Matl. Type	Piece-Mark	Serial No.	Material Heat No.	Matl. Type
39F	1A55Y	LEAK TEST ASSY.		39R	1A55Y	LEAK TEST ASSY	
✓ 39-11	2PCs	40079		✓ 39-18	2PCs	30384	
✓ 39-12	2PCs	40079		✓ 39-2	2PCs	40079	
39G	1A55Y	LEAK TEST ASSY.		39S	1A55Y	LEAK TEST ASSY	
✓ 39-13	2PCs	40079		✓ 39-2	6PCs	40079	
✓ 39-22	2PCs	30384		✓ 39-19	6PCs	30384	
39H	2A55Y	LEAK TEST ASSY.		39T	2A55Y	LEAK TEST ASSY.	
✓ 39-11	4PCs	40079		✓ 39-2	4PCs	40079	
✓ 39-14	4PCs	40079		✓ 39-20	4PCs	30384	
39J	1A55Y	LEAK TEST ASSY.		39W	1A55Y	LEAK TEST ASSY	
✓ 39-13	2PCs	40079		✓ 39-21	2PCs	30384	
✓ 39-14	2PCs	40079		✓ 39-12	2PCs	40079	
39K	1A55Y	LEAK TEST ASSY.		39Y	1A55Y	LEAK TEST ASSY	
✓ 39-2	2PCs	40489		✓ 39-13	6PCs	40079	
✓ 39-15	10PCs	40079		✓ 39-15	6PCs	40079	
39P	1A55Y	LEAK TEST ASSY		39A-A	1A55Y	LEAK TEST ASSY	
✓ 39-16	2PCs	30384		✓ 39-23	2PCs	30384	
✓ 39-22	2PCs	30384		✓ 39-2	2PCs	40079	
39M	2A55Y	LEAK TEST ASSY.		39B-B	1A55Y	LEAK TEST ASSY.	
✓ 39-13	4PCs	40079		✓ 39-24	2PCs	30384	
✓ 39-2	2PCs	40079		✓ 39-25	2PCs	40079	
✓ 39-1	2PCs	40489		39C-C	1A55Y	LEAK TEST ASSY	
✓ 39-3	2PCs	JR		✓ 39-26	2PCs	40079	
✓ 39-4	2PCs	KY		✓ 39-10	2PCs	40489	

Data taken from records in accordance with applicable CB&I QA Manual.  
 CBI Shop QA *Gill Stanek*

Date 1/30/75

BY  
CHKD  
DATE

Reviewed (for material covered by code):  
 Authorized Inspector (Shop)

N/A

18-1

Contract No.  
13-6336

No. 39  
Sh 2 of 1



SUPPLEMENTAL SUMMARY SHEET  
FOR MATERIAL VERIFICATION  
CHICAGO BRIDGE & IRON COMPANY

Calculation L-001337  
Project No. 10248-012  
ATTACHMENT D  
Page 18 Of 39 R/C

GO 823

CONTRACT NO.

73-6336

LOCATION

CCM

ITEM ID	u.m	5.6	ENGINEERING PIECE MARK	SERIAL NO.	NO. PIECES FABRICATED
30384		13-5	39-16	1-4	4
			39-18	1-2	2
			39-19	1-6	6
			39-20	1-4	4
			39-21	1-2	2
			39-22	1-4	4
			39-23	1-2	2
			39-24	1-2	2
469494	u.m	23-8	417-5	1-2	2
			422-7	1-4	4
			423-7	1-4	4
		21-8	368-4		1
			371-4		1
			372-4		1
			373-4		1
			386-4		1
	34-8	502-4		1-2	2
		520-7		1-2	2
		438-5		1-2	2
	63-8	302-5		1-10	10
		302-4		1-10	10
	M-8	473-8		1-2	2
	21-10	399-4		1-4	4
		342-5		1-2	2
		456-4		1-2	2
	22-11	466-2			1
		529-4			1
		424-4			1









METAL GOODS  
 PUR P. O. # C 73-6336-C123  
 JR NUMBER 24-91097  
 DATE SHIPPED 10/24/74  
 SPECIFICATIONS ASTM A-276  
 ITEM 304 Channel 131  
 3 x 1 3/8 x 3/16 x 20ft Rdm  
 10-31-74 984

8200 Lehigh Avenue, Morton Grove, Ill. 60053  
 (312) 966-6000

Project No. 10248-012  
 ATTACHMENT D  
 Page 23 of 39 R/o

CERTIFIED TEST REPORT

Date: 10/21/74

HMH Register No. 005743

HMH Drawing No.

HMH Work Order No.

Weight and Pieces		Description of Item			Material
Shape	Size	Length			
3,320 LBS 25 PCS	CHANNEL	3x1 3/8x3/16"	R/L		304 STAINLESS STEEL

SPEC: ASTH A 276

Chemical Analysis

Heat Number	C	S	P	CU	MO	CR	NI	SI	MN
40489	.051	.021	.030	.24	.09	18.56	9.96	.56	1.55

Mechanical Properties

Heat Number	Tensile Strength	Yield Strength	Elongation	R of A	Hardness
40489	89,200	51,600	50.0	68.0	

10/21/74  
40489

We hereby certify that the above figures are correct as contained in the records of this company.

By John D. Person, Q.C. MANAGER  
 Name and Title



ITT Harper Inc.

8200 Lehigh Avenue  
(312) 966-6000

OUR NUMBER

24-90675

DATE SHIPPED

3-5-74

SPECIFICATIONS 6005 ASTM A-26

ITEM

① T316 SS Channel

2 x 1 x 3/16

CERTIFIED TEST REPORT

Date: 3/14/74

00130

HMH Register No.

Sbrau  
4-5-7Customer: METAL GOODS SERVICE CENTER  
DIV. / ALCAN ALUMINUM  
11400 W. ADDISON STREET  
FRANKLIN PARK, ILLINOIS 60131

Calculation L-001337

Project No. 10248-012

ATTACHMENT D

Page 24 of 39 R/o

HMH Drawing No.

HMH Work Order No.

Purchase Order No. 24-90675

Description of Item				
Weight and Pieces	Shape	Size	Length	Material
3315 LBS 61 PCS	CHANNEL	2 x 1 x 3/16	19' L/L	304 STAINLESS STEEL
920 LBS 11 PCS	CHANNEL	3 x 1 3/8 x 3/16	1 1/2' R/L	304 STAINLESS STEEL

## Chemical Analysis

Heat Number	C	S	P	CU	MO	CR	NI	SI	MN	LBS
30660	.065	.025	.023	.30	.29	18.84	9.71	.57	1.41	2730
30549	.52	.015	.015	.23	.27	18.56	1.90	.46	1.60	585
40079	.017	.014	.021	.20	.19	12.55	9.63	.53	1.89	22

## Mechanical Properties

Heat Number	Tensile Strength	Yield Strength	Elongation	R of A	Hardness
30660	90,850	55,100	42	61.6	
30549	86,400	43,750	46.8	69	
40079	85,350	40,200	52.5	71	


We hereby certify that the above figures are correct as contained in the records of this company.

By

C. J. Tamm

Name and Title

11  
OC20



ITT Harper Inc.

8200 Lehigh Avenue, Morton Grove, IL 60053

\* CORRECTED 10/17/

CERTIFIED TEST REPORT

Date: 8/8/73

IMM Register No. 002751-C

Customer: INDUSTRIAL SERVICE CENTER  
255 BENT STREET  
CAMBRIDGE, MASS. 02141

IMM Drawing No.

Address: (Now: Metal Goods Service Centers)

IMM Work Order No.

Purchase Order No. 5-15536-0

Description of Item				
Weight and Pieces	Shape	Size	Length	Material
3170 LBS 34 PCS	CHANNEL	3 x 1-3/8 x 3/16"	18/24"	304 STAINLESS STEEL

\* SPEC ASME SA 479


Chemical Analysis

Heat Number	C	S	P	CU	MO	CR	NI	SI	MN	CO
30408	.065	.020	.022	.32	.35	18.73	10.43	.45	1.52	
30384	.067	.021	.023	.37	.31	18.22	10.27	.37	1.83	

Mechanical Properties

Heat Number	Tensile Strength	Yield Strength	%Elongation	R of A	Hardness	PCS	LBS
30408	92,000	52,200	50.8	71.5		20	1651
30384	91,400	51,500	51.3	71.7		14	1312

R145 - 10248P - 012



Calculation L-001337  
Project No. 10248-012  
ATTACHMENT D  
Page 26 Of 39 R/c



Piece-Mark	Serial No.	Material Heat No.	Matl. Type	Piece-Mark	Serial No.	Material Heat No.	Matl. Type
32 B	1A55Y	LEAK TEST ASSY				Calculation L-001337	
✓ 32-5	2PCS	40489				Project No. 10248-012	
✓ 32-10	2PCS	40489				ATTACHMENT D	
						Page 28 Of 39	R/I
32 C	1A55Y	LEAK TEST ASSY					
✓ 32-6	2PCS	40489					
✓ 32-11	2PCS	40489					
32 D	1A55Y	LEAK TEST ASSY					
✓ 32-8	2PCS	40489					
✓ 32-12	2PCS	40489					
32 E	1A55Y	LEAK TEST ASSY					
✓ 32-9	2PCS	40489					
✓ 32-13	2PCS	40489					

Data taken from records in accordance with applicable CB&I QA Manual.  
 CBI Shop QA

REV BY CHKD DATE

Reviewed (for material covered by code):

N/19 16-1

Contract No.  
73-6336

No. 32  
Sh 3 of 1

Authorized Inspector (Shop)



Morton Grove, Ill. 60053

OUR NUMBER

3-5-74

ITT Harper Inc.

8200 Lehigh Avenue

(312) 966-6000

DATE SHIPPED

SPECIFICATIONS 60055 ASTM A-236

ITEM

T304 SS Channel

2 x 1 x 3/16

Date: 3/14/74

PORT Date: 10/21/74

MMH Register No. 005743

L-001337

10248-012

MENT D

39 R/o

MMH Drawing No.

Calculation L-001337

Project No. 10248-012

ATTACHMENT D

Page 30 Of 39 R/o

MMH Register No.

Sbrau

4-5-1

MMH Work Order No.

MMH Drawing No.

MMH Work Order No.

Item

Length	Material	Description of Item	Material
R/L		Size	Length
	304 STAINLESS STEEL	3/16	19' R/L
		3 - 3/16	15-2/4 R/L

Ni	Si	Mn
9.96	.56	1.55

Chemical Analysis

Cu	Mo	Cr	Ni	Si	Mn	LBS
.30	.29	18.84	9.74	.57	1.41	2730
.23	.27	18.06	9.90	.46	1.60	555
.20	.19	12.55	9.63	.53	1.83	22

ation	R of A	Hardness
	68.0	

Mechanical Properties

Yield Strength	Elongation	R of A	Hardness
55,100	42	61.6	
43,750	46.8	69	
40,200	52.5	71	

contained in the records of this

? Please Q.C. MANAGER  
Name and Title

figures are correct as contained in the records of this

17  
10

By

Signature: Tom  
Name and Title:

OUR P. U. # C 73-6336-C123  
 IR NUMBER 24-91097  
 DATE SHIPPED 10/24/74  
 SPECIFICATIONS ASTM A-27  
 EM 304 Channel  
3 x 1 3/8 x 3/16 x 20ft Rdm  
10/31/74 - 989

2000 Loring Avenue • Worcester, Massachusetts  
 (312) 966-8000

CERTIFIED TEST REPORT

Date: 10/21/74

HMH Register No. 005743

Calculation L-001337  
 Project No. 10248-012  
 ATTACHMENT D  
 Page 31 of 39 R/o

HMH Drawing No.

HMH Work Order No.

Weight and Pieces	Shape	Description of Item			Material
		Size	Length		
3,320 LBS 25 PCS	CHANNEL	3x1 3/8x3/16"	R/L		304 STAINLESS STEEL

SPEC: ASTM A 27F


Chemical Analysis									
Heat Number	C	S	P	CU	MO	CR	NI	SI	MN
40489	.051	.021	.030	.24	.09	18.56	9.96	.56	1.55

Mechanical Properties					
Heat Number	Tensile Strength	Yield Strength	Elongation	R of A.	Hardness
40489	89,200	51,600	50.0	68.0	


10/21/74  
2018

We hereby certify that the above figures are correct as contained in the records of this company.


By John D. Pearson, Q.C. MANAGER  
 Name and Title




SECTION THRU PC ①




SECTION THRU PC ⑤



SECTION THRU PC ⑩




SECTION THRU PC ⑬




SECTION THRU PC ⑭

REF #	NAME	AMOUNT IN	DESCRIPTION	LENGTH		SPEC ID	MATERIAL
				FT	IN		
1 287-1	RUN C 3X4.1	180	O	A36	D <sub>2</sub> 100%		
	(LENGTH ON 41'-2 1/4 H.R.)						
1 287-5	RUN C 3X4.1	130	O	A36	D <sub>2</sub> 100%		
	(LENGTH ON 31'-5 1/4 H.R.)						
1 287-11	RUN C 3X4.1	645	O	A36	D <sub>2</sub> 100%		
	(LENGTH ON 38'-9 H.R.)						
1 287-12	RUN C 3X4.1	705	O	A36	D <sub>2</sub> 100%		
	(LENGTH ON 36'-3 1/4 H.R.)						
1 287-13	RUN C 3X4.1	500	O	A36	D <sub>2</sub> 100%		
	(LENGTH ON 33'-10 1/2 H.R.)						
1 287-14	RUN C 3X4.1	225	O	A36	D <sub>2</sub> 100%		
	(LENGTH ON 31'-5 1/4 H.R.)						
1 287-15	RUN C 3X4.1	1750	O	A36	D <sub>2</sub> 100%		
6 287-16	PE SK X 1/4 (C.S. 21) (PE 2 1/2 X 4 1/2)			A36	D <sub>2</sub> 100%		
B6B 287-17	PE 2 X 1/4 (C.S. 21)		O 4	A36	D <sub>2</sub> 100%		
131 287-18	1/4" #3000# HALF CPLG (SCR'D)			A105	D <sub>2</sub> 100%		
131 287-19	1/4" #3000# SQ. HD. PLUG (SCR'D)			A105	D <sub>2</sub> 100%		



SECTION THRU PC ⑫

9712020014-3



⑯

INDICATES CHANGES FROM PREVIOUS ISSUE

RECEIVED
MAR - 1 1976
SARGENT
LUNDY

Calculation L-001337  
Project No. 10248-012  
ATTACHMENT D  
Page 32 Of 39 R/o

APPROVED PER NUCLEAR G.S. MANUAL  
RELEASED FOR USE  
*El. Gentley* 9-11-75  
Controlled by \_\_\_\_\_  
RECORDED BY ELS 3 BASED 7-7-75

LA SALLE COUNTY STATION, UNIT 1  
COMMONWEALTH EDISON COMPANY

ADDED TO Drawing FOR YOU EMBODIED MANUFACTURED BY Chicago Bridge & Iron Company Atto O. G. Johnson Bruce & Raymond P.C., 216 24th & 7th Sts, 100-015-1300
--

Chicago Bridge & Iron Company

CBI

### MISC. DETAILS


FOR LOWER CONE LEAK TEST.

160496  
JRS 7-25-75  
*P. Gentley*


73-6336

Spec. 287 Rev. 3


THIS DRAWING IS THE PROPERTY OF CHICAGO BRIDGE & IRON COMPANY AND IS TO BE  
USED EXCLUSIVELY IN CONNECTION WITH PERFORMANCE OF WORK BY THE CHICAGO BRIDGE &  
IRON COMPANY. IT IS NOT TO BE COPIED OR REPRODUCED IN WHOLE OR IN PART FOR ANY OTHER PURPOSE.  
EXCEPT AS PROVIDED IN THE CONTRACT.




SECTION THRU PC ①




SECTION THRU PC ⑤




SECTION THRU PC ⑪




SECTION THRU PC ⑬



SECTION THRU PC ⑭



SECTION THRU PC ④



SECTION THRU PC ⑫

## ANSTEC APERTURE CARD

Also Available on  
Aperture Card

RECEIVED	
MAR - 8 1976	
SARGENT & LUNDY	

APPROVED PER NUCLEAR G.S. MANUAL  
RELEASCO FOR USE  
*R.L. Bentlage* 9-1-75  
Controlled by \_\_\_\_\_  
REV. 3 NAVF 21-21

LA SALLE COUNTY STATION, UNIT 1  
COMMONWEALTH EDISON COMPANY



⑯

► INDICATES CHANGE FROM PREVIOUS ISSUE

REF. NO.	ARMOR	ARM. CL.	DESCRIPTION	LENGTH	PIPE ID	MATERIAL
1 293-1			RUN C 3X4.1 (LENGTH ON 31'-5 1/2" H.R.)	95' 0	A36 D <sub>2</sub> 100%	
1 293-4			RUN C 3X4.1 (LENGTH ON 20'-4 1/2" H.R.)	115' 0	A36 D <sub>2</sub> 100%	
1 293-5			RUN C 3X4.1 (LENGTH ON 19'-0" H.R.)	35' 0	A36 D <sub>2</sub> 100%	
						Calculation L-001337
						Project No. 10248-012
						ATTACHMENT D
						Page 33 OF 39 R/o
1 293-11			RUN C 3X4.1 (LENGTH ON 27'-8 1/2" H.R.)	455' 0	A36 D <sub>2</sub> 100%	
1 293-12			RUN C 3X4.1 (LENGTH ON 24'-0 1/2" H.R.)	380' 0	A36 D <sub>2</sub> 100%	
1 293-13			RUN C 3X4.1 (LENGTH ON 20'-3 1/2" H.R.)	125' 0	A36 D <sub>2</sub> 100%	
1 293-14			RUN C 3X4.1 (LENGTH ON 17'-10" H.R.)	125' 0	A36 D <sub>2</sub> 100%	
1 293-15			RUN C 3X4.1 (LENGTH ON 27'-8 1/2" H.R.)	975' 0	A36 D <sub>2</sub> 100%	
2 293-16	PL SK X 1/4	(C/P PL 2 1/2 X 1/4 = 0.4%)			A36 D <sub>2</sub> 100%	
930 293-17	PL 2 X 1/4			0' 4	A7C D <sub>2</sub> 100%	
77 293-18	1/4" 3000# HALF CPLG (SCREWED)				A105 D <sub>2</sub> 100%	
77 293-19	1/4" 3000# SQ. HD. PLUG (SCREWED)				A105 D <sub>2</sub> 100%	

Chicago Bridge & Iron Company <b>CBI</b>	
<u>MISC. DETAILS</u>	
FOR LEAK TEST RINGS #15 THRU #18	
Permit No. <b>160496</b> I.R.C. Date <b>7-28-75</b> R.L. Bentlage	Document No. <b>73-6336</b> Date <b>293</b> Rev. <b>2</b>
THIS DRAWING IS THE PROPERTY OF CHICAGO BRIDGE & IRON COMPANY AND IS TO BE USED ONLY IN CONNECTION WITH PERFORMANCE OF WORK BY THE CHICAGO BRIDGE & IRON COMPANY OR SUBCONTRACTORS IN WHOLE OR IN PART FOR ANY OTHER PURPOSE IS PROHIBITED.	



SUPPLEMENTAL SUMMARY SHEET  
FOR MATERIAL VERIFICATION

Calculation L-001337  
Project No. 10248-012  
ATTACHMENT D  
Page 34 Of 39 R/o

CONTRACT NO. 72-6-336

LOCATION C C 107

SUPPLIER'S ID NO.		ENGINEERING PIECE MARK	SERIAL NO.	NO. PIECES FABRICATED
D81784	100-6	603-2 611-3 611-6 609-2 609-3	1-1 1-2 1 1-4 1-2	1 2 1 4 2
M92565	100-13	711-2 715-4 719-4 723-4		6 2 2 2
94541	102-19	740-4 731-4 731-5 741-4	1-4 1-3 1 1-4	4 3 1 4
KA4989	102-18	751-4 753-4 731-11 740-10 741-10 692-7		1 1 1-2 1-2 1-2 1-2
94541	102-19	287-5 673-20 287-1 287-5 287-11	1 1 1 1 1	1 1 1 1 1
KA4989	100-18	82-17 84-14 293-12 293-13 293-14 110-17 283-2 283-5		1 1 1 1 1 1 1

**CBI**SUPPLEMENTAL SUMMARY SHEET  
FOR MATERIAL VERIFICATIONCalculation L-001337  
Project No. 10248-012  
ATTACHMENT D  
Page 35 Of 39 R/o

GO #23 REV 11-72

ITEM ID	LOCATION	ENGINEERING PIECE MARK	SERIAL NO.	NO. PIECES FABRICATED
945-11	100-19	142-10	283-6	1
			283-8	1
			283-9	1
	94-1A	287-12		1
		287-13		1
		287-14		1
		293-1		1
		293-4		1
		293-5		1
		293-11		1
	111-12	596-3	1	1
		596-4	1	1
801804750	100-12	115-12	712-2	48
			712-3	24
			716-1	16
			716-2	8
			720-1	16
			720-2	8
			724-1	16
			724-2	8
			725-3	6
			725-3	6





Calculation L-001337  
Project No. 10248-012  
ATTACHMENT D  
Page 37 Of 39 R/o

SUPPLEMENTAL SUMMARY SHEET #12  
FOR MATERIAL VERIFICATION

QD 823 REV 11-72

CONTRACT NO. 73-6334

LOCATION CCM

ITEM ID	ITEM #	PIECE MARK	SERIAL NO.	NO. PIECES FABRICATED
Heat # 51ab	5-6			
40489	67-3	39-1	1-36	36
	10-3	39-20	1-8	8
	10-BuRents	32-10	1-2	2
		32-13	1-2	2
		32-12	1-2	2
		32-11	1-2	2
		32-14	1-2	2
	15-3	39-31	1-60	60
		39-32	1-60	60
	19-3	39-2	1-120	120
		39-5	1-4	4
		39-6	1-2	2
		39-7	1-2	2
		39-8	1-12	12
		39-9	1-2	2
		39-10	1-4	4
	28-3	39-30	1	1
	55-3	32-5	1-2	2
		32-6	1-2	2
		32-7	1-2	2
		32-8	1-2	2
		32-9	1-2	2
	35-2	39-33	1	1
	32-5	39-35	1	1
	55-2	39-34	1	1
93043	67-4	11717	293-15	30

## INLAND STEEL COMPANY

## REPORT OF CHEMICAL AND PHYSICAL TESTS • METALLURGICAL DEPARTMENT



## CONSIGNEE

CHICAGO BRIDGE & IRON CO.  
P. O. BOX 774  
KANKAKEE, IL. 60901

## DATE

2 25 1975

65  
91

## DESTINATION

INDIAN OAKS, IL

## VIA

IC 97052

## MILL ORDER NO.

Z-43696

## SHIPPING NO.

55380,4

5

## SPECIFICATION &amp; DESCRIPTION

ASTM A-36-70 C3X4.1#

PIECES	LENGTH		WEIGHT	CUSTOMER ORDER NO.	HEAT NO.	SLAB NO.	YIELD POINT LBS./SQ. IN.	TEAR STRAIN LBS./SQ. IN.	BOND LENGTH IN.	BEND %
	FT.	IN.								
201	30		24723	C73-6336G-159	94541	52200	72300	8 27	OK	

Item # - 100-79

HEAT NO.	CHEMICAL ANALYSIS											A1	
	C	Mn	P	S	Si	Cu	Ni	Mo	Cr	Cb	V	B	
94541	16	80	009	032									

Calculation L-001337  
Project No. 10248-012  
ATTACHMENT D  
Page 38 of 39  
R/6

STATE OF INDIANA

SUBSCRIBED AND SWEARN TO BEFORE ME THIS

COUNTY OF LAKE

DAY OF

A.D. 19

NOTARY PUBLIC

WE HEREBY CERTIFY THAT THE ABOVE FIGURES ARE CORRECT  
AS CONTAINED IN THE RECORDS OF THE COMPANY.

RAYMOND L. GILSON



**JONES & LAUGHLIN STEEL SERVICE CENTER DIVISION**  
**JONES & LAUGHLIN STEEL CORPORATION**  
**CERTIFIED RECORD OF CHEMICAL AND MECHANICAL PROPERTIES**



PURCHASER  
 PURCHASED BY  
 Chicago Bridge & Iron Company  
 POST OFFICE BOX 1746  
 Rockford, Illinois 60701  
 Attn: Art Johnson

DATE 9-19-74  
 YOUR ORDER NO. C73-63368-115 - C74-2270E108  
C73-63368-124  
 OUR INVOICE NO. 41-16082

CORRECTED

MATERIAL AS DESCRIBED ON INVOICE

ITEM	MANUFACTURER	CARBON	MANG.	PHOS.	SULPHUR	SILOCON	CHROM.	NICKEL	MOLY.	COPPER	TIN OR CH. IR.
1	B.W.	.24	.64	.018	.47						40°
2	B.W.	.24	.64	.018	.47						"
3	Inland	.50 Channel	"	"	"						60°

HEAT NO.	TENSILE PSI	YIELD PSI	ELONGATION IN 2 INCHES %	ELONGATION IN 8 INCHES %	REDUCTION OF AREA %	HARDNESS	BEND TEST	GRAIN TEST	EMB.	JOINTING HARDENABILITY
1 60930	66000	47300				25				
2 60930	66000	47300				25				
3 93063	68100	50400	101	101	21	27				

SUBSCRIBED AND SWEORN TO BEFORE ME THIS 29th DAY OF September, 19 74  
 NOTARY PUBLIC

MY COMMISSION EXPIRES 1-22-75

WE CERTIFY THE ABOVE INFORMATION IS AN EXACT COPY OF CERTIFIED TEST CERTIFICATES  
 FURNISHED BY THE ABOVE MANUFACTURERS AND KEPT IN OUR PERMANENT RECORD FILES.

**JONES & LAUGHLIN STEEL SERVICE CENTER DIVISION**

**CHICAGO**  
*John Carroll*

SERVICE CENTER

CHICAGO  
*John Carroll*  
 SIGNED John Carroll  
 MY COMMISSION EXPIRES 1-22-75

## Attachment K

### References

References

1. NRC Inspection Report 50-373/78-33, dated January 19, 1979
2. L. O. DelGeorge (ComEd) letter to A. Schwencer (NRC), "LaSalle County Station, Units 1 and 2, Containment Leak Chase Channels," dated August 10, 1981
3. L. O. DelGeorge (ComEd) letter to A. Schwencer (NRC), "LaSalle County Station, Units 1 and 2, Supplemental Information Concerning Containment Leak Chase Channels," dated September 1, 1981
4. L. O. DelGeorge (ComEd) letter to A. Schwencer (NRC), "LaSalle County Station, Units 1 and 2, Containment Leak Chase Channels," dated October 1, 1981
5. NRC Inspection Report 50-373/81-28, dated November 6, 1981
6. S. V. Athavale (NRC) letter to Donald F. Schnell (Union Electric Company), "Containment Liner Leak Chase Channel Venting Callaway Plant Unit No. 1 (TAC No. 72750)," dated March 14, 1990
7. Stephen P. Sands (NRC) letter to Thomas J. Kovach (ComEd), "Safety Evaluation of Containment Leak Chase Channels - Byron, Unit Nos. 1 and 2, Braidwood, Unit Nos. 1 and 2 (TAC Nos. 72569, 73570, 66476, and 66477)," dated May 17, 1990
8. Licensee Event Report (LER) 50-373/97-030-00, dated September 17, 1997