

JUN 23 1986

Mr. D. M. Musolf, Manager  
Nuclear Support Services  
Northern States Power Company  
414 Nicollet Mall  
Midland Square, 4th Floor  
Minneapolis, Minnesota 55401

Dear Mr. Musolf:

SUBJECT: PROJECTED VALUES OF MATERIAL PROPERTIES FOR FRACTURE TOUGHNESS  
REQUIREMENTS FOR PROTECTION AGAINST PRESSURIZED THERMAL SHOCK EVENTS  
PRAIRIE ISLAND NUCLEAR GENERATING PLANT UNIT NO. 2

We have reviewed your letter dated January 10, 1986 which were submitted in response to the Pressurized Thermal Shock (PTS) Rule, 10 CFR 50.61 for the Prairie Island Nuclear Generating Plant, Unit No. 2. We have found the material properties of reactor vessel beltline materials, the projected fluence at the inner surface of the reactor vessel at the expiration date of the license and the calculated  $RT_{PTS}$  at the expiration date of the license, June 25, 2008, to be acceptable. The calculated  $RT_{PTS}$  is below the screening criterion of 300 °F for circumferential weld material at the expiration date of the license. This meets the requirements of the PTS rule.

We note that you have applied for an amendment to extend your license for Prairie Island Nuclear Generating Plant Unit No. 2 and you have provided information to support operation of your plant to the proposed expiration date of the license without exceeding the PTS screening criteria. We did not deal with this issue in our evaluation since this issue will be addressed in the evaluation of your proposed amendment to extend the expiration date of your license.

The PTS Rule requires that the projected assessment of the  $RT_{PTS}$  must be updated whenever changes in core loadings, surveillance measurements or other information (including changes in capacity factor) indicated a significant change in the project values. This ensures that the licensees will track the fluence at the limiting beltline materials throughout the life of the plant to verify their assumptions. In this regard we request you to submit a

8607100117 860623  
PDR ADOCK 05000306  
P PDR

re-evaluation of the RT<sup>PTS</sup> and comparison of the predicted value with future Pressure-Temperature submittals which are required by 10 CFR 50, Appendix G. This completes our review of the PTS issue for your plant. Our associated Safety Evaluation is enclosed.

/s/

George E. Lear, Director  
PWR Project Directorate #1  
Division of PWR Licensing-A

Enclosure:  
As stated

cc: w/enclosure  
See next page

Office: LA/PAD#1  
Surname: PShuttleworth  
Date: 06/ /86

PM/PAD#1 200  
DDilanni:ii1  
06/13/86

PBD6  
GVissing  
06/14/86

PD/PAD#1  
GLear  
06/23/86

Mr. D. M. Musolf  
Northern States Power Company

Prairie Island Nuclear Generating  
Plant

cc:

Gerald Charnoff, Esq.  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, NW  
Washington, DC 20036

Executive Director  
Minnesota Pollution Control Agency  
1935 W. County Road, B2  
Roseville, Minnesota 55113

Mr. E. L. Watzl, Plant Manager  
Prairie Island Nuclear Generating Plant  
Northern States Power Company  
Route 2  
Welch, Minnesota 55089

Jocelyn F. Olson, Esq.  
Special Assistant Attorney General  
Minnesota Pollution Control Agency  
1935 W. County Road, B2  
Roseville, Minnesota 55113

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
Route #2, Box 500A  
Welch, Minnesota 55089

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
Office of Executive Director for  
Operations  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Mr. William Miller, Auditor  
Goodhue County Courthouse  
Red Wing, Minnesota 55066

Distribution Copies:

Docket No(s)

NRC PDR

Local PDR

PAD#1 r/f

PAD#1 p/f

TNovak, Actg. DD

NThompson, DHFT

ELD

EJordan

BGrimes

JPartlow

GLear

PShuttleworth

DDiIanni

ACRS (10)