



H. B. Barron
Vice President, McGuire
Nuclear Generation Department

Duke Power Company
A Duke Energy Company
McGuire Nuclear Station
MG01VF
12700 Hagers Ferry Rd.
Huntersville, NC 28078-9340

(704) 875-4800 OFFICE
(704) 875-4809 FAX

DATE: November 21, 1997

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: McGuire Nuclear Station, Unit 1 and 2
Docket No. 50-369
Licensee Event Report 369/97-10, Revision 0
Problem Investigation Process No.: 0-M97-3945

Gentlemen:

Pursuant to 10 CFR 50.73 Sections (a) (1) and (d), attached is Licensee Event Report 369/97-10, Revision 0, concerning the potential for inadequate margin to be maintained with regard to Reactor Coolant system flow rate due to inadequate analytical basis for the associated Technical Specification. This report is being submitted in accordance with 10 CFR 50.73 (a) (2) (v). This event is considered to be of no significance with respect to the health and safety of the public.

Very truly yours,

H. B. Barron, Jr.

TER/bcb

Attachment

cc: Mr. L. A. Reyes
U.S. Nuclear Regulatory Commission
Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, GA 30323

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339

Mr. Victor Nerses
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

Mr. Scott Shaeffer
NRC Resident Inspector
McGuire Nuclear Station

9712020233 971121
PDR ADOCK 05000369
S PDR



bxc: B. L. Walsh (EC11C)
M. S. Kitlan (CNS)
G. A. Copp (EC050)
J. I. Glenn (MG02ME)
P. R. Herran (MG01VP)
L. S. Davis (MG05SE)
J. E. Burchfield (ONS Reg Compliance)
G. H. Savage (EC06E)
G. B. Swindlehurst (EC11-0842)
C. M. Misenheimer (EC08I)
R. F. Cole (EC05N)
R. J. Freudenberger (EC05N)
T. G. Becker (PB02L)
P. M. Abraham (EC08I)
R. B. White (MG01VP)
R. T. Bond (ON03SR)
R. L. Bain (CN05SR)
K. L. Crane (MG01RC)
G. D. Gilbert (EC05N)
NSRB Support Staff (EC05N)