



Westinghouse
Electric Corporation

Energy Systems

Box 355
Pittsburgh Pennsylvania 15230-0355

DCP/NRC1244
NSD-NRC-98-5555
Docket No.: 52-003

February 3, 1998

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: T. R. QUAY

SUBJECT: OPEN ISSUES ON FIRE PROTECTION; REQUEST FOR MANAGEMENT MEETING

- References:
1. NRC Letter, "Request for Additional Information Relative to Open Items in the AP600 Design Certification Review," dated December 18, 1997.
 2. Westinghouse letter DCP/NRC1211, dated January 12, 1998.
 3. Westinghouse letter DCP/NRC1213, dated January 14, 1998.
 4. Westinghouse letter DCP/NRC1227, dated January 23, 1998.
 5. Westinghouse letter DCP/NRC1232, dated January 28, 1998.
 6. Westinghouse letter DCP/NRC1240, dated January 30, 1998.


Dear Mr. Quay:

This is to request a meeting with NRC management to resolve outstanding AP600 fire protection issues, if required. NRC provided Westinghouse with six AP600 fire protection open items by Reference 1. Westinghouse has responded to all six by References 2 through 6. Prior to issuing the responses NRC and Westinghouse discussed them by telephone. In a number of cases NRC and Westinghouse agreed that resolution of the two positions may require a management meeting.

Westinghouse believes that resolution has been reached on Open Items 280.33F (6499) Fire Protection Water Supply, 280.35F (6501) Spurious Actuation, and 280.36F (5602) Smoke Control. Westinghouse responses were provided by References 4, 2, and 3, respectively. Subsequent telefaxes confirmed SSAR wording for 280.33F (6499). Westinghouse believes there may be disagreement with 280.32F (6498) Fire Protection of Safe Shutdown and Cold Shutdown Capability, 280.34F (6500) High/Low Pressure Interfaces, and 280.37F (6503) Spent Fuel Pool Cooling. Westinghouse provided positions on these items in References 5, 6, 4, respectively.

9802110037 980203
PDR ADOCK C5200003
E PDR

110044



E00410

DCP/NRC1244
NSD-NRC-98-5555

-2-

February 3, 1998

If disagreement still remains for any of the fire protection items, Westinghouse requests a meeting with the NRC management as soon as possible to establish an acceptable and formal resolution.

If you have any questions on this letter, please contact me on 412-374-4334 or Jim Winters on 412-374-5290.

Susan V. Santo for

Brian A. McIntyre, Manager
Advanced Plant Safety and Licensing

jml

cc: D. C. Scaletti, NRC
N. J. Liparulo, Westinghouse