




UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

7c

NOV 5 1984

MEMORANDUM FOR: Larry Shao, Leader  
Civil & Mechanical Team  
Comanche Peak TRT

FROM: Shou-nien Hou  
Mechanical & Piping Discipline Leader  
Civil & Mechanical Team  
Comanche Peak TRT


SUBJECT: INTERVIEW WITH ALLEGER 

A conference call was arranged by R. C. Tang during 8:00 to 10:00 p.m. on October 31, 1984. The purpose was to discuss with the alleged on TRT findings. Three persons, P. Chen, R. Masterson and V. Ferrarini from Mechanical and Piping Group of the TRT participated in the conference call with presence of other three persons from civil and structure group, which included D. Jeng, C. Hofmayer, and R. Philleo, and R. Bangert from Region IV.

Highlights of alleged issues being discussed in Mechanical & Piping area and our suggested follow-up actions are summarized in the attached list. Discussions in Civil & Structure area are discussed in a separate memo by D. Jeng.

*Shou-nien Hou*  
Shou-nien Hou  
Mechanical & Piping, TRT

Enclosure: As stated

cc: V. Noonan  
R. C. Tang  
P. Chen  
R. Masterson   
V. Ferrarini

8607100243 860630  
PDR FOIA  
GARDE85-59 PDR

RECORDED

CC/153

Interview with Allegor on TRT Findings

<u>Allegor</u>	<u>Interview Date</u>	<u>TRT Person</u>	<u>M&amp;P Cat. #</u>	<u>Allegation #</u>	<u>Highlights</u>
[REDACTED]	10/31/84 8-10 p.m. by phone	Chen	#11	AP-13	<ul style="list-style-type: none"> <li>• Regarding mainsteam line forced into position</li> <li>• Allegor does not agree:               <ol style="list-style-type: none"> <li>1. Flushing line was connected to FW (should be to SG)</li> <li>2. Chain was used during MS lifting by crane (not used)</li> <li>3. Under engineering supervision during lifting (no)</li> </ol> </li> <li>• <u>Action:</u> Reflect what the allegor said in open issue and discuss with licensee.</li> </ul>
"	"	Ferrarini	#6	AW-45	<ul style="list-style-type: none"> <li>• Regarding welding performed without inerting.</li> <li>• Allegor indicated that inerting was not done for welding repairs. <sup>Vic</sup> indicated that inerting was not required for repairs (if <math>t &gt; \frac{1}{4}</math>)</li> <li>• <u>Action:</u> TRT should insist that inerting is not required.</li> </ul>
"	"	Masterson	#32	AH-10 AH-18	<ul style="list-style-type: none"> <li>• Regarding bent bolts used for hangers</li> <li>• Allegor indicated that holds in tube stocks <sup>steel</sup> were enlarged by torch cutting for accommodating the bent bolts. He personally replaced the tube steel on 3 supports. But he indicated that similar cases may exist all over the plant.</li> <li>• <u>Action:</u> TRT may agree with what allegor said, but shall emphasize safety significance in the SSER.</li> </ul>

7c

FIELD WALKDOWN WITH [REDACTED]

On 11-7-84 the RRI, J. Cummings, and I went on a field walkdown with [REDACTED] and the following items were discussed:

- (1) A feedwater restraint along the inner wall of the Reactor Building (RB) in Unit 1 was pointed out. During the installation the alleged stated that it was necessary to bend the rods that were screwed into the Richmond inserts. This bending was accomplished by heating and banging on the rods. Since the base plate for this restraint is very large and contains numerous holes this allegation has a high probability of being true even if the inserts were within their tolerance. (New Allegation)
- (2) [REDACTED] also pointed out the stainless steel line that he alleged had unauthorized welding performed without a required purge. He stated that the welding was done by a welding foreman named [REDACTED]. He, however, could not point out the exact weld but indicated one of three possibilities. (M/P CAT 6, AW-45 V. Ferrarini)
- (3) He also pointed out a restraint that had holes out of round in tube steel. He was not sure which Steam Generator (SG) bay it was located in, however, he said a man named [REDACTED] cut them. He stated [REDACTED] did so under orders. (M/P CAT 32, AH-18, R. Masterson)  
10
- (4) The alleged pointed out a fit-up gap problem on a main steam (MS) restraint on the MS line from SG No. 4. (New Allegation)
- (5) The alleged also showed us an area on the turbine deck where rebar was cut without authorization. Note the turbine building is a non seismic category 1 structure and therefore this problem is not a safety concern.
- (6) He also showed where the polar crane was attached to the No. 1 MS line and used to pull the piping to elevation. (M/P CAT 11, AR-13, W. P. Chen)

The major new concerns that were raised are:

- a. How did the bending of the rods affect the rod's ultimate strength.
- b. What effect did the heating and banging of the rods have on the Richmond inserts?
- c. What was the effect on the ultimate strength of the concrete insert?

Upon leaving [REDACTED] stated that he has talked to the NRC numerous times in the past and has given them numerous names and nothing has ever happened.

I think that it is very important to point out that during our walkdown [REDACTED] was approached by at least 12 construction personnel who were happy to see him. It appears that he is well liked by the plant construction personnel. This writer feels that [REDACTED] in general, is very knowledgeable and a capable construction worker.

FUJIA

CC/154

V. P. Ferrarini, TRT member

7c

7c

RESPONSE FOR ALLEGATIONS  
of [REDACTED] in  
Mechanical/Piping Area

7c

- Allegation (1) It is alleged that bolt holes in tube steel were cut over size with a torch to accommodate misplaced concrete inserts.
- (2) It is alleged that an unqualified individual was fabricating pipe hangers.
- (3) Welding repair was performed without inerting on the 832' El of the Unit One Reactor Building. The welding involved welding of a support lug on a stainless steel line.

TRT Response During Telephone Interview of 10-31-84

- (1) The TRT reported to the allogger that after talking with site personnel, reviewing hearing records and other transcripts, and reviewing fabrication procedures, that no evidence could be found to substantiate his allegation. He insisted he could show the TRT examples of his allegation if allowed to go on site.
- (2) The TRT was unable to locate the person alleged to be unqualified and therefore, could not substantiate the allegations.

TRT Followup on site visit with [REDACTED] 11-7-84

- (1) [REDACTED] pointed out a restraint that had holes out of round in tube steel. He was not sure which steam generator bay it was located in, however, he said [REDACTED] cut them under orders.

The TRT has not had an opportunity to follow up at the site on this new information. However, the TRT does plan to pursue this allegation and report the final findings in the SSER.

- (3) [REDACTED] pointed out the location of the alleged improper welding. The TRT reviewed the records for the systems that [REDACTED] pointed out and found that all those lines were carbon steel which does not require inerting. It should be pointed out that [REDACTED] stated that the area had changed a great deal since he left the site and therefore he was not sure as to the correct support, however, he stated that it was located in the area that he indicated.

The TRT will attempt to locate the alleged weld by reviewing the area during its next site visit.

c/155

7c

1. Category No.: 32 TRT Member: R. Masterson

2. Subject: Hanger Fabrication Deficiencies

3. Summary of Allegations:

These allegations (AH-4, AH-9 through AH-11, AH-16, AH-20, AH-21) concern various hanger fabrication deficiencies such as torch cutting of bolt holes and structural steel, using sledge hammers on supports during fabrication, welding of items not on the design drawing and an unqualified individual fabricating supports. These allegations were made by [REDACTED]

7c

4. Region IV's Conclusions:

Region IV inspectors did not address allegations AH-4, AH-18, AH-20 and AH-21. Region IV inspection report 50-445/84-05 which addresses AH-9 and AH-11 is a duplicate of allegations AP-18, AP-20, and AP-22 (see Category #31) and resulted in no violations or discrepancies. Region IV report 50-445/83-27, which addresses AH-10, concluded that due to the lack of specificity and the un-corroborated testimony of the alleger, the allegation could not be substantiated.

5. What TRT Had Done:

The TRT interviewed the allegers for AH-4, AH-18, AH-20 and AH-21 and was unable to generate more detailed information. The allegations were nondescript and vague and did not permit a review of specific hangers. The allegers either did not have firsthand knowledge of the incidents or could not remember specific hanger numbers or locations. The TRT interviewed various fabrication and QC inspection personnel and reviewed construction and QC inspection procedures and determined that in general the types of deficiencies described by the allegations were covered by procedures.

The TRT also reviewed AH-9 through AH-11 and discovered that AH-9 was a duplicate of AP-18, 20 and 22 and that AH-10 and AH-11 concerned the same incident which was associated with Unit 2. The TRT talked to one of the allegers and determined that the hanger identified in the allegation had been replaced and he knew of no other similar hangers. Six other individuals also had been interviewed by Region IV and stated that they knew of no instances of using a torch to elongate bolt holes. The TRT, as part of AC-31, inspected 150 anchors connecting tubular steel to concrete and saw no evidence of torch cutting of bolt holes.

CC/156

7c

6. TRT's Conclusions:

(a) Not Valid - All allegations were reviewed and no evidence could be found to substantiate the concerns. The TRT found that the types of cutting operations and fabrication techniques described by the various allegeders were addressed in the process. Since the allegeder stated that for AH-10 and AH-11 the support has been replaced, the allegation cannot be substantiated. The TRT could find no further evidence of this use of torch cutting through personal interviews or inspections.

(b) These allegations have neither safety significance or generic implications.

(c) [redacted] made [redacted] allegation in an interview and sworn statement in September 15, 1983. [redacted] made [redacted] allegation in an OI Report of Inquiry dated February 9, 1984, which reiterated [redacted] sworn statements of November 22, 1983 and January 26, 1984. [redacted] repeated the incident to the TRT in an interview on September 11, 1984. [redacted] made [redacted] allegations in a February 3, 1983 affidavit and an interview on April 14, 1983. [redacted] repeated the allegations in the July 12, 1983 deposition and again to the TRT on September 19, 1984. [redacted] made [redacted] allegations in [redacted] affidavit of March 31, 1984. [redacted] discussed the concern with the TRT on August 7, 1984.

7c

24

AND ~~REPEATED~~ AGAIN IN A TELEPHONE INTERVIEW WITH THE TRT ON AUGUST 28, 1984.

7c

Q: you recall ever having seen that posted at Comanche Peak?

A: No, I don't. You've got bulletin boards in front of the main tool room, one on the turbine deck, and one in the Administration Building. I had access as a Foreman to all of them, and I don't remember ever seeing it.

I don't know what can be done about the waste, the materials, and the back-stabbing that goes on at Comanche Peak. There are \$100 plus per Hilti bolt that are scrapped daily by the skip pan full. There's wood, lumber, steel, and what it's costing the taxpayers, it's ungodly. There's no reason for it. It's ridiculous, it's the misfits, it's the supervision you've got

out there. For instance, the general foreman on nights built a gold hat a sun deck or porch on his house. [REDACTED]

[REDACTED] because he'd been out there five or six years, and he was a good ole boy. [REDACTED]

[REDACTED] He could not handle his position. And here they were paying him \$14 or more an hour. Now this man is a general foreman, underneath a gold hat, in charge of pipe hangers on nights. The man is unqualified, incompetent,

can't do his work. He's cut holes in hangers where if there were any kind of vibration the hanger would fall off the wall; he used a cutting torch, and you're not allowed to use a cutting torch on any kind of material out there on a pipe hanger unless it is done in the Fab Shop under QA supervision.

Well, he cut holes in them so that sometimes he couldn't even figure out his holes, he couldn't figure out the tolerances or anything. And this man is now a general foreman on nights on big bore pipe hangers.

I can tell you lots of things. I was a [REDACTED] out there. Let me just give you a general perception of what's going on there.

7c

~~AH-16~~  
NEW

AH-10  
AH-9 relates

7c

FOIA-85-59  
cc/157

1547

1 I've been in steel work all my life -- I've been a fabricator, I've supervised  
2 a shop, and the whole bit. You've got people out there who do rebar tying.  
3 You've got two pieces of steel to tie together with a piece of wire. This is  
4 rebar people, all right? All they've got to do is to go up there and tie  
5 the rebar, and pour the concrete around it. It's all a hidden object, right?  
6 This entire rebar organization and building department has come into pipe hangers.

7 The entire rebar staff out there is a kind of clique, and they went into the  
8 hanger department. They suddenly became hanger geniuses.

9 There's one man  
10 out there right now who, three weeks before he was transferred from scaffold  
11 and rebar said, "Man, I don't know how in the hell you read these blueprints  
12 -- I don't know how in the hell you can make these things (pipe hangers)."

13 And as God is my witness, three weeks later this man was a General Foreman over  
14 pipe hangers. He was a general foreman next to a gold hat over pipe hangers.

15 He suddenly knew all about pipe hangers. He suddenly knew all about steel.

16 And here was a man that has done nothing but concrete and rebar all his life.

17 But all of a sudden he is a steel genius because he is in the clique, because

18 he belongs to the building department out there, because he is one of Billy

19 Ward's little boys.

20 There's jokes floating all over that plant where they show a pipe hanger  
21 tied together with wire or nailed together with wood because of the carpenters  
22 and rebar hands that came over into pipe hangers. They're coming over as foremen,  
23 they're coming over as General Foremen and they're coming over as gold hats  
24 (superintendents). And all of a sudden they know everything about pipe hangers  
25 and about steel.

I'm just fed up with it, cause I've got to live here. I was here before

127



night GF  
Big bore hangers

M

35

10

1 a cutting torch on hangers. I don't personally  
2 know, is it improper to use a cutting torch to tear  
3 down or alter a hanger?


4 A Not to tear down and alter, but it's  
5 illegal to use it in the containment building where  
6 I was the entire supervision, when I was hanging  
7 pipe supports. You drill everything and everything  
8 has to go on the wall according to the drill size.  
9 I took down a hanger -- took down several hangers  
10 that was put up by this general foreman out there  
11 that I tried to fire.

12 Q Which one is this?

13 A Oh, boy.

14 Q Was it your general foreman?

15 A No, he wasn't my general foreman.



18 Q You were a foreman?

19 A [Yeah. They call them supervisors out  
20 there.] You got a supervisor, a general supervisor,  
21 a three-stripe general supervisor and then a  
22 superintendent.

23 Q I see. Is a foreman higher than a  
24 general foreman?

25 A No. The general foreman's got two

FOIA-SE

1 stripes on his hat.

2 Q So this guy was your boss?

3 A

4 [REDACTED] He later made general  
5 [REDACTED] foreman because he went out to [REDACTED]

6 [REDACTED] and then he became a  
7 general foreman overnight over in pipe hangers. I  
8 heard he got fired, which I hope he did.

9 He had taken a torch and cut the back side  
10 of a tube out because a lot of bolts are put in like  
11 this, the holes in the wall. They are supposed to  
12 be straight, ninety degrees off the wall. They're  
13 anchored in the wall, poured into the concrete.

14 MS. ELLIS: Richman inserts.

15 A Yes. And you go to hang a pipe hanger on  
16 that and they give you a threaded piece of steel and  
17 you're supposed to stick it in there and it's  
18 supposed to come ninety degrees off the wall. Well,  
19 they come off this way and come off that way and  
20 come off this way and this way --

21 MS. ELLIS: For the record, could you  
22 kind of try to describe those angles that you  
23 are talking about? That's kind of hard to do  
24 sometimes.

25 Q Let me just ask you, maybe it would be

Stanley, Harris, Rice 741-4567

1           A           But in the containment itself, you would  
2 probably find them in the compartments would  
3 probably be the major part of them.


4           Q           All right. Let's go back to this, the  
5 use of the cutting torch. Is that --

6           A           That's what I'm saying. This hanger in  
7 these compartments, if they didn't have enough  
8 intelligence to find out what kind of angle it is  
9 and how to drill the hole from the back and make it  
10 come out center from the front, what this foreman  
11 done out there or general foreman on nights, what he  
12 done was take a torch and cut about a three-inch  
13 hole. And you can see, if I cut -- if I got this  
14 angle here and say we have another one here and the  
15 back was at another angle, we just cut that sucker  
16 out like that so we can move that thing any way we  
17 want to to get it started.

18          Q           How do they fill in the hole or is it --

19          A           They don't fill it in; it's covered with  
20 a washer. The only reason I found it out, the  
21 hanger that was particularly put up by this guy was  
22 designed wrong. I had to go down there and tear it  
23 down. And I went to my superior [REDACTED] and I said,  
24 what are you going to do about this? I mean, I got  
25 my butt tore up yesterday because I put something in

REV. DATE		CHK	APP	DESCRIPTION	DR.	CHK APP.
11/13	11/13	RM	RM			
DESCRIPTION				ISSUE FOR CONST		
				FWI-2		




ELEVATION A-A


LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVTS (LN.)	THER.	SEISMIC	REFERENCE DRAWINGS	G & H ISOMETRIC	REV
						NORM.	EMERG.	FLD.						
UP									VERT.			2323-MI-23204	2323	
DN	352		477		352				N-S			FAB. ISOMETRIC	REV	
N									E-W			MS-1-PE-14	2323	
S									PIPE CALC.	77				
E									DATA POINT	2523				
W									SUPPT CALC.	50-42-77				

WPS:  
NDE:

ITEM NO	NO REQ'D	DESCRIPTION	WT.	ASME OR ASTM	PRM	MIC
1	3	FHN-1" H.V. HEX NUT		A-307	CSS	
2	3	RWP-09 EXCEPT 1" x 4" x 2" CTR.		SA-36	CSS	
3	1	TS 4" x 4" x .375		A-500GRB	L	
4	4	RAT-09 x 1" - 1" LG. STD		SA-36	CSS	
5	1	TS 4" x 4" x .375		A-500GRB	L	
6	1	TS 4" x 4" x .375		A-500GRB	L	
7	1	NT 4 x 3.5 x 1" - 4" LG.		SA-36	L	
8	2	FB 2 1/4" x 3/8" x 4 3/8" LG. (SEE DET. 3)		SA-36	L	
9	1	IMF-06 BASE MOUNTED VAR. SPRING N/LOAD FLANGE & TVL STOP HL=352# CL=375# MVT=.504UP			CSS	
10	2	TS 4" x 4" x .375		A-500GRB	L	



**VOID**




SEL. 355'-0"  
1" - 4" MS-1-150-1303-2

**TI APERTURE CARD**

- ASME TI NAMEPLATE

Also Available On Aperture Card



SECTION B-B

11032 VISUAL

PIPELINE	REVISION	DATE	BY	CHK'D	DATE	APPV'D	DATE
ELECTRICAL	REV. 1		CEDELIAS				
MECHANICAL	REV. 2		PAINT				
STRUCTURAL	REV. 3						
SPRINGS	REV. 4						
P.O. NO. CP-0046 A.1		MFG. REL. TC-113					
PRODUCTION ORDER		SERIAL NUMBER		SHEET			
151		MX. NO. MS-1-150-110-3525		1 of 2			
REV. 0							

CPSES  
Brown & Root, Inc.  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS  
35-1195

Brown & Root, Inc.  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS


FOIA-85-59

cc/159

8607100243-01

THIS DRAWING AND THE DESIGN IT CONTAINS ARE THE PROPERTY OF M.P. INDUSTRIES. THEY ARE HEREBY LOANED AND ON THE BORROWER'S EXPRESS AGREEMENT THAT THEY WILL NOT BE REPRODUCED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN CONSENT GIVEN BY THE LENDER.

REV. DATE	CHK	APP	DESCRIPTION	DR. CHK APP.
11/1/73	KW	(Signature)	ISSUE FOR CONST FW 1-4	



SECTION C-C


LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVTS (IN.)	THER.	SEISMIC	REFERENCE DRAWINGS	G & H ISOMETRIC	
						NORMAL USE	EMERG.	FLTD					REV	ST
UP									VERT.			2323-M	2323	
DN									N-S			FAB. ISOMETRIC		ST
N									E-W					2323
S									PIPE CALC					
E									DATA POINT					
W									SUPPT CALC					

OWNER	TEXAS UTILITIES SERVICE
PROJECT	COMANCHE PEAK UNITS
ENGINEER	GIBBS & HILL

ITEM NO.	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	MIC.

VOID


**TI  
APERTURE  
CARD**  
  
Also Available On  
Aperture Card



DETAIL 8



WPS: 11032  
NDE: VISUAL



DRAWING	NO.	ELECTRICAL	REV.	CODE/CLASS	DRAWN	DATE	CHK'D	DATE	APPV'D	DATE
	35-1105	CPSES	1	1105	R.P.P.	9/17/79	R.N.	10/2/79		10/3/79
STRUCTURAL		H.V.A.E.	REV.	ZONE	P.O. NO. CP-0045 A1		MFG. REL. TC-113			
		1105-M	1		PRODUCTION ORDER		SERIAL NUMBER	SHEET		
										2042
					151	MK. NO. MS-1-151-110-2525			REV. 0	


CPSES  
Brown & Root, Inc.  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS



8607100243-02

11  
3.8

REV. DATE	APP	CHK	DWN	DESCRIPTION
8-24-74	JW	RWD		ISSUE FOR CONST. F.W.'S 1-12



**TI APERTURE CARD**

Also Available On Aperture Card

**THER. UPSET MVTS**

$V = .000"$   
 $N-S = .000"$   
 $E = 1.51"$



3.5"



LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVTS (IN.)	WIND THER.	SEISMIC	REFERENCE DRAWINGS	G & H ISOMETRIC REV.
						FORM UPSET	EMERG.	FLTD.					
UP									VERT.	-		FAB. ISOMETRIC REV.	
DN									N-S	-		M3-1-RB-15 5 2	
N				397	794	397	794		E-W	1.51		OWNER	TEXAS UTILITIES SER
S		130		397	794	527	924		PIPE CALC.	76		PROJECT	COMANCHE PEAK UNITS
E'									DATA POINT	228		ENGINEER	GIBBS & HIL
W									SUPPT CALC.	SC-37-76			

11"




ITEM NO	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	31070	31070	MIC.
1	1	L 3" x 3" x 3/8"		SA36	L		
2	1	WT 4 x 8.5 x 6 LG (SEE SECT B-B)		SA36	L		
3	2	SRS-06-BA-CC RIGID SWAY STRUT				CSS	
4	2	FB 5" x 1/2" x 5"		SA36	L		
6	2	TS 4" x 4" x .375"		A500GRB	L		
6	2	TS 4" x 4" x .375"		A500GRB	L		
7	2	TS 3" x 3" x .1875"		A500GRB	L		
8	2	FB 5" x 1/2" x 8"		SA36	L		
9	2	TS 4" x 4" x .375" (BY FIELD)		A500GRB	L		
10	6	RFT-12 L=13" ROD		SA36	CSS		
11	12	FHN-12 HVY HEX NUT		SA307GRB	CSS		
12	12	FB 4" x 4" x 1" W/(1) 1 7/8" HOLE ON CTR		SA36	L		
13	4	FB 2 1/4" x 3/8" x 4 7/8" SEE DETAIL 13		SA36	L		
14	1	PUS-040 STD U-BOLT B=9"		SA36	CSS		

A  
FIELD TRIM TO SUIT



**VOID**



55 SUPD TISO NPSI-MS-1-RE-15


PIPING	REV.	ELECTRICAL	REV.	CODE/CLASS: III/2	DRAWN	DATE	CHK'D	DATE	APPV'D	DATE
323-MI-0507	10	2323-EI-0501-02	4	PAINT CATEZINC NO 11	PK	1/4/79	TB	1/24/79	2/0	1-25-79
STRUCTURAL	REV.	H.V.A.C.	REV.	ZONE -	FE		AM			
323-SI-0522	3	2323-MI-0551	3							
VICES INC.					P.O. NO. CP-0046 A1			MFG. REL. TC-158		
NO. 1 & 2					PRODUCTION ORDER			SERIAL NUMBER		
L INC.					2013			MK. NO. MS-1-151-037-C52R		
CPSES					Brown & Root, Inc.			SHEET		
35-1195					HOUSTON, TEXAS			10F2		
					REV. 0					

FOIA-85-59

cc/160 8607100243-03


5:8

REV	DATE	BY	APP	DESCRIPTION
△	8/24/77	JW	hjm	ISSUE FOR CONST. F.W.'S 13-17



**TI APERTURE CARD**

Also Available On Aperture Card



8.5


LOAD (LBS)	GRAV.	THER.	HYDRO	OBE	SSE	DESIGN LOADS			MVTS (IN.)	THER.	SEISMIC	REFERENCE DRAWINGS	G & H ISOMETRIC
						NORM.	EMERG.	FLTD.					
UP									VERT.			2323-M	
DN									N-S			FAB. ISOMETRIC	
N									E-W				
S									PIPE CALC.	76			
E									DATA POINT	223			
W									SUPPT CALC.	SC-37-76			

OWNER TEXAS UTILITIES  
 PROJECT COMANCHE PEAK UN  
 ENGINEER GIBBS &

11

OVERVIEW

ITEM NO	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	MIC.
<b>VOID</b>					



53 SUPPLIES NPSI-MS-1-RE-15

PIPING	REV.	ELECTRICAL	REV.	CODE/CLASS	1/2
2323-M		2323-E		PAINT PRESSING	NO 11
STRUCTURAL	REV.	H.V.A.C.	REV.	ZONE	-
2323-S		2323-m			

DRAWN	DATE	CHK'D	DATE	APP'V	DATE
RE PK	1/4/79	AM TE	1/4/79	210	1-25-79
P.O. NO. CP-0046A1			MFG. REL. TC-15R		
PRODUCTION ORDER		SERIAL NUMBER		SHEET	
				20F2	
2013	MK. NO. MS-1-151-037 C52R			REV. 0	

SERVICES INC.  
ITS NO. 1 & 2  
HILL INC.




**Brown & Root, Inc.**  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS

8607100243-04

8.5

REV. DATE	APP.	DESCRIPTION	REV. DATE	CHK.	APP.	DESCRIPTION
10-1-79	JW	ISSUE FOR CONST. F.W.'S 1-5				



THERMAL UPSET  
MVT.  
S = .366  
V = 0  
W = .740

LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVT. (IN.)	NCR. THER.	SEISMIC	REFERENCE DRAWINGS	OWNER	PROJECT	ENGINEER
						NCR. UPSET	EMERG.	FLTD							
UP									VERT.	0		G & H ISOMETRIC REV. 2323-MI-3030-97 E	TEXAS UTILITIES SERV	COMANCHE PEAK UNIT	GIBBS & H
DN									N-S	.23		FAB. ISOMETRIC REV. CT-1-R.B-317			
N				491	982	491	982		E-W	.466					
S				491	982	491	982		PIPE CALC.		37A1/#2				
E				466	932	466	932		DATA POINT		517				
W				466	932	466	932		SUPPT. CALC.		SC-93-37A1				

8.5

11"

ITEM NO	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	PR M	MIC.
1	4	FHN-12 HVY HEX NUT		A-307	CSS	
2	2	RFT-12 L 13 ROD		SA-36	CSS	
3	2	a) SMS-1-BA-		-	CSS	
		MECH. SNUBBER		-		
	2	b) SMFB-1 FORWARD BRACKET		-	CSS	
4	1	M4 X 13		SA-36	L	
5	2	PUS-060-B-8 1/4" STD. U-BOLT		SA-36	CSS	
6	1	P 3 SCH. 40 X 3 1/16" LG		A53/A106 GRB	L	
7	1	TS 4" X 4" X .375 (BY FIELD)		A-500 GRB	L	
8	4	FB 4" X 1" X 4" W/(1) 1 1/8" Ø HOLE ON CTR		SA-36	CSS	
9	1	ASTM III NAVE PLATE PROVIDE TEMPORARY SPACE IR C-C = 14 3/8"				



ETV = FIELD TO VERIFY

1/16" Ø HOLE ON GAGE (TYP) (BY FIELD)

NF-5222

NF-5223 TYP 2 PLCS

WELD TO PIPE




SECTION B-B



TI APERTURE CARD

Also Available On Aperture Card

SECTION A-A



204 SUPP'T ISO NPSI-CT-1-RB-31


PIPING	REV. 6	ELECTRICAL	REV. 3	CODE/CLASS: II/2	DRAWN	DATE	CHK'D	DATE	APP'VD	DATE
2323-MI-0504-01		2323-EI-0503		PAINT CARBOZING #11	AS	6/13/79	PK	6-2379	HD	7-6-79
STRUCTURAL	REV. 2	H.V.A.C.	REV. 3		ZONE					
2323-SI-0532		2323-MI-0552			P.O. NO. CP-0046 A.1		MFG. REL. TC-198			
SERVICES INC.					PRODUCTION ORDER		SERIAL NUMBER		SHEET	
NO. 1 & 2									10F1	
LL INC.					2663		MK. NO. CT-1-051-413-CTCK		REV. 0	



Brown & Root, Inc.  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS

# TI APERTURE CARD

Also Available On Aperture Card



ELEV. LKG. SOUTH-EAST


DESCRIPTION	REV	DATE	DWN	CHK	APP
ISSUE FOR CONST. F.W.'S 1-2	1	12/4/77	MJP	JW	EW

LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVTS (IN.)	NORM THER.	SEISMIC
						NORM UPSET	EMERG	FLTD			
UP	-	-	-	1122	2244	1122	2244	VERT.	.49		
DN	-	-	-	1122	2244	1122	2244	N-S	.32		
N								E-W	.18		
S								PIPE CALC.		35A	#0
E								DATA POINT		506	
W								SUPPT CALC.		SC-73-35A	



REFERENCE DRAWINGS	G & H ISOMETRIC	REV.
	2323-MI-3232-61	D 2
	FAB. ISOMETRIC	REV.
	CT-1-RB-30	9 2
OWNER	TEXAS UTILITIES SERV	
PROJECT	COMANCHE PEAK UNITS	
ENGINEER	GIBBS & HILL	

ITEM NO.	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	PR M	SEC	MIC.
1	1	T.S. 6"X6"X.375 (BY FIELD)		SA-36	L		
2	2	RFT-12-L15 ROD		SA-36	CSS		
3	4	FXN-12 HVY HEX NUT.		A-307 GRB	CSS		
4	1	T.S. 4"X4"X.375		SA-36	L		
5	1	a). SMS-3-RO MECH. SNUBBER		—	CSS		
	1	b). SMTT-3-L = 17 1/4" TRANSITION KIT		—	CSS		
6	1	SPC-10-060 PIPE CLAMP		SA-36	CSS		
7	4	F3 6"X1"X6" W/(1) 15/8" Ø HOLE ON E.		SA-36	PR		
8	1	ASME II NAMEPLATE		—			

FTV = FIELD TO VERIFY



SECT. A-A.



163	FAB 150	NPSI-CT-1-RB-30								
PIPING	REV.	ELECTRICAL	REV.	CODE/CLASS: D/2	DRAWN	DATE	CHK'D	DATE	APPV'D	D..TE
233-MI-0504-01	6	2323-EI-0510-01	1	PAINT CARBOZINC	PP P.K	9-13-79	PT	9/13/79	AS GC	9.14.79
STRUCTURAL	REV.	H.V.A.C.	REV.	ZONE -						
233-SI-0532	2	2323-MI-0552	5							
VICES INC.	CPSES Brown & Root, Inc.		ENGINEERS AND CONSTRUCTORS		PRODUCTION ORDER		SERIAL NUMBER		SHEET	
NO. 1 & 2	HOUSTON, TEXAS								1 OF 1	
L INC.	35-1195				1516		MK. NOCT-1-036-403-C72K		REV. 0	


FOIA-85-59

CC/162

8607100243-06

# TI APERTURE CARD

Also Available  
Aperture Card



ELEV. LOOKING SOUTH-EAST


LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVTS (IN.)	THER.	SEISM C		REFERENCE DRAWINGS	G & H ISOMETRIC REV.	
						NORM. UPSET	EMERG.	FLTD			+	-		2323-MI-3232-61	0
UP									VERT.	6827	-	-	FAB. ISOMETRIC REV.		
DN									N-S	0	-	-	CT-1-23-30	9	23
N	9	144		2731	5462	2820	5351		E-W	0	-	-	COWNER	TEXAS UTILITIES SERV	
S		833		2731	5462	3683	6216		PIPE CALC.		354 40		PROJECT	COMANCHE PEAK UNITS	
E		82		3226	6452	3361	6687		DATA POINT		5051		ENGINEER	GIBBS & HILL	
W	13	172		3226	6452	3711	6937		SUPPT CALC.		46-73-354				



ITEM NO.	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	P	MIC.
1	2	TS 6"X6"X.375"		A-500GR-B	L	
2	5	RFT-12 L15 ROD		SA-36	CS	
3	10	FHN-12 H.V. HEX NUTS		A-307GR-B	CS	
4	10	FB 6"X1"X6" U/15/8" HOLE ON E		SA-36	PS	
5	2	TS 4"X4"X.375"		A-500GR-B	L	
6	2	TS 4"X4"X.375"		A-500GR-B	L	
7	1	TS 6"X6"X.375"		A-500GR-B	L	
8	4	FB 5"X1/2"X5"		SA-36	PS	
9	4	TS 4"X4"X.375"		A-500GR-B	L	
10	2	TS 6"X6"X.375 (BY FIELD)		A500GR-B	L	
11	1	ASME III NAME PLATE				

TYP NF5222


TYP NF5222



CPSES  
35-1195  
CONTROL  
COPY  
CONTROL CENTER

163 SUPP'T ISO	NPSI-CT-1-EB-30	PIPELINE	REV. 4	CODE/CLASS: III/2	DRAWN	DATE	CHK'D	DATE	APP'V'D	DATE
23-MI-0504-01	2323-EI-0510-01	PAINT	REV. 4	PAINT CARBON STEEL	PK	9/22/79	ST	9/13/79	H. G. C.	9/14/79
23-SI-0532	2323-MI-0552	H.V.A.C.	REV. 5	ZONE	P.O. NO.	CP-0046 A-1	MFG. REL.	TC-270		
ICES INC.	CPSES	Brown & Root, Inc.			PRODUCTION ORDER		SERIAL NUMBER		SHEET	1062
NO. 1 & 2	35-1195	ENGINEERS AND CONTRACTORS			1517	MK. NO. CT-1-026-204-C722			REV. 0	
INC.		HOUSTON, TEXAS								

REV	DATE	BY	CHK	APP	DESCRIPTION
					ISSUE FOR CONST.



SECTION-B-B

UNIT	GRAV.	THER.	HYDRO	OBE	SSE	DESIGN LOADS			MVT (IN.)	THER.	SEISMIC		REFERENCE DRAWINGS	G. & H ISOMETRIC REV.	
						NORM/UPSET	EMERG	FLTD						2323-M	232
UP									VERT.				FAB. ISOMETRIC	REV.	S
DN									N-S				C-1-RB-30	2	232
N									E-W			OWNER	TEXAS UTILITIES SERVICE		
S									PIPE CALC	354 #0		PROJECT	COMANCHE PEAK UNITS		
E									DATA POINT	5051		ENGINEER	GIBBS & HILL		
W									SUPPT CALC.	50-73-35A					


ITEM NO	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	MIC.




**VOID**

**TI  
APERTURE  
CARD**


Also Available 0  
Aperture



163 SUPP'T 150 NP51-27-1RB-30

PIPING	REV.	ELECTRICAL	REV.	CODE/CLASS: 2/2	DRAWN	DATE	CHK'D	DATE	APPV'D	DATE
-M		2323-E		PAINT 423024	<del>23</del> EK	9-13-79	<del>1</del> PT	9/13/79	KB	9.14.79
STRUCTURAL	REV.	H.V.A.C.	REV.	ZONE -	P.O. NO. CP-0046 A-1 MFG. REL. TC-270					
B-S		2323-M		PRODUCTION ORDER			SERIAL NUMBER		SHEET	
 <b>CPSES</b> <b>Brown &amp; Root, Inc.</b> <small>ENGINEERS AND CONSTRUCTORS</small> HOUSTON, TEXAS					1517	MK. NO. CT-1036-408-672R			REV. 0	
					20F2					
					8607100243-08					

REV	DATE	CHK	APP	DESCRIPTION
1	12-10-79	[Signature]	[Signature]	ISSUE FOR CONSTRUCTION
2				
3				



PLAN ← N  
@ EL. 837'-1 1/2"

\* GTN-3655G

LOAD (LBS)	GRAV	THER	HYDRO	OBE	SSE	DESIGN LOADS		MVTS (IN.)	NORM THER	SEISMIC	REFERENCE DRAWINGS	G & H ISOMETRIC REV
						NORM (DEPT)	EMERG FLTD					
UP								VERT.	DN		FAB. ISOMETRIC REV	
DN								N-S	0		CC-1-RB-53 5 2	
N	10			400	600	410	610	E-W	0		OWNER TEXAS UTILITIES SERV	
S		160		400	600	550	750	PIPE CALC	56B # *		PROJECT COMANCHE PEAK UNITS	
W		90		320	480	410	570	DATA POINT	160		ENGINEER	
E				320	480	320	480	SUPPORT A.C.	SC-70-56B		GIBBS & HIL	

SUPPLY MK # CC-1-233-002  
NPS # 2729, THIS P

1 7/8" φ HOLE IN CENTER OF TUBE (TYP) BY FIELD

45°


NF5233

4" CC-1-2

ITEM NO	NO REQ'D	DESCRIPTION	WT	ASME OR ASTM	PO	FIN	MIC
1	2	TS 4 X 4 X .375 (BY FIELD)		A500GRB	L		
2	1	TS 4 X 4 X .375		A500GRB	L		
3	1	a) SRS-06-RO-CC = 30 1/2" RIGID SWAY STRUT		-		E3D	
	1	b) SPC-06-040 PIPE CLAMP		SA-36	CSS		
4	8	FB 4 X 1 X 4 W/(1) 1 5/8" Ø HOLE ON E.		SA-36	P85		
5	8	FHN-12 HVY HEX NUT		A307GRB	CSS		
6	4	RFT-12-L13 ROD		SA-36	CSS		
7	1	ASME III NAMEPLATE		-			


153C  
200

F.T.V. = FIELD TO VERIFY



TI APERTURE CARD

Also Available On Aperture Co.



152 SUPP'T ISO NPSI-CC-1-RB-5B

PIPING	REV.	ELECTRICAL	REV.	CODE/CLASS: III/3	DRAWN	DATE	CHK'D	DATE	APPV'D	DATE
23-MI-0507	12	2323-EI-0501-02	7	PAINT CARBOLINE #11	FY SR	8/2/79	SP2 RP	9/12/79	HD PC	9.13.79
STRUCTURAL	REV.	H.V.A.C.	REV.	ZONE -						
23-SI-0522	3	2323-MI-0551	5							
ICES INC.					P.O. NO. CP-0046 A.1		MFG. REL. TC-267			
NO. 1 & 2					PRODUCTION ORDER		SERIAL NUMBER		SHEET	
INC.									10F1	
CPSES Brown & Root, Inc. ENGINEERS AND CONTRACTORS HOUSTON, TEXAS					2723		MK. NO. CC-1-233-001-C53R		REV. 0	

8607100243-09


FOIA-85-59

CC/164

P/A SPOOL # 2


SI-1-104-007-C52K D.P.

SI-1-104-003-C52K D.P.



TI APERTURE CARD

Also Available On Aperture Card



**BILL OF MATERIAL**

PC NO.	REQ.	HEAT NO.	DESCRIPTION	ASMP ESTM	GRADE	COLOR CODE

REV.	DATE	DESCRIPTION	DWR.	CHK'D.	APP'D.
△ 1	11/7/8	ISSUED FOR HANGER IDENTIFICATION AND ACCOUNTABILITY ONLY	OG	MJP	LMH
△ 2		REV AS NOTED, REDRAWN, VERIFIED FOR STRESS	OG	OG	LMH


FOR OFFICE AND  
ENGINEERING USE ONLY

WELD NO.
RT
MT
LP
UT

COST CODE	PAINT	INSTR.	CL.	TNRNS.
FLOOR DIA.	COMPOSITE	SPEC.	DCS-NO.	CAT./CL.

NOTES  
8607100243-10

TEXAS UTILITIES SERVICES INC.  
C. P. S. E. S. 35-1195 GLEN ROSE, TEXAS



**Brown & Root, Inc.**  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS


DRAWING TITLE  
SAFETY INJECTION

Q	REVISION NO. KPM-3701	DATE TO BRHL-SI-1-RB-039	REV. 1
---	-----------------------	--------------------------	--------

FOIA-85-59  
cc/165



NOTE DIRECTION OF NORTH ARROW




TI  
APERTURE  
CARD

Also Available On  
Aperture Card



ACCUMULATOR N32  
 TBX-SIATAT-927



**VOID**



ON SITE DELIVERY DATE 8" & SMALLER  
 ON SITE DELIVERY DATE 8" & LARGER  
 TURNOVER NO.

**BILL OF MATERIAL**

REV.	DATE	DESCRIPTION	QTY	UNIT	SYMBOL	ASTM	GRADE	COLOR CODE

REV.	DATE	DESCRIPTION	QTY	UNIT	SYMBOL	ASTM	GRADE	COLOR CODE
△		STEEL FOR HANDLING IDENTIFICATION AND ACCOUNTABILITY ONLY				GLL	M.P	LM

DESIGNED BY	CHECKED BY	APPROVED BY	DATE	SCALE
NOTES				
<p>8607100243-11</p> <p>TEXAS UTILITIES SERVICES INC.          GLEN ROSE, TEXAS</p> <p><b>Brown &amp; Root, Inc.</b>          ENGINEERS AND CONSTRUCTORS          HOUSTON, TEXAS</p>				
<p>DRAWING TITLE</p> <p><b>SAFETY INJECTION</b></p>				
PROJECT NO.	REV. NO.	DATE	BY	
RFT-M 5701	0	APRIL - 51 - 1 - 68 - 039		


11

8.5

8.5

11

REV	DATE	APP	CHK	DESCRIPTION	DESCRIPTION	REV	DATE	APP	CHK
1	8/24/74	JW	JW	ISSUE FOR CONST. F.W.'S 13-17	ADDED SH. 3 VENDOR CERT. REF. G.T.N. 60719	1			
2	11/16/74	JN	JN	SELECTED PARTS PER NIPSI REV. 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100					
3	4/13/83	JR	JR	REV'D AS NTD. REF. ZML# B4428 R.5. IDLA TLOT. SEE AT. 2) 'AS BUILT'					



THERM. UPSET MVTS.  
DN = .033"  
E = 1.737"

T/O #3401

PLAN VIEW  
@ ELEV. 841'-0"

LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVTS (IN.)	NORM THER.	SEISMIC	REFERENCE DRAWINGS	OWNER	PROJECT	ENGINEER
						NORMAL UPSET	EMERG.	FLTD							
UP									VERT.			BRHL MS-1-RB-015	TEXAS UTILITIES	COMANCHE PEAK UN	GIBBS &
DN									N-S			FAB. ISOMETRIC			
N						192	280		E-W			MS-1-RB-15			
S						333	421		PIPE CALC.	AB-1-76B/R/O					
E									DATA POINT	2288					
W									SUPP. CALC.	SL-37-76					

\* FIELD CUT


AS-BUILT

VENDOR CERTIFIED  
DRAWING REV. NO. 2  
BY [Signature] DATE 4-13-83

TO SUIT

ITEM NO	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	PRM	MIC.
2	1	WT 4x8.5x6" LG (SEE SECT. 8-8)		SA 36	L	
3	2	SRS-06-BA SWAY STRUT			CSS	
* 6	2	T.S. 4"x4"x3/8"		A 500 GR.B	L	
* 9	1	T.S. 4"x4"x3/8"		A 500 GR.B	L	
10	6	RFT-12 L=13" ROD		SA 36	CSS	
11	12	FHM 12 HVY. HEX NUTS		SA 307 GR.B	CSS	
12	12	F.B. 4"x4"x1" W/ 1 5/8" Ø HOLE ON CIR.		SA 36	L	
13	4	F.B. 2 1/4"x 3/8"x 4 1/8" (SEE DETAIL 13)		SA 36	L	
14	1	PUS-040 STD. U-BOLT B=9"		SA 36	CSS	
* 16	2	T.S. 4"x4"x3/8"x6" LG		A 500 GR.B	L	
* 17	2	T.S. 3"x3"x3/8"x3'-6" LG		A 500 GR.B	L	
* 18	1	T.S. 4"x4"x3/8"x5'-7" LG		A 500 GR.B	L	
19	2	1/2" RATE 5"x9 1/2" LG.		SA 36	P4S	
21	1	1/2" R. 5"x6"		SA 36		
* 22	2	T.S. 4"x4"x3/8"x2'-10" LG		A 500 GR.B	L	
23	1	W 4x13x3'-2" LG		SA 36	L	
26	1	PUS-040 U-BOLT B=9"		SA 36	CSS	

NF5222 TYP.



1 1/2" DIA. INSERTS EXIST (TYP.)

**NOTE:**


2.) Locking devices for high strength bolts are not required per DCA 7607

**FOR OFFICE AND ENGINEERING USE ONLY**

**TI APERTURE CARD**

Also Available On Aperture

FOIA-85-59



33	SUPPT 150.	NPSI MS-1-RB-15
REV.	ELECTRICAL	REV.
2323-MI-0507	10	2323-EI-0501-02
REV.	H.V.A.C.	REV.
2323-SI-0522	3	2323-MI-0551

CODE/CLASS: II/2	DRAWN	DATE	CHK'D	DATE	APPV'D	DATE
PAINT CASE 30 ZINC=11	RE PK	1/4/79	AM TB	1/24/79	JW	1-25-79
ZONE CH	P.O. NO.	CP-0046	AI	MFG. REL.	TC-158A	
PRODUCTION ORDER	SERIAL NUMBER	SHEET	2			
2013	MK. NO.	MS-1-151-037-C52R	REV.	2		


SERVICES INC.  
ITS NO. 1 & 2  
HILL INC.

**Brown & Root, Inc.**  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS  
38-1198

FOIA-85-59 CC/166 8607100243-12

11

18



REV	DATE	APP	CHK	APP	DESCRIPTION
1					ISSUE FOR CONST. F.H.'S 1-12
2					REV'D FOR REVISIONS
3					REV'D AS BUILT SEE REV. NO. 2 AS-BUILT
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					

T/O # 3401

TI APERTURE CARD

Also Available in Aperture


LOAD (LBS)	GRAV.	THER.	HYDRIC	OBE	SSE	DESIGN LOADS			MVTS (IN.)	THER.	SEISMIC	REFERENCE DRAWINGS	ISOMETRIC REV.
						PROG. UPSET	EMERG.	FLTO					
UP									VERT.				
DN									N-S				
N									E-W				
S									PIPE CALC.				
E									DATA POINT				
W									SUPPT. CALC.				
												OWNER TEXAS UTILITIES SE	
												PROJECT COMANCHE PEAK UNIT	
												ENGINEER GIBBS & H	
												2288	
												SL-37-76	

11"

ITEM NO.	NO. REQ'D.	DESCRIPTION	WT.	ASME OR ASTM
27	1	1/2" LSR 5"x5"		SA 36
28	1	T.S. 4"x4"x3/8"x12"		A SCO GR B
29	1	1" LSR 5"x6"		SA 36

FOR OFFICE AND  
ENGINEERING USE ONLY

★ CHANGE NOT MADE BY CMC




FIELD DRILL (4) 5/8" DIA HOLES ON 1 3/4" GAGE

EL. 841'-0"

EL. 840'-0"

NFS222



SECTION "B-B"

◆ ROUND OFF CORNERS

PIPING	REV.	ELECTRICAL	REV.	CODE/CLASS: III/2	DRAWN	DATE	CHK'D	DATE	APPV'D	DATE
2323-M		2323-E		PAINT CARROZINE #11						
STRUCTURAL	REV.	H.V.A.C.	REV.	ZONE						
2323-S		2323-M								
					P.O. NO. CP-0046 A.1			MFG. REL. TC-150 A		
SERVICES INC.					PRODUCTION ORDER			SERIAL NUMBER		SHEET
S NO. 1 & 2										2 of 3
LL INC.										
					2013			MK. NO. MS-1-151-037-C52R		REV. 2




**Brown & Root, Inc.**  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS

8607100243-13

# AS-BUILT

VENDOR CERTIFIED  
 DRAWING REV. NO. 2  
 BY Retrieved DATE 4.13.83

REV.	DATE	DR.	CHK.	APP.	DESCRIPTION
1	4/13/83	R	R		ISSUED FOR AS-BUILT REF. <u>PLAN 84428, R51DLA 7607, SEE</u>
2					VENDOR CERT. REF. <u>ST.N. 60119</u>





SECTION "C-C"

T/0# 3401

LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVTS (IN.)	THER.	SEISMIC		REFERENCE DRAWINGS	SOMETRIC REV.
						PERM.	EMERG.	PLTD.						
UP									VERT.				FAB. ISOMETRIC REV.	
DN									N-S					
N									E-W				OWNER TEXAS UTILITIES S	
S									PIPE CALC.				PROJECT COMANCHE PEAK UNI	
E									DATA POINT	2288			ENGINEER	
W									SUPPT CALC.	SL-37-76			GIBBS & P	

FIELD DRILL 1/8"  
HOLES THRU T.S.  
(TYP.)



DETAIL "13"

**TI  
APERTURE  
CARD**

*Also Available On  
Aperture Card*

**FOR OFFICE AND  
ENGINEERING USE ONLY**

8607100243-14

PIPING	REV.	ELECTRICAL	REV.	CODE/CLASS: III/2	DRAWN	DATE	CHK'D	DATE	APPV'D	DATE
2323-M		2322-E		PAINT CARBOZOL <sup>®</sup> II						
STRUCTURAL	REV.	H.V.A.C.	REV.	ZONE						
2323-S		2323-M			P.O. NO. CP-0046 A.1			MFG. REL. TC-158A		
SERVICES INC.		C.R.S.E.S.		<b>Brown &amp; Root, Inc.</b>	PRODUCTION ORDER			SERIAL NUMBER		SHEET
TS NO. 1 & 2				ENGINEERS AND CONSTRUCTORS						3 of 3
ILL INC.		88-1188		HOUSTON, TEXAS	2013			MX. NO. MS-1-151-037-C52R		REV. 2

11

1:8


TI APERTURE CARD

Also Available On Aperture Card

3.5"

1"


REV	DATE	DWN	CHK	APP	DESCRIPTION
1	1/4/80	MJP	JW		ISSUE FOR CONST. F.W.'S 1-2.
2	11/83	TJW	Q		REV'D AS NOTD. REF. CMC-12480 R-9. DCA-7607 (NTI) AS BUILT
3	5-7-83	WP	Q		REV'D AS BUILT RLP CMC #04515 R0 VENDOR CERTIFICATION REF IN 42740



LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVT (IN.)	NORTH THER.	SEISMIC		REFERENCE DRAWINGS
						PERM.	EMERG.	FLTD.			PERM.	EMERG.	
UP	—	—	—	—	—	923	1543		VERT.	497	497	BRHL 150	
DN	—	—	—	—	—	923	1543		N-S	273	273	CT-1-RB-30	
N									E-W	156	156	FAB. ISOMETRIC	
S									PIPE CALC.	AB-1-35A R-0		CT-1-RB-30	
E									DATA POINT	506		OWNER TEXAS UTILITIES	
W									SUPPLY CALC.	SC-73-35A		PROJECT COMANCHE PEAK	
												ENGINEER GIBBS	

ELEV. LKG. SOUTHEAST






ITEM NO.	NO. REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	FIN.	MIC.
1	1	TS 6x6x3/8		A500 GRB	L	
2	2	RFT-12-L15 ROD		SA-36	SS	
3	4	FXN-12 HVY. HEX NUT		A-307 GRB	SS	
4	1	TS-4x4x3/8		A-500 GRB	L	
5	1	2) SMA+3-RO ( ) SNUBBER		-	SS	
		( ) TRANSITION KIT		-	SS	
6	1	SPC-10-060 PIPE CLAMP		SA-36	SS	
7	2	FB 6x1x6 W/(1) 1 5/8" Ø HOLE ON E		SA-36	SS	
9	1	TS 3x3x1/4x21 LG.		A500 GRB	L	
10	2	FB 6x1x6 W/1 5/8" Ø HOLE AS SHOWN		SA-36	SS	
11	1	CS R1 THK. FER SEC B-B		SA-36	SS	
12	4	BSA 34-812 STUD ANCHORS		A-108 GR	SS	

\*FIELD TRIM TO SUIT\*

N B-B


FOR OFFICE AND ENGINEERING USE ONLY

NOTE:  
1) Locking devices for high strength bolts are not required per DCA 7607



SECTION A-A

SEE BRHL FOR HG R. LOCATION



163 FAB ISO NPSI-CT-1-RB-30

TO 4802

REV. 1	PIPING	REV. 6	ELECTRICAL	REV. 7	CODE/CLASS: II 2	DRAWN	DATE	CHK'D	DATE	APPV'D	DATE
3	2223-MI-0504-01	6	2223-E-0510-01	7	PAINT						
REV. 2	STRUCTURAL	REV. 2	H.V.A.C.	REV. 5	ZONE -						
9	2223-SI-0532	2	2173-MI-0552								
SERVICES INC.		CPSES		Brown & Root, Inc.		P.O. NO. CP-0046 A-1		MFG. REL. TC-271			
UNITS NO. 1 & 2		Brown & Root, Inc.		ENGINEERS AND CONSTRUCTORS		PRODUCTION ORDER		SERIAL NUMBER		SHEET	
HILL INC.		HOUSTON, TEXAS								10/1	
		28-1188				1516		MK. NO. CT-1-036-403-CT2		REV. 2	

FOIA-85-59

CC/167

8607100243-15


**TI APERTURE CARD**

Also Available On Aperture Card

REV	DATE	DWN	CNA	APP	DESCRIPTION
10-1	74	Ju	W	PC	ISSUE FOR CONST. F.W.'S 1-5
4-2	60	SM	W	PC	REV'D PER NPSI REV. 1
10-13	60	SM	W	PC	REV'D PER NPSI REV. 1
4-2	60	SM	W	PC	REV'D PER NPSI REV. 1

**AS-BUILT**  
 VENDOR CERTIFIED  
 DRAWING REV. NO. 4  
 BY *[Signature]* DATE 6-8-83

★ CHANGE NOT MADE BY CMC



T/D = 4802 \*FIELD TRIM TO SUIT

LOAD (LBS)	GRAV	THER	HYDRO	OBE	SSE	DESIGN LOADS			MVT (IN)	NO. OTHER THER POINTS	REFERENCE DRAWINGS	OWNER	PROJECT	ENGINEER
						PERM	EMERG	FLTD						
UP											20-1 ISOMETRIC	TEXAS UTIL	COMANCHE PEAK	GIBBS
DN											CT-1-RB-31			
N						100	153		VERT					
S						100	153		N-C	2,335	2,335			
E						95	145		E-C	1,723	1,723			
W						95	145		PIPE CALC.					
									DATA POINT	1517				
									SUPPLY CALC.	SC-83-37A1				


ITEM NO.	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM		MIC.
1	4	FHN-12 HVY HEX NUTS		A-307	CSS	
2	2	RFT-12-L13 ROD		SA-316	CSS	
3	2	SMF-1-BA MECH. SNUBBER W/ (2) <del>W/ (2) FORWARD BRACKET</del>			CSS	
4	1	M4x13		SA-316	L	
7	1	3/8" T.S. 4"x4"		A500 GR.B	L	
8	4	FB 4"x1"x4" W/ (1) 1 5/8" DIA HOLE ON CTR.		SA-316	CSS	
9	1	ASME III NAME PLATE OR ALTERNATE MARKING				
10	1	3/4" CSR PER SECT A-A		SA-316	CSS	
11	1	3/8" T.S. 4"x4"x3'-2" LG		A500 GR.B	L	
12	4	BSA 3/8"x3/2" HILTI KWIK BOLTS			CSS	
13	2	PUS-060 U-BOLTS B=11"		SA-316	CSS	
14	1	3" SCH 40 x 5 5/16" LG		SA-406 GR.B	L	
	2	PROVIDE TEMPORARY SPACER G-C = 14 3/4"				

AREAS OF WELD  
REQUIRES  
STRUCTURALLY  
ON BOTH SIDES

UF 5222

5222


4



FOR OFFICE AND  
ENGINEERING USE ONLY

UF 5222  
TYP (4)  
PLCS

NOTE  
Locking devices for  
high strength bolts  
are not required  
per DCA 7607



20A	30FPT 150	NPS1 CT-1-RB-31	CODE/CLASS: II/2	DRAWN	DATE	CHK'D	DATE	APP'V'D	DATE
REV 1	PIPING 2323-M-0508-01	REV 5	ELECTRICAL 2323-EI-0503	7					
REV 2	STRUCTURAL 2323-S-0532	REV 2	H.V.A.C. 2323-MI-0552	5					
Brown & Root, Inc.				P.O. NO. CP-0046 A.1		MFG. REL. TC-178 X			
Brown & Root, Inc.				PRODUCTION ORDER		SERIAL NUMBER		SHEET	
Brown & Root, Inc.				2668		MK. NO. CT-1-051-413-C72K		REV. 4	

FOIA-85-59

cc/168 8607100243-16

AS-BUILT

VENDOR CERTIFIED

DRAWING REV. NO. 3


BY J. [unclear] DATE 7-5-83

NOTE:  
1) Locking device  
high strength  
are not reqd  
per DCA 7

REV	DATE	BY	CHK	APP	DESCRIPTION
1	1-12	AM	RA	Q	ISSUE FOR CONST. F.M.'S
2	6-23	AM	RA	Q	REV'D AS NTP REC. CMC #
3	7-5	AM	RA	Q	FIELD DRILL HOLE IN CENTER OF TUBE

1/2" INSERT EXISTS (TYP)

FIELD DRILL 1 5/8" Ø HOLE IN CENTER OF TUBE (TYP)



ELEV. LOCKING SCIT FOR OFFICE ENGINEERING U

TO 4300

LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVT (IN.)	THER.	SEISMIC
						PERM.	EMERG.	FLD			
UP									VERT.		
DN									N-S		
N						724	109		E-W		
S						1244	1059		TYPE CALC DATA POINT SUPPT CALL.	AS-1-35A/20	
E						154	1053			5051	
W						272	575			SC-73-35A	

REFERENCE DRAWINGS	ISOMETRIC REV. 3
	ISOMETRIC REV. 2
OWNER	TEXAS UTILITIES S
PROJECT	COMANCHE PEAK UNI
ENGINEER	GIBBS & H

TI APERTURE CARD


Also Available On Aperture Card

ITEM NO.	NO REQ'D.	DESCRIPTION	ASME OR ASTM	P	MIC.
1	2	TS 6" X 6" X .375"	A-500GRB	L	
2	4	RFT-12 L15 ROD	A-36	KS	
3	8	FHN-12 HEAVY HEX NUTS	A-307GRB	KS	
4	2	FB 6" X 1" X 6" U1/8" HOLE ON E	A-36	PS	
5	1	TS 3" X 4" X 3/8"	A-500GRB	L	
6	1	TS 4" X 4" X 3/8"	A-500GRB	L	
7	1	TS 6" X 6" X .375"	A-500GRB	L	
8	2	FB 5" X 1/2" X 5"	A-36	PS	
9	2	TS 4" X 4" X 3/8"	A-500GRB	L	
10	1	TS 6" X 6" X 1/2"	A-500GRB	L	
11	1	ASME III NAMEPLATE			
12	1	TS 2" X 2" X 1/8"	A-500GRB	L	
13	1	FB 6" X 1" X 6" WITH 2 HOLES AS SHOWN	A-36	PS	
14	1	RFT-12 1/2" ROD L15"	A-36		
15	2	FHN-12 HEAVY HEX NUT	A-307GRB		
16	1	TS 2" X 2" X 1/8"	A-500GRB	L	
17	1	TS 2" X 2" X 1/8"	A-500GRB	L	
18	1	FP 5/8" X 6" X 6"	A-36	YES	

ACC'D  
CT-1-C-16-301R-2

EL. ED PER  
10-105 CTR  
1/8"

AND  
USE ONLY



103 SUPP 150 NPS-CT-1-EB 30

REV	DESCRIPTION	REV	CODE/CLASS
1	ELECTRICAL	1	2
2	PAINT	1	1
3	H.V.A.C.	1	1
4	ZONE	1	1

SERVICES INC.  
 TS NO. & 2  
 ILL INC.


**CPSES** Brown & Root, Inc.  
 ENGINEERS AND CONTRACTORS  
 HOUSTON, TEXAS  
 35-1199

DRAWN	DATE	CHK'D	DATE	APP'VD	DATE
PK	2/2/73	AK	2/13/73	ADP	9.4.79
P.O. NO. CP-0045 A-1		MFG. REL. TC-270			
PRODUCTION ORDER		SERIAL NUMBER		SHEET	
				10F2	
5.7	WK. NO. CT-036-204-C722			REV. 3	

AS-BUILT

VENDOR CERTIFIED  
DRAWING REV. NO. 3  
BY Etter DATE 7-5-83

REV	DATE	BY	CHK	APP	DESCRIPTION
1	7-5-83	ET	ET	ET	ISSUE FOR CONST.
2	7-5-83	ET	ET	ET	REV'D AS NOTED PER CMC 5/11/83 & DCAL (SEE NT) DELETED PER ET 7/5/83 BUILTY
3					VENDOR CERTIFIED PER GIB 6/27/80




**TI APERTURE CARD**

SECTION B-B


Also Available On Aperture Card TO 4002

CARD (LBS)	GRAV.	THER.	HYDRO	OBE	SSE	DESIGN LOADS			MVT (IN.)	THER.	SEISMIC	REFERENCE DRAWINGS	ISOMETRIC REV.	
						PERM.	EMERG.	FLTD.					FAB. ISOMETRIC	REV.
UP									VERT.					23
DN									N-S				C-1-28-30	23
N									E-W			OWNER	TEXAS UTILITIES SERVICE	
S									PIPE CALC	AB-1-35A/RD		PROJECT	COMANCHE PEAK UNITS	
E									DATA POINT	5051		ENGINEER	GIBBS & HILL	
W									SUPPL. CALC.	2-73-35A				

ITEM NO	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	MIC.
19	1	1" THK. P. (SEE SECTION "C-C")		A304	
21	4	1" x 12" SUPER HILTI-KWIK BOLTS			



FOR OFFICE AND ENGINEERING USE ONLY



153	SUPP.T 150	NPST-CT-1123-30								
PIPING	REV. 2323-E	ELECTRICAL	REV.	CODE/CLASS: <u>2/2</u>	DRAWN	DATE	CHK'D	DATE	APPV'D	DATE
3-M				PAINT <u>2323ENC</u>	<u>PK</u>	9-13-79	<u>PT</u>	9/13/79	<u>H</u>	9.14.79
STRUCTURAL	REV. 2323-M	H.V.A.C.	REV.	ZONE -	P.O. NO. CP-0046	A-1	MFG. REL. TC-270			
3-5					PRODUCTION ORDER		SERIAL NUMBER			SHEET
										20F2
					1517	MR. NO. CT-056-201-CT2K				REV. 3

CPSES Brown & Root, Inc. HOUSTON, TEXAS

APPENDIX

AH-10

U. S. NUCLEAR REGULATORY COMMISSION  
REGION IV

NRC Inspection Report: 50-445/83-27

Docket: 50-445

Construction Permit: CPPR-126


Licensee: Texas Utilities Generating Company (TUGCO)  
2001 Bryan Tower  
Dallas, Texas 75201

Facility Name: Comanche Peak, Unit 1

Inspection At: Comanche Peak, Unit 1, Glen Rose, Texas


Inspection Conducted: May 10-July 1, and September 9-22, 1983

Inspector:

  
\_\_\_\_\_  
R. C. Stewart, Reactor Inspector  
Reactor Project Section A

9-28-83  
Date

Approved:

  
\_\_\_\_\_  
D. M. Hunnicutt, Chief  
Reactor Project Section A

9-28-83  
Date

**TI**  
**APERTURE**  
**CARD**

Also Available On  
Aperture Card

~~2314187019~~  
500

FOIA-85-59

cc/170



DetailsA. Persons ContactedTexas Utilities Services Incorporated (TUSI) Employees

- B. G. Scott, Quality Engineering Supervisor
- G. Tanley, General Superintendent
- C. R. Hooton, Lead Civil Engineer
- R. M. Kissinger, Project Civil Engineer
- C. Fleming, Field Engineer

Brown & Root (B&R) Employees

- W. Wright, Project Welding Engineer
- B. Hauser, Field Engineering Superintendent
- C. Osborn, Tool Crib Foreman

The NRC inspector also contacted other licensee and contractor employees during the course of the inspection.

Note: Prior to this inspection, separate and independent investigative interviews were conducted by members of the Office of Investigation Field Office, Region IV (see attached Report A4-83-005, dated May 20, 1983).

B. Alleged Improper Construction Practices -

The NRC inspector, through an interpretative review of Mr. R. L. Messerly's affidavit, dated February 3, 1983, and his statements during his interview, April 14, 1983, determined that there were seven specifically alleged matters that required a detailed inspection effort to assess their technical merit and/or their potential impact on safety-related systems, component, and structures.

The seven areas of NRC concern which Mr. Messerly alleged to have occurred are summarized as follows:

1. That B&R employees drilled undocumented and unauthorized holes that cut through reinforcing steel and that such drilling and cutting was done at the direction of supervisors. Mr. Messerly provided a copy of a personal diary which, he alleged, reflected undocumented and unauthorized drilling.
2. That one of the main steam lines in Unit 1 was moved using the polar crane, thereby placing the section of pipe line in an unsafe stressed condition.
3. That he had cut through concrete reinforcing steel as directed by work instructions that were not in accordance with the approved method of documentation.

4. That tubular hanger/support steel anchor bolt holes were enlarged with a burning torch which he said was unauthorized.
5. That (Richmond) anchor bolts were not perpendicular to concrete surface and, therefore, unacceptable.
6. That stainless steel pipe attachments were welded on piping without an inerting purge.
7. That NRC Form 3, "Notice to Employees" was not posted on three main bulletin boards.

C. Inspection Findings

Allegation 1

1. Discussion

Mr. Messerly stated that during his assignment as foreman over the first crew responsible for drilling through concrete and reinforcing steel (rebar) during installation of cable tray and pipe hanger supports, he was ordered by his supervisors to loan out drill bits and/or drill undocumented and unauthorized holes through rebar.

To further support his allegation, Mr. Messerly named B&R employees responsible for the alleged improprieties and those who could substantiate his allegations. <sup>1/</sup>

In addition, Mr. Messerly provided the NRC staff a copy of his personal daily diary in which he logged drilling of holes for electric cable trays/hanger supports and rebar cutting details. He stated that this diary also identified holes he drilled, in or through, rebar and concrete without having documentation and authorization.

2. Chronological Findings 1978-1982

In order to determine the magnitude of implication and the resulting findings of Mr. Messerly's allegations.

<sup>1/</sup> See attached "Assistance to Inspection Report," Report A4-83-005, dated May 20, 1983

Allegation 41. Discussion

During Mr. Messerly's interview on April 14, 1983, and as stated in his February 3, 1983 affidavit, Mr. Messerly indicated that anchor bolt holes in tubular steel hanger supports were enlarged with a burning torch in order to compensate for the angularity of the previously installed (Richmond) anchor bolts, rather than redrill the holes.

2. Conclusion - Allegation 4

The results of the interviews of eight B&R employees, whose names were provided by Mr. Messerly and alleged to have knowledge concerning the improper use of cutting torches on hanger material, is contained in the attached "Assistance to Inspection Report." 1/ Two individuals stated that they recall an instance during a redesign modification of a hanger where it was discovered that holes had been enlarged by a burning torch, therefore, that portion of the hanger was scrapped.

During the onsite followup inspection concerning this matter, the NRC inspector discussed the use of cutting torches with the licensee's welding engineers and fabrication department engineers. The NRC inspector was informed that the use of cutting torches is not prohibited, provided it is done in accordance with prescribed B&R procedures and/or ASME, Section III, Subsection 4211 (thermal cutting). In the case of tubular hanger installations, the preferred method of correction for hole misalignment is to drill offset hole(s). This has been done on many occasions via the design change CMC document. The cognizant project engineer, responsible for approving and issuing CMC's for hanger modifications, stated that he knew of no CMC that involved authorization of hole enlargement or hole relocation on tubular hanger supports utilizing thermal cutting; however, thermal cutting has been permitted as necessary on other types of carbon steel supports, base plates, etc.

The NRC inspector conducted a walk-through of the containment building to examine accessible installed tubular hangers, specifically in the plant areas mentioned by Mr. Messerly during his interview. The inspector examined approximately 60 hangers at the 905' and 860' elevations in the containment building. Although limited in visual accessibility to each 1" or 1-1/4" drilled hole in each section of the tubular hangers, the NRC inspector did not find any hole that was enlarged by a cutting torch.

In addition, the NRC inspector discussed the subject of thermal cutting with the cognizant QC supervising inspector who was involved with inspections of tubular hanger installation during 1980-1982. The QC supervisor stated, that neither he nor any inspector discovered

an installed tubular hanger hole having been enlarged by a cutting torch.

Based on the lack of specificity by Mr. Messerly, the lack of corroborative testimony by Messerly's witnesses, interviews by the NRC inspector with cognizant site personnel, and the (limited) examinations of installed hangers, this allegation could not be substantiated.

There were no violations or deviations identified in this area of the inspection.

#### Allegation 5

##### 1. Discussion

During the interview on April 14, 1983, Mr. Messerly stated that Richmond Insert anchor bolts installed between elevations 905' and 860' in the reactor containment building have not been installed perpendicular to the concrete surfaces and, therefore, are unacceptable. In addition, Mr. Messerly stated, ". . . whatever angle it is, we would drill it at that angle so that it would come through the tube (i.e., tubular steel) and when it comes out the other side of the tube, it comes out as close to center as we could get it."

Mr. Messerly also stated, "Just go out there and pull any . . . studded rod out of there, pull three of them and two of them is [sic] crooked."

##### 2. Conclusion - Allegation 5

During the NRC inspector's onsite follow up of this matter, the inspector found that the B&R Procedure CP-CPM 9.10, "Fabrication of ASME-Related Component Supports," (original issue 12/28/78) is the primary construction installation procedure to be implemented and followed by the hanger installation crews. The "General Fabrication and Installation Requirements," Section 3.3.1.2 "Installation Tolerances," states in part,

##### "Field Fit Tolerances


"The tolerances discussed above shall be maintained for support fabrication activities. However, if during the installation, the support won't fit, the members may be "field fit" provided the piping and elevation tolerances shown below have been maintained. All other tolerances regarding axial location, alignment, and base plate attachments must be adhered to unless otherwise noted on the drawing."

# AS-BUILT

CT EL. 860'-0"

REV	DATE	DWN	CHK	APP	DESCRIPTION
1	1/13	MM	KK	MM	REV'D AS NOTED REF NPS1 REV 1 & C PPA 5900 SEE NT
2	1/13	CH	FB	CH	REV'D AS NOTED REF COMC 4350 R7 DCA7607 INT 2 AS BUILT
3	5/12/83	PH	MI	PH	VENDOR CERTIFICATION; REF. STN 632B3
4	8/12/83	IM	MB	IM	VENDOR CERTIFICATION; REF. 1106# M-100045
5	8/12/83	MB	MB	MB	VENDOR CERTIFICATION; REF. C PPA 54095 MK MS-1-150-010-0515

REV	DATE	DWN	CHK	APP	DESCRIPTION
1	1/13	MM	KK	MM	ISSUE FOR CONST
2	1/13	CH	FB	CH	SHEET 2 FW 35 WAS 1-4



T.D. 3401  
THERM.  
UPSET MVTS  
V = .276  
S = .276  
W = .646


## ELEVATION LKG NORTHEAST

LOAD (LBS)	GRAV.	THER.	HYDRO	OBE	SSE	DESIGN LOADS			MVTS (IN.)	NORM THER.	SEISMIC	REFERENCE DRAWINGS	REV.
						NORM UPSET	EMERG	FLTD					
UP						1684	1716		VERT.	~		BRHL 150	2
DN						349	381		N-S	~		MS-1-RB-014	2
N									E-W	~		FAB. ISOMETRIC	REV.
S									PIPE CALC.	AB-1-77 RZ		MS-1-RB-14	4
E									DATA POINT	2503		OWNER	TEXAS UTILITIES SE
W									SUPPT CALC.	SL-02-77		PROJECT	COMANCHE PEAK UNIT
												ENGINEER	GIBBS & HI

Also Available  
Aparts

ITEM NO.	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	PRM	MIC.
1	6	FHN-1" HVY. HEX NUT		A-307	CSS	
2	4	RWP-08 EXCEPT 1"x4"x4" STK.		SA515GR65	CSS	
3	1	TS 4"x4"x.375		A500GRB	L	
4	5	RAT-08 x 1'-1" LG. STUD		SA-36	CSS	
5	1	TS 4"x4"x.375		A500GRB	L	
6	1	TS 4"x4"x.375		A500GRB	L	
7	1	WT 4 x 8.5 x 1'-4" LG.		SA-36	L	
8	2	FB 2 1/4" x 3/8" x 4 3/8" LG. (SEE DET. 8)		SA-36	L	

REV	DESCRIPTION	DATE	DWN.	CHKD.	APP'D.
A	REV'D VENDOR CERT.	11-14-83	CMB	CBH	[Signature]
A	REV. VENDOR CERT. REF CMC 95134	12-6-83	CMB	CBH	[Signature]
9	Rev. Vendor Cert. REF: CPDM # 36095	2-6-84	Q	IFB	[Signature]
11	1	TS 4"x4"x 3/8" x 4'-6" LG.			A 500GRB L
12	1	TS 4"x2"x 1/4" x 2'-0" LG.			A 500GRB L
13	1	FB 3" x 1/2" x 5" PLATE (BY FIELD)			SA-36 PES
14	1	TS x 3" x 3" x 3/16" x 2'-8" LG.			A500GRB L
15	1	TS x 3" x 3" x 3/16" x 7" LG			A 500GRB L



\*\* = FIELD TRIM TO SUIT

4 EL. 855'-0"  
4" MS-1-150-1303-2


SECTION B-B CONTROL  
(PARTIAL)



FOR OFFICE AND ENGINEERING USE ONLY

SEE BRHL FOR HIGR. LOCATION

8607100243-19



110 SUPPIT, 150. NPSI-MS-1-RB-14

PIPE	REV.	ELECTRICAL	REV.	CODE/CLASS	DRAWN	DATE	CHK'D	DATE	APPY'D	DATE
2323-MI-0507	13	2323-EI-0501-02	10	PAINT CARBOZIM No. 11	RP	6/6/78		6/8/78	JG	4/9/78
2323-SI-0525	4	2323-MI-0551	5	ZONE -						

P.O. NO. CP-0046 A-1	MFG. REL. TC-113
PRODUCTION ORDER	SERIAL NUMBER
151	1062
MK. NO. MS-1-150-210-052R	REV. 9



Brown & Root, Inc.  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS

FOIA-85-59



CC/171

**II APERTURE CARD**

Also Available On Aperture Card

REV	DATE	OWN	CNK	APP	DESCRIPTION
1	10-5	MW	KR	[Signature]	REV'D AS NOTED, REF NPSI REV 1 & CPPA 5900 SEE NT 1
2	10-5	Q	UB	[Signature]	REV'D AS NOTED, REF CMC 43301 AT DCAT 007 NT 2, AS BUILT
3	9-2	Q	UB	[Signature]	VENDOR CERTIFICATION, REF GT 2 W 3235
4	8-12	Q	UB	[Signature]	REV'D VENDOR CERT. REF. NICK # M-100095
5	8-3	Q	UB	[Signature]	REV'D VENDOR CERTIFICATION. REF: CPPA # 34095, MK # MS-1-150-010-0-525
6	11-1	Q	UB	[Signature]	

REV	DATE	OWN	CNK	APP	DESCRIPTION
1	11/1/73	CM	KJ	[Signature]	ISSUE FOR CONST FW-1-2
2	11/5/73	CM	KJ	[Signature]	SHEET 2 FW-3-5 WAS 1-4



**SECTION C-C**


FIELD DRILL (4) 1/8" Ø HOLE  
 CHANGE NOT MADE BY CMC

LOAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVT (IN.)	SEISMIC		REFERENCE DRAWINGS	OWNER	PROJECT	ENGINEER
						NORM UPSET	EMERG	FLTD		THER.					
UP									VERT.			BRHL 150.	TEXAS UTILITIES SER	COMANCHE PEAK UNITS	GIBBS & HI
DN									N-S			MS-1-RB-014			
Z									E-W			FAB. ISOMETRIC			
S									PIPE CALC.			MS-1-R3-014			
E									DATA POINT	2503					
W									SUPPT CALC.	SL-42-77					


ITEM NO.	NO. FOUND	DESCRIPTION	WT.	ASME OR ACT.	P2, SE.	MIC.
33	1	T.S. 3"x3"x 1/4"		A 500GRB	L	
34	2	FB. 2 1/4" x 3/8" x 4 1/16" LG. (FIELD TRIM CUT SUIT)		SA-36	L	
35	1	WT 4"x9"x6" LG.		SA-36	L	
17	1	FP 1"x13"x13" (SEE DET. -17)		SA-36	P25	
20	4	3/8" X 6" HILT KWIK BOLTS (BYFIELD)		A/CB 52	CS5	
21	4	FB 4"x1"x4" W/1) 1/8" Ø HOLE ON CTR		SA515GR65	P25	
22	4	FHL-08 HV4 HEX NUT		A-307	CS5	
23	2	<del>257-08 L13</del>		<del>SA-36</del>		
24	1	TS 4"x4"x 3/8" X 2'-7" LG.		A500GRB	L	
25	2	FB 4"x1"x4" W/1) 1/8" Ø HOLE AS SHOWN		SA515GR65	P25	
26	1	TS. 3"x3"x 3/4" X 6'-0" LG.		A500GRB	L	
26	2	L 3"x3"x 3/8" X 2'-5" LG.		SA36	L	
29	1	L 4"x4"x 1/2" X 19" LG.		SA36	L	
30	1	L 3"x3"x 3/8" X 9" LG.		SA36	L	
31	1	L 3"x3"x 3/8" X 6" LG.		SA36	L	
32	2	L 3"x3"x 3/8" X 16 3/8" LG.		SA36	L	
CONT. ABOVE						

FOR OFFICE AND ENGINEERING USE ONLY


DATE	BY	CHK	APP	DESCRIPTION
1/14/83	WJ	CB	[Signature]	REVID VENDOR CERT.
12/6/83	WJ	CB	[Signature]	REV. VENDOR CERT. REF CMC 95134
2/6/84	Q	[Signature]	[Signature]	REV. VENDOR CERTIFICATION. REF CPM# 36095



DETAIL 8



SECTION D-D



DETAIL 34 (UPPER SIDE)

T.O. 34-01		110 SUPP'T 150.	LPSI-MS-1-RB-14	DRAWN	DATE	CHK'D	DATE	APP'VD	DATE
PIPING	REV.	ELECTRICAL	REV.	CODE/CLASS: II/2	RP	6/6/73	PN	6/8/73	JG 6/9/73
323-W		2323-E		PAINT CARBOSZING # 11					
STRUCTURAL	REV.	H.V.A.C.	REV.	ZONE					
323-S		2323-M							
VICES INC.		Brown & Root, Inc.		P.O. NO. CP-0046 A-1		MFG. REL. TC-113		PRODUCTION ORDER	
NO. 1 & 2		ENGINEERS AND CONSTRUCTORS HOUSTON, TEXAS		SERIAL NUMBER		SHEET		2 of 2	
L INC.		CPSES 35-1193		151		MK. NO. MS-1-150-010-C52R		REV. 9	


8607100243-20



8

REV	DATE	OWN	CHK	APP	DESCRIPTION
3	7-27-83	VM	R	Q	REV'D VENDOR CERTIFICATION, REF: CPPA# 79925
4	7-27-83	VM	R	Q	REV'D VENDOR CERTIFICATION, REF: CPPA# 79925
5	11-28-83	VM	R	Q	REV'D VENDOR CERT. REF, WPT 0633

**AS-BUILT**  
 VENDOR CERTIFIED  
 DRAWING REV. NO. 5  
 BY AWD DATE 28 NOV 83



**AT APERTURE CARD**

Also Available On Aperture Card

**NOTE**  
 Locking devices for high strength bolts are not required per DCA 7607  
 T.O.#1103


**PLAN**

OAD (LBS)	GRAV.	THER.	HYDRO.	OBE	SSE	DESIGN LOADS			MVT (IN)	THER. (1000)	SEISMIC	REFERENCE DRAWINGS
						NOAM	EMERG	FLTD				
UP									VERT.			224
DN									N-S	00A		
N						170	234		E-W	00A		
S						164	228		PIPE CALC.	AP-1-512/22		
E						164	228		DATA POINT	2260		
W						170	234		SUPPT CALC.	SC-70-56B		

3.5"

ITEM NO.	NO REQ'D.	DESCRIPTION	WT.	ASME OR ASTM	PRM.	MIC.
1	1	T.S. 4"x4"x 3/8" (BY FIELD)		A-500 GR. B	L	
2	1	T.S. 4"x4"x 3/8"		A-500 GR. B	L	
3	1	a) SRS-06-RO RIGID SWAY STRUT			CSS	
	1	b) SPC-06-040 PIPE CLAMP		SA-36	CSS	2
4	4	FB 1"x4"x4" W/ 1 9/16" HOLE ON E.		SA-36	P&S	
5	6	FHN-12 HVY. HEX NUT		A-307 GR. B	CSS	
6	3	RFT-12-L13 ROD		SA-36	CSS	
7	1	ASME III W/ PIPE PLATE				
8	1	T.S. 4"x4"x 3/8"x 5'-0" LG.		A-500 GR. B	L	
9	1	FB 1" THK. PER DET. #9.		SA-36	P&S	
10	6	FXJ-16 JAM NUT		A-307 GR. B	CSS	
11	2	FB 1"x4"x4" W/ 1 9/16" HOLE OFF CENTER AS SHOWN		SA-36	P&S	
12	6	FB 1"x4"x4" W/ 2 1/8" HOLE ON E.		SA-36	P&S	
13	6	FHN-16 HVY. HEX. NUT		A-307 GR. B	CSS	

FOR OFFICE AND ENGINEERING USE ONLY



FOIA-85-59

SUPPT 150.	NPS-CC-1-RB-58	CODE/CLASS: III/3	DRW/N	DATE	CHK'D	DATE	APPV'D	DATE
PIPING	REV. ELECTRICAL	REV. 10	SR	8/21/79	RP	9/12/79	HS PC	9.13.79
STRUCTURAL	REV. H.V.A.C.	REV. 5						
2323-S-0522	2323-MI-0551	PAINT CARBO-ZINCH	P.O. NO. CP-0046 A.1	MFG. REL. TC-267				
SERVICES INC.	CPSES	Brown & Root, Inc.	PRODUCTION ORDER	SERIAL NUMBER	SHEET			
ITS NO. 1 & 2	25-1195	ENGINEERS AND CONTRACTORS			1 OF 1			
HILL INC.		HOUSTON, TEXAS	2723	MK. NO. CC-1-233-001-C53R	REV. 5			

FOIA-85-59 cc/172 8607100243-21

1) \* CC-1-043-014-A 43K (REV 112)


ITEM #15 PUS 240 U-BOLT B=1'-8 1/2"

2) REV 0 +1 USED A S. CLAMP SPC 24-240

LOAD = ± 10891 (A+B) 15409 (C) PSA 35

3) RIA 16304, 16305

4) REV 0 + LATEST REV OF H613 IN ②



6) \* SI-1-AB037 EXAMPLE OF C2 WITH  
WITH A WRENCH ATTACHMENT

FOIA-85-59

cc/173

~~4~~ NCR

M-84-00754-5

~~4~~ DO CLASS 5 HGAS REQUIRE MILE OR  
CMTL OR COC CHECK PROCEDURE

~~4~~ CHECK CMC + DCA AT LEAST TW-X

~~4~~ PAPER CHANG

~~4~~ P M SUPPORTS

ROOT ~~11.1~~ 1" = .552 IN

~~4~~ MENSURE U-BAR ON DAVE'S HCR.

~~4~~ TALK TO CHALLIE ON CLASS 5 MAT

HFE SAYS NO.

~~4~~ COPIES OF SKETCHES FOR RM.

CP-CPM-7.1I

CT-1-126-025-Y45R

CT-1-YA-02

CT-1-073-001-Y45R NO MIC

---

R.M. G. 1925

SW-1-173-760-533R } MS-1-151-069-C52R }  
MS-1-150-013-C52R } \*MS-1-151-037-C52R }  
① CC-1-233-001-C53R } CC-1-234-016-C53R

CT-1-053-426-C52R } CC-1-215-036-C53R

CC-1-217-002-C53K } CC-1-206-001-C53R

CC-1-207-014-C53R } SI-1-121-004-C52R

② MS-1-150-010-C52S } FW-1-077-706-C52R

FW-1-097-031-C62R } FW-1-096-005-C62R

CH-1-030-012-C62R

CT-1-036-403-C72K = 1/8 - 7/10

CT-1-036-404-C72K = 1/8 - 7/10

CT-1-051-413-C72K = 7/10

Alt-10

operation without damage, it would probably not suffer damage in use since it gains strength rapidly while it is fresh and at a decreasing rate as it ages. All elements of the internals assembly were loaded at the 860-ft. elevation. The NRC Technical Review Team (TRT) inspected all the grouted plates at the 860 and 862-foot elevations and found no evidence of grout failure. While the allegation may be true, all the grout survived the initial loading without damage.

*are we  
using  
concrete  
consists.*

*It was alleged in*

~~Allegation AC-31~~ was that Richmond Insert anchor bolt inserts were installed between the 860 and 905-foot elevations in Unit 1 at angles not perpendicular to the concrete surface and that this non-perpendicularity was compensated for by use of tapered washers. The allegation referred to discrepancies as great as ten degrees. The allegation is dealt with in NRC Inspection Report 50-445/83-27, which was reviewed by the NRC TRT. Brown & Root Procedure CP-CPM 9.10, "Fabrication of ASME-Related Component Supports" states in Section 3.3.2:

*[Signature]*

Surfaces of bolted parts in contact with the bolt or nut shall have a slope of no more than 1:20 with respect to a plan normal to the bolt axis. Where the surface of a high strength bolted part has a slope of more than 1:20, a beveled washer shall be used to compensate for the lack of parallelism.

Thus, inserts may depart 3° from perpendicularity without any compensation and may depart further if beveled washers are used. The procedure mentions no upper limit on lack of perpendicularity, but that is controlled by the fact that the predrilled holes in the tubular steel hanger supports may not, in the case of safety-related supports, be enlarged without prior approval. The NRC TRT inspected 150 anchors between the 860 and 905-foot elevations and found no violation of the installation procedure. The allegation was correct in its assertion that some anchor inserts were not perpendicular to the concrete surface, but that in itself did not constitute a violation of the procedures.

*Let's discuss*  
Expand how the inspection was done

Allegation AC-36 was that trash from a Christmas party that took place on December 2, 3 or 4, 1978, was thrown in the form and covered with concrete while concrete was being placed on one of the two containment structures. The alleged incident is extensively discussed in NRC Inspection Report 79-20, which was reviewed by the NRC TRT. Reported interviews with alleged participants cast considerable doubt as to whether the party actually occurred. The NRC TRT obtained a printout of all concrete placements on the containment structures and determined that the only placement which occurred during the period reported was on the dome of Unit 1 on December 3, 1978. The TRT examined concrete placement package 101-8805-002, that contains a complete narrative of the placing operation by the placing inspector. Nothing unusual is noted. Both

The information preceding was given to CASE in the form of an affidavit on December 18, 1982. However, I did not want them to turn it in in the hearings or to turn it over to the NRC or the utility. I gave the information to some newspaper reporters, and an article ran in the FORT WORTH STAR-TELEGRAM on January 7, 1983. A copy of that article is attached. After that interview, I was shot at and have been on the run ever since and have been in touch with CASE a few times by phone from different states. One night when I came home, I found my cat; its head had been cut off smooth and its body was missing. Since the article appeared in the paper, I have had a front-end problem with three different vehicles (one truck and two cars); they all appear to have the same problem -- the nuts were just about to fall off the tie-rod ends. I've been scared to go back and sign up every six weeks for my unemployment because I'm scared someone may shoot me.

Some of the reasons I'm scared is because of the things I know about at Comanche Peak and another nuclear plant where I've worked, the South Port, North Carolina, Brunswick Project Nuclear Plant. As I mentioned before, there are weld seams around the Reactor Core and new spent fuel pools which we were told were not supposed to lose 1/2 ounce of contaminated liquid per year per seam. These seams were approximately 100 feet long; when we tested these seams, some of them were losing approximately 65 lbs. a minute. Instead of repairing some of these seams, the gauge was blocked off and pressure was put on the gauge only. When the inspector passed the weld seam, he thought the whole 100 feet was under pressure, not just a few inches. Also, some of the stainless liner walls broke loose from embedded plates that are in concrete walls which some of these plates were improperly welded. By these walls breaking loose they sprang out several inches from concrete wall; therefore, when refueling the reactors, the stainless steel liners were flooded with water. Of course, the weight of the water will push the liner walls back to the concrete. After the refueling process is over and water is drained out of the liner, the walls will spring back out, which could result in welds cracking or walls splitting. When I reported these violations to Brown & Root's Vice President, he told me he was not that concerned about the gauges being blocked off but he was concerned about the walls breaking loose. If I had told him of improper welding on these walls, I wonder if he would have been concerned at all? I feel these problems should be repaired.

Regarding Comanche Peak nuclear plant, there are safety violations such as torquing. For instance, quality control is supposed to verify the torquing of piping support that should be torqued at 130 lbs. The hanger is on a 20 foot ceiling with a scaffold built to them. Quality control is on the floor; the torque wrench is sent down to get QC to verify the number and setting of the torque wrench and carried back up and placed on the nut before torquing. QC hears a torque wrench click twice on each nut and buys off (approves) the hanger. What QC did not know was that the construction personnel had a second torque wrench and also had a nut welded on the scaffold. The second torque wrench was set at a low torque poundage such as 3 lbs. and they clicked it twice. Therefore, the nut on the hanger was never torqued; only the nut on the scaffold was torqued.

This is  
ATB-7  
AH-1  
AL

There were also violations such as pipe supports around the pipe. For instance, 3/16" clearance is supposed to be maintained on each side and on top and the pipe is supposed to be resting gently on the bottom of the support. For instance, a 2" pipe: a construction supervisor will climb on the pipe and get some of his crewmen so when QC comes to inspect the support, the weight will push the pipe to the bottom. In some cases, the pipe was binding so tight they would use a timber to jack the pipe down from the ceiling while QC bought off the pipe.

AH-1  
AL

R. Matheson #

AH-20

FOIA-85-59

CC/175



21  
AH  
In some cases, when they can't get the right clearance on each side of the pipe, they take a grinder and grind between the pipe and tube steel, which in some cases results in a reduction of wall thickness of pipe. I believe this could result in a rupture of the pipe. Construction has also tried to straighten a pipe support by using a sledge hammer; this is done quite often. An employee told me that while hitting on the hanger he also hit the pipe and caved in the side of the 2" pipe 1/2 inch or more. He reported it to his supervisor who said not to tell anyone and covered it up with I.D. tags.

AH-2  
neu

Another incident is improper personnel designing and engineering pipe supports. For instance, one helper told me while he was employed at the plant he designed many pipe supports for engineers. One day he wondered if they were using his engineering and if they were then checking his work, so he decided that he would design a hanger improperly and send it to engineering. The engineer passed it on to construction which built the hanger and it is presently installed improperly. The helper said that he did not want to go to any NRC hearing but he would love to have a showing and he could show many things if he was allowed to take investigators and actually show them the supports in the plant. Other helpers have also been involved in making major decisions for which they are not qualified.

AH-5

Another violation is a sensor in a dam was run over and broken by a bulldozer. I understand that these sensors are placed in the dam in a vertical position in order to tell whether the dam moves or not. This sensor was not removed or repaired. It was held up and dirt packed around it while being embedded in the dam.

The construction company, Brown & Root, lost a \$3 million contract at Crystal River Power Company in Florida, by a dam breaking, I was told by one of the Vice Presidents of Brown & Root. What concerns me is that if this dam breaks, they will lose more than a \$3 million contract; it will endanger many lives.

There is also a violation that concerns me regarding the use of rejected concrete material in the early stages of the plant when the reactor core was poured. A friend of mine told Brown & Root's Vice President's investigating crew that he was a front end loader operator at the concrete plant and one day a QC inspector told him that the concrete should be thrown away because it was hard and dried. The inspector walked away and my friend started throwing it away and a supervisor told him to put it back in and use it and they did.

AC-16  
AC-27

My friend also told the investigating crew of some type of sampling machine that tells whether there are good samples or bad samples in the concrete. It had a wire run to it while QC watched the machine to verify the use of good samples. Personnel would pull the wire to make it read good when it was not. My friend also told of other people that know of these violations and as far as I know, Brown & Root did not contact any of these people, but talked with one of their supervisors and his brother that worked at the batch plant; they, of course, told them that they knew nothing of this incident and since the superintendent is deceased, they did not see any further investigation of this incident. I am sure that the NRC is aware of this statement, because it was in the FORT WORTH STAR TELEGRAM article (attached). Undoubtedly, they are not concerned about the situation. I have not been contacted and neither has my friend.

AC-4  
neu

CONTROLLED COPY

COMANCHE PEAK NUCLEAR POWER PLANT  
ALLEGATIONS AND/OR INVESTIGATIONS SUMMARY

TASK NO.	ALLEGATION OR CONCERN	ACTION/STATUS	SOURCE		BN/DATE	CROSS REF./OR TRACKING SYSTEM NO.	COMPLETION CATEGORY 1-7 LEAD	SCHEDULE		ALLEGOR-DATE RECEIVED SOURCE DOCUMENT PAGE
			ANON	CONFID				OPEN	COMPLETE	
AQH-17	NCR written against a hanger has not yet been dispositioned. Concern that they will try to cover up with paper as oppose to fixing problem.			X			1 TRT			A-5 Interview 5/18 P. 35-36
AH-18	General foreman in charge of night crew pipe hangers is unqualified (no specific date, but predates 2/3/83).	Open		X			1 TRT			A-19 Affidavit of 2/3/83 P. 6-7
AQH-19	QC Inspection of torque on hanger bolts is deficient.	<del>Open</del>		X			1 TRT			A-4 Affidavit of 3/31/84 P. 3
AH-20	Violation of pipe support tolerances around the pipe.	Open		X			1 TRT			A-4 Affidavit of 3/31/83 P. 3
AH-21	Pipe supports straightened using a sledge hammer.	Open		X			1 TRT			A-4 Affidavit of 3/31/83 P. 4

*Delete. This x duplicates ATB-y*

cc/176  
FOIA-85-59

*12-21  
12-20*

Ch. Special others going + come forward.

Rowd 7C  
Shaw  
2 Masters

8/2  
1:20 PM



CPK Viol Conf. al 2 x by R4  
Dir. Review Specialist  
Trainer on CPPAC

QAPs / employees inspectors  
Certif Lead Arlstr  
Level II - Welks  
Mag / Ling Penet.

April 12 1982

Pictures

Talk by John Maxwell = / TVCCO  
Loose new material - cut up & found in lab  
Heat #s used from this material

since  
List of heat #s

- Tommie Clayette - W. of Webster  
have detailed information

- Laydon Yard - 6  
S. 009, S. 002, S. 003, S. 001  
CAZ-41 - initiated in 1980  
closed in 1982

- Eric Klimist - in Houston B&I  
EJ/v

Thomas entry became  
B&I Triple ordered = \$

Well... which was ordered more cheaply.

→ List of locations where - Japanese  
mutl. plant.

... offered priv. to Dick  
... 1985  
... FOIA-85-59

cc/177

\* Has legs - 995 welds  
 Will probably look us - 85 -  
 will not share leg books yet  
 Wants to see ~~at~~ our actions on what  
 we pursue.

Vendor welds on PZR Relief Tank  
 - vendor weld on hanger alongside tank  
 - 24" to 18" in line  
 Main only tanks in room  
 8:2 level on R.H. side  
 of PRT room.  
 Had various defects in welds - all out

C.A. - NCR written - never filed  
 Also NCR on T.R. going holes on it  
 of bolts broke

New Issue?

Many bolts were breaking under high torque  
 because 1-1 1/2" dia - 6" long.  
 Bill Hanson  
 Mike Foote

Test Frank work  
 in CTSI  
 Randy Smith  
 Richard Ice  
 No torque standards exist for many  
 bolts

+ Ike  
 S. P. E

TC

walk / ~~to~~ to look at  
Heat loss, Welds, Pipe work, Tests, Divg NDB, (C. L. & Hill),  
w/6 travelers

THW Call

3-man team from NCC

I call for report =

Mixture of various deficiencies in D weld & fitting.

After being allego. on 52 hangers

TUGCO looked at 51 - were deficient

file ref - sent to ASLB

Appl. Exhibit 122, 123, 124

July 26, 1982 ASLB Hogs

Sub 3 station at site & can help locate Randy Smith

Piping

N. Value Room Aux Piping  
8" SS velan line 2/3 of way back  
worker quenched welds w/ ice water

THW Call

back for 150

We will send back list.



TC

Audits to Tennessee (Wall & Tute

- Audit in January 1982 (SC 8)

with notes taking from TUGCO

Prime liability for TSTC bid audit  
Terry Walker for TUGCO

TC

3PM

M3407 on 810' Elev.  
Class II N. Valve Room  
Go to: ASME NCR M8200/61

Had ice water applied to it  
Viol. welding procedures

Also in the N. Valve Room  
Hangers - right behind & in front of valve  
+ 1 on back wall  
Look at vendor welds  
(part of list of 995 items)

Japanese material - no spec. in yet


S/C (W) supports - bottom level  
Look @ any joint on cross-T  
Looks like "dog bone"  
Mag. particle indications - welds  
Main supports for S/Cs  
NCR # \_\_\_\_\_ will provide

ZV Head welds  
He'll provide info

- Developing another list - will work.

7c

AH-3 SITE DOUBLE ORDERED MATERIAL  
 THEN TRANSFERRED THE HEAT NOS TO  
 UNAUTHORIZED JAPANESE STEEL  
 WHICH WAS THEN USED THROUGH  
 OUT THE PLANT. THE OTHER  
 STEEL WAS CUT UP AND EITHER  
 USED FOR SCRAP OR THROWN INTO  
 THE LAKE. THE MATERIAL WAS IN  
 LAYDOWN AREA #6. THE ALLEGED  
 SUPPLIER US WITH A LIST OF PEOPLE  
 TO TALK TO WHO MIGHT PROVIDE MORE  
 DETAIL. HE ALSO GAVE US A  
 LIST OF APPROX. 85 DOCUMENTS  
 PERTAINING TO H6B3 THAT WOULD  
 LEAD US TO SPECIFIC PROBLEMS  
 LEAS WITH H6B3 MATERIALS,  
 WELDING + FABRICATION.



CAT 32 1

HE SAID CAG #41 WAS OPERATIONAL  
 IN 1970 + CLOSED OUT IN 1972. HE  
 TOLD US TO CHECK 5001, 5003 + 5009  
 QC SITE SURVEILLANCE REPORTS.

FOIA-85-59  
 CC/178

7C

THE DOCUMENTS ON THE LIST ARE  
SUCH AS CDCE - TRANSFERS

2323 - ETC. - 60H. PIPING DWGS

SI - ETC. WIND RESTRAINTS. HE

ALSO SAID THAT IN THE NORTH VALVE  
ROOM, AUXILIARY BLDG GROUND FLOOR,

THERE IS AN 8" SS LINE 2/3 OF

THE WAY BACK INTO THE ROOM THAT

HAD THE PIPE WELDS BURNISHED

WITH ICE WATER AFTER WELDING


THE JAPANESE'S WERE WITH TEMPERED

AH-3

AH-7

AH-15

ARW-71



11192-11212

7C

4845-4892

PROCEDURES: CI-QAP-11.1-22 PARA 3.2.1.3  
CP-AP-50 CP-EP-9.2, CP-CPM-6.9C, CI-CPM-8.2,  
CI-CPM-8.1, CP-CPM-9.10, ACP-3,  
CP-CPM-9.1 CP-QAP 8.1

AH-7 USED SCRAP I-BEAM

AH-15 USED SCRAP THAT IN Q HANGERS - FIRST PR

ARW-71 HANGERS WITH AD. REST #3

AH-3

11192-11212



7c

QUESTIONS FOR [REDACTED]

- 1) WHAT HANGERS DID YOU USE SCRAP
- PIECE OF I-BEAM? WHAT AIDS, SYS
- TEA, AREA, ROOM, ETC?
- 2) WAS THIS DONE MORE THAN ONCE?
- WAS IT A RECURRING HAPPENING
- 3) DEFINE A SCRAP PIECE OF I-BEAM
- 4) WHAT MAKES IT SCRAP
- 5) CAN YOU IDENTIFY NON-Q TO Q

7c

QUESTIONS FOR [REDACTED]



- 1) DEFINE Q VS NON-Q MATERIAL
- 2) IS Q WHAT CONSIDERED Q.
- 3) DO YOU HAVE ANY SPECIAL HGR
- AND/OR AIDS, SYS TEAS, ELEV. ETC.

7c

QUESTIONS FOR [REDACTED]

- 1) CAN YOU IDENTIFY THE 20 HGRS IN
- QUESTION
- 2) WHAT MEANS LEVEL, SYS TEAS ETC.
- 3) DO ALL HGRS REQUIRE THIS

TALK TO



1 PM

FIRE PROTECTION HQS



1) AS ME CASE GIVES TO BOB O.E. TO  
SATISH KANADIVE, ED MORRIS

2) NOW AS ME CASE KANADIVE

IN TRAINER HOURS FROM THE ROOM

C.R.P.-5.0 P.V.8

3) TVS & BOB PURCHASED HAS COMPLETED

IN LATE 87 EARLY 82

4) QUALIFIED JAPANESE COULD BE BROUGHT

ALTHOUGH AT ONE TIME IT WAS NOT

ALLOWED.


5) TALKED TO



C.P.M.-9.10

RULE OF THUMB AT STAD UNDER 5'

6)



7) TACKLED TO [REDACTED]

ALL MATERIAL ON SITE USED FOR  
FASTENERS WILL HAVE AT LEAST  
NO. 6 BT 90-000-8.1 FROM BARBERS  
LANCASTER.

5) [REDACTED] STALL ON SITE WORKS  
FOR TUB CO ADDITIONAL TAKE IN BARBERS  
LANCASTER.

7) ITT-G SUPPLIED STEEL FOR  
SITE. SOME SUPPLIES COULD  
HAVE BEEN TUB CO & ITT STEEL.

10) [REDACTED]

11) TALK TO [REDACTED]

12) WORK AT CP-CPM-79

13) ORIGINAL F.P. # UP UNTIL 1 1/2  
YRS AGO DESIGNED THE SUPPLIES

1.) [REDACTED]

SAID THAT HE HAD NOT  
SEEN ANY IMPROVEMENTS ON SITE

BOTH ON TUB CO GENERATORS THE CO  
GIVE HIM MATERIALS WHICH HE THEN  
TYPED UP & GAVE TO C.E. FOR USE.

OFF. THEN THE P.D.'S 193600. WHEN  
THE MATERIAL COMES IN ON RECEIPT  
INSPECTION CHECKS IT OUT, USUALLY ON  
THE TRUCK. IF NO PAPERWORK IS PRE-  
SENT THE SHIPMENT IS <sup>HOLD</sup> STAGED UNTIL  
PAPER COMES IN. IF NO PAPER WITHIN  
A CERTAIN TIME, IT IS SOLD.

2/

[REDACTED]

SAYS

THAT ALL HGR MATERIAL CAME IN  
WITH CMTR'S. NO JAPANESE STEEL.  
HE DOES NOT GET ANY SCRAP AT  
THE WAREHOUSE FROM HGR'S SUCH  
AS PIECES OF STRUCTURAL STEEL.

3/

[REDACTED]

HGR

THE ONLY SCRAP HE

GETS IS USUALLY VARIOUS CANNON  
ITEMS, NO STRUCTURAL STEEL PIECES  
THE HECK OF THEM IS 5' +  
UNCLE IS SCRAPPED + SOLD.

4/ THESE TO

[REDACTED]

AT USGR

HE SAID THERE IS NO WAY TO USE  
NON-Q MATERIAL. THE MR IS USED  
TO GET Q-MAT FROM THE WAREHOUSE.  
ONCE AT THE SITE THE FIELD Q-MAT TO  
SUITS ARE MADE AND THE MATERIAL  
IS PUT ON THE MIL. THIS DOCU-  
MENT IS USED BY DC TO ASSURE  
PRIOR TO WELDING THAT THE CORRECT  
PIECE OF Q-MAT IS USED.

5)



ALLEGED WORKED FOR DC APPROX MAR-JUL 82  
1981 WAS WORKED ALL THAT WAS ORDERED WITH  
CFRS FOR VENDOR & MIL. ALL SITE SUPPLIES  
MAY BEHINDS AND REAR SUPPLIES WERE BE  
VENDOR GUARANTIES OR SITE SUPPLIES ON  
BOTH. AT ONE TIME THERE WAS NO MIL  
& THE DC HAD GIVEN OUT THE  
DRAWING & MR.

6/ ITT GRIFFIN DIO SUPPLY BOTH -  
STEEL COMPONENT SPD SUPPERS  
UNTIL 1980 OR 1981 ACCORDING TO  
DAVE POWERS @ ITT-G

7/ CHECKED NCR LOG BOOK 1/1/82-7/31/82

✓*	M-3117	2X2X <sup>1</sup> / <sub>4</sub> TS	NO HT#
	M-3127	CT-1-020-009-522K	
	M-3130R-1	MATERIAL EXCEPT W/O DOCUMENT	
✓*	M-3137	LOST TRAX ON TS	
	M-3152	SI-1-090-006-C41K	
✓*	M-3168	INSTALLED WITHIN PICKUP CS-1-158-027-542R	
	M-3200SR-1	CC-1-066-003-533R	MAT TRAX
✓*	M-3214	RC-1-018-021-C71R	BRICKWORK CUT W/O TRANSFER HT#
	M-3234	CS-2-037-005-A53R	UNAUTHORIZED MAT
	M-3241	CC-2-021-009-A33K	CHANGED HT#
	M-3254	AF-2-009-408-533S	HT# GROUND OFF
✓*	M-3345	RC-1-147-007-C81K	WITHIN MAT GRADE
	M-3346S	SI-1-031-071-532K	
✓*	M-3354R	MS-1-076-009-552K	HT# NOT VERIFIED

WRONG HT #  
✓\* 3379 CS-1-333-703-A53R  
✓\* 3412 HT # MISSING ON LOWER SUP  
\* 3427 DUPLICATE HT #  
NO HT # TRACE  
\* 3431 SW-1-129-045-A43R  
3508 CS-2-358-012-A53R

8.1 CHECKED ~~P-2 NUMBERS~~ ABOVE NCA'S

M-3117 AT WAREHOUSE A

2X2X1/4 TS ARRIVED ON SITE  
WITHOUT TRACEABILITY. RECORDS  
SHOW SHIPPING RECORD 35-1195  
11/01/82 SENDING BACK TO GULF  
FALCON INC

M-3137 ITEM #2 OF BR-X-206-700 -  
A 53R 3X3X1/4" TS INSTALLED  
WITHOUT HT #. DISPOSITION WAS  
TO SCRAP + REPAIR. B+R TR  
9/21/82 CUSES W/ NCA, WITH  
INSPECTION OF DEFECTED PIECE,  
MIL VERIFIES NEW PIECE

M-3168

CS-1-158-027-542R

DWG REQUIRES ITEM 3 TO  
BE S 3 X 5.7 BUT A 3 X 4.1  
CHANNEL WAS INSTALLED.

DISPOSITION WAS TO REMOVE  
ACCORDING TO IRN 113191, 127322,  
124741 (SCRAP + REBUILD)

B + R IR 4/29/82 DOCUMENTS

SAT 123 PRO RIA OF NEW

HBR. MIL INDICATES CORRECT

S 3 X 5.7

M-3214

PC-1-018-021-071R

4 BEARING PLATES 4 X 4 X 1 <sup>ITEM # 4</sup>

HAS DIFFERENT # IN PLATES N-

1115 WHERE VAULT DOCUMENTA-

TION SAYS IT SHOULD BE

N-1045. DISPOSITION IS TO

SALVAGE EXISTING R FOR CL203

HGBS + REPLACE PLATES B + R

IR DATED 3/31/82 DOCUMENTS

REPLACEMENT OF ITEM # 5

MIL SHOWS NEW PIECES WITH



HT # 303P76640.

M-3345

RC-1-147-007-C81K ITEM #9

HAS ALL VENDOR MARKINGS GROUND  
OFF + ANOTHER # AF 5703 HAS  
BEEN SCRIBED ON. DISPOSITION  
IS TO REPLACE WITH TRACE REAR

BIGT. BOLIA DOCUMENTS IN-

SPECIMEN OF NEW RA BIGT +

5/1/82

WEEDS. MIC DOCUMENTS NEW

HT # 5104 AF

M-3354R

MS-1-076-009-552K ITEM #12

WAS CUT + FABRICKED WITH UT O.C.

INSPECTION FOR HT # TRANS PER

PRON TO CHANG. DISPOSITION

WAS USE AS IS SINCE ENOUGH

RECORDS ARE AVAILABLE TO TRACE

THE PIECE. IT'S O.K.

M-3379

CS-1-333-703-A53R ITEM #2

353X 1/4 TS HAS NO DOCUMENTATION TO

VERIFY HT # 56788. DISPOSITION

TO REMOVE ITEMS 2, 6, & 7 + RE-

PLACE. BOLIA DOCUMENTS INSPECTION

OF NEW MAT. 5/14/82. MIC VEHICLES

~~NEW~~ NEW HT # D27500 K25908

M-3412 + 3427 - MATERIAL FOR C102

SUPPLIED WITH DUPLICATION OF  
HT #. DISPOSITION TO ASSIGN  
A SPECIFIC PL NUMBER TO A  
SPECIFIC HT #.

M-3431

SW-1-129-045-A432 NO HT#  
IN THE HP OR ON THE BASE PLATES  
ITEMS 708. DISPOSITIONED TO  
CHECK BOTTOM OF PLATE FOR HT#  
IF NONE WAS FOUND, REPLACE  
MAT. BORIA 5/28/82 DOCU-  
MENTS REMOVAL + REPLACEMENT  
OF ITEMS 708 WITH NEW MAT.  
MIL DOCUMENTS NEW HT#  
E48435

9)

REVIEWED CP-GAP-8.1

3.0 DESCRIBES RIR, HOLD TAB -  
MATERIALS EQUIP LOG, INSPEC-  
TION METHODS

3.8 DESCRIBES MAT STORAGE,  
+ LOSS OF IDENTITY + RECORDS

10) CHECK P.O.S FOR JAPANESE

	STEEL	RANDOM	SAMPLE	DATE	CP#
	SA-36	FT. WORTH, TX	Q.E	7-15-81	
OK	of	PLATE WILL BAMES STEEL			CPF-523-S
	SA-36	LITTLE ROCK, AR	Q.E	7-31-81	
OK	of	LS AFCD STEEL			CPF-529-S
	CROSBY	MONTRELO CAL	Q.E	6-1-81	
OK	of	MAT HERCBL/MCI DIV			CPF-551-S
	A-500	L.A., AR	Q.E	7-13-81	
OK	of	A-36 AFCD STEEL			CPF-599-S
	A-500	HOUSTON, TX	Q.E	7-13-81	
OK	of	GULFALOY			CPF-1000-S
	A-36		Q.E(CA)	8-7-81	
OK	of	AFCD			CPF-1025-S
	A-36	TWINSBORO, OH	Q.E	4-14-82	
OK	of	A-193 MILLS MLOY			CPF-1026-S
	A-36		Q.E	7-14-81	
OK	of	AFCD SUP 1-7			CPF-1830-S
	SA-240	SECAUCUS, NJ	Q.E	1-16-82	
OK	of	NPS1			CPF-1304
	A-36		Q.E	5-11-82	
OK	of	AFCD			CPF-1585

11) FOR MH-3 CHECKED CAR-41 5003

+ 5-009

CHECKED NCR'S

\* of M-2265 R. 1

ALL DOCUMENTATION IS PRESENT

COMC 35679, 33296, B&R 12 11/19/80,

MIL 11/19/80,

6) M-2326

SASIS FOR

OK PER ENGINEERING

SA 36

c) M-2324, 2308

WRONG HT # HOWEVER IT  
SEEMS OBVIOUS THAT THE CORRECT  
# CAN BE TAKEN TO THE MR.

\*

d) M-2318

ALL DOCUMENTS PRESENT BORIR  
REPAIRED STOUT ACC  
10/2/80, 11/21/80, CPM-9.12

e) M-2312

ALL DOCUMENTS PRESENT, BORIR  
7-18-80 RIR 12141, 13708, 13376,  
09152

f) M-2303

ALL DOCUMENTS PRESENT, CMC  
36600, BORIR 9/12/80

\*

g) M-2297

REPAIRED STOUT ACCORDING  
TO CP-CPM-9.12

hf M-2294

OK PER PAGR 515 FOR SA-36

\* hf M-2289

DOCUMENTS PRESENT, IR 7/2/80,  
B+R IR 9/25/80

\* hf M-2287

DOCUMENTS PRESENT B+R IR 2/1/81

hf M-2234

NCR WAS INCORPORATED IN ITS  
STATEMENT : OK

\* hf M-2248 R.2

DOCUMENTS PRESENT, B+R IR  
1/9/81

\* SPMT PAV BEEN IB BY RES

7c

package 15

Hangers P 1

CONTROLLED COPY

CONARCHE PEAK NUCLEAR POWER PLANT  
ALLEGATIONS AND/OR INVESTIGATIONS SUMMARY

TASK NO.	ALLEGATION OR CONCERN	ACTION/STATUS	SOURCE AIRM CODE ID	DN/DATE	CROSS REF FOR TRACKING SYSTEM NO.	COMPLETION CATEGORY 1-7**	SCHEDULE OPEN COMPLETE	ALLEGOR-DATE RECEIVED SOURCE DOCUMENT PAGE
1001	<del>General maintenance and inspection of the Hangers. The Hangers are in poor condition and need to be replaced. The Hangers are also in need of painting. The Hangers are also in need of repair. The Hangers are also in need of replacement. The Hangers are also in need of replacement. The Hangers are also in need of replacement.</del>	<del>Under Review</del>	<del>1001</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1002	<del>Hanger not secured with lock</del>	<del>Under Review</del>	<del>1002</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1003	<del>Defective Hangers did not have lock</del>	<del>Under Review</del>	<del>1003</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1004	<del>Deficient Hanger</del>	<del>Under Review</del>	<del>1004</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1005	<del>Active Fire Hangers</del>	<del>Under Review</del>	<del>1005</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1006	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1006</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1007	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1007</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1008	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1008</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1009	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1009</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1010	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1010</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1011	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1011</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1012	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1012</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1013	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1013</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1014	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1014</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1015	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1015</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1016	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1016</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1017	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1017</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1018	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1018</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1019	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1019</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1020	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1020</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1021	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1021</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1022	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1022</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1023	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1023</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1024	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1024</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1025	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1025</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1026	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1026</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1027	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1027</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1028	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1028</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1029	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1029</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1030	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1030</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1031	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1031</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1032	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1032</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1033	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1033</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1034	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1034</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1035	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1035</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1036	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1036</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1037	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1037</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1038	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1038</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1039	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1039</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1040	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1040</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1041	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1041</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1042	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1042</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1043	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1043</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1044	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1044</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1045	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1045</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1046	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1046</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1047	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1047</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1048	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1048</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1049	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1049</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>
1050	<del>Employees of labour substituted into Hangers</del>	<del>Under Review</del>	<del>1050</del>	<del>10/1/84</del>		<del>ART</del>	<del>OPEN</del>	<del>10-01-84</del>

7c 7c 7c

FOIA-85-59

CC/179



# Brown & Root, Inc.

REPORT NO. **09152**

QUALITY ASSURANCE  
RECEIVING INSPECTION REPORT

**70439--225**

UNIT <b>1E2</b>	SYSTEM <b>MECH</b>	COMPONENT <b>Stock For Hanger Assys</b>	IDENTIFICATION/SPIN NO. <b>N/A</b>	DWG / SPECIFICATION & REV. <b>GEH2323 MS46A Rev. 1</b>
P.O. <b>CP-0046A.1</b>	MRR <b>CP-3968</b>	CHARACTERISTIC INSPECTION: <b>QI-QAP</b> <del>0111-7.2-11</del> <b>74M 2-7-79</b>		
VENDOR <b>N.P.S. Industries, Austin</b>	QR <b>N/A</b>	SAT. <input checked="" type="checkbox"/> UNSAT. <input type="checkbox"/> NCR _____ HOLD TAG _____		
APPARENT RESPONSIBILITY FOR UNSATISFACTORY ITEMS:		B&R <input type="checkbox"/> VENDOR <input type="checkbox"/> TRANSPORTER <input type="checkbox"/> <b>N/A</b>		
DATE DEFICIENCY DISCLOSED _____				

ITEM	QTY.	DESCRIPTION/REMARKS
		660ft 4in. X 4in. X 3/8in Structural Tubing, A-500 Gr.-B 160 ft. Mic No: 145NT, and 500ft. Mic No. 497NTA
		1000ft. 6in. X 6in. X 3/8in Structural Tubing, A-500 Gr.-B 720ft. Mic No: 814NT, 48ft. MIC#: 734NT, and <sup>232</sup> 232ft. Mic#: 735NT.

QA RECEIVED  
DATE FOR REVIEW  
FILE NO.  
SUBFILE NO.  
**11-412**

BROWN & ROOT, INC  
RECEIVED  
FEB 15 1979  
INFORMATION  
FILED & NOTED  
**COPY**  
QUALITY ASSURANCE  
PPRV

Shipping Notice - TX-SN-7211/TDA

AUTHORIZED NUCLEAR INSPECTOR NOTIFICATION:  
 DATE: \_\_\_\_\_ TIME: \_\_\_\_\_ MEDIA: \_\_\_\_\_ N/A  INIT. **JH/11**  
 ANI WITNESS: SAT. \_\_\_\_\_ ☆☆ UNSAT. \_\_\_\_\_ ☆☆ WAIVED \_\_\_\_\_ DATE \_\_\_\_\_  
 ☆☆ ANI'S INITIALS REQUIRED

**FOIA-85-59**

STORAGE LOCATION: **Warehouse "B"**  
**Hanger Yard** TYPE: **"E"**

QC ENGINEER/INSPECTOR  
**John A. [Signature]**

DATE: **7-1-79**



# Brown & Root, Inc.

QUALITY ASSURANCE DEPARTMENT

QI-QAP-7.2-11

REVISION 0

FIGURE 1

"RECEIVING TUSI/G&H SAFETY RELATED EQUIPMENT"

70439--226

	SAT.	UNSAT.	N/A
1. Check documents received with shipment			
a. G&H Quality Assurance Release (QAR) obtained?	_____	_____	✓
b. Are "Review Checklist" items on QAR accepted?	_____	_____	✓
c. Was final inspection performed by TUSI/G&H?	_____	_____	✓
d. ASME Code Data Report obtained?	_____	_____	✓
e. Authorization for shipment?	✓	_____	_____
2. Equipment Identification			
a. Do Data Reports and Equipment Code Plate agree?	_____	_____	✓
b. Do Data Report & G&H QAR agree?	_____	_____	✓
c. Does Identification Tag/spin number compare with G&H QAR?	_____	_____	✓
3. Was there any damage?	✓	_____	_____
4. Authorized Nuclear Inspector notified?	_____	_____	✓
5. Applicable QC receiving tags applied?	_____	_____	✓

Comments:

*None*

QC Receiving Inspector

*John H. [Signature]*

Date *8 Feb 79*

INFORMATION

**COPY**

PPRV



MATERIAL RECEIVED RECORD

CP

Job No. 35-1195

COMANCHE PEAK S. E. S.

PAGE OF 1

MR NO. 3968

SHIPPED TO:  B & R  G & H  F & N  W  TUSI  OTHER

**79433-227** CP-0046A1

REQ. NO.

[Empty box for REQ. NO.]

VENDOR:

**NPS INDUSTRIES, INC  
AUSTIN, TEXAS**

DATE:

**1-26-79**

SHIPPER:

**S&B**

F.O.B.

**AUSTIN**

Partial  Complete

QUANTITY	UNIT	ITEM	MATERIAL DESCRIPTION	LOCATION
1000*	FL/IN		CONCRETE T.S.	W/2 ON REC
1	set		CONCRETE papers	

**NOTE: The shipment is inspected and there is no evidence of tampering, loss, or other visible damage.**

**BROWN & ROOT  
RECEIVED  
FEB 15 1979  
FILES NOTED  
QUALITY ASSURANCE**

**INFORMATION  
COPY  
PPRY**

A. Reel

RECEIVED BY:

**TUSI**

**THIS INSPECTION  
DOCUMENTED ON**

RIR NO. 9152

Q.C. CHECK BY	EXP.	PP	TEX PAK	UPS	PREPAID	COLLECT
					<b>YIX</b>	

**Sthan**

DELIVERING CARRIER

F B NO.	CAR NO.
<b>18306</b>	

Jan 1 1979

EXTRA

TEXAS UTILITIES GENERATING COMPANY

2001 BRYAN TOWER - DALLAS, TEXAS 75201

70439--228

QAA-182

TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK STEAM ELECTRIC STATION  
1981-83 2300MW INSTALLATION  
PURCHASE ORDER NO. CP-0046A.1  
AUTHORIZATION FOR SHIPMENT

By copy of this letter TUGCO Quality Assurance releases the following equipment to be shipped by NPS INC. AUSTIN, TX.

*Shipping ticket TX-SN-7211/TDA*

*660' 4" x 4" x 3/8" Str. Tubing A500 GR B*

*1000' 6" x 6" x 3/8" " " " "*

Final shipment inspected, QAR No. N/A

Final inspection waived

INFORMATION  
**COPY**  
PPRV

*[Signature]*  
TUGCO QA Inspector

2-7-79  
Date

nps

S  
H  
I  
P  
T  
O

Texas Utilities Services, Inc.  
C/O Brown & Root, Inc.  
Comanche Peak Steam Elect. Site  
Glen Rose, Texas

S  
O  
L  
D  
T  
O

Texas Utilities Services Inc.  
C/O Brown & Root Inc.  
Comanche Peak Steam Elect. Site  
Glen Rose, Texas

CP0046A.1 <small>PURCHASE ORDER NO.</small>	TUSI <small>PROJECT</small>
70439--229	

1/25/79 <small>DATE SHIPPED</small>	SIKES <small>CARRIER</small>	1 1 <small>PAGE OF</small>
6-Bundles <small>NO. BOXES</small>	<small>BILL OF LADING NO.</small>	<small>TRAILER/CAR NO.</small>  <small>F.O.B.</small>


ASSEMBLY MK. NO.	R E V	QTY	REMARKS
T.S. 4X4X3/8		660'	33 Pieces
T.S. 6X6X3/8		1000'	48 Pieces

ASSEMBLY MK. NO.	R E V	QTY	REMARKS

INFORMATION

COPY

PPRV



nps Industries, inc.

10420 metric boulevard  
austin, texas 78758  
telephone 512-836-4161

Date: **7-04-80**  
NPSI: TX-SN-7211/TDA

Reference: P.O. #CP0046A.1

CERTIFICATE OF COMPLIANCE


This letter shall certify that the materials supplied on the subject purchase order comply with the requirements as specified in that purchase order, and A.S.M.E. Section III, subsection NF, 1974 Edition, Winter 1974 Addenda, and Code Case 1644.

This material has been processed by NPSI in accordance with our Identification and Verification Program.

A.S.M.E. Quality Systems Certificate (Materials) Number N-2048, expires on February 24, 1981.

A.S.M.E. Certificate of Authorization (NPT) Number N-1883 expires on September 30, 1980.

Certified Material Test Reports Attached.



Yours Truly,

*Fred Robinson*

Fred Robinson  
Manager of Quality Assurance

GMH/lrw

**REGAL TUBE COMPANY**

7401 South Linder Avenue  
Chicago, Illinois 60638 U.S.A.

Regal Order No. 48278

Invoice No. \_\_\_\_\_  
**70439--231**  
Date 11-13-78

**TEST REPORT**

<p>Customer:</p> <p>NPS Ind. Inc. 10420 Metric Lane Formerly Running Bird Lane Austin, Tx 78758</p>	<p>Specification:</p> <p>6 Sq x 3/8 structural tubing ASTM A 500 77 Grade B</p>
---	---

HEAT NO.	CHEMICAL ANALYSIS, %									
	C	Mn	P	S						
63582 ✓ NPSI-AUSTIN MIC NO. <b>735NT</b>	.23	.75	.016	.029						
502187 NPSI-AUSTIN MIC NO.	.21	.96	.007	.019						
61861 ✓ <b>734NT</b>	.21	.80	.014	.021						

MECHANICAL PROPERTIES					
HEAT NO.	LAB NO.	YIELD STRENGTH PSI	TENSILE STRENGTH PSI	ELONGATION %	HARDNESS R <sub>b</sub>
63582 ✓ NPSI-AUSTIN MIC NO. <b>735NT</b>		51,400	60,000	40	
502187 NPSI-AUSTIN MIC NO.		66,900	76,300	31	
61861 ✓ <b>734NT</b>		60,200	67,300	24	

YIELD STRENGTH IS 0.2% OFFSET — ELONGATION IN 2 INCHES

Other Tests

DOCUMENT REVIEWED BY  
Q.A. WJ DATE 11/16/78

INFORMATION

Subscribed and sworn to before me a  
Notary Public in and for the  
State of \_\_\_\_\_ County of \_\_\_\_\_  
this \_\_\_\_\_ day of \_\_\_\_\_ 19\_\_\_\_

*J. Kal*

Metallurgist

# INDEPENDENCE TUBE CORPORATION

6226 West 74th St.  
Chicago, Illinois 60638  
(312) 496-0380

70439--232

December 12, 1978

Chicago Tube & Iron Co.  
2531 W. 48th St.  
Chicago, Ill. 60632

Attn.: Test Report Area

The following material shipped on your Order No. TS-0709 QA  
Invoice No. 15218, meets the requirements of ASTM A-500  
Grade B-77

NPSI-AUSTIN MIC NO. <b>814 NT</b>	6" sq. x 3/8"	Yield	<u>60070</u>	psi
	Heat #890427 ✓	Tensile	<u>65270</u>	psi
		Elong. 2"	<u>36.0</u>	%

<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>
.18	.90	.011	.011

DOCUMENT REVIEWED BY  
Q.A. WJ DATE 1/3/79

*B. A. Gontez*

Vice President-Materials

THESE TEST REPORTS APPLY TO  
Your Purchase Order AUS 1618  
Our Shipping # 8796 NO  
CHICAGO TUBE & IRON CO.

**COPY**  
PPRV

RECEIVED BY NPSI

S/N-7211

Sold to: NPS Ind. Inc. 10420 Running Bird Lane Austin, Texas 78758	Shipped to: <b>OCT 18 1977</b> Same AUSTIN, TEXAS	Date: 10-12-77
		Lab No. <b>70439-233</b>
Customer Order No. 7A1326 6769	Regal Order No. 039189 038798	Invoice No.

Specification:

Hollow-form electric welded structural steel tubing - ASTM - A-500-76 Grade B

Size	Gauge	Heat Number	%CHEMICAL ANALYSIS				Yield (psi)	Tensile (psi)	%Elong in 2"
			C	Mn	P	S			
4 sq	3/8	803030	.18	.74	.011	.019	61,400	64,600	23
NPSI-AUSTIN MIC NO. 145 N-T									

The chemical results shown on this report represent mill certifications of ladle analyses as furnished to Regal by our suppliers or actual results of tests performed on samples of tubing taken from production rollings of the material. The above tests were made in accordance with the standards of the American Society for Testing Materials, and results are on file at Regal Tube Company, a Copperweld Enterprise, 7401 S. Linder, Chicago, Illinois 60638.

DOCUMENT REVIEWED BY  
 Q.A. ABC DATE 12/2/77

INFORMATION  
 Metallurgist  
**COPY**  
 PPRV

**REGAL TUBE COMPANY**  
 7401 South Linder Avenue  
 Chicago, Illinois 60638 U.S.A.

RECEIVED BY CUSTOMER Order No. AUS 1512

JUL 18 1978 Regal Order No. 045948

AUSTIN, TEXAS Invoice No. \_\_\_\_\_

**TEST REPORT** **70439--234** Date 7-12-78

Ind. Inc.  
 Metric Lane  
 Austin, Tx 78758

Specification:  
 4 sq x 3/8 structural tubing  
 ASTM A 500 77 Grade B

HEAT NO.

CHEMICAL ANALYSIS, %

HEAT NO.	C	Mn	P	S						
	88 NPSI-AUSTIN MIC NO. <b>497NTA</b>	✓ .22	.64	✓ .007	✓ .019					

MECHANICAL PROPERTIES

NO.	LAB NO.	YIELD STRENGTH PSI	TENSILE STRENGTH PSI	ELONGATION %	HARDNESS R <sub>b</sub>
88	12936	✓ 70,000	✓ 71,600	✓ 23	

THIS IS 0.2% OFFSET — ELONGATION IN 2 INCHES

RECEIVED BY N.P.S.I

JUL 18 1978

AUSTIN, TEXAS

DOCUMENT REVIEWED BY  
 Q.A. AMH DATE 8-16-78

Subscribed and sworn to before me a  
 Notary Public in and for the State of \_\_\_\_\_  
 this \_\_\_\_\_ day of \_\_\_\_\_ 1978

INFORMATION  
**COPY**  
 PPRV

[Signature]  
 Metallurgist





**Brown & Root, Inc.**  
 QUALITY ASSURANCE  
 RECEIVING INSPECTION REPORT

REPORT NO. 12161  
 INDEXED

OWN  
 FILE NO. B.6  
 SUBFILE NO.

UNIT <u>1/2</u>	SYSTEM <u>MECH.</u>	COMPONENT <u>Pipe Hanger Stock</u>	IDENTIFICATION/SPIN NO. <u>N/A</u>	DATE	DWG / SPECIFICATION & REV. <u>B&amp;R-2323 M546A, Rev-2</u>
P.O. <u>35-1195</u> <u>30220</u>	MRR <u>92199</u>	CHARACTERISTIC INSPECTION: <u>QI-QAP 7.2-12</u> <u>11-27-79</u>		SAT. <input checked="" type="checkbox"/> UNSAT. <input type="checkbox"/> NCR _____ HOLD TAG _____	
VENDOR <u>NPSI</u> <u>Portland</u>	QR <u>N/A</u>	APPARENT RESPONSIBILITY FOR UNSATISFACTORY ITEMS: B&R <input type="checkbox"/> VENDOR <input type="checkbox"/> TRANSPORTER <input type="checkbox"/> <u>N/A</u>		DATE DEFICIENCY DISCLOSED _____	

ITEM	QTY.	DESCRIPTION/REMARKS
002	500ft	2 1/2" X 2 1/2" X 1/4" Angle, MIC No's - 300ft. A39 & 200ft. NA-235
003	150ft	2 1/2" X 2 1/2" X 3/8" Angle, MIC No. - NA246
005	20ft	6" X 6" X 3/4" Angle, MIC No. - NA224
007	250ft	3/4" Round Bar, MIC No. - NR-279
008	500ft	1" Round Bar, MIC No - R5
009	200ft	3 in X 5.7# I-Beam, MIC No. - NW-436
010	300ft	W8 at 17 lb Channel, MIC No. - W5
013	500ft	2" X 4" X 1/4" RECT. Tube, MIC No. - NT131
014	250ft	3" X 3" X 1/4" Sq. Tube, MIC No. - T149
015	60ft	4" X 6" X 1/4" Rect. Tube, MIC No. - NT206
016	100ft	8" X 8" X 1/4" Sq. Tube, MIC No's - 60ft. NT132 and 40ft. NT117
017	140ft	6" X 10" X 1/2" Rect. Tube, MIC No. - NT217

*This steel was measured & checked for ID markings  
 Results Acceptable.  
 For Class 2 Use, Items 2, 3, 5, 7, 8, 9, 16, & arc A-36, Items 13 thru  
 arc A-500G*

INFORMATION  
**COPY**  
 BROWN & ROOT,  
 RECEIVED  
 NOV 1979  
 FILES NOTED  
 QUALITY ASSURANCE

AUTHORIZED NUCLEAR INSPECTOR NOTIFICATION:  
 DATE: \_\_\_\_\_ TIME: \_\_\_\_\_ MEDIA: \_\_\_\_\_ N/A \_\_\_\_\_ INIT. JAM

ANI WITNESS: SAT. \_\_\_\_\_ ☆☆ UNSAT. \_\_\_\_\_ ☆☆ WAIVED \_\_\_\_\_  
 ☆☆ ANI'S INITIALS REQUIRED

STORAGE LOCATION: Iron Fab Shop TYPE: "E"  
 QC ENGINEER/INSPECTOR: John A. [Signature] DATE: \_\_\_\_\_  
 CC/181  
 QC - 1.1/3-1

**FOIA-85-59**



# Brown & Root Inc

QUALITY ASSURANCE DEPARTMENT

QI-QAP-7.2-12

REVISION 0


FIGURE 1

"RECEIVING MISCELLANEOUS STEEL"

12181

	SAT.	UNSAT.	N/A
1. Did all required documentation accompany shipment?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Is shipment packaged satisfactorily?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Are material markings in accordance with specification requirements?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Is certification adequate and accurate when compared to the applicable specifications?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Is there any damage?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Have all NDE requirements been met?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7. Was shipment accompanied by a B&R QA Department Conformance Certificate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Was the Certificate signed by a B&R Surveillance Specialist?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
If not, is a B&R QA Source Inspection Waiver Form available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Applicable QC Receiving tags have been applied	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Comments: None



QC Inspector John A. Merton

Date NOV 27 1979

# MATERIAL RECEIVED RECORD

COMANCHE PEAK S. E. S.

No. 35-1195

92199

PAGE 1 OF 2

MR NO. \_\_\_\_\_

SHIPPED TO: \_\_\_\_\_

B & R

G & H

F & N

W

TUSI

OTHER

P. O. NO. 35-1195-30220

REQ. NO. \_\_\_\_\_

FK 126778

VENDOR: \_\_\_\_\_

QA RECORDED

DATE: \_\_\_\_\_

**N.P.S. Industries, Inc.**  
**Secaucus, NJ**

RTR <b>L</b>	QA REVIEW
-----------------	-----------

**11-26-79**

SHIPPER: \_\_\_\_\_

ARMS

FILE NO. <b>8.1.10</b>	
SUBFILE NO. <b>92199</b>	

F.O.B. \_\_\_\_\_

**Same**

INDEXED

**SP/PPA**

Partial  Complete  DATE: \_\_\_\_\_

QUANTITY	UNIT	ITEM	MATERIAL DESCRIPTION	LOCATION
500	Ft	2	2-1/2" x 2-1/2" x 3/8" Angle (200 Ft. NT# NA-232 & 300 Ft. NT# A-39)	N/S Iron Fab Lay-down Yd. 16
150	Ft	3	2-1/2" x 2-1/2" x 3/8" Angle (NT# NA-246)	
20	Ft	5	6" x 6" x 3/4" Angle (NT# NA-224)	
250	Ft	7	3/4" Round Bar (NT# NA-279)	
500	Ft	8	1" Round Bar (NT# R-5)	
250	Ft	9	3/8" x 2-1/2" T Bar (NT# NA-246)	
300	Ft	10	1/2" x 170 Wide Flange (NT# N-5)	
500	Ft	13	1/4" x 2" x 4" Structural Tubing (NT# NT-131)	
250	Ft	14	1/4" x 3" x 3" SQ. Structural Tubing (NT# T-149)	
60	Ft	15	1/4" x 4" x 8" Rect. Structural Tubing (NT# NT-206)	
100	Ft	16	1/4" x 8" x 8" SQ. Structural Tubing (NT# 60 Ft.-NT-132 & 40 Ft.-NT-117)	
140	Ft	17	1/2" x 6" x 10" Rect. Structural Tubing (NT# NT-217)	
1	set		Certification Papers	

INFORMATION  
**COPY**  
 PPRV

BROWN & ROOT, INC.  
 RECEIVED  
 NOV 30 1979

FILES NOTED  
 QUALITY ASSURANCE!

Issued QA Rec.

RECEIVED BY: <b>Carl Bryce</b>	G.C. CHECK BY	EXP.	PP	TEX PAK	UPS	PREPAID	COLLECT
--------------------------------	---------------	------	----	---------	-----	---------	---------

THIS INSPECTION  
 DOCUMENTED ON

Express Transit

08 11-26-79  
 Hanger Dept.

FB NO. \_\_\_\_\_ DELIVERING CARRIER CAR NO. \_\_\_\_\_

RIR NO. 12161

#7170

MATERIAL RECEIVED RECORD

PAGE \_\_\_\_\_ ORDER NO. \_\_\_\_\_

QUANTITY	UNIT	ITEM	MATERIAL DESCRIPTION	LOCATION
			NOTE: RECEIVED IN GOOD CONDITION EXCEPT AS NOTED.	
			NOTE: SHORTAGE OF 250 SQ. FT ITEM 12, 1/4" PLATE, SEE 0520 70/400	

INFORMATION  
**COPY**  
 PPRV

# Brown & Root, Inc.

## QUALITY ASSURANCE DEPARTMENT CONFORMANCE CERTIFICATE

PROJECT: COMMANCHE PEAK      JOB NO.: 35-1195      UNIT 1 & 2      PAGE 1 OF 1

(1) VENDOR: NPS INDUSTRIES, INC.      (2) ADDRESS OF VENDOR FACILITY: 2750 SW MOODY PORTLAND, OREGON 97201

(3) PURCHASE ORDER NO.: 35-1195-30220      (4) SPECIFICATION NO.: N/A      REV.:      (5) DRAWING NO.: N/A      REV.:

(6) ITEM DESCRIPTION(S): SEE SHIPPER #NPSI-3667/NAP      (7) NO. OF ITEMS: 19      (8) NO. RELEASED: 13

(9) COMPLETE:       YES       NO

(10) SERIAL OR IDENTIFICATION NO(S):

ITEM #2 MIC #NA-232 ✓	ITEM #12 MIC #NF-1112 ✓
"   MIC # A-39 ✓	ITEM #13 MIC #NT-131 ✓
ITEM #3 MIC #NA-246 ✓	ITEM #14 MIC # T-149 ✓
ITEM #5 MIC #NA-224 ✓	ITEM #15 MIC #NT-206 ✓
ITEM #7 MIC #NR-279 ✓	ITEM #16 MIC #NT-132 ✓
ITEM #8 MIC # R-5 ✓	"   MIC #NT-117 ✓
ITEM #9 MIC #NW-436 ✓	ITEM #17 MIC #NT-217 ✓
ITEM #10 MIC #W-5 ✓	

Records checked (✓) below are being transmitted with this certificate as required by the Brown & Root Document Data Sheet.

- |                               |   |   |   |
|-------------------------------|---|---|---|
| (11) RECORDS TRANSMITTAL LIST | <input checked="" type="checkbox"/> Material Certifications | <input type="checkbox"/> Operating Elec. Test Records     | <input type="checkbox"/> Visual Inspection Records    |
|                               | <input type="checkbox"/> Heat Treat Records                 | <input type="checkbox"/> Non-Operating Elec. Test Records | <input type="checkbox"/> Dimensional Inspect. Records |
|                               | <input type="checkbox"/> RT Film & Records                  | <input type="checkbox"/> Pressure Test Records            | <input type="checkbox"/> Cleanliness Records          |
|                               | <input type="checkbox"/> PT/MT Records                      | <input type="checkbox"/> Seat Tightness Test Records      | <input type="checkbox"/> Painting Records             |
|                               | <input type="checkbox"/> UT Records                         | <input type="checkbox"/> Performance Test Records         | <input type="checkbox"/> Packaging Records            |
|                               | <input type="checkbox"/> Approved Stress Report             | <input type="checkbox"/> Weld. Personnel Qual. Certs.     | <input type="checkbox"/> Spare Parts List             |
|                               | <input type="checkbox"/> Approved Design Analyses           | <input type="checkbox"/> NDE Personnel Qual. Certs.       |   |
|                               | <input type="checkbox"/> Special Handling Instruc.          | <input type="checkbox"/> Nameplate Facsimile              |   |
|                               | <input type="checkbox"/> Operating Manuals                  | <input type="checkbox"/> Code Data Report(s)              |   |

Deviations:       None       Listed Below

(12) REMARKS: INFORMATION  
COPY  
PPRV

(13) VENDOR CERTIFICATION: THE VENDOR CERTIFIES that the item(s) described above are in conformance with the requirements of the Brown & Root Specification with the approved deviations listed above; are suitable for the purpose intended; are free from defects in design, workmanship, and materials; and are new and of specified quality. A copy of this completed Conformance Certificate will be included with the bill of lading and shipped with the item(s) to Brown & Root, Inc. at the address designated in the procurement documents.

VENDOR AUTHORIZED SIGNATURE: [Signature]      TITLE: QA MANAGER      DATE: 11 / 12 / 79

RELEASE STATEMENT: The Vendor has certified that the items above meet all contractual requirements. Brown & Root has reviewed evidence supporting this Certificate and, except as noted under "Remarks" above, has verified conformance to requirements. This Certificate does not waive any rights Brown & Root may have under the Purchase Order including the right to reject the item(s) upon discovery of deficiencies during or after arrival at destination.

Final Surveillance:       Performed       Waived

SIGNATURE OF B&R SURVEILLANCE SPECIALIST:      DATE:      SHIPMENT WAIVER NUMBER: SW-1015      DATE: 11 / 15 /



# Brown & Root, Inc.

S. W. 1015

QUALITY ASSURANCE DEPARTMENT

## SHIPMENT WAIVER

PROJECT: CPSES JOB NO.: 35-1195 UNIT 142 PAGE 1 OF 1

TO: N. P. S. Ind., Inc. Attn. Jo Ann Souders  
2750 S. W. Moody, Portland OR. 97201

REFERENCE: Purchase order/subcontract number 35-1195-30220;  
our telephone conversation this date concerning shipment waiver.

Gentlemen:

Confirming the telephone conversation between your Mr. Jo Ann Souders

and our Mr. Ron Meisner as referenced above, we have waived final examination at your facility of the following items only:

Order Item No.	Qty.	Description
Item 11	500ft.	L 2 1/2" x 2 1/2" x 2 1/2" ASME-SA-36
"	150ft.	L 3 1/2" x 2 1/2" x 2 1/2" "
"	20ft.	L 3 1/2" x 2 1/2" x 2 1/2" "
"	250ft.	L 3 1/2" x 6" x 6" "
"	500ft.	Round Rod 1/2" ASME-SA-36
"	200ft.	" " " " " " " "
"	300ft.	I-Beam 3 @ 5.7 " " " "
"	250 sq. ft.	WB # 17 105.1ft. wide flange ASME-SA-36
"	500ft.	12 1/2" ASME SA-615 Gr. 65 or ASME-SA-36
"	250ft.	2 1/2" x 2 1/2" x 4" STRUCTURAL TUBING ASTM A-500 Gr. B
"	60ft.	2 1/2" x 3 1/2" x 3 1/2" " " " " " "
"	100ft.	2 1/2" x 4 1/2" x 6" " " " " " "
"	140ft.	2 1/2" x 8" x 8" " " " " " "
"		2" x 6" x 10" " " " " " "

Shipment of the above described items must be accompanied with Brown & Root, Inc. Form QA-045 titled "Quality Assurance Department Conformance Certificate" properly completed and signed by you. Further, this shipment waiver does not waive any rights Brown & Root may have under this purchase order including the right to reject the item(s) upon discovery of deficiencies during or after arrival at destination.

Sincerely,

BROWN & ROOT, INC.

J. P. Clarke III

J. P. Clarke III  
Vendor Surveillance Supervisor

INFORMATION  
COPY  
PPRV

JCP:bj  
cc: J. P. Clarke III  
B&R Site Receiving Insp. Dept.  
B&R Site Purchasing Dept.  
V53.0-1



# nps Industries, Inc.

2750 S.W. Moody  
Portland, Oregon 97201  
Telephone 503-226-1300

DATE: 11-12-79  
NPSI: 8667/NAP  
PAGE 3 OF 3


## CERTIFICATE OF COMPLIANCE

CUSTOMER: BROWN & ROOT INC.

PURCHASE ORDER: 35-1195-30220

We certify that the Items furnished on your P.O. #35-1195-30220, NPSI Shipping Notice #8667/NAP are in conformance with ASME III Subsection NF 2000, Class 2, Winter 1974 Addenda and the Material Specifications listed:


ITEMS: 2, 3, 5, 7, 8, 9, 10, 12 SA/ASTM A36  
ITEMS: 13 thru 16 A500 GR. B CODE CASE 1644-7

  
MANAGER OF QUALITY ASSURANCE

QUALITY SYSTEMS CERTIFICATE (MATERIALS)  
NUMBER N-2324-1  
EXPIRES ON JULY 13, 1982

### Distribution:

Document Control  
Procurement Dept.  
NPSI-NJ  
Quality Assurance



ELECTRIC STEEL Manufactured by  
 NORTHWEST STEEL ROLLING MILLS, INC.  
 411 - Duane - Portland, ORE. • 503-271-1111 • 97208-0001 • 1977

NA-232 ~~2817~~  
 DATE 3/17/78

PHYSICAL and CHEMICAL TESTS

DATE ASTM A-36-75 CLIENT GILMORE STEEL CORP. \*PORT  
 SPECIFICATION 7803-12 P.O. BOX 03008  
 CITY PORTLAND, OREGON ZIP 97203

SECTION	HEAT NO.	SIZE	YIELD SQUARE INCH	TENSILE SQUARE INCH	ELONG. 8 IN.	BEND	CHEMICAL ANALYSIS				REMARKS
							C	MN	S	P	
A36	E653	1-1/2X 1-1/2X 3/16 ANG				OK	15	.44	.014	.003	
A36	0742	2-1/2X 2-1/2X 1/4 ANG	48,300	68,210	28.0	OK	20	.54	.030	.006	
A36	0817	2-1/2X 2-1/2X 1/4 ANG	48,780	63,040	27.0	OK	18	.60	.022	.006	

INFORMATION  
**COPY**  
 PPRV

ASME SA 36  
 8/10/78

8894 NA 232

Manufactured by NORTHWEST STEEL ROLLING MILLS, INC.

By *V. Tester*





PRODUCTION DEPARTMENT - METALLURGICAL

# United States Steel Corporation

7081

TEST REPORT OF

BARS, CARBON STL

WORKS CANY

U.S.S. ORDER NO. SGQ8510

LOAD TALLY OR INVOICE NO. 154-12753

CUSTOMER ORDER NO. 7/29/74

CAR OR TRUCK NO. MILN 92457

SHIPPER NO. & DATE 402456 3/15/75

# A-39

U S STEEL SUPPLY DIV  
UNITED STATES STEEL CORP  
P O BOX 3807  
SEATTLE WASH 98124

SHIP TO

U S STEEL SUPPLY DIV  
UNITED STATES STEEL CORP  
2345 N 4 NICOLA STREET  
PORTLAND OREG

HR BARS CARBON MQ ASTM A36-70A MECH REQ CUST INFO  
MILOR CODE PINK

CR

09-002071

MILL

C300

WE HEREBY CERTIFY THAT THE CHEMICAL ANALYSIS AND/OR TESTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

SIGNATURE D.A. HAYES, CH. MET.


DATE 3-17-75

ITEM NO.	HEAT NO.	TEST OR PIECE IDENTITY NO.	MATERIAL DESCRIPTION				WEIGHT	YIELD STRENGTH	TENSILE STRENGTH	ELONGATION		REDUCED AREA
			NO. PCS.	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH				IN. G.	IN. 2.	
05	B4R355		160	L2-1/2X 2-1/2X3/16	3.0	20'	9800	* 38900 * 46500	63900 64300	32.0 31.0		
06	B4R365		147	L2-1/2X 2-1/2X1/4	4.1	20'	11560	* 38900 * 46500	63900 64300	32.0 31.0		
06	<b>B4R365</b>		141	L2-1/2X 2-1/2X1/4	4.1	20'	11040	* 46500 * 38900	64300 63900	31.0 32.0		
08	B3R376		172	L2X2X1/4	3.1	20'	11000	* 45700 * 47800	65300 64400	24.5 25.0		

SA 36

B&C/G.E.R.I. JOB #215

CHECKED BY RWT DATE 8/5/76



*Op*

*8/5/76*

THIS TEST REPORT CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE

Fe	C	Mn	P	S	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Ti	Ch	Co
		49	009	024												
		50	007	023												

BETHLEHEM STEEL CORPORATION  
METALLURGICAL DEPARTMENT

(NA-246)

~~125~~

46014 (8-72)

DATE SHIPPED 3/30/78	SHIPMENT NO. 3212-0294-1/3, 2/3 & 3/3	CARRIER, INITIAL AND NO. (SP) BN 560070	PLANT 50 SAN FRANCISCO CA
-------------------------	---	--	------------------------------

SOLD TO  
GILMORE STEEL CORP  
1901 POPLAR AVE  
OAKLAND CA 94607

SHIPPED TO  
GILMORE STEEL CORP  
1960 CYPRESS ST  
OAKLAND CA 94607

GILMORE STEEL CORP.  
APPROVED BY:  
Q. C. CLERK QCF  
DATE 3/1/78

REPORT OF MECHANICAL AND CHEMICAL TESTS

Customer's Order No.	Section Slab or Mill Order No.	Heat No.	Description	Thickness	Yield Point	Tensile Strength	Elong %	Red %	Bonds	CHEMICAL ANALYSIS				Specification or Remarks
										C	Mn	P	S	
3-62-78		10X533	L 2 1/2 X 2 1/2 X 3/8		42,030	67,430	27			.22	.50	.009	.026	ASTM A36-75
		11X719	L 2 1/2 X 2 1/2 X 5/16		45,520	69,510	24			.23	.49	.008	.032	"
		2P553	"		45,370	67,670	26			.23	.55	.012	.041	"
		3X575	L 2 1/2 X 2 1/2 X 3/16		44,460	65,050	27			.19	.47	.011	.050	"
		2A398	L 2 1/2 X 1 1/2 X 3/16		49,450	72,340	24			.23	.49	.009	.034	"
		2X202	"		47,460	67,460	26			.20	.48	.019	.036	"
		11X462	L 2 X 2 X 3/8		42,050	68,150	27			.22	.46	.010	.026	"
										.23	.50	.010	.048	"
										.23	.49	.006	.040	"
										.23	.53	.025	.040	"
										.21	.49	.011	.038	"
										.23	.53	.009	.030	"
										.24	.49	.015	.034	"
			10A201	1/4 X 7		51,570	74,020	23			.23	.50	.008	.020
		11A787	1 X 8		42,940	71,770	22			.24	.49	.008	.020	M1075/1023
		11A516	3/4 X 8		38,320	63,540	27			.22	.50	.009	.033	ASTM A36-75
		2A652	3/16 X 3							.10	.51	.007	.041	C.15 MAX COMM QUAL

ASME SA-36

AW 9/5/78

9099N NA-246

INFORMATION  
 COPY

JOE DUNLAP

SUPT. REBAR, FABRICATING, PLACING TR

I certify the above results to be correct as contained in the records of the company.

BETHLEHEM STEEL CORPORATION  
METALLURGICAL DEPARTMENT

NA-224

41110 (4-73)

DATE SHIPPED

6-8-78

SHIPMENT NO.

3301-2878

1/7 to 7/7

CARRIER, INITIAL AND NO.

565946

PLANT

SEATTLE

INFORMATION  
**COPY**  
PPRV

SOLD TO

GILMORE STEEL CORP.

SHIPPED TO

PORTLAND

REPORT OF MECHANICAL AND CHEMICAL TESTS

Customer's Order No.	Section Slab or Mill Order No.	Heat No.	Description	Thickness	Yield Point	Tensile Strength	Elong. %	Red. %	Bends	CHEMICAL ANALYSIS				Specifications or Remarks		
										C	Mn	P	S			
7803-15	UJ 234-1185*			ASTM	A36-75		8"									
		331C539	C 6x8.2#		51690	66800	25.0		ok	.22	.45	.007	.025			
7803-52	UJ 234-1220B*				47960	66650	26.0		ok	.23	.45	.013	.043			
		330C355	C 6x8.2#													
7804-22	UJ 234-1250				42130	62800	25.0		ok	.18	.42	.007	.036			
		331A861	L 8x4x1/2													
		331B286	L 8x4x1/2		41910	66760	27.0		ok	.21	.45	.012	.022			
7804-22	UJ 235-1250A				<del>41470</del>	<del>65680</del>	<del>28.0</del>		<del>ok</del>	<del>.23</del>	<del>.44</del>	<del>.009</del>	<del>.027</del>			
		330C383	L 6x6x3/4													
		330C392	L 6x6x3/8		41110	58890	28.0		ok	.21	.42	.007	.020			
		330C394	L 6x6x5/16		41700	60110	28.5		ok	.18	.46	.008	.020			
7804-22	UJ 234-1250B				42660	62060	26.5		ok	.19	.40	.007	.020			
		330C399	L 5x3 1/2 x 3/8													
		330C503	L 5x3 1/2 x 1/4		47980	67560	22.0		ok	.22	.47	.007	.026			
		3										.009	.028			
		3										.007	.019			
7804-22	UJ 234-1250C											.007	.021			
		3										.007	.020			
7804-02	SJ 234-1063R															
		3														
		3														

Item #2  
MIC # NA224

ASME SA-36

RAW 7/19/78

8652

NA224

WEIGHT #140410

C. T. Burtch

Per P. E.

ELECTRIC STEEL Manufactured by  
**NORTHWEST STEEL ROLLING MILLS, INC.**  
 435 DuBois Avenue N.W. - SEATTLE, WASHINGTON 98107

NR-279  
 DATE 10/18/76

REPORT of PHYSICAL and CHEMICAL TESTS

CERTIFICATE ASTM A36-75

MATERIAL Electro Steel

STRUCTURE 9369


for Merchant Bar

CUSTOMER N. P. S. Industries

2750 S. W. Moody, Portland, Oregon 97201

	HEAT NO.	SIZE	YIELD SQUARE INCH	TENSILE SQUARE INCH	ELONG % IN.	FRACTURE	BEND	CHEMICAL ANALYSIS				REMARKS
								C	MN	S	P	
Gr. A-36	S-476	3/4 Pl Rnd	43,650	62,350	29.0	✓	OK	.16	.60	.025	.005	
Gr. A-36	S-396	3/4 Pl Rnd	43,830 ✓	66,670 ✓	30.0	✓	OK	.21	.67	.034	.016	✓
Gr. A-36	P-433	7/8 Pl Rnd	46,430	65,930	31.0		OK	.21	.62	.018	.006	

REPORT OF 10/11/78 WAS IN ERROR, CERTIFICATE SHOULD HAVE SHOWN ASTM A-36-75,



ASTM SA-36

REV 10/20/78

9369

NR  
279

Certified by NORTHWEST STEEL ROLLING MILLS, INC

By *[Signature]*

MIC  
DATE 11/1 3A R 5

REPORT OF PHYSICAL AND CHEMICAL TESTS

CERTIFICATE ASTM - A-36 MATERIAL ELECTRO - STEEL

STRUCTURE P.O. # 7404-33 for PLAIN Round Bars  
West Columbia Steel Corp. P.O. Box 03008, Portland, Oregon 97203

TEST	DIA.	S. 28	S. 28 AND 29	TENSILE STRENGTH	ELOG. IN 8	FRAC. TURE	GENE	CHEMICAL ANALYSIS			REMARKS
								CU	S	P	
N-758	1" φ		45910	66600	24.0	OK	20	64	032	012	20,252.4
N-213	1 1/4" φ		43880	65230	28.0	OK	17	63	014	012	10002.4
N-952	1 3/4" φ		43120	65350	30.0	OK	17	64	023	007	10,634.4
N-957	2" φ		47110	60950	25.0	OK	19	67	033	005	21,360.4
N-900	2 3/8" φ					OK	27	60	020	011	9,635.4
MATERIAL PHYSICAL TESTS PERFORMED AT THE PORTLAND STEEL ROLLING MILLS BY SA 36 DATE 8/15/26 INITIALS 8/15/26 TESTER J. J. JONES SUPERVISOR P. W. 8/16/26											

INFORMATION  
 COPY  
 PPRV

Certified by PORTLAND STEEL ROLLING MILLS, INC.

Witnessed by Henry Kinstry

MICNO / NW 720  
 3301-1656  
 1/6 to 6/6

BETHLEHEM STEEL CORPORATION  
 METALLURGICAL DEPARTMENT  
 CARRIER, INITIAL AND NO.  
 NP. 57507

DATE SHIPPED  
 3-27-79

331H466  
 SEATTLE

GILMORE STEEL CORP. PORTLAND  
 SHIPPED TO

REPORT OF MECHANICAL AND CHEMICAL TESTS

Customer's Order No.	Section Size or Mill Order No.	Heat No.	Description	Specimen	Tensile Strength	Elong. %	Red. %	Bends	CHEMICAL ANALYSIS					
									C	Mn	P	S	Specimen No.	
7900-42	UJ234-1764C			ASTM A36-77A		B <sup>11</sup>								
		330H290	L 3 1/2 x 3 x 3/8	45610	67510	21.0		ok	.23	.50	.008	.020		
		331H488	L 3 1/2 x 3 x 5/16	49060	68070	23.0		ok	.19	.50	.007	.019		
		331H491	L 3 1/2 x 3 x 1/4	48920	67840	22.0		ok	.23	.44	.012	.025		
		331H488	L 3 1/2 x 3 x 1/4	46640	66110	25.5		ok	.19	.50	.007	.019		
7900-15	UJ234-1732B													
		330H290	L 3 1/2 x 3 x 3/8	45610	67510	21.0		ok	.23	.50	.008	.020		
		331H488	L 3 1/2 x 3 x 5/16	49060	68070	23.0		ok	.19	.50	.007	.019		
7900-01	UJ234-1687*													
		331H498	L 3 x 2 x 1/4	47210	65300	22.5		ok	.19	.45	.007	.034		
		330H301	L 3 x 2 x 1/4	47330	64910	22.5		ok	.19	.40	.007	.023		
7900-20	UJ234-1677D*													
		330H290	L 3 1/2 x 3 x 3/8	45610	67510	21.0		ok	.23	.50	.008	.020		
7902-10	UJ234-1622*													
		330H280	L 3 1/2 x 3 1/2 x 3/8	46970	67230	27.0		ok	.21	.47	.021	.031		
7901-10	UJ234-1628*													
		331H466	S 3 x 5.7#	51780	70730	21.5	✓	ok	.23	.45	.015	.022		
				WEIGHT	#157820				GILMORE STEEL CORP. APPROVED BY: <i>W.A.V.</i> Q.C. CLERK DATE: APR 05 1979					

INFORMATION  
 COPY  
 PPRV

DOCUMENT REVIEWED  
 P.O. # 10162  
 MIC # NW 436  
 O.C. SUPERVISOR *R.W.* DATE 4/16/79

01394	J1																			
980																				
NPS INDUSTRIES INC 235 MOORE ST HACKENSACK N J 07601										NPS INDUSTRIES INC 4870 NORTH FATHOM ST SWAN ISLAND PORTLAND ORE										

RECEIVED

SEP 15 1975

THIS IS TO CERTIFY THAT THE CHEMICAL ANALYSES AND/OR TEST RESULTS SHOWN IN THIS REPORT ARE CORRECT, AS CONDUCTED IN THE RECORDS OF THE COMPANY.

*Philip E. Jones*

PHILIP E. JONES, Chief Metallurgist

NPS INDUSTRIES INC  
235 MOORE ST  
HACKENSACK N J 07601

75-2006 6/30/75  
NPS INDUSTRIES INC  
4870 NORTH FATHOM ST  
SWAN ISLAND  
PORTLAND ORE

NPS INDUSTRIES  
PORTLAND

TRF (TL 40M)(COL) /O/ TRUCK (40M)  
 PROD STRL SHAPES CARBON  
 SPEC ASME SA36-70A  
 QMI KEEP NBR OF HEATS TO A MAX OF TWO NO MILL WELD REPAIRS  
 ATH CUST PREFERS ONE HEAT, IF POSSIBLE  
 APN FABRICATING PIPE SUPPORTS  
 IMP MILL RA/SN CERTIFIED T/R REPORT TEST RESULTS PER SPEC

REPORT OF CHEMICAL AND PHYSICAL TESTS

SEP 04 1975

ITEM NO.	HEAT NUMBER	INGOT SLAB NO.	MATERIAL DESCRIPTION	LADLE <input checked="" type="checkbox"/> CHECK <input type="checkbox"/>					TEST LOC. OR GAGE TESTED	YIELD POINT 100 P.S.I.	TENSILE STRENGTH 100 P.S.I.	ELONG. % 8 IN	BEND TEST	HARD. TEST	AVE. IMPACT VALUE FT. LBS.
				C	MN	P	S	SI							
03	90A286	W4	WB x 17" x 40"	.22	.58	.012	.022	.05	.230	396	631	25.0	OK		
	94A496	W5	L	.23	.53	.012	.022	.06	.230	405	648	26.5	OK		
									.230	487	666	26.0	OK		
									.230	500	655	28.0	OK		
MATERIAL IS IDENTICAL WITH THE REQUIREMENTS OF SA 36															
Q.A. DOCUMENTATION REVIEW INTERVIEW DATE 2/10/77															

INFORMATION  
PPRY



Division of Unarco Industries, Inc.

1717 West 115th Street  
Chicago, Illinois 60643

Phone 312 239 7700 Telex 25 4297  
Wats 800 621 4610

Unarco Leavitt Specialty Tubular Products  
1200 Dodge Avenue Evanston, Illinois 60202

# CERTIFICATION

CUSTOMER: J.T. Ryerson & Sons, Inc.  
P.O. Box 8006A  
Chicago, IL 60680

Bill of Lading No. 63089

Date: April 6, 1978

I HEREBY CERTIFY THAT THE MATERIAL ITEMIZED BELOW WAS PRODUCED IN CONFORMITY WITH THE SPECIFICATIONS INDICATED, AND THAT ALL TESTS REQUIRED BY THOSE SPECIFICATIONS, INCLUDING SUCH OTHER DOCUMENTS AS THEY MAY REFERENCE, WERE SUCCESSFULLY PERFORMED AT A FREQUENCY GREATER THAN OR EQUAL TO THAT REQUIRED BY THE SPECIFICATIONS. ALL DATA TRULY REPRESENTS THE INFORMATION CONTAINED IN THE RECORDS OF THE CORPORATION.

	No. of Pieces	Size & Gage	Length	Total Amount	Customer P.O.	Mill Order No.
1	60	3 x 4 x 3/16	40'	2,400'	DA 747B2	225836
2	112	2 x 4 x 1/4	40'	4,480'	1A 5740	136973

ITEM NO	1	2			
SPECIFICATION	ASTM-A500	ASTM-A500			
GRADE	B	B			
HEAT NO	W 7000	793437			

CHEMISTRY	CARBON	.17	.17 ✓
	MANGANESE	.39	.39 ✓
	PHOSPHORUS	.013	.007 ✓
	SULFUR	.022	.017 ✓
	ALUMINUM		

TESTING	EXPAND		
	FLATTEN		
	REVERSE FLATTEN		
	FLARE	X	X
	CRUSH		
	EDDY CURRENT		
	HYDROSTATIC		
	AIR		
	HARDNESS (Rb)		
	YIELD STRENGTH (PSI)	50,000	55,000 ✓
0.2% OFFSET (MPa)	345	379 ✓	
TENSIL STRENGTH (PSI)	62,500	65,000 ✓	
(MPa)	431	488 ✓	
ELONGATION IN 2" (%)	22	27 ✓	



DOCUMENT REVIEWED	
P.O. #	MIC #
8711	NT 131
QC. SUPERVISOR	DATE
RBW	4/23/78

CLEARER REPLACEMENT (RBW)

*(Handwritten Signature)*  
Signature



# INDEPENDENCE TUBE CORPORATION

6226 West 74th St.  
Chicago, Illinois 60638  
(312) 496-0380

June 3, 1978

Joseph T. Ryerson & Son  
P. O. Box 8000-A  
Chicago, Illinois

Attention: Test Report Area

The following material shipped on your Order No. 1A-146

Invoice No. 12042, meets the requirements of ASTM A-500

Grade B

Heat#783662

3" Sq. x 1/4"

Yield 63,270 ✓ psi

Tensile 66,940 ✓ psi

Elong. 2" 27.5 ✓ %

<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>
.18 ✓	.70	.017 ✓	.024 ✓

B. A. Yontez  
Vice President-Materials

INFORMATION  
**COPY**  
PPRV

9006

T-149

ASTM A500  
RAW 8/31/78

T-149

# INDEPENDENCE TUBE CORPORATION

6226 West 74th St.  
Chicago, Illinois 60638  
(312) 496-0380

July 23, 1979

Joseph T. Ryerson & Son, Inc.  
P.O. Box 8000-A  
Chicago, Illinois 60680

ATTN: Test Report Area

The following material shipped on your Order No. CA 45425

Invoice No. 19205, meets the requirements of ASTM A-500  
Grade B-77.

<u>Size, Gauge</u>	<u>Yield PSI</u>	<u>Tensile PSI</u>	<u>Elong. 2"</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>
5" x 3" x 5/16" HT # M 65438	60,650	62,970	32.5	.23	.77	.016	.017
6" x 4" x 1/4" HT # C 93560 -	59,610 ✓	66,275 ✓	29.5 ✓	.21 ✓	.73	.005 ✓	.030 ✓

INFORMATION  
**COPY**  
PPRV

75413560  
RT 45321

DOCUMENT REVIEWED	
P.O. # 10275	MIC # NT206
Q.C. SUPERVISOR RBW	DATE 8/14/79

*B. A. Gontez*

Vice President-Materials

# The Copperweld Tubemakers

## REGAL TUBE COMPANY

7401 South Linder Avenue  
Chicago, Illinois 60638 U.S.A.

Customer Order No. A11-3235

Regal Order No. 045879

Invoice No. \_\_\_\_\_

Date 6/30/78

**TEST REPORT**  
AMERICAN STEEL INC.  
**RECEIVED**

**Customer:**

American Steel  
4033 Northwest Yeon Ave.  
Portland, Or 97210

JUL 10 1978

**Specification:**

8 sq x 1/4 structural tubing  
ASTM A 500 77 Grade B

TESTS CHECKED \_\_\_\_\_  
NO. OF EXPS \_\_\_\_\_  
NO. OF TESTS \_\_\_\_\_  
NO. CHANGED \_\_\_\_\_

HEAT NO.	CHEMICAL ANALYSIS, %			
	C	Mn	P	S
52793	.21	.71	.013	.021

MATERIAL IS IDENTICAL

TO THE REQUIREMENTS  
*ASME A500 Gr B*

*PPRV 8/16/78*

QUALITY SYSTEM CERTIFICATE

CERTIFICATE NUMBER: 141341

EXPIRES: JANUARY 5, 1979

NO. OF TESTS: *8455* AND NO. *NT-132*

*MRR 1418*

HEAT NO.	LAB NO.	YIELD STRENGTH PSI	TENSILE STRENGTH PSI	ELONGATION %	HARDNESS R <sub>b</sub>
52793	8689	53,000 ✓	59,900 ✓	34 ✓	

YIELD STRENGTH IS 0.2% OFFSET — ELONGATION IN 2 INCHES

**Other Tests**

*NPS 2.0 # DOT 8455*

**INFORMATION**  
**COPY**

Subscribed and sworn to before me a  
Notary Public in and for the  
State of \_\_\_\_\_ County of \_\_\_\_\_  
this PPRV day of \_\_\_\_\_ 19\_\_

*Orvan R. Carter*  
Metallurgist

# The Copperweld Tubemakers

119718

Customer Order No. A11-3235

## REGAL TUBE COMPANY

7401 South Linder Avenue

Chicago, Illinois 60638 U.S.A.

Regal Order No. 045879

Invoice No. \_\_\_\_\_

Date 6/30/78

### TEST REPORT

AMERICAN STEEL INC.  
**RECEIVED**

Customer:

American Steel  
4033 Northwest Yeon Ave.  
Portland, Or 97210

JUL 10 1978

Specification:

8 sq x 1/4 structural tubing  
ASTM A 500 77 Grade B

FILES CHECKED \_\_\_\_\_  
FILES & EXT'S \_\_\_\_\_  
NO. OF TESTS \_\_\_\_\_  
A/C CHARGED \_\_\_\_\_

HEAT NO.	CHEMICAL ANALYSIS, %									
	C	Mn	P	S	Si	Al	Ca	Mg	Ni	Other
52793	.21 ✓	.71 ✓	.013 ✓	.021 ✓						

MECHANICAL PROPERTIES					
HEAT NO.	LAB NO.	YIELD STRENGTH PSI	TENSILE STRENGTH PSI	ELONGATION %	HARDNESS R <sub>b</sub>
52793	8689	53,000 ✓	59,900 ✓	34 ✓	

ASTM A 500 GR B

RBW 7/28/78

COPIY  
PPRV

NT 117

YIELD STRENGTH  
Other Tests

8455

NT-117

Subscribed and sworn to before me a  
Notary Public in and for the  
State of \_\_\_\_\_ County of \_\_\_\_\_  
this \_\_\_\_\_ day of \_\_\_\_\_, 19\_\_

Oscar R. Canty  
Metallurgist

NT 217

MIC NO



MILL TEST REPORT WELDED STRUCTURAL STEEL TUBING

WELDED TUBE COMPANY OF AMERICA

11200 S. MICHIGAN AVE. CHICAGO, ILLINOIS 60633

PHONE 312/840-4000

SOLD TO:

DATE:  
SHIPPED TO:

NO. - CH35594  
COPY INFORMATION

CUSTOMER P.O. NO.

ITEM NO.	SIZE	LENGTH	WEIGHT	YIELD STRENGTH	TENSILE STRENGTH	ELONGATION	WELDING
1001	10" x 6" 1/2"	40' 0"	20	80010"	58,600	66,500	13%
1002	SAME			62,200	68,700	29%	✓
1003							
1004							
1005							
1006							
1007							
1008							
1009							
1010							
1011							
1012							
1013							
1014							
1015							
1016							
1017							
1018							
1019							
1020							
1021							
1022							
1023							
1024							
1025							
1026							
1027							
1028							
1029							
1030							
1031							
1032							
1033							
1034							
1035							
1036							
1037							
1038							
1039							
1040							
1041							
1042							
1043							
1044							
1045							
1046							
1047							
1048							
1049							
1050							
1051							
1052							
1053							
1054							
1055							
1056							
1057							
1058							
1059							
1060							
1061							
1062							
1063							
1064							
1065							
1066							
1067							
1068							
1069							
1070							
1071							
1072							
1073							
1074							
1075							
1076							
1077							
1078							
1079							
1080							
1081							
1082							
1083							
1084							
1085							
1086							
1087							
1088							
1089							
1090							
1091							
1092							
1093							
1094							
1095							
1096							
1097							
1098							
1099							
1100							

DOCUMENT REVIEWED

PO #	MIC #
10686	NT 217
DATE	
10/22/99	

THIS MATERIAL MEETS MINIMUM SPECIFICATIONS SET FORTH IN ASTM A-500-77 GRADE "B"

WELDED TUBE COMPANY OF AMERICA AND ARE CERTIFIED AS BEING CORRECT BY: M. J. ...

11. 0. 110

# Brown & Root, Inc.

QUALITY ASSURANCE  
RECEIVING INSPECTION REPORT

REPORT NO

13376

ARMS  
INDEXED

UNIT <b>X</b>	SYSTEM <b>Q Stock</b>	COMPONENT <b>TUBE steel</b>	IDENTIFICATION/SPIN NO. <b>N/A</b>	DWG./SPECIFICATION & REV. <b>N/A</b>
P.O. <b>35-1195</b>	MRR	CHARACTERISTIC INSPECTION:		<b>DWL OCT 11 7.2-12</b> <b>3/4/80 SIGAP</b>
<b>30141</b>	<b>090418</b>	SAT: <input checked="" type="checkbox"/> UNSAT: <input type="checkbox"/> NCR _____		HOLD TAG _____
VENDOR <b>NPS</b>	QR <b>N/A</b>	APPARENT RESPONSIBILITY FOR UNSATISFACTORY ITEMS:		
		B&R <input type="checkbox"/>	VENDOR <input type="checkbox"/>	TRANSPORTER <input type="checkbox"/> <b>N/A</b>
DATE DEFICIENCY DISCLOSED _____				

ITEM	QTY.	DESCRIPTION/REMARKS
<b>33</b>	<b>140 L.F.</b>	<b>6x8x1/2 TUBE steel ASTM A-500 GR B</b> <b>MIC # 3185NT HT # C 93096</b>

INFORMATION  
**COPY**  
PPRV

BROWN & ROOT, INC.  
RECEIVED  
MAR 06 1980  
QUALITY ASSURANCE

REC'D  
JUL 3/4/80  
13376

*S.W. 1229*

AUTHORIZED NUCLEAR INSPECTOR NOTIFICATION:

DATE: \_\_\_\_\_ TIME: \_\_\_\_\_ MEDIA: \_\_\_\_\_ N/A  INIT. *Duck*

ANI WITNESS: SAT. \_\_\_\_\_ ☆☆ UNSAT. \_\_\_\_\_ ☆☆ WAIVE \_\_\_\_\_

☆☆ ANI'S INITIALS REQUIRED

**FOIA-85-59**

STORAGE LOCATION <b>Steel FAB</b>	QC ENGINEER/INSPECTOR <i>Dwight W. Leigh</i>	DATE <i>2/11/81</i>
TYPE: <b>F</b>		

FOIA-85-59 CC/182

QC-1.1/3-1

	SAT.	UNSAT.	R/A
1. Did all required documentation accompany shipment?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Is shipment packaged satisfactorily?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Are material markings in accordance with specification requirements?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Is certification adequate and accurate when compared to the applicable specifications?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Is there any damage?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Have all NDE requirements been met?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7. Was shipment accompanied by a B&R QA Department Conformance Certificate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Was the Certificate signed by a B&R Surveillance Specialist?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
If not, is a B&R QA Source Inspection Waiver Form available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Applicable QC Receiving tags have been applied	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Comments: N/A

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

QC Inspector Danny Leigh

Date 9/3/80

INFORMATION  
**COPY**  
 PPRV

096418

PAGE 1 OF 1 ORDER NO.

SHIPPED TO:  B & R  G & H  F & N  W  TUSI  OTHER P.O. NO. 35-1195-30141

REQ. NO. PR 126434 c/o 1

BROWN & ROOT, INC.

VENDOR: R.P.S. Industries Secaucus, NJ

MAR 06 1980

DATE: 2-29-80

SHIPPER: Same Austin, TX

FILES NOTED QUALITY ASSURANCE

F.O.B. SP/PPA

Partial  16 Complete

QUANTITY	UNIT	ITEM	MATERIAL DESCRIPTION	LOCATION
140	WEL.	33	6 x 8 x 1/2 T3 Structural Tubing K17C30000 5677 total Ft. lbs. (40.55 lbs. per ft.)	N/A GA Rec. Center Pipe Yd.
1	lot		Certification Papers	Insult GA Rec.

NOTE: RECEIVED IN GOOD CONDITION

This Inspection Has Been Documented  
 INFORMATION  
 RIR No. 2337  
 COPY  
 PPRV

RECEIVED BY: S. Ward

QC CHECK BY	EXP	PP	TEX PAK	UPS	PREPAID	COLLECT
XXX					239.55	

Central  
 DELIVERING CARRIER  
 F.B. NO. 23 66834648  
 CAR NO.

Est. 2-77  
 Iron F.





# Brown & Root, Inc.

QUALITY ASSURANCE DEPARTMENT

S. W. 1229

DATE: 2/22/80

## SHIPMENT WAIVER

PROJECT: CPSES

JOB NO.: 35-1195

UNIT 182 PAGE 1 OF 1

TO: N.P.S. Ind. Inc.

10420 Metric Blvd., Austin, Texas 78753

REFERENCE: Purchase order/subcontract number (Varies)  
our telephone conversation this date concerning shipment waiver.

Gentlemen:

Confirming the telephone conversation between your Mr. C. Dunham

and our Mr. Ron Meissner as referenced above, we have waived final examination at your facility of the following items only:

Order Item No.	Qty	Description
<u>P.O. 35-1195-30191 (1)</u> <u>item 33</u>	<u>140ft.</u> <u>(7 R.)</u>	<u>T.S. 6"x8"x 1/2" @ 20'-0" ASTM A-500</u> <u>Gr. B</u>
<u>P.O. 35-1195-30267</u> <u>item 8</u>	<u>180ft</u> <u>(9 R.)</u>	<u>T.S. 6"x4"x 1/2" @ 20'-0" ASTM A-500</u> <u>Gr. B</u>

Brown & Root, Inc. Form QA-045 titled "Quality Assurance Department Conformance Certificate" properly completed and signed is not required. This shipment waiver does not waive any rights Brown & Root may have under this purchase order including the right to reject the item(s) upon discovery of deficiencies during or after arrival at destination.

Sincerely,

BROWN & ROOT, INC.

Ronald T. Meissner for  
R. Klimist  
Site Quality Assurance Manager

JPC/bj

cc: J. P. Clarke III


B&R Site Receiving Insp. Dept.

B&R Site Purchasing Dept.

V530-1

INFORMATION  
**COPY**  
PPRV

SW-12-2



# nps Industries, Inc.

SHIPPED FROM:  
NPS INDUSTRIES, INC.  
10420 Metric Boulevard  
Austin, Texas 78758

**SHIPPING NOTICE**  
No. AUS 8732/TDA  
**ALWAYS REFER TO ABOVE NUMBER.**

PAGE 1 OF 1

SOLD TO: Brown & Root Inc.  
P.O. Box 1001  
Glen Rose, TX

SHIP TO: Brown & Root Inc.  
C/O Comanche Peak  
SES FM 201  
Glen Rose, TX

### SPECIAL INSTRUCTIONS

DATE SHIPPED 2/26/80	PURCHASE ORDER NO. 35-1195-30141	PROJECT TITLE Brown & Root Inc.	SALES REL. NO. NA-356	PROD. REL. NO. 9513/TDA	SALES ACCT. NO. 3058
SHIPPED - VIA CARRIER CENTRAL FREIGHT		F.O.B. Austin	<input checked="" type="checkbox"/> PREPAID <input checked="" type="checkbox"/> C.O.D. <input type="checkbox"/> COLLECT		

ITEM NUMBER	ORDER QUANTITY	QUANTITY SHIPPED	QUANTITY B.O.	DESCRIPTION/ASSEMBLY MARK®, REV.	COMMENTS MIC#
33	160'	140'	20'	6 x 8 x 1/2 TS  1 BUNDLE 6962  2/20/80	8085NR

INFORMATION  
**COPY**  
PPRV



**nps Industries, Inc.**

10420 running bird lane  
austin, texas 78758  
telephone 512-836-4161

Date: 2/22/80  
NPSI: AUS-8732/TDA

Reference: Texas Utilities Services, Inc.  
PO # 35-1195-30141 CO #1  
NA-356  
Item #33 (Mic. #3185NT)

CERTIFICATE OF COMPLIANCE

NPS Industries certifies that the material described on the attached Shipping Notice AUS-8732/TDA supplied on your P.O. 35-1195-30141 CO#1 is in compliance with the requirements of A.S.M.E. Boiler and Pressure Vessel Code Section III, Subsection NF, Article 2000, Class II, Winter 1974 Addenda; and ASTM/ASME material specification identified on your P.O.:

Item #33 conforms to ASTM A-500 Gr. B, Code case 1644-7


A.S.M.E. Quality Systems Certificate (Materials) Number N-2048, expires on February 24, 1981.

Yours truly,

Jack Gober  
Manager of Quality Assurance

cc: Verlon Moore  
Ron Meissner  
Shipment  
File

JG/crd



**BROWN & ROOT, INC.**  
**QUALITY ASSURANCE DEPARTMENT**  
**CONFORMANCE CERTIFICATE**

DATE: 7 1979  
 AUSTIN, TEXAS

PROJECT: \_\_\_\_\_ JOB NO.: \_\_\_\_\_ UNIT: \_\_\_\_\_ PAGE: \_\_\_\_\_ OF: \_\_\_\_\_

(1) VENDOR <b>NPS Industries</b>	(2) ADDRESS OF VENDOR FACILITY <b>10420 Metric Boulevard 78758</b>
-------------------------------------	---

(3) PURCHASE ORDER NO. <b>35-1195-30141</b>	(4) SPECIFICATION NO. <b>N/A</b>	REV. <b>N/A</b>	(5) DRAWING NO. <b>N/A</b>	REV. <b>N/A</b>
--	-------------------------------------	--------------------	-------------------------------	--------------------

(6) ITEM DESCRIPTION(S) <b>6 x 8 x 1/2 TS</b>	(7) NO. OF ITEMS <b>7</b>	(8) NO. RELEASED <b>1</b>
(9) COMPLETE <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		

(10) SERIAL OR IDENTIFICATION NO(S):

**Item 33 conforms to ASTM A-500 Gr. B**

Records checked (✓) below are being transmitted with this certificate as required by the Brown & Root Document Data Sheet.

<input checked="" type="checkbox"/> Material Certifications <input type="checkbox"/> Heat Treat Records <input type="checkbox"/> RT Film & Records <input type="checkbox"/> PT/MT Records <input type="checkbox"/> UT Records <input type="checkbox"/> Approved Stress Report <input type="checkbox"/> Approved Design Analyses <input type="checkbox"/> Special Handling Instruc. <input type="checkbox"/> Operating Manuals	<input type="checkbox"/> Operating Elec. Test Records <input type="checkbox"/> Non Operating Elec. Test Records <input type="checkbox"/> Pressure Test Records <input type="checkbox"/> Seat Tightness Test Records <input type="checkbox"/> Performance Test Records <input type="checkbox"/> Weld. Personnel Qual. Certs. <input type="checkbox"/> NDE Personnel Qual. Certs. <input type="checkbox"/> Nameplate Facsimile <input type="checkbox"/> Code Data Report(s)	<input type="checkbox"/> Visual Inspection Records <input type="checkbox"/> Dimensional Inspect. Records <input type="checkbox"/> Cleanliness Records <input type="checkbox"/> Painting Records <input type="checkbox"/> Packaging Records <input checked="" type="checkbox"/> Spare Parts List <input checked="" type="checkbox"/> Cert. of Compliance
---	---	---

(11) DEVIATIONS:       None       Listed Below

**INFORMATION COPY**

PPRV

THE VENDOR CERTIFIES that the item(s) described above are in conformance with the requirements of the Brown & Root Specifications with the approved deviations listed above, are suitable for the purpose intended, are free from defects in design, workmanship, and materials and are new and of specified quality. A copy of this completed Conformance Certificate will be included with the bill of lading and shipped with the item(s) to Brown & Root, Inc. at the address designated in the procurement documents.

VENDOR AUTHORIZED SIGNATURE <i>[Signature]</i>	TITLE: <b>Manager of Quality Assurance</b>	DATE: <b>2 / 26 / 80</b>
---	---	-----------------------------

The Vendor has certified that the items above meet all contractual requirements. Brown & Root has reviewed evidence supporting this Certificate and, except as noted under "Remarks" above, has verified conformance to requirements. This Certificate does not waive any rights Brown & Root may have under the Purchase Order including the right to reject the item(s) upon discovery of deficiencies during or after arrival at destination.

Final Surveillance: <input type="checkbox"/> Performed <input checked="" type="checkbox"/> Waived			
SIGNATURE OF B&R SURVEILLANCE SPECIALIST: _____	DATE: _____	SHIPMENT WAIVER NUMBER <b>SW-1229</b>	DATE: <b>2 / 26 / 80</b>

The item(s) described above are hereby released by Brown & Root Quality Assurance. Shipment may be made subject to authorization by Brown & Root Purchasing.

Chicago, Illinois 60638 U.S.A.

DEC 10 1979

Regal Order No. 058108

Invoice No. \_\_\_\_\_

AUSTIN, TEXAS

Date 11-29-79

**TEST REPORT**

<p>Customer:</p>  <p>NPS Ind. Inc. One Harmon Plaza Secaucus, N.J. 07094</p>	<p>Specification:</p> <p>8 x 6 x 1/2 structural tubing ASTM A 500 77 Grade B</p>
--	--

HEAT NO.	CHEMICAL ANALYSIS, %									
	C	Mn	P	S						
C93096 67000	20 ✓ 21	40 ✓ 84	.005 ✓ .012	.028 ✓ .037						

MECHANICAL PROPERTIES					
HEAT NO	LAB NO	YIELD STRENGTH PSI	TENSILE STRENGTH PSI	ELONGATION %	HARDNESS R <sub>b</sub>
C93096 6700	18296 17433	62,800 ✓ 62,000	68,200 ✓ 70,600	30 ✓ 23	

YIELD STRENGTH IS 0.2% OFFSET — ELONGATION IN 2 INCHES

Other Tests

DOCUMENT REVIEWED BY  
Q.A. *[Signature]* DATE 2-19-80

NPSI-AUSTIN  
MJC NO.  
3185NT

Subscribed and sworn to before me a  
Notary Public in and for the  
State of \_\_\_\_\_ County of \_\_\_\_\_  
this \_\_\_\_\_ day of \_\_\_\_\_ 19\_\_

INFORMATION  
**COPY**  
 PPRV

*[Signature]*  
Metallurgist



nps industries, inc.

FINAL INSPECTION CHECKLIST

AUC

PDX

SUPPORT/ITEM NO. PO. # 25-1195-30141 PROJECT Brown + Root CPSES  
RELEASE NO. TX-PR-9613/TDA OTHER IDENTIFICATION NR-356 Acct. # 325-

QUALITY CONTROL INSPECTOR VERIFY THE FOLLOWING

II	DIMENSIONS (Per Drawing/Instructions)	NCR/PAR If App'l	S.N. of Calib. Instrument Used:	Q.C. Accept
1.	Size/Weight of Material (ie. <u>3x4.1 channel</u> <u>4x4x3/8 Tubing</u> )	<u>N/A</u>	<u>N/A</u>	<u>OK</u>
2.	Cut Length / Angle of Material	↑	↑	<u>N/A</u>
3.	Cut Length / Diameter of Rod	↑	↑	↑
4.	Threads ( length/class ) ( internal/external )	↑	↑	↑
5.	As Welded Dimensions/Details	↑	↑	↑
6.	Clamp Dimensions ( radius,gap,take out,hole ptrn)	↑	↑	↑
7.	Hardware ( size,length,grade,threads )	↓	↓	↓
8.	Variables ( I.D. No.,travel stops,scale plate )	↓	↓	↓

Q.C. Acceptance: Douglas H. Curtis Date: 02/20/80

III PAINT/PROTECTIVE COATING (Per Drawing or Instructions)

Coating Data	
Type	Surf Prep. / Coating
Specif	
Procedure	
Thickness	

N/A  
A

Lubricants Applied (Exposed Threads, etc.)  
Thermolox or Equivalent Applied  
Workmanship  
S/N of Cal. Inst. Used: N/A

Q.C. Acceptance: N/A Date: N/A

IV MARKING/TAGGING (Per Customer Specification)

Support/Item Number (Support Mark No./Catalog Number)  
Metal Tags and/or NPT Nameplates  
M.I.C. No.(s) (List those not covered on Dwg. B/M)

21 33 Qty. ~~100~~ 140' 6" X 8" X 1/2" X 20' Latti G. 500 Gr. B Tube Steel  
Mic # 3185 NT

INFORMATION  
**COPY**  
PPRV

Q.C. Acceptance: Douglas H. Curtis Date: 02/20/80



QA RECORD

Brown & Root, Inc. INDEXED  
QUALITY ASSURANCE DEPARTMENT  
NONCONFORMANCE REPORT (NCR)

(1) NCR No. M-2294  
PAGE 1 OF 5

PROJECT CPSES

JOB NO. 35-1195

(2) UNIT <u>1</u>	STRUCTURE/SYSTEM <u>DD</u>	COMPONENT COMPONENT <u>SUPPORT</u>	TAG/ID NUMBER <u>DD-1-006-064-S35R</u>	LOCATION OR ELEVATION SAFEGUARD BLDG. <u>806 ELEV.</u>	RIR NO. <u>N/A</u>
----------------------	-------------------------------	--	---	--	-----------------------

(4) TREND CATEGORY G-9

(3) NONCONFORMING CONDITION

(3) DOCUMENT VIOLATED: CP-RAP-16.1 REV 0 PARA 2.3.1

WHILE DOING FINAL DOCUMENTATION REVIEW, THE FOLLOWING DISCREPANCY WAS DISCOVERED.

HANGER DRAWING AND C.M.C. #11642 SPECIFY THAT SA36 MATERIAL BE USED FOR ALL ITEMS.

SA515 MATERIAL WAS USED FOR PC #4.

THIS UN-AUTHORIZED USAGE OF MATERIAL CONSTITUTES A NON-CONFORMANCE IN ACCORDANCE WITH THE ABOVE-REFERENCED DOCUMENT.

(5) REPORTED BY: <u>R. WHEELER</u>	(6) DATE: <u>5/23/80</u>	(9) REVIEW/APPROVAL: <i>[Signature]</i>	(10) DATE: <u>5/23/80</u>
(7) PREPARED BY: <u>R. WHEELER</u>	(8) DATE: <u>5/23/80</u>	(11) ISSUED BY: <i>[Signature]</i>	(12) DATE: <u>5/23/80</u>

(13) DISPOSITION ASSIGNED TO: <u>D. FRANKUM</u>	(14) DUE DATE: <u>6/6/80</u>	(15) CORRECTIVE ACTION REQUEST. CAR NO. <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Required	(16) ASME CODE CLASS <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
--	---------------------------------	--	---

(17) DISPOSITION: REWORK TI 5-23-80 REPAIR \_\_\_\_\_ USE AS IS  SCRAP \_\_\_\_\_  
CMC #11642 HAS BEEN REVISED TO ALLOW THIS MATERIAL TO BE USED.

(18) CONSTRUCTION REVIEW/APPROVAL: <i>[Signature]</i>	(19) DATE: <u>5/21/80</u>	(20) QA/QC REVIEW/APPROVAL: <i>[Signature]</i>	(21) DATE: <u>5/23/80</u>
(22) ENG. REVIEW/APPROVAL: <i>[Signature]</i>	(23) DATE: <u>5/23/80</u>	(24) ANI REVIEW/APPROVAL: <i>[Signature]</i>	(25) DATE: <u>5/23/80</u>

(26) VERIFICATION <input checked="" type="checkbox"/> Satisfactory <input type="checkbox"/> Unsatisfactory <input type="checkbox"/> Not Req'd	
(27) QA/QC ENGR. INSPR. VERIFICATION: <i>[Signature]</i>	(28) DATE: <u>5/23/80</u>
(29) ANI CONCURRENCE: <i>[Signature]</i>	(30) DATE: <u>5/23/80</u>
(31) QA REVIEW/CLOSURE: <i>[Signature]</i>	(32) DATE: <u>5/23/80</u>

(33) REMARKS:

QA RECORD INFORMATION

**COPY**

FILE NO. L 2450280

SUBFILE NO. M 2294

PPRV

MATERIALS OPERATIONS

QUANTITY UNIT

SEISMIC PIPE RESTRAINT CONSISTING OF:

1 ALTERNATE EXISTS  
 65x0.7 (SA 36) 0' - 4 9/16" Long. TW-31  
 65x0.7 (SA 36) 0' - 4 9/16" Long. Detail A  
 TW-31

NCR M-2294  
 Pg 2 of 5

SEISMIC ASSEMBLY SKETCH & ENGINEERING  
 BUNDLE & TAG

MARK# DD-1-006-064 -S35R  
 3 PER CMC 11642  
 4 PER CMC 11642 SA 515 substituted for SA-36  
 5 PER CMC 11642

1 with 1-2-80  
 1 with 1-2-80  
 1 with 1-2-80

Apply one coat of Carbo Zinc #11 to  
 above mat'l except th'ds which shall  
 be coated w/e rust preventative.

INFORMATION  
 COPY  
 PPRV


ISSUED BY DDC

Approved By: UFP  
 Date: 4/5/78

QUAN. SHIP.

PBS  
 L  
 CS9  
 PRIM.  
 SEC.  
 AISC.

FOR MATERIALS AND OPERATIONS SEE SKETCH NO. SHEET OF



CONDITIONS	Fx	Fy	Fz	Mx	My	Mz
DESIGN						
NORMAL & UPSET	Δ	+911 -1119	+738			
EMERGENCY		+911 -1119	+800			
FAULTED						

REF. DRAWING NUMBERS

PIPE: MI-0604 REV. 14 ELECT: EI-060101 REV. 10  
 STEEL: SI-0618 REV. 10 HV.A.C. MI-0601 R.C.

REV	DATE	DWN	APP	DESCRIPTION
1	1/5/78	UFP		ISSUED FOR CONSTRUCTION
2	10-17-79	JWA		IFC FW-14; CLASS CODE WAS B31.1-5 REUSED PER ITT RW-1 SEND AS NOTED ~ PER ITT REV 2 SEE NOTE #4

CUSTOMER Texas Utilities Service, Inc.  
 ORDER OR CONT. NO. CP-0046  
 JOB NAME Corancho Peak 1 & 2  
 MARK NO. DD-1-006-064-535R  
 SKETCH NO. \_\_\_\_\_  
 SHEET 1 OF 1 REV. 2



NOV 2 1979



ITEM NO.	MATERIALS & OPERATIONS	QUANTITY	SHIP
1	SEISMIC PIPE RESTRAINT CONSISTING OF: A. MAIN ASSEMBLY SKETCH & ENGINEERING B. BUNDLE & TAG MARK C. APPLY ONE COAT OF CARBIC ZINC TO ABOVE AND EXCEPT THAT WHICH SHALL BE LISTED WITH FULL PARTICULARS.	ONE	
2	SEISMIC ASSEMBLY SKETCH & ENGINEERING	1	
3	BUNDLE & TAG MARK MARK: DD-7-006-064-535R	1	

QUANTITY	SHIP	INFORMATION	SHIP
ONE			

FOR MATERIALS AND OPERATIONS SEE SKETCH NO.	CONDITIONS	DESIGN	EMERGENCY	FAULTED	DESIGN	EMERGENCY	FAULTED

CUSTOMER	ORDER OR CONT NO.	JOB NAME	MAIN NO.	SMATCH NO.	SHEET	OF
Brown & Root, Inc.	CP-0046	Crashho Test 1 & 2	133-7026-014-1 & 2		1	1

NOTE: MATERIAL & WELDS UPGRADED TO LF STANDARDS.



- 1) All tolerances in accordance with Q.P. 2001 U.M.O.
- 2) Fab. Procedure to PII-1014-4
- 3) All products designed in accordance with KPL File No. 2 Nov. 5

C.P.T. Inc.  
I.P.D. Inc.  
Data Point  
Pipe Ins.  
Insul.


This hanger to be fabricated, erected, and connected to ASME section III requirements.

PA 3075

INFORMATION COPY

THIS DOCUMENT AFFECTED BY DESIGN CHANGES

Approved By: [Signature] Date: 4/15/78



THIRD PARTY INSPECTION CODE CLASS: ASME III-3

① APPLICATION: PIPE SUPPORT WELD MOD.  Q  NON-Q  DESIGN CHANGE/DEVIATION

② DWG. NO. 1TT-R2 BRH-R2

④ REASON FOR CHANGE: INTERFERENCE

⑦ REQUESTED/PREPARED BY:

LARRY TOWNLEY  
NAME

③ LINE NO./COMPONENT NO.  
DD-1-006-064-535R

PIPE SUPPORT, CONST  
DEPT.


⑤ INSTRUCTIONS:  
DD-1-006-064-535R

⑧ APPROVED BY:

[Signature] 7 Dec 74  
DATE

REMOVE  FW 1-4

⑥ SKETCH




ELEV VIEW LKG NORTH

SCRAP ITEM 142  
NICK 11-22-74  
Pg. 4 of 5

ADD  FW 5-12

- 3 CS-0.7x0'-5 1/4" LG (SA-36)
- 4 R 1/2 x 3' x 0'-5" LG (SA-36)
- 5 2 3/8 x 3' x 0'-4 1/2" LG (SA-36)



	DATE
	DATE
	DATE
	DATE
	DATE
	DATE

⑨ DISTRIBUTION	DCC CNTL NO.	QTY

ISSUED BY DCC

COMPONENT MODIFICATION CARD (CMC)

N<sup>o</sup> 11642R-1

SERIAL NO. \_\_\_\_\_

1 APPLICATION: PIPE SUPPORT WELD MOD.  Q  NON-Q  DESIGN CHANGE/DEVIATION

2 DWG. NO. 177-R2 BRH-R2  
DD-1-006-064-535R

4 REASON FOR CHANGE: INTERFERENCE  
REUSE MATL


3 LINE NO./COMPONENT NO.  
DD-1-006-064-535R

150# DD-1-SB-02-REV5

7 REQUESTED/PREPARED BY:  
LARRY TOWALEY  
NAME  
PIPE SUPPORT, CONST  
DEPT.

5 INSTRUCTIONS:

II-MOVE FW 1-4  
SCRAP ITEM 182  
NCR M-20284  
Pg. 5 of 5




8 APPROVED BY:  
John E. ... 7 Dec 79  
Christine ... 5-23-80  
DATE  
DATE  
DATE  
DATE  
DATE

9 DISTRIBUTION

DCC CNTL NO.	QTY

ADD FW 5-12  
LMS  
C5x6.7x0'-5 1/4" LG (SA-36)  
SA515 GRB  
D 1/2" x 3" x 0'-5" LG  
1/4" x 3" x 0'-4 1/2" LG (SA-36)

ELEV VIEW LKG NORTH



THIS REVISION VOIDS  
AND SUPERSEDES  
DOCUMENT SERIAL NO.  
CMC 11642R-D



# Brown & Root, Inc. INDEXED

QUALITY ASSURANCE DEPARTMENT  
NONCONFORMANCE REPORT (NCR)

(1) NCR No. M-2324

## QA RECORD

PROJECT CPSES

JOB NO 35-1195

PAGE 1 OF 3

(2) UNIT	STRUCTURE/SYSTEM	COMPONENT	TAG ID NUMBER	LOCATION OR ELEVATION	RIR NO
1	Component Cooling	Component Support	H-CC-1-EC-007-018	3 Hanger Fab Shop	N/A

(3) NONCONFORMING CONDITION CP-QAP-16.1 REV 0 PARA 3.1.2 & 3.1.3  
 (3) DOCUMENT VIOLATED \_\_\_\_\_ 4) TREND CATEGORY G-3

The above hanger has NCR M-2308 against it for material traceability. The 4x4x3/8" tube steel had heat number 05197 written on it and a hold tag applied. The number has now been changed to 051897. The disposition for NCR M-2308 has not been submitted to QA as of yet.

INFORMATION  
**COPY**

PPRV

(5) REPORTED BY J. Patton	(6) DATE 6 / 3 / 80	(9) REVIEW APPROVAL <i>[Signature]</i>	(10) DATE 6/4/80
(7) PREPARED BY J. Patton	(8) DATE 6 / 3 / 80	(11) ISSUED BY <i>[Signature]</i>	(12) DATE 6/5/80

(13) DISPOSITION ASSIGNED TO D. C. Frankum	(14) DUE DATE 6 / 17 / 80	(15) CORRECTIVE ACTION REQUEST CAR NO. <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Required	(16) ASME CODE XX Yes ___ No	CLASS 3
---	------------------------------	--	---------------------------------	------------

(17) DISPOSITION  
 REWORK \_\_\_\_\_ REPAIR \_\_\_\_\_ USE AS IS  SCRAP \_\_\_\_\_  
 Per MR. number 083021, correct heat number is 051897. Make correction to erroneous number.

(18) CONSTRUCTION REVIEW APPROVAL <i>[Signature]</i>	(19) DATE 6/16/80	(20) QA/QC REVIEW APPROVAL <i>[Signature]</i>	(21) DATE 6/16/80
---	----------------------	--	----------------------

(22) ENG REVIEW APPROVAL <i>[Signature]</i>	(23) DATE 6/16/80	(24) AMN REVIEW APPROVAL <i>[Signature]</i>	(25) DATE 6/17/80
--	----------------------	--	----------------------

(26) VERIFICATION  
 Satisfactory  Unsatisfactory  Not Req'd

(27) QA/QC ENGR/INSPR. VERIFICATION <i>[Signature]</i>	(28) DATE 6/18/80
---	----------------------

(29) AMN CONCURRENCE <i>[Signature]</i>	(30) DATE 6/18/80
--	----------------------

(31) QA REVIEW CLOSURE <i>[Signature]</i>	(32) DATE 6/18/80
--	----------------------

(33) REMARKS  
**QA RECORD**

RTN	QA REVIEW
L	866-19-80
FILE NO. 151	
SUBFILE NO. M-2324	

FOIA-85-59  
CC/184

INSPECTION REPORT

11/28/11

ITEM DESCRIPTION: **N F SUPPORT**  
 IDENTIFICATION NO.: **24-01-1-EL 007-018-3**  
 SYSTEM/STRUCTURE DESIGNATION: **COMPLEMENT C1012**  
 SPEC NO: **N/A**    REV: **N/A**    REF QC DDC B REV & CHANGE NO: **N/A**  
 MEASURE OR TEST EQUIP IDENT NO: **N/A**

IN PROCESS INSPECTION    
 PRE-INSTALLATION VERIFICATION    
 INSTALLATION INSPECTION    
 FINAL INSPECTION    
 PRETEST INSPECTION

INSPECTION RESULTS

INSPECTION COMPLETED, ALL APPLICABLE ITEMS SATISFACTORY

INSPECTION COMPLETED, UNSATISFACTORY ITEMS LISTED BELOW

*[Signature]*    *[Date]*  
 QC INSPECTOR    DATE

ITEM NO	INSPECTION ATTRIBUTES	SAT	UNSAT	DATE	QC SIGNATURE
---------	-----------------------	-----	-------	------	--------------

DISPOSITION OF NCR M2324 HAS BEEN ACCOMPLISHED SAT

*[Handwritten note]*

INFORMATION  
**COPY**  
 PPRV  
*[Signature]*

REMARKS (DWGS, SPECS, ETC):

RELATED NCR NO: **M2324**    I.R. CLOSED:     DATE: **N/A**    SIGNATURE: **N/A**    QC INSPECTOR:

R/R

CFSES MATERIAL REQUISITION

NUM 2312  
Pg. 3 of 3

30199

AFLO Steel Co R/R 11/25/85

DATE

QUANTITY	DESCRIPTION & TAG NUMBER	HEAT/LOT/SERIAL NUMBER	CODE
401 5,766 lbs	8 pcs T.S. 4x4x 3/8 x 40' A-500 Grade B	HT # G51897	
401 11,879 lbs	76 pcs SHTS 14GA X 60 X 120 ASTM <del>A5075</del> <sup>A570</sup> Grade D	HT # W10513	
250 pcs	1/2 PL RD 3/4 X 20'-0 ASME SA36	HT # E92741	
50 pcs	1/2 PL RD 5/8 X 20'-0 Grade ASME SA36	HT # W10461	2
<del>730 lbs</del> <del>500 lbs</del>	<del>PL 1/25 X 60 X 120 Grade D A570</del>	<del>HT # DD 5-27-84 5-91916</del>	

IRON Fab

IRMATION  
COPY  
PPRV

QC Stock color code orange

RECEIVED

AUTHORITY

ISSUED

*[Signature]*

For Bal Forest  
Supt of Forestry

*[Signature]*  
WAREHOUSE



# Brown & Root, Inc.

## QUALITY ASSURANCE DEPARTMENT NONCONFORMANCE REPORT (NCR)

(1) NCR No. M-2312

### QA RECORD

PROJECT CPSES \_\_\_\_\_ JOB NO. 35-1195 PAGE 1 OF 2

(2) UNIT	STRUCTURE SYSTEM	COMPONENT	TAG ID NUMBER	LOCATION OR ELEVATION	RIR NO.
N/A	N/A	N/A	See Below	Hanger Fab Shop	N/A

### (3) NONCONFORMING CONDITION

(3) DOCUMENT VIOLATED: CP-CPM-6.9D REV 0 PARA 2.5.4 2.5.5 (4) TREND CATEGORY M-10

During surveillance the following was found:

- ✓ 1. Tube steel 6x6x $\frac{1}{2}$  has 3 heat numbers marked on it; 389NTA, NT389 and 389NT, (one piece)
- ✓ 2. Tube steel 6x6x $\frac{1}{2}$  has 2 heat numbers marked on it; 389NTA and 389NT. (Two pieces)
- ✓ 3. I beam W6x16 has 2 heat numbers marked on it; 64819 and 61819. (One piece)
4. Tube steel 8x8x $\frac{1}{2}$  marked NT132 and also marked at another location NT117 over NT132. (One piece)
5. Tube steel 8x6x $\frac{1}{2}$  marked 3185NT and at another location marked 3185RB. (One piece)
6. Tube steel 6x6x $\frac{3}{8}$  marked 734NT and at another location is marked 734. (Two pieces)

*Three*  
*GMB 6-18-80*


Hold tags applied

(5) REPORTED BY: Keith Kirkpatrick	(6) DATE: 5 / 31 / 80	(9) REVIEW APPROVAL: <i>[Signature]</i>	(10) DATE: 6 / 3 / 80
(7) PREPARED BY: Keith Kirkpatrick	(8) DATE: 5 / 31 / 80	(11) ISSUED BY: <i>[Signature]</i>	(12) DATE: 6 / 13 / 80

(13) DISPOSITION ASSIGNED TO: D. C. Frankum	(14) DUE DATE: 6 / 14 / 80	(15) CORRECTIVE ACTION REQUEST CAR NO. <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Required	(16) ASME CODE CLASS: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
--	-------------------------------	---	--

(17) DISPOSITION: REWORK \_\_\_\_\_ REPAIR \_\_\_\_\_ USE AS IS 3, 4, 5 & 6 SCRAP 1 & 2

See attached for disposition.



(18) CONSTRUCTION REVIEW APPROVAL: <i>[Signature]</i>	(19) DATE: 6 / 12 / 80	(20) QA QC REVIEW APPROVAL: <i>[Signature]</i>	(21) DATE: 6 / 17 / 80
(22) ENG. REVIEW APPROVAL: <i>[Signature]</i>	(23) DATE: 6 / 12 / 80	(24) QA REVIEW APPROVAL: <i>[Signature]</i>	(25) DATE: 6 / 17 / 80

(26) VERIFICATION: <input checked="" type="checkbox"/> Satisfactory <input type="checkbox"/> Unsatisfactory <input type="checkbox"/> Not Req'd	
(27) QA QC ENGR INSPR VERIFICATION: <i>[Signature]</i>	(28) DATE: 6 / 18 / 80
(29) AM CONCURRENCE: <i>[Signature]</i>	(30) DATE: 6 / 18 / 80
(31) QA REVIEW CLOSURE: <i>[Signature]</i>	(32) DATE: 6 / 25 / 80

(33) REMARKS  
See attached <sup>copy of</sup> RIR'S GMB 6-18-80  
Request for verification of disposition, 6-17-80

# FOIA-85-59

CC / 185

Disposition to  
NCR M-2312

Pg. 2087  
NCR-2312

- Item 1: Scrap this material.
- Item 2: Scrap this material.
- ✓ Item 3: The W6x16 wide flange beam is stamped with heat number 64819. Documentation in the QA Vault shows this material received on MRR 96520 and verified by RIR 13708. Correct paint marking "61819" to read "64819".
- Item 4: This tube steel is stamped with MIC number NT117. Documentation in the QA Vault shows this material received on MRR 92199 and verified by RIR 12161. Remove paint marks "NT132" and "NT132", and repair primer paint as required.
- Item 5: This tube steel is stamped with MIC number 3185NT. Documentation in the QA Vault shows this material received on MRR96418 and verified on RIR 13376. Remove paint mark "3185RB" and repair primer paint as required.
- Item 6: This tube steel is ~~permanently marked~~ <sup>Stamped 206-12-80</sup> with MIC number 734NT. Documentation in the QA Vault shows this material received on MRR 3968 and verified on RIR 9152. Remove paint marks "734" and repair primer paint as required. Three pieces of steel have been identified.

INFORMATION  
COPY  
PPRV



2 PEAK STEEL  
INSPECTION REPORT

SHEET 1 OF 1  
M2312

ITEM DESCRIPTION <b>N.F. SUPPORT MATERIAL</b>	IDENTIFICATION NO <b>N/A</b>	SYSTEM / STRUCTURE DESIGNATION <b>N/A</b>
SPEC. NO. <b>N/A</b>	REV. <b>N/A</b>	REF. CC. DOC. & REV. & CHANGE NO. <b>N/A</b>
MEASURE OR TEST EQUIP. IDENT. NO. <b>N/A</b>		

<input type="checkbox"/> IN-PROCESS INSPECTION	<input type="checkbox"/> PRE-INSTALLATION VERIFICATION	<input type="checkbox"/> INSTALLATION INSPECTION	<input checked="" type="checkbox"/> FINAL INSPECTION
			<input type="checkbox"/> PRETEST INSPECTION

INSP. RESULTS

INSPECTION COMPLETED, ALL APPLICABLE ITEMS SATISFACTORY

INSPECTION COMPLETED, UNSATISFACTORY ITEMS LISTED BELOW

*Sam Williams*      **6 PM 6-20-98**  
QC INSPECTOR      DATE **7-18-98**

ITEM NO.	INSPECTION ATTRIBUTES	SAT	UNSAT	DATE	QC SIGNATURE
	Items 1-6 on disposition FDR NCR M2312 have been completed SAT.				

INFORMATION COPY

REMARKS: (CONS, SPECS, ETC.)

RELATED NCR NO. <b>N/A</b>	I.R. CLOSED <b>N/A</b>	DATE <b>N/A</b>	SIGNATURE <b>N/A</b>
-------------------------------	---------------------------	--------------------	-------------------------

RTN. 0  
 FILE NO. 8.6  
 SUBPILE NO.

# Brown & Root, Inc.

REPORT NO. 12161

QUALITY ASSURANCE  
 RECEIVING INSPECTION REPORT

INSPECTION

UNIT 1 & 2	SYSTEM MECH.	COMPONENT Pipe Hanger Stock	IDENTIFICATION/SPIN NO. N/A	DWG / SPECIFICATION & REV. E&H-2323 MS46A, Rev.
P.O. 35-1195 30220	MRR 92199	CHARACTERISTIC INSPECTION: QI-GAP 2.2-12 M11-27-79		
VENDOR NPSI Portland	QR N/A	SAT. <input checked="" type="checkbox"/> UNSAT. <input type="checkbox"/> NCR <input type="checkbox"/> HOLD TAG <input type="checkbox"/>		
		APPARENT RESPONSIBILITY FOR UNSATISFACTORY ITEMS: B&R <input type="checkbox"/> VENDOR <input type="checkbox"/> TRANSPORTER <input type="checkbox"/> N/A		
		DATE DEFICIENCY DISCLOSED _____		

ITEM	QTY.	DESCRIPTION/REMARKS
002	500ft.	2 1/2" X 2 1/2" X 1/4" Angle, MIC No's - 300ft. A35 & 200ft. NA-2
003	150ft.	2 1/2" X 2 1/2" X 3/8" Angle, MIC No. - NA 246
005	20ft.	6" X 6" X 3/4" Angle, MIC No. - NA 224
007	250ft.	3/4" Round Bar, MIC No. - NR-279
008	500ft.	1" Round Bar, MIC No. - R5
009	200ft.	3 in X 5.7# I-Beam, MIC No. - NW-436
010	300ft.	W8" at 17 lbs Channel, MIC No. - W5
013	500ft.	2" X 4" X 1/4" RECT. Tube, MIC No. - NT131
014	250ft.	3" X 3" X 1/4" Sq. Tube, MIC No. - T149
015	60ft.	4" X 6" X 1/4" Rect. Tube, MIC No. - NT206
016	100ft.	8" X 8" X 1/4" Sq. Tube, MIC No's - 60ft. NT132 and 40ft. NT117
017	140ft.	6" X 10" X 1/2" Rect. Tube, MIC No. - NT217

INFORMATION RECEIVED  
 NOV 30 1979  
 BROWN & ROOT, INC.  
 QUALITY ASSURANCE  
 FILES NOTED

This steel was measured & checked for ID markings  
 Results Acceptable.

For Class-2 Use, Items 2, 3, 5, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100, 101, 102, 103, 104, 105, 106, 107, 108, 109, 110, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124, 125, 126, 127, 128, 129, 130, 131, 132, 133, 134, 135, 136, 137, 138, 139, 140, 141, 142, 143, 144, 145, 146, 147, 148, 149, 150, 151, 152, 153, 154, 155, 156, 157, 158, 159, 160, 161, 162, 163, 164, 165, 166, 167, 168, 169, 170, 171, 172, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 190, 191, 192, 193, 194, 195, 196, 197, 198, 199, 200, 201, 202, 203, 204, 205, 206, 207, 208, 209, 210, 211, 212, 213, 214, 215, 216, 217, 218, 219, 220, 221, 222, 223, 224, 225, 226, 227, 228, 229, 230, 231, 232, 233, 234, 235, 236, 237, 238, 239, 240, 241, 242, 243, 244, 245, 246, 247, 248, 249, 250, 251, 252, 253, 254, 255, 256, 257, 258, 259, 260, 261, 262, 263, 264, 265, 266, 267, 268, 269, 270, 271, 272, 273, 274, 275, 276, 277, 278, 279, 280, 281, 282, 283, 284, 285, 286, 287, 288, 289, 290, 291, 292, 293, 294, 295, 296, 297, 298, 299, 300, 301, 302, 303, 304, 305, 306, 307, 308, 309, 310, 311, 312, 313, 314, 315, 316, 317, 318, 319, 320, 321, 322, 323, 324, 325, 326, 327, 328, 329, 330, 331, 332, 333, 334, 335, 336, 337, 338, 339, 340, 341, 342, 343, 344, 345, 346, 347, 348, 349, 350, 351, 352, 353, 354, 355, 356, 357, 358, 359, 360, 361, 362, 363, 364, 365, 366, 367, 368, 369, 370, 371, 372, 373, 374, 375, 376, 377, 378, 379, 380, 381, 382, 383, 384, 385, 386, 387, 388, 389, 390, 391, 392, 393, 394, 395, 396, 397, 398, 399, 400, 401, 402, 403, 404, 405, 406, 407, 408, 409, 410, 411, 412, 413, 414, 415, 416, 417, 418, 419, 420, 421, 422, 423, 424, 425, 426, 427, 428, 429, 430, 431, 432, 433, 434, 435, 436, 437, 438, 439, 440, 441, 442, 443, 444, 445, 446, 447, 448, 449, 450, 451, 452, 453, 454, 455, 456, 457, 458, 459, 460, 461, 462, 463, 464, 465, 466, 467, 468, 469, 470, 471, 472, 473, 474, 475, 476, 477, 478, 479, 480, 481, 482, 483, 484, 485, 486, 487, 488, 489, 490, 491, 492, 493, 494, 495, 496, 497, 498, 499, 500, 501, 502, 503, 504, 505, 506, 507, 508, 509, 510, 511, 512, 513, 514, 515, 516, 517, 518, 519, 520, 521, 522, 523, 524, 525, 526, 527, 528, 529, 530, 531, 532, 533, 534, 535, 536, 537, 538, 539, 540, 541, 542, 543, 544, 545, 546, 547, 548, 549, 550, 551, 552, 553, 554, 555, 556, 557, 558, 559, 560, 561, 562, 563, 564, 565, 566, 567, 568, 569, 570, 571, 572, 573, 574, 575, 576, 577, 578, 579, 580, 581, 582, 583, 584, 585, 586, 587, 588, 589, 590, 591, 592, 593, 594, 595, 596, 597, 598, 599, 600, 601, 602, 603, 604, 605, 606, 607, 608, 609, 610, 611, 612, 613, 614, 615, 616, 617, 618, 619, 620, 621, 622, 623, 624, 625, 626, 627, 628, 629, 630, 631, 632, 633, 634, 635, 636, 637, 638, 639, 640, 641, 642, 643, 644, 645, 646, 647, 648, 649, 650, 651, 652, 653, 654, 655, 656, 657, 658, 659, 660, 661, 662, 663, 664, 665, 666, 667, 668, 669, 670, 671, 672, 673, 674, 675, 676, 677, 678, 679, 680, 681, 682, 683, 684, 685, 686, 687, 688, 689, 690, 691, 692, 693, 694, 695, 696, 697, 698, 699, 700, 701, 702, 703, 704, 705, 706, 707, 708, 709, 710, 711, 712, 713, 714, 715, 716, 717, 718, 719, 720, 721, 722, 723, 724, 725, 726, 727, 728, 729, 730, 731, 732, 733, 734, 735, 736, 737, 738, 739, 740, 741, 742, 743, 744, 745, 746, 747, 748, 749, 750, 751, 752, 753, 754, 755, 756, 757, 758, 759, 760, 761, 762, 763, 764, 765, 766, 767, 768, 769, 770, 771, 772, 773, 774, 775, 776, 777, 778, 779, 780, 781, 782, 783, 784, 785, 786, 787, 788, 789, 790, 791, 792, 793, 794, 795, 796, 797, 798, 799, 800, 801, 802, 803, 804, 805, 806, 807, 808, 809, 810, 811, 812, 813, 814, 815, 816, 817, 818, 819, 820, 821, 822, 823, 824, 825, 826, 827, 828, 829, 830, 831, 832, 833, 834, 835, 836, 837, 838, 839, 840, 841, 842, 843, 844, 845, 846, 847, 848, 849, 850, 851, 852, 853, 854, 855, 856, 857, 858, 859, 860, 861, 862, 863, 864, 865, 866, 867, 868, 869, 870, 871, 872, 873, 874, 875, 876, 877, 878, 879, 880, 881, 882, 883, 884, 885, 886, 887, 888, 889, 890, 891, 892, 893, 894, 895, 896, 897, 898, 899, 900, 901, 902, 903, 904, 905, 906, 907, 908, 909, 910, 911, 912, 913, 914, 915, 916, 917, 918, 919, 920, 921, 922, 923, 924, 925, 926, 927, 928, 929, 930, 931, 932, 933, 934, 935, 936, 937, 938, 939, 940, 941, 942, 943, 944, 945, 946, 947, 948, 949, 950, 951, 952, 953, 954, 955, 956, 957, 958, 959, 960, 961, 962, 963, 964, 965, 966, 967, 968, 969, 970, 971, 972, 973, 974, 975, 976, 977, 978, 979, 980, 981, 982, 983, 984, 985, 986, 987, 988, 989, 990, 991, 992, 993, 994, 995, 996, 997, 998, 999, 1000.

AUTHORIZED NUCLEAR INSPECTOR NOTIFICATION:  
 DATE: \_\_\_\_\_ TIME: \_\_\_\_\_ MEDIA: \_\_\_\_\_ N/A  INIT. *JAM*

ANI WITNESS: SAT. \_\_\_\_\_ ☆☆ UNSAT. \_\_\_\_\_ ☆☆ WAIVED \_\_\_\_\_ DATE \_\_\_\_\_  
 ☆☆ ANI'S INITIALS REQUIRED

STORAGE LOCATION: *Iron Fab Shop* TYPE: *"E"*  
 QC ENGINEER/INSPECTOR: *John A. [Signature]* DATE: *27 Nov*

# Brown & Root, Inc.

QUALITY ASSURANCE  
RECEIVING INSPECTION REPORT

REPORT NO. **13708**

INDEXED

UNIT <b>X</b>	SYSTEM <b>Q</b> <b>Stock</b>	COMPONENT <b>Channel</b> <b>WIDE FLANGE</b>	IDENTIFICATION/SPIN NO. <b>N/A</b>	DWG./SPECIFICATION & REV. <b>N/A</b>
P.O. <b>35-1195</b>	MRR	CHARACTERISTIC INSPECTION:		<b>7.2-12</b> <b>QT QTP</b>
<b>30153</b>	<b>096520</b>	SAT. <input type="checkbox"/> UNSAT. <input type="checkbox"/> NCR _____		HOLD TAG _____
VENDOR <b>AFCO</b> <b>Steel</b>	QR <b>N/A</b>	APPARENT RESPONSIBILITY FOR UNSATISFACTORY ITEMS:		
		B&R <input type="checkbox"/> VENDOR <input type="checkbox"/> TRANSPORTER <input type="checkbox"/>		
DATE DEFICIENCY DISCLOSED _____				

ITEM	QTY.	DESCRIPTION/REMARKS
<b>4</b>	<b>25 PCS.</b>	<b>Channel 10x20x20' ASTM A36 HL#45381</b>
<b>19</b>	<b>11 PCS.</b>	<b>W 6x16x40' ASTM A36 (9 PCS.) HL#64819 (2 PCS.) HL#84109</b>

BROWN & ROOT, INC  
RECEIVED  
MAR 18 1980  
FILES NOTED  
QUALITY ASSURANCE

**Q**  
**L** **pull 3-12-80**  
**87**  
**13708**

INFORMATION  
**COPY**  
PPRV

**S.W. 1268**

AUTHORIZED NUCLEAR INSPECTOR NOTIFICATION:  
DATE: \_\_\_\_\_ TIME: \_\_\_\_\_ MEDIA: \_\_\_\_\_ N/A  INIT. **DWK**

ANI WITNESS: SAT. \_\_\_\_\_ ☆☆ UNSAT. \_\_\_\_\_ ☆☆ WAIVED \_\_\_\_\_ DATE \_\_\_\_\_  
☆☆ ANI'S INITIALS REQUIRED

STORAGE LOCATION: **FAB SHOP** TYPE: **E**  
QC ENGINEER/INSPECTOR: **Danny W. Leigh** DATE: **3-15-80**

# Brown & Root, Inc.

QUALITY ASSURANCE  
RECEIVING INSPECTION REPORT

REPORT NO. 13376

ARMS  
INDEXED

UNIT <b>X</b>	SYSTEM <b>Q Stock</b>	COMPONENT <b>TUBE steel</b>	IDENTIFICATION (SPIN NO.) <b>N/A</b>	DWG / SPECIFICATION & REV. <b>N/A</b>
P.O. <b>35-1195</b>	MRR	CHARACTERISTIC INSPECTION: SAT. <input checked="" type="checkbox"/> UNSAT. <input type="checkbox"/> NCR _____ HOLD TAG _____ <i>SWT OCT 11 7.2-12 3/4/80 SIGAP</i>		
VENDOR <b>30141 NPS</b>	QR <b>096418 N/A</b>	APPARENT RESPONSIBILITY FOR UNSATISFACTORY ITEMS: B&R <input type="checkbox"/> VENDOR <input type="checkbox"/> TRANSPORTER <input type="checkbox"/> <b>N/A</b>		
DATE DEFICIENCY DISCLOSED _____				

ITEM	QTY.	DESCRIPTION/REMARKS
<b>33</b>	<b>140 L.F.</b>	<b>6x8x1/2 TUBE steel ASTM A-500 GR B MIC # 3185NT HT # C93096</b>

BROWN & ROOT, INC.  
RECEIVED  
MAR 06 1980  
FILES NOTED  
QUALITY ASSURANCE

QA RECORD  
RTN.  OR REJECT  
**3/4/80**  
FILE NO.  
**81**  
SUB FILES  
**13376**

*S.W. 1229*

AUTHORIZED NUCLEAR INSPECTOR NOTIFICATION:  
DATE: \_\_\_\_\_ TIME: \_\_\_\_\_ MEDIA: \_\_\_\_\_ N/A  INIT. **DW**

ANI WITNESS: SAT. \_\_\_\_\_ ☆☆ UNSAT. \_\_\_\_\_ ☆☆ WAIVED \_\_\_\_\_ DATE \_\_\_\_\_  
☆☆ ANI'S INITIALS REQUIRED

STORAGE LOCATION: **Steel FAB** TYPE: **F**  
QC ENGINEER/INSPECTOR: **Dwight W. ...** DATE: **3/4/80**

# Brown & Root, Inc.

REPORT NO. 09152

## QUALITY ASSURANCE RECEIVING INSPECTION REPORT

70435--22E

UNIT <i>1E7</i>	SYSTEM <i>MECH</i>	COMPONENT <i>Stock For Hanger Assys</i>	IDENTIFICATION/SPIN NO. <i>N/A</i>	DWG./SPECIFICATION & REV. <i>GH2323 MS46A Rev.</i>
P.O. <i>CP-0046A.1</i>	MRR <i>CP-3968</i>	CHARACTERISTIC INSPECTION: <i>QI-QAP</i> <i>7.2-11</i> <i>JHM 2-7-79</i>		
VENDOR <i>N.P.S. Industries, Austin</i>	QR <i>N/A</i>	SAT. <input checked="" type="checkbox"/> UNSAT. <input type="checkbox"/> NCR _____ HOLD TAG _____		
APPARENT RESPONSIBILITY FOR UNSATISFACTORY ITEMS:		B&R <input type="checkbox"/> VENDOR <input type="checkbox"/> TRANSPORTER <input type="checkbox"/> <i>N/A</i>		
DATE DEFICIENCY DISCLOSED _____				

ITEM	QTY.	DESCRIPTION/REMARKS
		<p><i>660ft 4in. X 4in. X 3/8in Structural Tubing, A-500 Gr.-B</i></p> <p><i>160ft. Mic No: 145NT, and 500ft. Mic No. 497NTA</i></p> <p><i>1000ft. 6in. X 6in. X 3/8in Structural Tubing, A-500 Gr.-B</i></p> <p><i>720ft. Mic No: 814NT, 48ft. MIC#-734NT, and <sup>232</sup>232ft. Mic# 735A</i></p>

QA RECORD  
DATE: \_\_\_\_\_  
FILE NO. \_\_\_\_\_  
SUBFILE NO. \_\_\_\_\_  
*RIP# 9152*

BROWN & ROOT, INC  
RECEIVED  
FEB 15 1979  
FILES NOTED  
QUALITY ASSURANCE  
PPRV

*Shipping Notice - TX-SN-7211/TDA*

AUTHORIZED NUCLEAR INSPECTOR NOTIFICATION:

DATE: \_\_\_\_\_ TIME: \_\_\_\_\_ MEDIA: \_\_\_\_\_ N/A  INIT: *JHM*

ANI WITNESS: SAT. \_\_\_\_\_ ☆☆ UNSAT. \_\_\_\_\_ ☆☆ WAIVED \_\_\_\_\_ DATE \_\_\_\_\_

☆☆ ANI'S INITIALS REQUIRED

STORAGE LOCATION: *Warehouse "B"*  
*Hanger Yard* TYPE: *"E"*

QC ENGINEER/INSPECTOR  
*John A. [Signature]*

DATE  
*7 Feb-79*



# Brown & Root, Inc.

## QUALITY ASSURANCE DEPARTMENT NONCONFORMANCE REPORT (NCR)

(11) NCR No. M-2303

### QA RECORD

PAGE 1 OF 4

PROJECT CPSES		JOB NO. 35-1195		LOCATION OR ELEVATION	RIR NO
(2) UNIT	STRUCTURE SYSTEM	COMPONENT	TAG ID NUMBER		
2	CC/Aux. Bldg.	Sway Strut	CC-2-011-004-A73R	Aux. Bldg. 873'6"	N/A

(3) NONCONFORMING CONDITION	CP-CPM-6.9D	REV	0	PARA	2.5.5	(4) TREND CATEGORY	M-10
(3) DOCUMENT VIOLATED	CP-CPM-6.9D-11		0				
	CP-CPM-6.9F		0		1.0		

NPSI strut, SRS-06-R0-CC-561/8, has been shortened per CMC-35189. Material traceability was not maintained when strut was cut. Fitup was not performed by use of scribe lines as needed for a socket weld. CMC does not list a C-C dimension, only an overall hanger dimension.

Hold tag applied

(5) REPORTED BY Sam Bell	(6) DATE 5 / 29 / 80	(9) REVIEW APPROVAL <i>[Signature]</i>	(10) DATE 6 / 3 / 80
(7) PREPARED BY Sam Bell	(8) DATE 5 / 29 / 80	(11) ISSUED BY <i>[Signature]</i>	(12) DATE 6 / 3 / 80

(13) DISPOSITION ASSIGNED TO D. C. Frankum	(14) DUE DATE 6 / 12 / 80	(15) CORRECTIVE ACTION REQUEST CAR NO. <input checked="" type="checkbox"/> Required <input checked="" type="checkbox"/> Not Required S-41	(16) ASME CODE CLASS XX Yes - No
---	------------------------------	--	-------------------------------------

(17) DISPOSITION      REWORK       REPAIR \_\_\_\_\_      USE AS IS \_\_\_\_\_      SCRAP \_\_\_\_\_      X **DAC 6-5-80**

Rework per CMC-36686, attached.  
CMC-35189 R. 2 is void.

**INFORMATION  
COPY  
PPRV**

(18) CONSTRUCTION REVIEW APPROVAL <i>[Signature]</i>	(19) DATE 6/5/80	(20) QA REVIEW APPROVAL <i>[Signature]</i>	(21) DATE 6/5/80
(22) ENGR REVIEW APPROVAL N/A CH	(23) DATE 6/5/80	(24) AMR REVIEW APPROVAL <i>[Signature]</i>	(25) DATE 6/9/80

(26) VERIFICATION  
 Satisfactory     Unsatisfactory     Not Req'd

(27) QA QC ENGR INSPECTION VERIFICATION: <i>[Signature]</i>	(28) DATE 9/22/80
(29) AMR CONCURRENCE <i>[Signature]</i>	(30) DATE 9/22/80

(31) QA REVIEW CLOSURE  
*[Signature]*      (32) DATE  
9/22/80

(33) REMARKS  
**ARMS INDEXED**

DATE: \_\_\_\_\_

RTN.	QA REVIEW
L	CA 923-80
FILE NO.	15.1
SUBFILE NO.	N-2303

CC/186 **FOIA-85-59**

COMPONENT MODIFICATION CARD (CMC)

SERIAL NO. N<sup>o</sup> 35189

PEAK STEAM  
STATION (CPSES)

ORIGINATOR

1 DAL/B.McDONALD

NON PIPE  
SUPPORT

NAME

CPPE

ORIGINAL DESIGNER

DESIGN ERROR

4 REASON FOR CHANGE:


211-004-AF-17 REV 1

LINE NO / COMPONENT NO.

INSTRUCTIONS

NA  
MICR-0302  
R55094

6 SKETCH



NOTE: REMOVE (1) COUPLING NUT, SHORTEN PIPE 1/2" & REWELD AS SHOWN ABOVE.

INFORMATION  
COPY

3 APPROVED BY:

W.L. Gustafson 5-14-80

DATE

DATE

DATE

DATE

DATE

DATE

9 DISTRIBUTION

DCC  
CNTL  
NO.

QTY

1 NF0601

COMPONENT MODIFICATION CARD (CMC)

SERIAL NO. **Nº 36686**

JIMANCHE PEAK STEAM  
ELECTRIC STATION (CPSES)

DESIGN CHANGE/~~REVISION~~

NON-Q  WELD MOD.

REASON FOR CHANGE:

DESIGN ERROR  
REF. NCR # M-2303

ORIGINAL DESIGNER

ORIGINATOR  
**IAGLE McDONALD**  
NAME

CPPE

ORIGINAL DESIGNER


APPROVED BY  
**D. A. Gustafson** 6-4-80  
DATE

SKETCH

INSTRUCTIONS

MOVE **NA**

MAP ITEM # 3



**FOR ENGINEERING  
AND  
OFFICE USE ONLY**

**NA**

RS-06-RO  
WAY STRUT  
-C = 3'-8"

INFORMATION  
COPY  
PPRV

DISTRIBUTION

DCC  
CNTL  
NO.

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE





# Brown & Root, Inc.

INSPECTION REPORT

NCR M-2303  
Pg. 4 of 4

CC-2-011-004-A73R

PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-4	5-10	11-16

TAG SPIN IDENT NO						DRAWING SPECIFICATION NO				SERIAL NO	
A	B	C	D	E	F	G (Units)	H (Units)	I (Units)	J (Units)	K (Units)	L (Units)


PURCHASE ORDER NUMBER	VEND CODE
56-69	70-73

MRR NUMBER	RIR NUMBER	VENDOR'S HEAT/LOT/BATCH NO	COUNT	UNITS QUANTITY	PURCHS OR NO	RLS/HOLD NO	CODE	STATUS	INPUT DATE
74-79	80-85	86-95	96-105		106-111	112-121			122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: Close-out NCR M2303 as per assigned disposition.

RESULTS OF INSPECTION / SURVEILLANCE: Item #3 has been replaced w/ 8/9/80 Item 6 SALVAGED from Hng # BR-X-106-026-553R. This action completes disposition to NCR M2303.

Hold TAG removed



NCR NO. 2303

[Signature]  
QC ENGINEER/INSPECTOR

DATE 9/18/80

QUALITY CONTROL  
HANGER INSPECTION REPORT

Report No. Q-1-0058

IDENTIFICATION

HANGER NO. ① RH-1-005-069 C42R CLASS ② 2 DATE OF INSP. ③ Oct 28<sup>th</sup> 1990  
DRAWING NO. REV. ④ 0 CMC ⑤ 232/2 K1 PHBP ⑥ N/A

MATERIAL ACCEPTABILITY

GRADE/TYPE ⑦

Item #1 - 1/4" x 9" SA 36  
Item #2 - 1/2" x 11" A500 Gr B  
Item #3 - A507  
Item #10 - 1/2" x 1/2" Vendor supplied

HT NO. ⑧

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
N/A  
\_\_\_\_\_  
\_\_\_\_\_

INSTALLATION

DIMENSIONS ⑨ C. Patterson 10/28/90  
Inspector Date  
CONFIGURATION ⑩ C. Patterson 10/28/90  
Inspector Date  
FASTENERS ⑪ C. Patterson 10/28/90  
Inspector Date

SWAY STRUT ⑫ C. Patterson 10/28/90  
Inspector Date  
LOC. PER DWG. ⑬ C. Patterson 10/28/90  
Inspector Date

WELDING (Visual)

Fit-up Inspection ⑭ N/A  
Inspector Date  
All weld per ASME Sec. III ⑮ C. Patterson 10/28/90  
Inspector Date

ADDITIONAL NDE

<u>⑯</u>	<u>N/A</u>	Rev/Date	<u>⑰</u>	<u>N/A</u>	Date
Process	NDEP		Inspector		
	<u>N/A</u>			<u>N/A</u>	
Process	NDEP	Rev/Date	Inspector		Date

COMMENTS ⑱

Location & Elevation determined by field eng.

NCRs ⑲ \*2312 - closed out.

INFORMATION  
**COPY**  
PPRV


**FOIA-85-59**

CC/187

AS-BUILT



ITEM NO	NO REVD	DESCRIPTION	WT.	ASME OR ASTM	R	Q	MIC.
1		SPC-06-030 PIPE CLAMP		SA 36	C35		
2		FHN-12 4VY. HEX NUT		SA 36	C35		
3		RET-12 L-13 ROD		SA 36	C35		
4		ASME III NAME PLATE					
5		T.S. 4.4 x 3/8 - 10 1/2" LONG		A 500 GR 2 L			
6		T.S. 3 x 1/2 x 3"		SA 36	PFS		
7		T.S. 4 x 1 x 3" W/ 1/8" Ø HOLES AS SHOWN		SA 36	PFS		
8		T.S. 4 x 4 x 3/8 - 3' 8" LONG		A 500 GR 2 L			
9		SWS-06-RO 1 Sway Strut					

FOR OFFICE AND  
ENGINEERING USE ONLY



SECTION A-A

SEE BRHL FOR  
HIGR LOCATION



ELEV. LOOKING NORTH EAST

NOTES  
1) LOCATING DEVICES FOR HIGH STRENGTH BOLTS ARE NOT REQUIRED PER DCA 7507

VENDOR CERTIFIED  
DRAWING REV. NO. 4  
BY DATE 2-1-84

REV	DATE	DESCRIPTION	BY	CHK	APP
1	2-1-84	ISSUE FOR CONST. W.A.S. 1-2			
2		REVISIONS			
3		REVISIONS			
4		REVISIONS			

TO: 5801

REV	DATE	CHK'D	DATE	APPR'D	DATE
1	7-7-79	RD	7/19/79	RD	7-28-79
2					
3					
4					

REV	DATE	DESCRIPTION	BY	CHK	APP
1	7-7-79	PAINT CATALOG			
2		H.V.A.C.			
3		PIPE			
4		ZONE			

**Brown & Root, Inc.**  
CORPORATE OFFICE  
HOUSTON, TEXAS

**GIBBS & HILL INC.**  
ENGINEER  
PROJECT COMANCHE PEAK UNITS NO. 1 & 2

REV	DATE	DESCRIPTION	BY	CHK	APP
1	7-7-79	AS-BUILT			
2					
3					
4					

PA-015-009-C 422  
HANGER NUMBER

MATERIAL IDENTIFICATION LOG

Mat'l Spec	Material Description	Quantity	Heat/ID Number	Salvaged Hanger Number (where applicable)	QC Verification	Date
	STRT # 51-2-00A-406-5422		IT# B	TRBECOS	PA-015-009-C 422	10-23-80
	DUE TO NCR # 2362		ON	ORIGINAL VENDOR SUPC	JW	10/28/80
	IT # (8)	1	051897		Cyp	10/28/80
ASSOCUB	IT # (9)	1	4162901		Cp	10/28/80
SA-36	IT # (11)	1	551297		Cyp	10/28/80
ASSOCUB						

INFORMATION  
**COPY**  
PPRV

STRT FABBED PER CMC 33212A ~~82~~ 102380  
NEW STRUT TRIBBED OLD STRUT SCRAPPED PER L.W. 10/23/80  
TRANSFERRED FROM PAGE # J OF NCR-2362 (COPY IN PKG.)  
TRANSFERRED BY FB 10/28/80 Cp-QCI-1028/80

# SWAY STRUT MODIFICATION ONLY

MATERIAL IDENTIFICATION (cont)

RH-1-005-009-C42R  
MATERIAL NUMBER

Mat'l Spec	Material Description	Quantity	Host/ID Number	Salvaged Hanger Number (where applicable)	QC Verification & Date	Notes
SRS-06 item #13	BULK STRUT #18534-1 per cmc 33212 Rev 1.3	18534-1	370	62382PL, To Be removed, 2'3"	RH-1-005-009-C42R 6/12/82	

INFORMATION  
**COPY**  
PPRV

Failed strut per cmc JWB 6-12-82

QA RECORD

BROWN & ROOT, INC.  
Quality Assurance Department  
Nonconformance Report (NCR)  
CPSES-35-1105

INDEXED

NCR NO. M-2362

PAGE 1 OF 15

DRAWING/IDENTIFICATION	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
Pipe Support	RH-1-005-009-C42R	Reactor # 1 823'	N/A

NONCONFORMING CONDITION

DOCUMENT VIOLATED: CP-CPM-6.9F REV. 0 PARA. 3.0 TREND CATEGORY M-19  
G-3

Pipe support strut has been modified per CMC-33212 by shortening strut using 3000 pound coupling on about 4-23-80 (see WFML). Procedure CP-CPM-6.9F, VII, change notice number 2 was issued 4-28-80 to allow this type modification. The strut was modified prior to the 4-28-80 procedure issue. Therefore; strut is in an indeterminate condition as to alignment and fit-up and material traceability.

CMC directs relocating code plate which has been accomplished without QC or ANI verification or notification.

Hold tag applied

REPORTED BY: B. Snellgrove DATE: 6/18/80 REVIEWED BY: [Signature] DATE: 6-25-80 TIME: 9:15 a.m.

DISPOSITION RESPONSIBILITY: D. C. Frankum DISPOSITION ASSIGNED TO: [Signature] CAR NO.: S-41 ASME CODE ITEM: X Yes \_\_\_ No

DISPOSITION: REWORK \_\_\_ REPAIR \_\_\_ USE AS IS \_\_\_ SCRAP XX RETURN TO VENDOR \_\_\_

CMC will be revised deleting original strut and a new strut will be fabricated on site. Since strut is only item on this hanger with shop weld, CMC will also indicate that ASME plate is to be removed and given to QC for disposition.

INFORMATION COPY

CON. REVIEW/APPROVAL: [Signature] DATE: 16 July - 80 QC REVIEW: PPRV DATE: 12-5

ENG. REVIEW/APPROVAL: N. H. C. H. DATE: 7-14-80 [Signature] DATE: 7-18-80

QA/QC ENG. INSPR. VERIFICATION: [Signature] DATE: 10-29-80

ANI CONCURRENCE: [Signature] DATE: 10/20/80

QA REVIEW/CLOSURE: [Signature] DATE: 10/20/80

QA RECORD

RTN.	QA REVIEW
L	CH 115-80
FILE NO. 15.1	

SUBFILE NO.
11-3363

FOIA-85-59



CC/188

NC 11-11-82  
Pg. 2 of 15

ITEM NO.	REV.	DESCRIPTION	QTY	ASMT	UP	DATE	BY	CHK.
1	1	SRS-05-RO-CC-3-1/2" RIGID SWAY STRUT	1	DRY	5-1-80			
2	1	SFC-05-020 PIPE CLAMP	1	DRY	5-1-80			
3	4	FHN-12 NY HEX NUT	4	DRY	5-1-80			
4	2	RET-12 L-13" ROD	2	DRY	5-1-80			
5	1		1					
6	1		1					
7	1		1					
8	1	per CMC 33212	1					
9	1	per CMC 33212	1					
10	4	per CMC 33212	4					
11	1	per CMC 33212	1					
12	1	per CMC 33212	1					
7	1	lined through by mistake	1					

\* per CMC 33212  
B-11  
4-21-80


F.T.V. FIELD TO VERIFY



*For info only*

SECTION B-B

ISSUED BY DLU



REV	REV	REV	REV	DRAWN	DATE	DATE	APP'D	DATE
A	B	C	D	7/17/79	7/19/79	7/23/79		
P.O. NO. CP-00-6-01				MFG. REF. TC-211				
PRODUCTION CHECK				SERIAL NUMBER		SHEET		

INSPECTION REPORT





CLIENT/PROJECT CPSES JOB NO. CHL 33212  
SHEET 2 OF 2  
SUBJECT RH-1-005-009-C4213 ENGR. EW DATE 4/15/80  
CHK'D. \_\_\_\_\_ DATE \_\_\_\_\_

*Handwritten:* pg. 3 of 15

*Handwritten:* for info only

INFORMATION  
**COPY**  
PPRV

SECT A-A





COMANCHE PEAK STEAM  
ELECTRIC STATION (CPSES)

COMPONENT MODIFICATION CARD (CMC)

SERIAL NO. N° 33212

① APPLICATION: PIPE SUPPORT WELD MOD.  Q  NON-Q  DESIGN CHANGE/DEVIATION

② DWG. NO. NPS # 2167 REV. 0  
RH-1-005-009-C42R B&R REV. 0


④ REASON FOR CHANGE:  
REDESIGN AS PER FIELD CONDITION  
(HVAC DUCT & CONDUIT INTERFERENCE)

③ LINE NO./COMPONENT NO. N/A

⑦ ORIGINATOR  
ERNEST U. WA / HEBERT

CPPE NAME  
 ORIGINAL DESIGNER

⑤ INSTRUCTIONS:  
REMOVE   
DELETE ITEM#:  
4.) OF ITEM NO. ②  
11.) OF ITEM NO. ⑤  
REMOVE ITEM NO. ⑦ FROM ITEM  
⑤ AND RELOCATED TO ITEM NO. ②  
11.) OF ITEM NO. ⑥



⑧ APPROVED BY:  
Ernest U. Wa DATE 4/15/82

INFORMATION COPY  
DATE  
DATE  
DATE  
DATE  
DATE

ADD

ITEM NO.	QTY	SIZE	MAT
8	1	TS 4 x 4 x .375 - 10 1/2" LH	A500 4RF
9	1	FB 3" x 1/2" x 3"	SA-36
10	4	FD 1 1/2" x 1/2" x 4" w/ 1/8" offset VERT. AS SHOWN	SA-36
11	1	TS 4 x 4 x .375 - 3'-8 1/2" LH	A500 12B
12	1	1" SOCKET WELD COUPLER	A105

⑨ DISTRIBUTION  
NPS1 DCC CNTL NO. INFO QTY 2

ELEVATION  
LOOKING NORTH-EAST



Weld Filler Log  
Pg. 6 of 15

WDC Serial No. \_\_\_\_\_

Drawing No. RH-1-005-009-0422

WELD FILLER MATERIAL LOG

Weld No. NA

DRV  
5-1-80  
  
DRV  
5-1-80

WELD NO.	DATE	SIZE/CLASS	WELDER SYMBOL	WPS/ICN #	HEAT/LOT # or CODE #	AMT. ISS.	AMT. RT'D.	ISSUANCE APPROVAL
1/A	4/22/80	1/2	BGP	11032	482394	30	18	J. [Signature]
		E7018		7/0	026B204			
1/A	4/23/80	3/32 <sup>1/4-22</sup>	BGP	11032	464175	10	7	Gary S. Hill PP66
		E7018		7/0	026B602			

[Handwritten signature]

INFORMATION  
COPY  
PPRV

33217 33212

WDC SERIAL #  
DRAWING # AN-10-100-CH2R  
LINE # NA

MULTIPLE WELD DATA CARD

ITEM NO.	WPS NO.	REV.	ICN	WELD FILLER MATERIAL	WELD NOS.	P NO.	FABRICATION CODE & CLASS/ ACC STD ASME III-2
NA	11032	7	0	E7018	NA	1-1	

NOTES: 1. APPLICABLE QC/ANI HOLD POINTS SHALL BE INDICATED BY CHECKMARK  
 2. ANI INSPECTION POINTS INDICATED BY (X).  
 3. DENOTE SATISFACTORY INSPECTIONS BY AN "S"; UNSATISFACTORY INSPECTIONS BY A "U".

OPERATION #	OPERATIONS	
1	Support Number Identification	7 Spherical Bearings
2	Size, Configuration, Tolerance/Dwg.	8 All welds/Dwg. & WPS (V.T.)
3	Material Correct/Dwg.	9 Installation Complete
4	Fasteners Correct & Complete	10 Final PT/MT (as required)
5	Location & Elevation/Dwg.	11
6	Spring Can Stops Installed	12

PRODUCTION RELEASE

WELD NO.	OPERATION	HOLDPOINTS			CONST	SAT OR UNSAT	INSPECTION RESULTS (SIGN & DATE)			NOEP/REV.	MT&E # CALIB DUE DATE
		WT	QC	ANI			QC OR WT	NDE CERT LEVEL	ANI		
NA	1	NA	✓	NC		S	DRV 5-1-80	II			
NA	2	NA	✓	NC		S	DRV 5-1-80	II			
NA	3	NA	✓	NC		S	DRV 5-1-80	II			
NA	4	NA	✓	NC		S	DRV 5-1-80	II			
NA	5	NA	✓	NC		S	DRV 5-1-80	II			
NA	6	NA	<del>✓</del>	NC-20			N/A				
NA	7	NA	✓	NC		S	DRV 5-1-80	II			
NA	8	NA	✓	NC		S	DRV 5-1-80	II		acc 10-9-79	
NA	9	NA	NA	NC	JHSH		4-24-80				

Reviewed: *CM* 4-24-80

\* Location shot in by Field Engineers DRV 5-1-80

*JH* *MJD*

INFORMATION  
**COPY**  
PPRV





CLIENT/PROJECT

CPSES

pg. 9 of 15

SUBJECT

RH-1-005-002-C42R

JOB NO.

SHEET

OF


ENGR.

DATE

CHK'D.

DATE

2 OF 2  
SW 4/15/80



SECT A-A

INFORMATION  
COPY  
PPRV



# Brown & Root, Inc.

INSPECTION REPORT

*NCR #2362*  
*PG. 10 of 15*

*RH-1-005-009-C42R*

PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-4	5-10	11-16

TAG SPEC IDENT NO						DRAWING SPECIFICATION NO		SERIAL NO	
A	B	C	D	E	F	G	Units	H	Units
							17-55		

PUCHASE ORDER NUMBER	VEND CODE
56-99	10-13

MRR NUMBER	R/R NUMBER	VENDOR'S HEAT LOT BATCH NO	COUNT QUANTITY	UNITS	PURCHS OR NO	PLS/HOLD NO CODE STATUS	INPUT DATE
2-79	30-85	96-96	96-105		106-111	112-121	122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: *To verify the completeness of the dis-*  
*position to NCR #2362.*

RESULTS OF INSPECTION / SURVEILLANCE: *The inspection Results to the discription of*  
*NCR #2362 was found to be complete and satisfactorily accepted*  
*by the QCT. <sup>of 10/29/90</sup> Heat has been scrapped*  
*CODE PLATE HAS BEEN GIVEN TO Richard Wheeler Q.C. Sec 10/29/90*

*Hold Tag Removed.*

**INFORMATION COPY**  
**PPRV**

NCR NO 2362

*C. P. Patterson* Level II QCT  
 QC ENGINEER INSPECTOR

DATE Oct. 29<sup>th</sup> 1990

PPRV

MANCHE PEAK STEAM  
ELECTRIC STATION (CPSES)

COMPONENT MODIFICATION CARD (CMC)

SERIAL NO. NO 33212

SHT 1 OF 2

APPLICATION:  PIPE  WELD MOD.  NON- MAINTENANCE/REPAIR

(2) DWG. NO. NPS 2167 REV. 0  
RH-1-005-004-C42R B&R REV. 0

(3) LINE NO./COMPONENT NO. N/A

(4) REASON FOR CHANGE:  
REDESIGN AS PER FIELD CONDITION  
(HVAC DUCT & CONDUIT INTERFERENCE)  
REPLACE STRIP PER NCR 2362

(7) ORIGINATOR  
ERNEST A. WY / HERBERT


NAME

CPPE

ORIGINAL DESIGN '89

INSTRUCTIONS:

- (1) MOVE
- (2) DELETE ITEM:
- (3) ITEM NO. (2)
- (4) ITEM NO. (5)
- (5) ITEM NO. (7) FROM ITEM
- (6) RELOCATED TO ITEM NO. (2)
- (7) ITEM NO. (6)
- (8) DELETE ITEM NO. 12
- (9) MOVE ITEM FROM ITEM
- (10) Q.C. PRESENT AND
- (11) IT TO Q.C. FOR
- (12) ADD
- (13) ITEM NO. 117
- (14) ITEM NO. 141
- (15) ITEM NO. 42-36
- (16) ITEM NO. 42-36
- (17) ITEM NO. 3-84
- (18) ITEM NO. 42-36
- (19) ITEM NO. 42-36
- (20) ITEM NO. 42-36



(8) APPROVED BY:  
G. W. U. W. U.  
DATE 1/15/80  
M. J. J. J. J. J.  
DATE 1-15-80

DATE

DATE

DATE

(9) DISTRIBUTION  
NPS 1

DCC CNTL NO. 1070

CITY

THIS REVISION JOIDS  
AND SUPERSEDES  
DOCUMENT SERIAL NO.  
33212  
REV. 0





CLIENT/PROJECT

SUBJECT

IPSES

R4-1-005-009-C42R

ACK  
Pg. 12 of 15

JOB NO.

SHEET

2

C.

ENGR.

EW

DATE



9

CHK'D.

DATE

INFORMATION  
**COPY**  
PPRV

SECT A-A



MULTIPLE WELD DATA CARD

DRAWING # NA  
LINE # NA

ITEM NO.	WPS NO.	REV.	ICN	WELD FILLER MATERIAL	WELD NOS.	P NO.	FABRICATION CODE & CLASS/ ACC STD ASME III-2
NA	11032	7	0	E7018	NA	1-1	

NOTES: 1. APPLICABLE QC/ANI HOLD POINTS SHALL BE INDICATED BY CHECKMARK  
2. ANI INSPECTION POINTS INDICATED BY (X)  
3. DENOTE SATISFACTORY INSPECTIONS BY AN "S"; UNSATISFACTORY INSPECTIONS BY A "U".

OPERATION #	OPERATIONS	
1	Support Number Identification	7 Spherical Bearings
2	Size, Configuration, Tolerance/Dwg.	8 All Welds/Dwg. & WPS (V.T.) *
3	Material Correct/Dwg.	9 Installation Complete
4	Fasteners Correct & Complete	10 Final PT/MT (as required)
5	Location & Elevation/Dwg.	11 Verify assembly of ASME nameplate per AWS 33212.1
6	Spring Can Stops Installed	12

PRODUCTION RELEASE

WELD NO.	OPERATION	HOLDPOINTS			CONST	SAT OR UNSAT			INSPECTION RESULTS (SIGN & DATE)			NDEP/REV.	MT&E # CALIB DUE DATE
		WT	QC	ANI		UNSAT	QC OR WT	NDE CERT LEVEL	ANI				
NA	1	NA	✓	NC		S	DRV	5-1-80	II				
NA	2	NA	✓	NC		S	DRV	5-1-80	II				
NA	3	NA	✓	NC		S	DRV	5-1-80	II				
NA	4	NA	✓	NC		S	DRV	5-1-80	II				
NA	5	NA	✓	NC		S	DRV	5-1-80	II				
NA	6	NA	✗	NC-20			N/A						
NA	7	NA	✓	NC		S	DRV	5-1-80	II				
NA	8	NA	✓	NC		S	DRV	5-1-80	II			202 10-9-79	
NA	9	NA	NA	NC	JHSH			4-24-80					

Reviewed: *CM* 4-8-80  
 NA 11 NA ✓ NC\*\*  
 Reviewed: *CM* 10-27-80

\* Location shot in by Field Engineers DRV 5-1-80

INFORMATION  
**COPY**  
 PPRV

222. BAEK

xx Hold Point #1 waived by AWS T. Harper per Telcord 10-27-80 9:15 AM 10-27-80.

APPROVAL SIGNATURES SHALL BE APPLIED IN THE LINE IMMEDIATELY BELOW THE LAST STEP IN EACH SEQUENCE

\* Operations 1-8 are Final Inspections.

OPERATION	QTY	QC	ANI	UNSAT	NO. OF LEVEL	REV.	CALC. DUE DATE
<b>SWAY STRUT MODIFICATION</b> Operations as Established Below)							
B							
C							
D							
E.1							
E.2							
F							
G							
H							

A  
 B  
 C *10-23-80*  
 D *10-23-80*  
 E *10-23-80*  
 F *10/24/80*  
 G *10-23-80*  
 H

B Material added or deleted (document on MRS)  
 C ID/Marking transfer prior to cutting  
 D Acceptable TFS  
 E.1 Fit-up/Socket engagement (as applicable)  
 E.2 Final Surface/dimensional inspection  
 F (Reference Suppl. 6.9F-VIII)  
 G P/INT VT 200 10 6 79  
 H Dwg. Rev./CRC *NER M25.2*  
*CMC 33212 E.1*

WE

QC

ANI

MANUFACTURING RECORD SHEET  
BILL OF MATERIALS - SPOOL NO.

**THREADS UPSET (SAT)**  
*10-23-80*

ITEM	QUANTITY/ LENGTH/ SCHEDULE	RATING/ MATERIAL SPEC	TYPE/ GRADE	HEAT/CODE NUMBER	END PREP	APPLICABLE WELD NUMBERS	INSPECTOR INITIALS AND DATE
<i>No. 1125 Required</i>							

**INFORMATION COPY**  
 PPRV

NO.	OPERATION	B&R QC	ANI	B&R QC INIT	DATE	ANI INIT	DATE
1	DESIGN TRACEABILITY						
2	FINAL DIM'S/SURFACE COND. IDENT. REV						

ACCEPTANCE

B&R QA SIG. & DATE

ANI SIG. & DATE

3

ANC-33213 A  
NCR-2362

Welding  
Pg. 14 of 15

WDC SERIAL # 3887  
DRAWING # KH-1-05-09-042R  
LINE # NA

MULTIPLE WELD DATA CARD

ITEM NO.	WPS NO.	REV.	ICN	WELD FILLER MATERIAL	WELD NOS.	P NO.	FABRICATION CODE & CLASS/ ACC STD ASME III-2
NA	11032	7		E7018	NA	1-1	

NOTES: 1. APPLICABLE QC/ANI HOLD POINTS SHALL BE INDICATED BY CHECKMARK.  
2. ANI INSPECTION POINTS INDICATED BY (X).  
3. DENOTE SATISFACTORY INSPECTIONS BY AN "S"; UNSATISFACTORY INSPECTIONS BY A "U".

OPERATION #	OPERATIONS
1	Support Number Identification
2	Size, Configuration, Tolerance/Dwg.
3	Material Correct/Dwg.
4	Fasteners Correct & Complete
5	Location & Elevation/Dwg.
6	Spring Can Stops Installed
7	Spherical Bearings
8	All Welds/Dwg. & WPS (V.T.) *
9	Installation Complete
10	Final PT/MT (as required)
11	
12	

PRODUCTION RELEASE

WELD NO	OPERATION	HOLDPOINTS			CONST	SAT OR UNSAT		INSPECTION RESULTS (SIGN & DATE)			NDEP/REV.	MT&E # CALIB DUE DATE
		WT	QC	ANI		QC OR WT	NDE CERT. LEVEL	ANI				
NA	1	NA	✓	NC								
NA	2	NA	✓	NC								
NA	3	NA	✓	NC								
NA	4	NA	✓	NC								
NA	5	NA	✓	NC								
NA	6	NA	✓	NC								
NA	7	NA	✓	NC								
NA	8	NA	✓	NC								
NA	9	NA	NA	NC	✓							

Reviewed: [Signature] 10/28/20

HTR-B-1-0253



APPROVAL SIGNATURES SHALL BE AFFIXED IN THE LINE IMMEDIATELY BELOW THE LAST STEP IN EACH SEQUENCE.

\* Operations 1-9 are Final Inspections

WELM2362  
Pg. 15 of 15

WDC Serial No. 1178187

Drawing No. R11-1-005-009-CH2R

WELD FILLER MATERIAL LOG Weld No. NA

WELD NO.	DATE	SIZE/CLASS	WELDER SYMBOL	WPS/ICN #	HEAT/LOT # or CODE #	AMT. ISS.	AMT. RT'D.	ISSUANCE APPROVAL
4/1	4/22/80	1/2	BGP	11032	A82394	30	18	Jenny Hayden P155
		E7018		70	026B204			
4/A	4/23/80	3/32 X <sup>504</sup> + .22 <sup>70</sup>	BGP	11032	A64175	10	7	Gary A. Hill P966
		E7018		70	026B602			
E1	10-23-80	3/32	AWS	11032	643875	5	0	Roy D. Tarter P110
		E-7018		7-1	026B607			

DKV  
-1-80  
DKV  
-1-80  
W  
-2380

INFORMATION  
COPY  
PPRV

QA RECORD

BROWN & ROOT, INC.  
Quality Assurance Department  
Nonconformance Report (NCR)  
CPSES-35-1195

NCR NO. M-2386 R. 1

PAGE 1 OF 4

DRAWING/IDENTIFICATION	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
SW-1-027-005-J03R	SW-1-027-005-J03R	Service Water 798'9"	N/A

NONCONFORMING CONDITION

DOCUMENT VIOLATED: QAP-16.1 REV. 1 PARA. N/A TREND CATEGORY M-23

Sway strut, adjustable end has been replaced from unknown source while on hold (NCR M-2341). Disposition of initial NCR has not been determined, hold tag had been applied.

Revision 1:  
To clarify disposition.

Hold tag applied

REPORTED BY: Michal Norton	DATE: 6/20/80	REVIEW/APPROVAL <i>[Signature]</i>	DATE: 10/29/80	TIME: 9:15AM
DISPOSITION RESPONSIBILITY: D. C. Frankum	DISPOSITION ASSIGNED TO: J. J. Ryan	CAR NO.:	ASME CODE ITEM: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
DISPOSITION: REWORK <input type="checkbox"/> REPAIR <input type="checkbox"/> USE AS IS <input type="checkbox"/> SCRAP <input checked="" type="checkbox"/> RETURN TO VENDOR <input type="checkbox"/>				

1. Remove and scrap eye rod assembly.
2. Crafts are to be instructed to the requirements of QAP-16.1.

INFORMATION COPY

CON. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 10/29/80	QA/QC REVIEW: <i>[Signature]</i>	DATE: 10/29/80
ENG. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 11-7-80	ANI REVIEW: <i>[Signature]</i>	DATE: 11-7-80
QA/QC ENG/INSPECTION VERIFICATION: <i>[Signature]</i>	DATE: 11-9-80	INDEXED	
ANI CONCURRENCE: <i>[Signature]</i>	DATE: 12-9-80		
QA REVIEW/CLOSURE: <i>[Signature]</i>	DATE: 12-10-80		

QA RECORD

RTN.	QA REVIEW
L	3-6-80
FILE NO.	
SUBFILE NO.	

FOIA-85-59

CC/189

B. ...  
INSPECTION REPORT

152014

PLANT CODE	SYSTEM CODE	COMPONENT CODE
14	5-10	11-16

TAG/SPIN/IDENT NO.						DRAWING/SPECIFICATION NO.		SERIAL NO.	
A	B	C	D	E	F	G (Units)		H (Units)	
						17 55			

PURCHASE ORDER NUMBER	VEND CODE
56-69	70-73

MRR NUMBER	RIR NUMBER	VENDOR'S HEAT/LOT/BATCH NO.	COUNT	UNITS	PURCH'S QR NO.	RLS/HOLD NO. CODE	STATUS	INPUT DATE
74-79	80-85	86-95		QUANTITY	106-111		112-121	122-127
				96-105				

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: *partial closure of NCR m-2386 rev 1.*

RESULTS OF INSPECTION/SURVEILLANCE: *Sway Strut has been modified AND replaced per CMC 39981 per ATTACHED DOCUMENTATION. THIS CLOSES the disposition PART 1 of NCR m2386 Rev. 1*

NOTE: ORIGINAL STRUT WAS SCRAPPED BY CRAFT but WAS NOT WITHHELD BY QC. *SEB 12/18/12*

INFORMATION  
**COPY**  
PPRV



# Brown & Root, Inc.

INSPECTION REPORT

19304  
PAGE 2 OF 3

PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-4	5-10	11-18

TAG IDENT NO						DRAWING SPECIFICATION NO				SERIAL NO	
A	B	C	D	E	F	G	UNITS	H	UNITS	J	UNITS
SW-1-027-005-J03R											
17-55											

PURCHASE ORDER NUMBER	VEND CODE
56-69	10-73

MFR NUMBER	RIR NUMBER	VENDOR'S HEAT/LOT/BATCH NO	COUNT QUANTITY	UNITS	PURCH OR NO	RLS HOLD NO STATUS	CODE	INPUT DATE
74-79	80-85	86-95	96-105		106-111	112-121		122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: *partial done for NCR M-2386*  
*Rev. 1*

RESULTS OF INSPECTION / SURVEILLANCE: *Part 2 of the disposition has been accomplished by instructing the craft foreman and General foreman on the requirements of CP-QAP-16.1 per the attached memo.*

INFORMATION  
**COPY**  
 PERV

NCR NO *M-2386 Rev 1*

*J. R. Patton*  
QC ENGINEER INSPECTOR

DATE *12/9/82*





# Brown & Root, Inc.

P.O. BOX 1001 GLEN ROSE, TEXAS 76043

373

## MESSAGE

## REPLY

To NCR M-2386 Rev-1

DATE \_\_\_\_\_

*NCR M-2386 Rev-1  
12-4-80*

DATE 12/9/80

Purpose: To close NCRM-2386 R.1  
part 2 of the disposition: The  
following personnel received  
training on the requirements  
of CP-QAP-16.P. Instructors  
J. Patton - GC.

- RA Jeter A276 - General Foreman  
Lance Hollaway 0869 - Foreman

BY Patton

SIGNED \_\_\_\_\_

INSTRUCTIONS TO SENDER:

INSTRUCTIONS TO RECEIVER:

1. SEND TO JOB. FILE 2. SEND WHITE AND PINK COPIES WITH CARBON INTACT.

1. WRITE REPLY. 2. DETACH STUB, KEEP PINK COPY, RETURN WHITE COPY TO SENDER.

INFORMATION  
**COPY**  
PPRV

QA RECORD

BROWN & ROOT, INC.  
Quality Assurance Department  
Nonconformance Report (NCR)  
CPSES-35-1195

NCR NO. M-2341 R.1

PAGE 1 OF 6

DRAWING/IDENTIFICATION	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
SW-1-027-005-J03R	SW-1-027-005-J03R	Service Water 798'9"	N/A

NONCONFORMING CONDITION

DOCUMENT VIOLATED: QI-OAP-11.1-20 REV. 3 PARA. 3.1 TREND CATEGORY M-15

Support number SW-1-027-005-J03R, sway strut has been bent 10° off centerline, on adjustable end (West side) by unknown causes.

Revision 1:  
To clarify disposition.

Hold tag applied

REPORTED BY: Mike Norton	DATE: 6/10/80	REVIEW/APPROVAL <i>[Signature]</i>	DATE: 10/29/80	TIME: 9:15 AM
DISPOSITION RESPONSIBILITY: D. C. Frankum	DISPOSITION ASSIGNED TO: J. J. Ryan	CAR NO.:	ASME CODE ITEM: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
DISPOSITION: REWORK <input type="checkbox"/>	REPAIR <input type="checkbox"/>	USE AS IS <input type="checkbox"/>	SCRAP <input checked="" type="checkbox"/>	RETURN TO VENDOR <input type="checkbox"/>

See disposition to NCR M-2386.

ARMS  
INDEXED

DATE:

QA RECORD

RTN	QA REVIEW
FILE NO.	15.1
SUBFILE NO.	M-2341/R

CON. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 10/29/80	QA/QC REVIEW: <i>[Signature]</i>	DATE: 10/29/80
ENG. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 11/11/80	AN: REVIEW:	DATE:
QA/QC ENG/INSP/VERIFICATION: <i>[Signature]</i>	DATE: 12-9-80		
ANT. CONCURRENCE: <i>[Signature]</i>	DATE: 12-9-80		
QA REVIEW/CLOSURE: <i>[Signature]</i>	DATE: 12-10-80		

INFORMATION  
COPY

PPRV

FOIA-85-59

cc/190



# Brown & Root, Inc.

INSPECTION REPORT

154/11  
Pg 2 of 4  
PAGE \_\_\_ OF \_\_\_

PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-4	5-10	11-16

TAG/SPIN/IDENT NO						DRAWING SPECIFICATION NO		SERIAL NO
A	B	C	D	E	F	G	H	I
								17-55

PURCHASE ORDER NUMBER	VEND CODE
06-89	70-73

MRR NUMBER	R/R NUMBER	VENDOR'S HEAT LOT BATCH NO	COUNT QUANTITY	UNITS	PURCH OR NO	PLS/HOLD NO STATUS	CODE	INPUT DATE
74-79	80-85	96-95	96-105		106-111	112-121		122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

RESULTS OF INSPECTION / SURVEILLANCE \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

INFORMATION  
**COPY**  
 PPRV

MULTIPLE WELD DATA CARD

399510A-1 39981 A-4 10-15-80

ITEM NO.	WPS NO.	REV.	ICN	WELD FILLER MATERIAL	WELD NOS.	P NO.	FABRICATION CODE & CLASS/ ACC STD ASME III-
NA	11032	7	TI	E7012	NA	1-1	3

- NOTES: 1. APPLICABLE QC/ANI HOLD POINTS SHALL BE INDICATED BY CHECKMARK  
 2. ANI INSPECTION POINTS INDICATED BY (X).  
 3. DENOTE SATISFACTORY INSPECTIONS BY AN "S"; UNSATISFACTORY INSPECTIONS BY A "U".

OPERATION #	OPERATIONS
1	Support Number Identification
2	Size, Configuration, Tolerance/Dwg.
3	Material Correct/Dwg.
4	Fasteners Correct & Complete
5	Location & Elevation/Dwg.
6	Spring Can Stops Installed
7	Spherical Bearings
8	All Welds/Dwg. & WPS (V.T.) *
9	Installation Complete
10	Final PT/MT (as required)

PRODUCTION RELEASE

WELD NO.	OPERATION	HOLDPOINTS			CONST	SAT OR INSPECTION RESULTS (SIGN & DATE)				NDEP/REV.	MT&E # CALIB DUE DATE
		WT	QC	ANI		UNSAT	QC OR WT	NDE CERT LEVEL	ANI		
NA	1	NA	✓	NC		S	GKC 10/16/80	II			
NA	2	NA	✓	NC		S	GKC 10/16/80	II			
NA	3	NA	✓	NC		S	GKC 10/16/80	II			
NA	4	NA	✓	NC		S	GKC 10/16/80	II			
NA	5	NA	✓	NC		S	GKC 10/16/80	II			
NA	6	NA	✓	NC		NA	GKC 10/16/80	II			
NA	7	NA	✓	NC		S	GKC 10/16/80	II			
NA	8	NA	✓	NC		S	GKC 10/16/80	II			298/19
NA	9	NA	NA	NC	✓						

Reviewed: *[Signature]* 10-3-80

ARMS INDEXED

DATE

PERIOD: 10-3-80

L 17.1.04.13

BUFILE LOC Su-1-227-005-003R

FOR INFORMATION ONLY

INFORMATION COPY PPRV

FINAL REVIEWER: *J. Beaudette* 10/3/80

APPROVAL SIGNATURES SHALL BE AFFIXED IN THE LINE IMMEDIATELY BELOW THE LAST STEP IN EACH SEQUENCE.

\* Operations 1-8 are Final Inspections.

SAT OR INSPECTOR

CALIB  
DUE  
DATE

NCC M-23-1107  
P # 116

STAY STRUT MODIFICATION

(Operations as Established Below)

A  
B SW 10-7-80  
C SW 10-7-80  
D SW 10-7-80  
E N/A  
F  
G SW 10-7-80  
H

- B Material added or deleted (document on WPS)
- C ID/Marking transfer prior to cutting
- D Acceptable WPS
- E Fit-up/Socket Engagement (as applicable)
- F Final Surface/Dimensional Inspection (Reference Suppl. 6.9F-VII)
- G PT/MT (VT) 200 10-8-79  
Dwg. Rev./CMC 40020 R-1

**FOR INFORMATION ONLY**

WE

QC

Threads <sup>ANI</sup> UPSET SAT.  
SW 10-7-80

MANUFACTURING RECORD SHEET  
BILL OF MATERIALS - SPOOL NO.

ITEM QUANTITY/LENGTH SCHEDULE/RATING MATERIAL SPEC TYPE/GRADE HEAT/CODE NUMBER END PREP APPLICABLE WELD NUMBERS INSPECTOR INITIALS AND DATE

1 1/2 RS Required

INFORMATION  
**COPY**  
PPRV

NO.	OPERATION	B&R QC	ANI	B&R QC	INIT	DATE	ANI	INIT	DATE
1	DESIGN TRACEABILITY								
2	FINAL DIM'S/SURFACE COND. IDENT. REV								

ACCEPTANCE

B&R QA SIG. & DATE

ANI SIG. & DATE

WPS #  
11032

WCE M-554 R1  
 Pg. 4 of 6  
 504 12-10-80

WDC Serial No. 07914  
 Drawing No. SW-1.027-105-J  
 Weld No. NA


WELD FILLER MATERIAL LOG

10.7.80

WELD NO.	DATE	SIZE/CLASS	WELDER SYMBOL	WPS/ICN #	HEAT/LOT # or CODE #	AMT. ISS.	AMT. RT'D.	ISSUANCE APPROVAL
E	10/23/80	3/2 E-7018	B1H	11032 7-1	643875 026B607	5	1	Roger D. ... P109
NA	10/4/80	E7018 1/8	B3 R	11032 7-1	N94338 026B210	30	24	Jane Holloway P209
N/A	10/13/80	E7018 1/8	B6 N	11032 7-1	N94338 026B210	20	0	Jane Holloway P209
NA	10/16/80	E7018 1/8	B6 N	11032 7-1	N94338 026B210	20	11	Jane Holloway P-209
<p>10/16/80          ALL ENTRIES</p>								
<p><b>FOR INFORMATION ONLY</b></p>								
<p>INFORMATION  <b>COPY</b>          PPRV</p>								

MATERIAL IDENTIFICATION LOG

Saw-1-027-025-JOB #  
HANGER NUMBER



Mat'l Spec	Material Description	Quantity	Heat/ID Number	Salvaged Hanger Number (where applicable)	Date
	Heat Sec A	3728-3-5		to become Saw-1-027-025-3038	
	See CONC-40020			10-6-80	
SA36	1 1/2 X 7 Y 1/4 X 1/2 R	1	0715 307810	N/A	10-7-80
A500 GRB	1 1/2 X 7 Y 1/4 X 11'-0" TS	1	0713 054472	N/A	10-7-80
A500 GRB	1 1/2 X 7 Y 1/4 X 35 3/8"	1	0713 EC9854	N/A	10-10-80

FOR INFORMATION ONLY

Salvaged item 15, 13, 9 10-7-80

**Brown & Root, Inc.**  
 QUALITY ASSURANCE DEPARTMENT  
 CORRECTIVE ACTION REQUEST

OBJECT CPSES JOB NO 35 1195 UNIT: 1 & 2 PAGE OF  
 REQUEST NO S-41 GROUP ORGANIZATION Hanger Group/ Hal Goodson REPLY DUE DATE 6-23-80

REFERENCE DOCUMENT ASME III, NF-2150, NF-4122, MS-46A, ACP-3 and CP-CPM-6.9C

CONDITION DESCRIPTION

During ASME QA Surveillances S-003 (4-23/23-80) and S-009 (6-2 to date, 1980) identification of numerous discrepancies indicates there are significant generic problems in implementation of procedural and specification requirements.

This is a list of hanger related NCR's opened since 4-23-80 to present.

NCR M-2234	NCR M-2277	NCR M-2294 ✓	NCR M-2303 ✓	NCR M-2322
NCR M-2239	NCR M-2281 ✓	NCR M-2296	NCR M-2308	NCR M-2324 ✓
NCR M-2248	NCR M-2283	NCR M-2297	NCR M-2312 ✓	NCR M-2325
NCR M-2263	NCR M-2289	NCR M-2298	NCR M-2316	NCR M-2326
NCR M-2265	NCR M-2292	NCR M-2300	NCR M-2318	

See attached for list of findings.

REPLY REQUESTED FROM D. C. Frankum ACTION ADDRESSEE

INITIATED BY *A.P.M. Klimist* 6-9-80 PROJECT QA MANAGER DATE

CAUSE AND CORRECTIVE ACTION

*See IM-19464*

INFORMATION  
**COPY**  
 PPRV

QA RECORD

RTN	QA REVIEW
L	CH/235-81
FILE NO.	16.1
SUBFILE NO.	CARS-41

PREPARED BY *D. C. Frankum* 8/29/80 AUTHORIZED BY *D. C. Frankum* 12-17-80  
 NAME DATE

CORRECTIVE ACTION VERIFIED BY *Watten* 1/28/81  
 DATE

QA REVIEW CLOSURE BY *James E. ...* 1-28-81  
 DATE

**FOIA-85-59**

cc/191



Finding Number 1: Documentation


- A. MR. number 17988 has a discrepancy between the heat number and the MIC number (MRR88052). MR 17455 does not list vendor, RIR number or P.O. number.
- B. Person receiving material is not entering their badge number on MR.  
MR numbers 5243, 081309, 17455, 73870 and 72748
- C. Nuclear code class not entered on MR.  
MR numbers:      5043            60839            33298  
                  71035            60210            19452  
                  70378            60163            5243  
                  61240            49823            5211  
                  5042            5271            5041
- D. No "intended use" entry on MR.  
MR numbers: 64212, 46049 and 69812

Finding number 2: Hardware

- A. NPS - supplied SA-36 5/8" plate (RIR09590) is marked Grinnell with Nissen Marker.
- B. 5/8" plate marked SA-36 and SA-515 grade 65. 5/8" plate stamped "V", tag shows SA-36. Angle (MIC number 253NA) has wrong heat number. S/S 4"x20", 3"x9' and 3"x8'1" have no heat number.
- C. Either no or incorrect\*color code on the following:
- |                          |                     |        |               |
|--------------------------|---------------------|--------|---------------|
| Angle 4x4x $\frac{1}{2}$ | Ht. 2226NL          | SA-36  | No color code |
| Angle 3x3x $\frac{3}{8}$ | Ht. 86716           | SA-36  | No color code |
| W 8x17                   | Ht. W5              | SA-36  | No color code |
| W 6x16                   | Ht. 84154           | A-36*  | Color orange  |
| W 4x13                   | Ht. 170H355         | A-36*  | Color orange  |
| Plt 1-3/4                | Ht. 46291           | SA-515 | No color code |
| Plt $\frac{1}{2}$        | 4G2901              | SA-36  | No color code |
| Plt 3/4                  | 3G7719              | SA-36  | No color code |
| Plt 5/8                  | Mic 87ONF<br>E70986 | SA-36  | No color code |

Finding number 3: Craft Work Observation

- A. Craft using material from Laydown Yard without regard to heat number stamped in material.
- B. Craft person in Laydown Area number 6 not sure if material is intended for salvage or scrap.
- C. Craft using material from Laydown Area which has "Q" and Non "Q" mixed together.
- D. Craft not transferring material identification marking at the time the material is cut.




Attach to  
CAR S-41

6-19-80

This is a list of new NCR's against hangers issued since CAR S-41 was issued.

NCR M-2334	NCR M-2354
NCR M-2338	NCR M-2359
NCR M-2341 ✓	NCR M-2361
NCR M-2346	NCR M-2362 ✓
NCR M-2347	NCR M-2365
NCR M-2352	NCR M-2366

INFORMATION  
**COPY**  
PPRV



## INTEROFFICE MEMO

IM-19464

TO: J.V. Hawkins

DATE: August 28, 1980

FROM: J.P. Clarke, III

SUBJECT: Response to CAR S-41

An analysis of the NCR's referenced in the subject CAR revealed that of the NCR's referenced, approximately ten were due to inadequate traceability. To help in eliminating the inadequacies in the material traceability program, the following preventative actions have been taken:

- 1) Material identification markings have been reviewed and ASME materials identified and segregated from other safety-related materials.
- 2) The use of ink or paint markings only has been discontinued. Henceforth, heat number (or MIC, code, etc.) identification will be mechanically marked prior to cutting.

The remaining NCR's referenced in the CAR reflect predictable construction occurrences and are not addressed in this response. Instead, these varied types of problems are addressed daily by the appropriate levels of supervision to the craftspersons involved.

The following is offered in response to the findings discussed in the subject CAR:

Finding #1

- A. The NCR referenced MR#17988. The correct number is MR#17998. The RIR and MR for this item contains no discrepancy between heat and MIC numbers. The second allegation that MR#17455 does not list the vendor, RIR, or P.O. number is erroneous for two reasons: first, the correct MR number is MR#77453; secondly, the correct MR is on bulk pipe for which there is no requirement that vendor, P.O., or RIR number be noted.
- B. Four of the five MR's referenced do not have badge numbers listed. The first MR, number 5243 does have the receiver's badge number. The warehouse superintendent has cautioned all warehouse issue personnel to always require the receiving person's badge number.
- C. The referenced MR's issued miscellaneous, bulk material to the field. According to TUGCO QA and B&R QC receiving, procedure CPM 6.9C does not require entry of nuclear code class on MR's for miscellaneous bulk material.
- D. Three MR's were referenced which were indicated to lack an entry for "intended use". The first and last MR's were incorrectly identified and should be numbers 64272 and 69612, respectively, while two of the MR's do not have an "intended use" entry, the last MR, number 69612 does.


In conjunction with B above, warehouse personnel have been cautioned to always require an entry for "intended use" on MR's.

Finding #2

- A. The RIR referenced is on a NPS supplied plate. However, that plate is not marked Grinnell. The plate marked Grinnell was received/inspected per RIR-11180.
- B. The plate received/inspected per RIR-11180 has a metal tag (affixed by Grinnell) marked "SA-36/SA-515, grade 65". This plate was received on purchase order CP-46A/MR-17234 as SA-515, code "v". The angle referenced (MIC-253NA) had been identified by the Fab Shop as improperly documented and was relocated to "Yard 7", which is a non-Q yard. The material was moved while the surveillance was in progress.
- C. The craft's understanding of component support color coding is that it is not required to be maintained after it is issued from the warehouse, since they maintain material traceability by heat number or material specification number identification. To clear up this misunderstanding, the color coding has been deleted from the procedure as traceability is maintained by I.D. markings.

Finding #3

- A. The craft is not aware of this situation occurring. There is not adequate information contained in the finding to be able to address it.
- B. Material in Yard #6 is traceable Q material. Much of this material is from hangers which have been voided or deemed non-useable for their intended purpose. The decision to use this material will be on a case-by-case basis in accordance with CPM-6.9E, paragraph 3.13.
- C. The craft has no laydown yard where Q and non-Q are mixed. All yards except #7 are Q, and Yard #7 is non-Q. The "laydown area" referenced in the finding cannot be determined without further information.
- D. The craft marks all material, either mechanically or utilizing Nissen or Marsh markers, prior to cutting. This applies to material in the yards and in the shop.



  
J.P. Clarke, III  
Senior Staff Engineer



# Brown & Root, Inc.

INSPECTION REPORT

PAGE 1 OF 1

PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-4	5-10	11-18

TAG/SPIN/IDENT NO						DRAWING/SPECIFICATION NO		SERIAL NO	
A	B	C	D	E	F	G (Units)	H (Units)	J (Units)	
						17-55			

PURCHASE ORDER NUMBER	VEND CODE
56-69	70-73

MRR NUMBER	RIR NUMBER	VENDOR'S HEAT/LOT/BATCH NO.	COUNT QUANTITY	UNITS	PURCH'S OR NO.	RLS/HOLD NO. STATUS	CODE	INPUT DATE
74-79	80-85	86-95	96-105		106-111	112-121		122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: *To verify corrective action for CAR# 5-41.*

RESULTS OF INSPECTION / SURVEILLANCE: *This inspection report is to verify the corrective action listed per IM# 19464 of CAR# 5-41 has been satisfactorily accomplished.*

INFORMATION  
**COPY**  
PPRV

FORM NO. *CAR# 5-41*

*Patton*  
QC ENGINEER/INSPECTOR

DATE *1/28/81*



# Brown & Root, Inc.

P.O. BOX 1001 GLEN ROSE, TEXAS 76043

MESSAGE

REPLY

To: Gum Hawkins

FR: L.R. Shaw

DATE: 9-9-80

SUBJECT: CAR-41

Unable to accept Construction  
Response to CAR due to the  
following.

SA surveillances S-003 and S-009  
have not been presented nor  
closed

The following NCR's are still  
open, N. A-2239, M-2248, A-2263, M-2265  
A-2277, M-2281, A-2289, M-2297, M-2303

BY: Larry R. Shaw

DATE

AND A-2318

INFORMATION  
**COPY**  
PPRV

SIGNED

INTEROFFICE MEMO

IM-19465

TO: J.V. Hawkins

DATE: August 28, 1980

FROM: D.C. Frankum

SUBJECT: Open CAR's  
Reference: IM-19453

---


Concerning the referenced memo, the following information is provided.

CAR-32 - response submitted to QA, but "original" never returned to Construction for signature. This response was submitted sometime in April, 1980.

CAR-38 - response submitted to QA 9/17/79.

CAR-40 - closed 8/26/80.

CAR-41 - draft response submitted to QA 6/24/80 for review and comment. No comments received as of today, so final response will be submitted by 8/29/80.



D.C. Frankum  
Project Manager

DCF/cln


cc:


J.T. Merritt

R.G. Tolson


B.J. Murray

P.F. Foscolo









PC NO.	REV.	DATE	DESCRIPTION	ASME	GRADE	COLOR

REV. DATE DESCRIPTION

10 ISSUED FOR HANGER IDENTIFICATION AND ACCOUNTABILITY ONLY

4682 REDRAWN; REVISED AS NOTED & VERIFIED FOR STA. PROJ. #1-046T

- SW-1-129-003-A43R
- SW-1-129-046-A43R
- SW-1-129-045-A43R
- SW-1-129-043-A43R
- SW-1-129-044-A43K
- SW-1-129-004-A43R
- SW-1-129-725-A43R

WELD NO.	RT	MT	LP	UT

COST CODE PAINT INSUL. CL. THERM.

FLOW DIA. COMPOSITE SPEC. DESIGNER C.I. / CL.

**FOR OFFICE AND ENGINEERING USE ONLY**

TEXAS UTILITIES SERVICES INC. GLEN ROSE, TEXAS  
C. P. S. E. S.



**Brown & Root, Inc.**  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS




**TI APERTURE CARD**

STATION SERVICE WATER

Also Available On Aperture Card  
**8667100243-22**

"Q" DRAWING NO. 0402 DESGN. NO. BRHL-SW-1-A3-005 REV. 1




**TI**  
**APERTURE**  
**CARD**

Also Available On  
 Aperture Card

*Rm 775*

E

PIPE @ 820



BILL OF MATERIAL

PC NO.	HEAT NO.	DESCRIPTION	ASME ASTM	GRADE	COLOR CODE

REV.	DATE	DESCRIPTION	OWN.	CHK'D.	APP'D.
1	10/72	ISSUED FOR HANGER IDENTIFICATION AND ACCOUNTABILITY ONLY			
2	4/82	REDRAWN & REVISED AS NOTED; VERIFIED FOR STRESS PROBLEM #1-0522			

WELD NO.	RT	MT	LP	UT

COST CODE	PAINT	IRRA.	CL.	FRMS

8607100243-23

TEXAS UTILITIES SERVICES INC.  
C. P. S. E. S. GLEN ROSE, TEXAS

**Brown & Root, Inc.**  
ENGINEERS AND CONSTRUCTORS  
HOUSTON, TEXAS

DRAWING TITLE  
CHEMICAL & VOLUME CONTROL

FOR OFFICE AND ENGINEERING USE ONLY  
CC/193

QUALITY CONTROL  
HANGER INSPECTION REPORT

QI-QAP-11.1-28 Rev. 9  
QI-QAP-10.2-1 Rev. N/A  
QI-QAP-10.2-2 Rev. N/A

IDENTIFICATION

Hanger No. (1) 175-1-276-274-552K Class (2) 2  
Drawing No. Rev. (3) N/A

I. MATERIAL ACCEPTABILITY PER DRAWING AND NOTED ON M.I.L.

(4) H. Johnson II 4-27-82  
Inspector Level Date

II. INSTALLATION COMPLETE PER DRAWING

(5) H. Johnson II 4-27-82  
Inspector Level Date

a. Comments:

(i.e.) Snubber Not Installed

Other Scrub holes set

H. Johnson 4-27-82

H. Johnson 4-27-82

III. WELDING PER DRAWING INCLUDING ATTACHEMNTS

a. All weld per ASME Sec. III (6) H. Johnson II 4-27-82  
Inspector Level Date

b. ADDITIONAL NDE

c. HEAT TREAT

N/A  
Inspector

N/A  
Level

N/A  
Date

(7) N/A  
Process NDEP Rev/Date

N/A  
Inspector Level Date

N/A  
Process NDEP Rev/Date

N/A  
Inspector Level Date

COMMENTS: (8) N/A

NCRs: (9) ML-3354

INFORMATION  
**COPY**  
PPRV

**FOIA-85-59**

cc/194

K. POPE  
X 623

10-I

MS-1-076-009-552K  
LARGER WIDTH

MATERIAL IDENTIFICATION LOG

INFORMATION

Mat'l Spec	Material Description	Quantity	Heat/ID Number	QC Verification	Date
NA	1" X 12" SUPER HI-T KWIN BUTS	8	NA	Kirby Scott	3/12/82
SA36 SASIS GR65	1" X 13 1/8 X 15 7/8 C.S. RATE	1	803P26	1-23-82	
SA36 SASIS GR65	1 1/4" X 13 3/8 X 15 7/8 C.S. RATE	1	389591	H. Johnson 4-27-82	
SA36	5" X 8" X 22 3/4"	1	389564	H. Johnson 4-27-82	
AS50/GR.6	1/2" 6 X 6 T.S. 9 1/4"	1	C11645	H. Johnson 4-27-82	
SA-515 GR-65	1" 10" X 10" PL	1	CODE V	H. Johnson 4-27-82	
AS50/GR.8	1/2" 6 X 6 T.S. 5 1/2"	1	C11645	H. Johnson 4-27-82	
AS50/GR.8	1 1/4" X 3 1/2" X 5 1/8"	1	26695	H. Johnson 4-27-82	
AS50/GR.8	3/4" 5" X 5" PL	1	465699	H. Johnson 4-27-82	
SA36 SASIS GR65	1" PL-15 1/2" X 1 3/4"	1	CODE V	H. Johnson 4-27-82	
NA	5/8" X 8 1/2" HKB	6	NA	Kirby Scott	3/12/82
SA36 SASIS GR65	SAS OR STBOT	1	14841	H. Johnson 4-27-82	
SA36 SASIS GR65	KAR-10 R221101 KE	1	51042	H. Johnson 4-27-82	
SA36 SASIS GR65	KAR-08 R221101 KE	2	16660	H. Johnson 4-27-82	
SA36 SASIS GR65	KAR-08 R221101 KE	2	1-934	H. Johnson 4-27-82	

7 sheets RS Rev Mill 1-23-82 JRB

- \*3 MR 134474 - JRB 1-23-82
- \*2 MR 134364 - JRB 1-23-82
- \*1 MR 174053 - JRB 1-23-82
- FAB PER CHC #12, 13, 15, 16, 17, 11 PER MIL 2-11-82 G. JASSON

SCENM-3354 H. Johnson 4-27-82

M.S.-1-076-009-552 Rk  
4/1/82  
WATER NUMBER

MATERIAL IDENTIFICATION LOG

Mat'l Spec	Material Description	Quantity	Heat/ID Number	Salvaged Hanger Number (Where applicable)	QC Verification & Date	Notes
A500/B	T.S. 6x6x $\frac{1}{2}$ 12" Lg.	1 X	C11645	N/A	3/11/82 P. J. Johnson 4:25 PM	20R130246 27R3-12-82

INFORMATION  
**COPY**  
PPRV

Subbed T.S. 27R N 3-12-82

QUALITY CONTROL  
HANGER INSPECTION REPORT

QI-QAP-11.1-28 Rev. 9  
QI-QAP-10.2-1 Rev. 11  
QI-QAP-10.2-2 Rev. 11

IDENTIFICATION

Hanger No. (1) CS-1-158-027-S42R Class (2) 2  
Drawing No. Rev. (3) 2

I. MATERIAL ACCEPTABILITY PER DRAWING AND NOTED ON M.I.L.

(4) A Johnson II 4-29-82  
Inspector Level Date

II. INSTALLATION COMPLETE PER DRAWING

(5) A Johnson II 4-29-82  
Inspector Level Date

a. Comments:

(i.e.) Snubber Not Installed N/A  
Other N/A N/A

III. WELDING PER DRAWING INCLUDING ATTACHEMNTS

a. All weld per ASME Sec. III (6) A Johnson II 4-25-82  
Inspector Level Date

b. ADDITIONAL NDE c. HEAT TREAT N/A N/A N/A  
Inspector Level Date

(7) N/A N/A N/A  
Process NDEP Rev/Date Inspector Level Date

N/A N/A N/A  
Process NDEP Rev/Date Inspector Level Date

COMMENTS: (8) N/A

NCRs: (9) m-316E

INFORMATION  
**COPY**  
PPR MODIFICATION  
PPR TRN# 113191, 124741 + 127322  
CR 4/22/82

**FOIA-85-59**  
CC/195

Figure 16.1-1

BROWN & ROOT, INC.  
Quality Assurance Department  
Nonconformance Report (NCR)  
CPSES-35-1195

QA RECORD

NCR NO. M-3168

PAGE 1 OF 13

DRAWING/IDENTIFICATION	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
CS-1-158-027-S42R	CS-1-158-027-S42R	Safeguard #1 829'9"	N/A

NONCONFORMING CONDITION T/O 4900  
TREND  
DOCUMENT VIOLATED: CS-1-158-027-S42R REV. 2 PARA. N/A CATEGORY M-14

The drawing requires that item 3 be fabricated from S 3"x5.7. Contrary to the above, 3"x4.1 channel has been installed.

Note: IRN # 124741 issued to remove channel.

FOR INFORMATION ONLY

Hold tag applied

REPORTED BY: J. P. Patton	DATE: 1/26/82	REVIEW/APPROVAL <i>[Signature]</i>	DATE: 1/27/82	TIME: 10AM
ACTION ADDRESSEE J. Finneran		CAR NO.:	ASME CODE ITEM: XX Yes ___ No	

DISPOSITION: REWORK \_\_\_ REPAIR \_\_\_ USE AS IS XX SCRAP \_\_\_ RETURN TO VENDOR \_\_\_

Field survey indicates that support is installed per design. Rework has been accomplished in accordance with IRN's 113191, 127322, 124741 QC to re-inspect, and document re-inspection to above IRN's.

ARMS INDEXED INFORMATION  
DATE: \_\_\_\_\_  
QA RECORD  
MINOR REVIEW  
FILE NO. 151  
SUBFILE NO. M-3168  
PPR

COM. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 4-10-82	QA/QC REVIEW: <i>[Signature]</i>	DATE: 4/16/82
ENG. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 4-14-82	SSI REVIEW: Joe C. Hair	DATE: 4-19-82
QA/QC/ENG/INSBR. VERIFICATION: <i>[Signature]</i>	DATE: 5-3-82		
ANY CONCURRENCE: M. C. Hair	DATE: 5-24-82		
QA REVIEW/CLOSURE: <i>[Signature]</i>	DATE: 5/24/82		



INSPECTED ITEM REMOVAL NOTICE

SYSTEM / STRUCTURE DESIGNATION	IDENTIFICATION	ITEM DESCRIPTION	QC NOTIFIED BY
3105	05-1-158-027-542R	PIPE HANG	MONA...

THIS I&U TO CLARIFY IRN 12732  
 TO BE REMOVED AND SCRAP  
 NEW MATERIAL TO BE RE-INSTALLED

**MODIFICATION**

CO

INSPECTED ITEM REMOVAL NOTICE

IDENTIFICATION	QC NOTIFIED BY
05-1-158-027-542R	

Remove torque on shot base plate  
 to be replaced

Mike Holman  
 The Foreman Deal

REQUEST HANGER OR PARTS

Date: 1 / 21 / 82

FOREMAN: NORMAN HANGER NO.: CS-1-158-027-54ZR REV.: 2

ITEMS NEEDED PER PRINT: 3, 4

ITEMS NEEDED PER CMC: \_\_\_\_\_

CMC NO.: 31826 (INCORPORATED IN BRN) REV.: 1 T/O No.: \_\_\_\_\_

REQUEST MISC. MATERIAL FOR ABOVE HANGER

REQUEST ITEMS REFABBED & REASON


REQUEST RECEIVED BY: Waver DATE: 1-24-82 TIME: 10:23

BELOW TO BE FILLED OUT AT WAREHOUSE "A"

REQUEST REVIEWED BY: Rennie DATE: 1-21-82 TIME: 11:00

ITEMS TO TO BE FURNISHED BY WAREHOUSE: \_\_\_\_\_

ITEMS TO BE FABBED ON SITE: 3, 4, 5



ITEMS NOT AVAILABLE ON JOB SITE - ORDERED ON CPPA

Rennie J. [unclear] 1-21-82

TO FILLED OUT AT FAB SHOP

FABBED BY: J. R. Barron DATE: 1-21-82

ITEMS FABBED

HT. NO.'S

3 53'5" Blum  
4 1/4" x 2" x 2" L  
5 1/2" R

A  
1078 NL  
130200

REQUEST RETURNED TO FIELD  
REASON: \_\_\_\_\_

DATE: \_\_\_\_\_

CS-1-58-027-542R  
 TOWER HANGER

MATERIAL IDENTIFICATION LOG

Mat'l Spec	Material Description	Quantity	Host/ID Number	Salvaged Hanger Member (Where applicable)	QC Verification & Data	Notes
SA 36	5/8" x 5/8" x 1'10"	2	A	N/A	1-21-82 1-21-82	
SA 36	1/2" x 1/2" x 2" x 2" x 4 1/2"	2	1078NL	N/A	1-21-82 1-21-82	
SA 36	1/2" x 1/2" x 5/8" x 5/8" x 1'10"	2	80200	N/A	1-21-82 1-21-82	
SA-36	1" x 6" WFT	1	G5465	N/A	1-21-82 1-21-82	
N/A	1/2" x 5/8" HKB	3	N/A	N/A	1-21-82 1-21-82	
SA 307/B	1" HEX NUTS	2	N/A	N/A	1-21-82 1-21-82	
*	WTS 1/2-16Z				1-21-82 1-21-82	

INFORMATION  
**COPY**  
 PPRV

③  
 ④  
 ⑤  
 ⑥  
 ⑦  
 ⑧

7 of 10  
 #4 - MR 17217 of FRWD - 1-21-82  
 #3 - MR-5042 of FRWD - 1-21-82  
 #5 - MR-098236 of FRWD - 1-21-82

BA 000 38 (1987) PAGES

INSPECTION ITEM REMOVAL NOTICE

DATE 12-21-81	LOCATION SAFE ROOM	ITEM DESCRIPTION Acc
SYSTEM/STRUCTURE DESIGNATION FIRE SUPPORT	IDENTIFICATION PS-1-158-027-SHER	QC NOTIFIED BY CHAMBERLAIN

REASON FOR REMOVAL

THINNERS WERE USED INSTEAD OF 5" SHAPES ON THE CHAMBERLAIN

DIRTY TO EXHIBIT

PPRV  
COPY  
MODIFICATION  
INFORMATION

CS-1-158-027-542R  
HANGER NUMBER

MATERIAL IDENTIFICATION LOG

Mat'l Spec	Material Description	Quantity	Heat/ID Number	Salvaged Hanger Number (where applicable)	QC Verification	Date
SA 36	BASE PLATE	1	#5 462901	GKC 3/17/81	<div style="border: 2px solid black; padding: 5px; transform: rotate(-45deg); display: inline-block;">           INFORMATION COPY            PPRV         </div>	
SA 36	1/4 X 2 X 2 JOUANE	2	#4 NA 258	GKC 3/17/81		
SA 36	53 X 5.7 1-10"	2	#3 NA 436	GKC 3/17/81		
NA	1/2 X 5 1/2 H/H/S	3	#1 NA	NA		3-4-81
NA	1" X 6" 8g 140 p 1144	1	#2 NA	GKC 3/17/81		
SA 307	1" Hex nut	2	#7 NA			3/17/81
SA 36	53 X 5.7 = 1/10"	2	#3 C 31	GKC		3/17/81
SA 36	25 X 2 X 2 A = 0.42"	2	#4 C 3426	GKC		3/17/81
SA 36	2" X 2" X 1/16"	1	#6 388579	GKC		3/17/81
SA 36	OR RFT = 6 L <sub>2</sub>	1	#6 65465	GKC		3/17/81
	1/2 X 5 1/2 H/H/S	3		Reverified	VHS	3-11-81
	This material	removed per I	Rev 104199	284/39/82		

PPRV

Item # 34, 586 for Print Rev A

23 X 4 1/2  
MAR 17 1981

[

MAR 3/10/81

REQUEST HANGER OR PARTS

Date: 3 19 81

FOREMAN: CARTRET HANGER NO.: CS-1-158-027-542R REV.: 2

ITEMS NEEDED PER PRINT: #3-#4-#5-6#7 (INSIDE)

ITEMS NEEDED PER CMC: NONE

CMC NO.: \_\_\_\_\_ REV.: \_\_\_\_\_ T/O No.: 4900

REQUEST MISC. MATERIAL FOR ABOVE HANGER

REQUEST ITEMS REFABBED & REASON

BASE R. WRONG THICKNESS IRN# 104199

REQUEST RECEIVED BY: Crosby DATE: 3-9-81 TIME: 1.45


BELOW TO BE FILLED OUT AT WAREHOUSE "A"

REQUEST REVIEWED BY: Tom DATE: 3-9-81 TIME: 3:30

ITEMS TO TO BE FURNISHED BY WAREHOUSE: \_\_\_\_\_

ITEMS TO BE FABBED ON SITE: 3, 4, 5, 6

ITEMS NOT AVAILABLE ON JOB SITE - ORDERED \_\_\_\_\_



TO FILLED OUT AT FAB SHOP

FABBED BY: [Signature] DATE: 3/10/81

KGR  
3-10-81

ITEMS FABBED	HT. NO.'S	
<u>#3 53454</u>	<u>C-31</u>	<u>B.R.E. 2-11-81</u>
<u>4 25" X 2" X 2" G</u>	<u>C5426</u>	<u>B.C. 3-11-81</u>
<u>5 1/2" R</u>	<u>307578</u>	<u>B.C. 2-11-81</u>
<u>6 1" Round Rod</u>	<u>Q5465</u>	<u>B.C. 2-11-81</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____

RETURNED TO FIELD DATE: \_\_\_\_\_

MATERIAL RECORD

MARK NO. CS-1158-027-842R REV. CA PROD. RELEASE 2808 CODE ASME II | 2

ITEM NO.	01	02	03	04	05	06	07	08	09	10
MTC NO.	<u>BY FIELD NF 855 NW436 NA258</u>									
ITEM NO.	11	12	13	14	15	16	17	18	19	20
MTC NO.										
ITEM NO.	21	22	23	24	25	26	27	28	29	30
MTC NO.										

SUBASSEMBLIES

DRAWING/ITEM NO.	
MATERIAL	MTC NO.

DRAWING/ITEM NO.	
MATERIAL	MTC NO.

DRAWING/ITEM NO.	
MATERIAL	MTC NO.

**INFORMATION**  
**COPY**  
**PPRV**

Q.A. Review Lola Adams Date 5-24  
 S.C. Review \_\_\_\_\_ Date \_\_\_\_\_

MIC NO **NW 436**

BETHLEHEM STEEL CORPORATION  
METALLURGICAL DEPARTMENT

**331H466**

4328 (Rev. A 3 77)

DATE SHIPPED <b>3-27-79</b>	SHIPMENT NO. <b>3301-1656</b> <b>1/6 to 6/6</b>	CARRIER, INITIAL AND NO. <b>NP. 57507</b>	PLANT <b>SEATTLE</b>
--------------------------------	---	--	-------------------------

SOLD TO

GILMORE STEEL CORP.

SHIPPED TO

INFORMATION  
**PORTLAND**  
**PRV**

REPORT OF MECHANICAL AND CHEMICAL TESTS

Customer's Order No.	Section Slab or Mill Order No.	Heat No.	Description	Thickness	Yield Point	Tensile Strength	Elong. %	Red. %	Bends	CHEMICAL ANALYSIS				Specific Gravity or Remarks										
										C	Mn	P	S											
7902-42 UJ234-1764C		330H290	L 3½x3x3/8	ASTM: A36-77A	45610	67510	21.0		ok	.23	.50	.008	.020											
															331H488	L 3½x3x5/16	49060	68070	23.0	ok	.19	.50	.007	.019
															331H491	L 3½x3x1/4	48920	67840	22.0	ok	.23	.44	.012	.025
															331H488	L 3½x3x1/4	46440	66110	25.5	ok	.19	.50	.007	.019
															7902-15 UJ234-1732B	330H290	L 3½x3x3/8	45610	67510	21.0	ok	.23	.50	.008
7902-03 UJ234-1687*	331H498	L 3x2x1/4	47210	65300	22.5	ok	.19	.45	.007	.034	330H301	L 3x2x1/4	47330	64910	22.5	ok	.19	.40	.007	.023				
																					7809-25 UJ234-1477D*	330H290	L 3½x3x3/8	45610
7902-16 UJ234-1732A	330H280	L 3½x3½x3/8	46970	67230	27.0	ok	.21	.47	.021	.031														
7901-10 UJ234-1622B	331H466	S 3x5.7#	51780 ✓	70730 ✓	21.5 ✓	ok	.23 ✓	.45 ✓	.015 ✓	.022 ✓														
				WEIGHT	#157820																			

DOCUMENT REVIEWED	
P.O. # <b>10162</b>	MIC # <b>NW 436</b>
Q.C. SUPERVISOR <b>RBW</b>	DATE <b>4/16/79</b>

GILMORE STEEL CORP.  
 APPROVED BY: **W.A.Y.**  
 Q.C. CLERK  
 DATE **APR 05 1979**

I certify that the above results are a true and correct copy of records prepared and maintained by Bethlehem in compliance with the requirements of the specification cited above.

C. T. BURTCH  
CHIEF METALLURGIST

For **PETE**



MATERIAL VERIFICATION CHECKLIST

HANGER MARK # H-CC-1-EC-007-018-3

INFORMATION  
**COPY**  
PPRV

△ of BRH lists items # \_\_\_\_\_  
 △ of CP-AA 102 lists items # 1, 2  
 △ of CP-AA \_\_\_\_\_ lists items # \_\_\_\_\_  
 CMC \_\_\_\_\_ △ Revised items # \_\_\_\_\_  
 CMC 37146 △ Deleted items # 1  
 CMC 37146 △ Added items # 4, 5

REVISED BILL OF MATERIAL

ITEM #	QNTY	DESCRIPTION	HEAT, MIC, SALVAGE	QC VERIFIED
<u>2</u>	<u>1</u>	<u>PL 1x12x12</u>	<u>R1R13942</u> <u>MB 73411</u>	<u>✓</u>
<u>3</u>	<u>4</u>	<u>3/4x8 1/2 H.H.</u>	<u>NIA</u>	<u>✓</u>
<u>4</u>	<u>1</u>	<u>TS 4x4x3/8x6"</u>	<u>051392</u>	<u>✓</u>
<u>5</u>	<u>1</u>	<u>SME-1-B0 Snubber</u>	<u>Not Installed</u>	
	<u>2</u>	<u>Rear Brackets</u>	<u>NF 767</u>	<u>✓</u>

Susie Wassmann 5-17-82

NEED HEAT # FOR ITEMS # \_\_\_\_\_

ALL ITEMS TRACEABLE

**FOIA-85-59**

CC/196

Figure 16.1-1

QA RECORD

BROWN & ROOT, INC.  
Quality Assurance Department  
Nonconformance Report (NCR)  
CPSES-35-1195

NCR NO. M-3168

PAGE 1 OF 13

DRAWING/IDENTIFICATION	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
CS-1-158-027-S42R	CS-1-158-027-S42K	Safeguard #1 829'9"	N/A

NONCONFORMING CONDITION

T/O 4900

TREND

DOCUMENT VIOLATED: CS-1-158-027-S42R REV. 2 PARA. N/A CATEGORY M-14

The drawing requires that item 3 be fabricated from S 3"x5.7. Contrary to the above, 3"x4.1 channel has been installed.

Note: IRN # 124741 issued to remove channel.

Hold tag applied

REPORTED BY: J. P. Patton DATE: 1/26/82 REVIEW/APPROVAL: *[Signature]* DATE: 1/27/82 TIME: 10AM

ACTION ADDRESSEE: J. Finneran CAR NO.: ASME CODE ITEM: XX Yes      No

DISPOSITION: REWORK      REPAIR      USE AS IS XX SCRAP      RETURN TO VENDOR     

Field survey indicates that support is installed per design. Rework has been accomplished in accordance with IRN's 113191, 127322, 124741 QC to re-inspect, and document re-inspection to above IRN's.

ARMS INDEXED

DATE:

QA RECORD INFORMATION COPY

RTN.	DA REVIEW
L	2/15/82
FILE NO.	
SUBFILE NO.	M-3168

PPRV

CON. REVIEW/APPROVAL:	DATE: 11-14-82	QA/QC REVIEW:	DATE: 4/6/82
ENG. REVIEW/APPROVAL:	DATE: 4-14-82	API REVIEW:	DATE: 4-19-82
QA/QC ENG/INSBR. VERIFICATION:	DATE: 5-3-82		
API CONCURRENCE:	DATE: 5-24-82		
QA REVIEW/CLOSURE:	DATE: 5/24/82		

FOIA-85-59

cc/197



**Brown & Root, Inc.**  
INSPECTION REPORT

*11-3168*  
*pg. 6 of 13*

PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-4	5-10	11-16

*4942502*

TAG/SPIN/IDENT NO.						DRAWING/SPECIFICATION NO.			SERIAL NO.					
A	B	C	D	E	F	G, (Units)			H, (Units)			J, (Units)		
						17-58								

PURCHASE ORDER NUMBER	VEND CODE
56-89	70-73

MRR NUMBER	RIR NUMBER	VENDOR'S HEAT/LOT/BATCH NO.	COUNT	UNITS	PURCH'S OR NO.	RLS/HOLD NO. CODE	STATUS	INPUT DATE
74-79	80-85	86-95	96-105		106-111	112-121	122-127	

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: *NCR - 111-3168*

RESULTS OF INSPECTION/SURVEILLANCE: *Re-work and documentation accomplished satisfactorily per disposition of NCR - 111-3168*

*Hold Tag removed.*

INFORMATION  
**COPY**  
PPRV

NCR NO. *111-3168*

*[Signature]*  
QC ENGINEER/INSPECTOR

DATE *1/20/80*



QUALITY CONTROL  
HANGER INSPECTION REPORT

QI-QAP-11.1-28 Rev. 9  
QI-QAP-10.2-1 Rev. NA  
QI-QAP-10.2-2 Rev. NA

IDENTIFICATION

Hanger No. (1) SW-1-129-045-A43R Class (2) 3  
Drawing No. Rev. (3) 3

I. MATERIAL ACCEPTABILITY PER DRAWING AND NOTED ON M.I.L.

(4) Richard M. Smith II 5-28-82  
Inspector Level Date

II. INSTALLATION COMPLETE PER DRAWING

(5) Richard M. Smith II 5-28-82  
Inspector Level Date

a. Comments:

(i.e.) Snubber Not Installed NA  
Other SIGHT HOLES PRESENT NA 5-28-82

III. WELDING PER DRAWING INCLUDING ATTACHEMNTS

a. All weld per ASME Sec. III (6) Richard M. Smith II 5-28-82  
Inspector Level Date

b. ADDITIONAL NDE

c. HEAT TREAT

NA  
Inspector

NA  
Level

NA  
Date

(7) NA  
Process NDEP Rev/Date


NA  
Inspector Level Date

NA  
Process NDEP Rev/Date

NA  
Inspector Level Date

COMMENTS: (8) NA

NCRs: (9) M-3431



**MODIFICATION PACKAGE**

**MOD. WORK PER IRN** 124965

**ORIGINAL IN VAULT** RS 5-24-82

**FOIA-85-59**

CC/198

65095

NCC SERIAL #  
DRAWING # 5W-1-129-015-A432  
LINE # NA

14433R 156782 Jm

MULTIPLE WELD DATA CARD

WELD NO.	WPS NO.	QTY.	CON.	WELD FILLER MATERIAL	WELD NOS.	FAC.	FAB CODE & CLASS/ACC. STD.
NA	11032	P	O	E7018	NA	1-1	ASME III -3 CPM-9.10

- NOTES:
1. APPLICABLE TO ANY WELD POINTS SHALL BE INDICATED BY CHECKMARK
  2. ANY INSPECTION POINTS INDICATED BY (X)
  3. DENOTE UNSATISFACTORY INSPECTIONS BY AN "S". UNSATISFACTORY INSPECTIONS BY A "U".

OPERATIONS

1	Support Vessel Identification	Spherical Bearings
2	Size, Configuration, Tolerances/Dwg.	All welds/Dwg. & WPS (1-1) <i>SE-CAP 11-23</i>
3	Material Connect/Dwg.	Installation Complete
4	Fasteners Connect & Complete	Final PT/MT (as required) <i>10/2/82</i>
5	Location & Elevation/Dwg.	
6	Sealing Can Space Installed	

PREP: P SLATER 5-24-82

WELD NO.	OPERATION	CL. POINTS		CONST.	SAT OR INSPECTION RESULTS (DATE)			NCC/REL.	MTG # CALIB. DATE
		AT	QC		ANS	UNSAT	QC OR AT		
NA	1	NA	NA	NA	S	QC	5-28-82		
NA	2	NA	NA	NA	S	QC	5-28-82		
NA	3	NA	NA	NA	S	QC	5-28-82		
NA	4	NA	NA	NA	S	QC	5-28-82		
NA	5	NA	NA	NA	S	QC	5-28-82		
NA	7	NA	NA	NA	S	QC	5-28-82		
NA	8	NA	NA	NA	S	QC	5-28-82		
NA	9	NA	NA	NA	S	QC	5-28-82		

Reviewed: *G. Pauls 5/24/82*

\* VERIFIED REMOVAL OF ITEMS # 7 & 8 - NO HT. NOS PRESENT - REMOVED ITEMS 7 & 8 AND REPLACED WITH NEW ITEMS 7 & 8 (E48435) *Apr 5-28-82*

NO GROUT REQUIRED *Quinn M. Smith 5-28-82*

INFORMATION  
COPY  
PPRV

*Item # 43855 Trapped and sealed with NA (1) 1/2 x 5 1/2 Hella, and (1) 1/2 x 9 Hella *Per May 5-12-82**

*NCR M 3431 was closed 5-30-82 *Per 6-9-82**

MODIFICATION PACKAGE  
MCD. WORK PER IRN 12495  
ORIGINAL IN VAULT *RS 5-24-82*

INSTALLATION TO BE IN ACCORDANCE WITH PROCEDURES REFERENCED IN CPM 6.11  
*IN: R. Byers 9/22/87*

SA-1-129-045-A43R  
 JAMES WINTER

MATERIAL IDENTIFICATION LOG

Mat'l Spec	Material Description	Quantity	Heat/ID Number	Salvaged Hanger Number (where applicable)	QC Verification & In Process	Notes
SA36	1/2 x 5/8 x 8 1/2	1	E48435	N/A	QC 5/26/82 In Process 5/26/82	MR 201876
SA36	1/2 x 5/8 x 8 1/2	1	E48435	N/A	QC 5/26/82 In Process 5/26/82	MR 201876
NA	1/2 x 5 1/2 x KB	7	NA	NA	QC 5/27/82 In Process 5/27/82	
NA	1/2 x 9 x KB	1	NA	NA	QC 5/27/82 In Process 5/27/82	

INFORMATION  
**COPY**  
 PPRV

Failed items - 7/8 per print SWB 5-26-82

REVISION #  
 DATE

INFORMATION  
**COPY**  
INSPECTED ITEM FOR REMOVAL NOTICE

**777**  
 SEE AD

R&R Job 35-1195, CPSES	No 124915		
DATE 4/29/62	LOCAL PPRV Auc	ITEM DESCRIPTION See Below	QC NOTIFIED BY Reto Mason
SYSTEM - STRUCTURE DESIGNATION Sw-1	IDENTIFICATION Sw-1-129-095-A430		
REASON FOR REMOVAL			
<p>Cut items 7+8 from item #10 (T.S.)          if no heat #1  <b>MODIFIED</b>          and see if heat set ADDITIONAL INFORMATION - Per          NCR M-3431</p>			
<p>PR Part B NCR 142431          Rec'd 4-27-62          R.D. 5-19-62</p>			

125x




MATERIAL VERIFICATION CHECKLIST

HANGER MARK # SW-1-129-045-A43R IRN124915

3 of BRH lists items # 2, 3, 4, 5, 6, 7, 8, 9, 10

△ CMC 74483 REVISIED DELETED items # 2 QTY(7)  
 △ CMC \_\_\_\_\_ DELETED items # \_\_\_\_\_  
 △ CMC 74483 ADDED items # 11  
 △ CMC \_\_\_\_\_ ADDED items # \_\_\_\_\_  
 △ CMC \_\_\_\_\_ ADDED items # \_\_\_\_\_



REVISED BILL OF MATERIAL

ITEM #	QNTY	DESCRIPTION	HEAT, MIC, SALVAGE	QC VERIFIED
* 2	7	1/2" x 5 1/2" Hilti	NA	✓
3	1	Fig 211 B Strut	B-8678	✓
	1	Clamp	"A"	✓
	1	Rear Brkt	B-8678	✓
4	1	Fig 211 B Strut	B-8678	✓
	1	Clamp	"A"	✓
	1	Rear Brkt	B-8678	✓
5	1	4" Slanchion	"H"	✓
			"H"	✓
6	1	4" Slanchion	"H"	✓
* 7	1	R 1/2" x 8 1/4" x 8 1/2"	E <sup>48435</sup> <del>483</del>	✓
* 8	1	R 1/2" x 8 1/4" x 8 1/4"	E48435	✓
9	2	R 1/2" x 6" x 6 1/2"	1 Q 0200	✓
10	2	TS 1/2" x 4" x 4" x 10"	88484	✓
* 11	1	1/2" x 9" Hilti	NA	✓

NEED HEAT # FOR ITEM # \_\_\_\_\_

ALL ITEMS TRACEABLE

\* Verified in IRN 124915 MODIFICATION Package 1

MATERIAL VERIFICATION CHECKLIST

HANGER MARK # SH-1-129-045-R43R Original

of BRH lists items 2,3,4,5,6,7,8

CMC 48741  $\Delta$  Deleted items 1

CMC 48741  $\Delta$  Added items 9,10

REVISED BILL OF MATERIAL

QNTY	ITEM #	DESCRIPTION	HT, MIC, or SALVAGE #	VERIFIED BY QC
8	2	HKB	N/A	✓
1	3	STRUT 211 "B"	B-8678	✓
1	4	STRUT 211 "B"	B-8678	✓
1	5	H.S. 63 "C" C.S.	H	✓
1	6	H.S. 63 "C" C.S.	H	✓
1	7	$\frac{1}{2} \times 8\frac{1}{4} \times 8\frac{1}{2}$ PL.	<del>sampled</del> HT 88484	✓
1	8	$\frac{1}{2} \times 8\frac{1}{4} \times 8\frac{1}{4}$ PL.	<del>sampled</del> HT 88484	✓
2	9	$\frac{1}{2} \times 6 \times 6\frac{1}{2}$ PL.	HIG0200	✓
2	10	$\frac{1}{2} \times 4 \times 4$ PL.	HT88484	✓
		CIAMP	A	✓
		R. BRACKET	B8678	✓

INFORMATION COPY PPRV

Check item # 7+8 for heat #. No HT # for ITEM # 7, 8.

4/8/82

Date 4/12/82

Tracy Simmons

See Modification IIRN 124915

Weld Attachment in IIRN 124915 Modification Package

ALL ITEMS TRACEABLE

Figure 16.1-1

BROWN & ROOT, INC.  
 Quality Assurance Department  
 Nonconformance Report (NCR)  
 CPSES-35-1195

NCR NO. M-3431

QA RECORD

PAGE 1 OF 7

DRAWING/IDENTIFICATION	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
SW-1-129-045-A43R	SW-1-129-045-A43R	A.B. 820'2"	N/A

NONCONFORMING CONDITION

T/O 0402  
 TREND

DOCUMENT VIOLATED: CP-QAP-16.1 REV. 9 PARA. 2.2.2 CATEGORY M-19

Traceability for Items 7 and 8, the base plates for SW-1-129-045-A43R, can not be verified. There are no heat numbers on the documentation package or on the base plates.

ARMS  
 INDEXED

QA RECORD

RTN/	QA REVIEW
	4-16-82
FILE NO.	15.1
SUBFILE NO.	M-3431

DATE:

Hold tag applied.

REPORTED BY: Richard Gray	DATE: 4-16-82	REVIEW/APPROVAL <i>[Signature]</i>	DATE: 4-16-82	TIME: 2:30 PM
ACTION ADDRESSEE C. Moehlman		CAR NO.:	ASME CODE ITEM: XX Yes ___ No	

DISPOSITION:  
 REWORK XX REPAIR \_\_\_ USE AS IS \_\_\_ SCRAP \_\_\_ RETURN TO VENDOR \_\_\_

Remove Item 7 and 8 from wall, if heat number is visible at this time, transfer to a visible location with QC witness and re-install hanger. If heat numbers do not exist then replace Items 7 and 8 with new plates which have the proper traceability.

INFORMATION  
**COPY**  
 PPRV

CON. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 4-23-82	QA/QC REVIEW: <i>[Signature]</i>	DATE: 4-23-82
ENG. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 4-23-82	ANI REVIEW: <i>[Signature]</i>	DATE: 4-26-82
QA/QC ENG/INSPR. VERIFICATION: <i>[Signature]</i>	DATE: 5-30-82		
ANI CONCURRENCE: <i>[Signature]</i>	DATE: 5-30-82		
QA REVIEW/CLOSURE: <i>[Signature]</i>	DATE: 5-30-82		

FOIA-85-59

CC/199



**Brown & Root, Inc.**  
INSPECTION REPORT

NCR # M-3431  
page 3 of 7  
PAGE 1 OF 1

PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-4	5-10	11-16

TAG/SPIN/IDENT NO.						DRAWING/SPECIFICATION NO.		SERIAL NO.
A	B	C	D	E	F	G, (Units)		H, (Units)
SWI-129-045-A43R						17-56		

PURCHASE ORDER NUMBER	VEND CODE
56-89	70-73

MRR NUMBER	RIR NUMBER	VENDOR'S HEAT/LOT/BATCH NO.	COUNT QUANTITY	UNITS	PURCH'S OR NO.	RLS/HOLD NO. CODE STATUS	INPUT DATE
74-79	80-85	86-95	96-106		106-111	112-121	122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: CLOSURE OF NCR # M-3431.  
REMOVAL OF BASE PLATES ITEMS 7 & 8 TO CHECK FOR HT. NO.

RESULTS OF INSPECTION/SURVEILLANCE: VERIFIED REMOVAL OF BASE PLATE ITEM # 7 & 8  
AND NO HEAT NUMBER EXISTED - ITEMS 7 & 8 WERE RE-  
PLACED WITH NEW PLATES HT. NO. (E48435)

(1) HOLD TAG REMOVED

INFORMATION  
**COPY**  
P25V

NCR NO. M-3431

D. L. Smith Jr  
IC ENGINEER/INSPECTOR

5/28/82  
DATE

INDEXED

QA RECORD

BROWN & ROOT, INC.  
Quality Assurance Department  
Nonconformance Report (NCR)  
CPSES-35-1195

NCR NO. M-3354 R1

PAGE 1 OF 1

DRAWING/IDENTIFICATION	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
MS-1-076-009-S52K	MS-1-076-009-S52K	839' El. 5'10" North of 5-S	N/A

NONCONFORMING CONDITION

T/O #3401

TREND

CATEGORY M-19

DOCUMENT VIOLATED: QI-QAP-11.1-28 REV. 9 PARA. 3.1.1

Item number 12, T.S. 1/2" x 6" x 6", fabbed without QC verification for heat number transfer prior to cutting in Fab Shop. Hanger has been installed and welded. Heat #C11645

Revision 1: To re-open and change disposition.

HOLD TAG APPLIED

REPORTED BY: H. Johnson	DATE: 3/23/82	REVIEW/APPROVAL <i>R.C. Washington</i>	DATE: 9-2-82
ACTION ADDRESSEE J. Finneran		CAR NO.: NA	ASME CODE ITEM: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

DISPOSITION: REWORK  REPAIR  USE AS IS  SCRAP  RETURN TO VENDOR

C11645 is a valid heat number for 6" x 6" x 1/2" T.S. and is documented on shop records (attached) for a length of tube steel sufficient to fabricate items 12 & 15. These records conform to the information recorded on the MIL.

QA RECORD

RTN.	QA REVIEW
L	DA 9 10 82
FILE NO.	151
SUBFILE NO.	M-3354 R1

CON. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 9-2-82	QA/QC REVIEW: <i>R.C. Washington</i>	DATE: 9-2-82
ENG. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 9-8-82	ANI REVIEW: <i>[Signature]</i>	DATE: 9/5/82
QA/QC/ENG/INSPR. VERIFICATION: <i>R.C. Washington</i>	DATE: 9-9-82		
ANI CONCURRENCE: <i>[Signature]</i>	DATE: 9-9-82		
QA REVIEW/CLOSURE: <i>[Signature]</i>	DATE: 9-11-82		

INFORMATION  
**COPY**  
PPRV

FOIA-85-59

CC/200

ACR# M-3351R1  
 292010

INFORMATION  
**COPY**  
 PPRV


FABRICATOR: GOMESON DATE: 2-11-85

MATERIAL TYPE: (1-36 or SA-36) ACRYL: (CF, RB, NP)	MATERIAL SIZE	MATERIAL KIND	FOURGE USED	DRAWING NO. OR MR NO. OR HANGER NO.	HEAT NO., OR MIC. NO. OR CODE
PP 06430	3/8" X 4" X 4" ✓	TS	36"	CC-2-215-415-052K	26695 MR 128491
AS 00680	3/4" ✓	PL	12 1/2" X 15 3/4"	CC-2-215-415-052K	465629 MR 174185
SA 36 IF	1/2" X 6" ✓	TS	111-5"	MSI-076-009-552K	011645 MR 130245
SA 515 IF	1" ✓	PL	10" X 10"	M21-076-009 552K	00PEV MR 5271
AS 00680	3/8" X 4" X 4" ✓	TS	0'-5 1/8"	M21-076-009 552K	26695 MR 128491
SA 36 IF	3/4" ✓	PL	5" X 5"	MSI 076 009 552K	465629 MR 174185
SA 515 IF	1" ✓	PL	15 7/8" X 13 7/8"	MSI 076 009 552K	00PEV MR 5271



BLUELINE 1-25-82

NOTES  
 1) FOR REVIEW BY GCH SITE ANALYSIS, SUPPORT NEED BE DESIGNED TO DESIGN LOAD ONLY & NOT TO MAX SLUBBER RATING (REF GTN 40522 & 1007 PSE)  
 2) VALVE DNG. 354226 OF LOAD & VALVE INFO. FROM GTN 40522



NOTES  
 X = 7.030  
 Y = 4.128  
 Z = 0.093

PIPE MI-0606 REV. 10  
 G.H.I. ISO. MI-3239-41 REV. J  
 I.P.D. ISO. M8-1-58 03 REV. 4  
 Data Point 1241/1-1-79 D. R. B.  
 Pipe Mat'l. 2A322 044  
 Insul. 113 Bludg. 5

T. O. 3401

ITEM NO.	MATERIALS & OPERATIONS	QUANTITY	SHIP
7	5/8" X 1/2" HILTI-MAK COAK ANCHORS	6	
8	5/8" THK. C.S. PLATE FOR SECT. D (MARK 354226)	1	
9	5/8" X 1/2" SUPER HILTI COAK ANCHORS	6	
10	1" THK. C.S. PLATE, PER SECT. C (MARK 354226)	1	
11	1" X 10" X 1/2" C.S. PLATE (MARK 354226)	1	
12	1" X 10" X 1/2" C.S. PLATE (MARK 354226)	1	
13	1" X 10" X 1/2" C.S. PLATE (MARK 354226)	1	
14	1" X 10" X 1/2" C.S. PLATE (MARK 354226)	1	
15	1" X 10" X 1/2" C.S. PLATE (MARK 354226)	1	
16	1" X 10" X 1/2" C.S. PLATE (MARK 354226)	1	
17	1" X 10" X 1/2" C.S. PLATE (MARK 354226)	1	
18	KRD-10 RING BRACKET (MARK 354226)	1	
19	SAF-03-80 FIXED BRACKET, L=2", C-C=15.0"	1	

INFORMATION COPY PPRV

INFORMATION COPY PPRV

MARK B. M3-T-07C-009-S52K  
 PAINT CARBO ZINC II

CONDITIONS	Fx	Fy	Fz	Mx	My	Mz
DESIGN						
NORMAL						
EMERGENCY						
FAULTED						


FOR MATERIALS AND OPERATIONS SEE SKETCH NO. \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

PIPE: RUCD 1204 ELECT: MI-002-0182  
 STEEL: 21-0043 W-4 HV.A.C. MI-0053 E4

REF DRAWING NUMBERS  
 ELECT: MI-002-0182  
 HV.A.C. MI-0053 E4

BROWN & ROOT, INC.  
 ENGINEERS & CONSTRUCTORS






CUSTOMER: Texas Utilities Service, Inc.  
 ORDER OR CONT NO: CP-0046  
 JOB NAME: Comanche Peak 1A 2  
 PROJECT NO: 100-100-100-100-100  
 SHEET NO: \_\_\_\_\_ REV: \_\_\_\_\_



PLAN VIEW @ ELEV. 039'-0"



BLUELINE: 1-25-82



<b>BROWN &amp; ROOT, INC.</b> ENGINEERS & CONSTRUCTORS	
REF. DRAWING NUMBERS	
PIPE: _____	FLECT: _____
STEEL: _____	H.V.A.C.: _____
CUSTOMER: Texas Utilities Service, Inc.	
ORDER OR CONT. NO: CP-0046	
JOB NAME: Comanche Peak 1 & 2	
DRAWING NO: MS-1-076-009-552K	
SKETCH NO: _____	
SHEET 2 OF 2      REV. 1	

THIRD PARTY INSPECTION  
CODE CLASS: ASME III-2

REV.	DATE	BY	APP.	DESCRIPTION
1	1-22-82	MB	[Signature]	ISSUED FOR CONST. REF. PPHS
2	1-24-82	MB	[Signature]	REVISED PER DRAWING REF. PPHS REV. 1

T.O. 3401.

Chicago, Illinois 60638 U.S.A.

*1002-11-23-21-21  
PPRV  
CA 4/15/80*

# TEST REPORT

Invoice No. \_\_\_\_\_

Date 4-6-81

Customer:

Gulfalloy Inc.  
4730 Darien St  
P. O. Box 52518  
Houston, TX 77005

**FOR INFORMATION ONLY**

Specification:

6 Sq x 1/2 structural tubing  
ASTM A 500 Grade B 80  
Material produced in accordance  
with Q. A. program surveyed by  
Gulfalloy on 8-21-80

HEAT NO	CHEMICAL ANALYSIS, %									
	C	Mn	P	S						
C11045	.21	.75	.006	.018						
S11N05270	.24	.80	.022	.023						

## MECHANICAL PROPERTIES

HEAT NO	LAB NO	YIELD STRENGTH PSI	TENSILE STRENGTH PSI	ELONGATION %	HARDNESS R <sub>B</sub>
C11045	25588	65,500	71,500	25	
S11N05270	25586	66,200	72,100	27	

YIELD STRENGTH (0.2% OFFSET) — ELONGATION IN 2 INCHES


**INFORMATION  
COPY  
PPRV**

Witnessed and sworn to before me as  
Notary Public in and for the  
State of \_\_\_\_\_ County of \_\_\_\_\_  
this \_\_\_\_\_ day of \_\_\_\_\_ 19\_\_\_\_


*Dean R. Cantel*  
Metallurgist

BLUELINE 1-25-82

- NOTES
- 1) PER REVIEW BY GCH SITE ANALYSIS, SUPPORT NEED BE DESIGNED TO DESIGN LOAD ONLY & NOT TO MAX. SHUBBER RATING. (REF. GTN 40522 & 1007 PSE)
  - 2) VALVE DWG. 35A226 RF LOAD & VALVE INFO. FROM GTN 40522.



PLAN VIEW @ ELEV. 039'-0"



NOTES  
 X=7030  
 Y=120  
 Z=093

PIPE MI-0006 REV. 10  
 G.H.I. ISO. MI-2239-41 REV. J  
 I.P.D. ISO. MI-1-58-03 REV. 4  
 Data Point 1351/11-790828  
 Pipe Mat'l. SA333-085  
 Insul. 1 1/2 Bldg. 8

T.O. 3401

ITEM NO.	MATERIALS & OPERATIONS	QUAN.	SHIP
7	5/8" x 1/2" HILTI-KWIK CONC. ANCHORS	6	
8	5/8" THK. C.S. PLATE PER SECT. D D.W.M./S.A.P.P. 10/2	1	
9	S09-08-BA, C-C=5.4", SWAY STRUT	1	
10	1" x 12" BUTTER HILTI CONC. ANCHORS	6	
11	1" THK. C.S. PLATE, PER SECT. C-C	1	
12	1/2" x 2" x 5" T.S. 1" x 4" T.S.	1	
13	1" x 10" x 1/2" C.S. PLATE	1	
14	1/4" THK. C.S. PLATE PER SECT. B-B	1	
15	1/2" x 2" x 5" T.S. 1" x 4" T.S.	1	
16	3/4" x 4" x 4" T.S. 0" 5/16" LG.	1	
17	3/4" x 5" x 2" C.S. PLATE	1	
18	REQ-10 85M2 BRACKET (AUGUST 1982)	1	
19	5M2-03-80 FIXED SHUBBER, 12" x 2", C-C=10 1/2"	1	

FOR MATERIALS AND OPERATIONS SEE SKETCH NO.	CONDITIONS	Fx	Fy	Fz	Mx	My	Mz
	DESIGN						
	NORMAL & UPSET						
	EMERGENCY						
	FAULTED						






PIPE: PECD 1254 ELECT: 01-0005-01887  
 STEEL: 31-00-00 2 4 HV.A.C.: MI-0653 8 6

DESCRIPTION  
 INSULATED BRACKET FOR PIPE

REF. DRAWING NUMBERS  
 PECD 1254 ELECT: 01-0005-01887  
 HV.A.C.: MI-0653 8 6

CUSTOMER: Texas Utilities Service, Inc.  
 ORDER OR CONT NO: CP-0046  
 JOB NAME: Comanche Peak 1A 2  
 DRAWING NO: MI-1-58-03 REV. 4  
 SKETCH NO: 1351/11-790828  
 SHEET NO: 2 REV: 1

BLUELINE 1-25-82




<b>BROWN &amp; ROOT, INC.</b> ENGINEERS & CONSTRUCTORS	
<b>REF. DRAWING NUMBERS</b>	
PIPE: _____	FLECT: _____
STEEL: _____	HVAC: _____
CUSTOMER <u>Texas Utilities Service, Inc.</u>	
ORDER OR CONT. NO. <u>CP-0046</u>	
JOB NAME <u>Comanche Peak 1A2</u>	
MARK. NO. <u>MS-1-076-002-552K</u>	
SKETCH NO. _____	
SHEET 2 OF 2	REV 1

THIRD PARTY INSPECTION  
CODE CLASS: ASME III-2


T.O. 3401.

BLUELINE 1.25.82


NICK #1-3354R1  
PS 8710




SECTION B-B




SECTION C-C



SECTION D-D



SECTION A-A



<b>BROWN &amp; ROOT, INC.</b> ENGINEERS & CONSTRUCTORS	
REF. DRAWING NUMBERS	
PIPE: _____	FICT: _____
STEEL: _____	HVAC: _____
CUSTOMER: Texas Utilities Service, Inc.	
ORDER OR CONT. NO: CP-0046	
JOB NAME: Comanche Park 1A 2	
MARK NO: _____	
SKETCH NO: _____	
SHEET 2 OF 2      REV 1	

THIRD PARTY INSPECTION  
CODE CLASS: ASME III-2

REV	DATE	BY	APP	DESCRIPTION
1	1-27-82	MD	[Signature]	ISSUED FOR CONSTRUCTION PER THIS
2	2-1-82	MD	[Signature]	CONTRACT REVISION. SEE THIS REV.



# Brown & Root, Inc.

## INSPECTION REPORT

100-11-001-55214  
 2 of 7  
 PAGE 10 OF 1

PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-4	5-10	11-16

TAG/SPIN/IDENT NO						DRAWING/SPECIFICATION NO.			SERIAL NO
A	B	C	D	E	F	G (Units)		H (Units)	J (Units)
						17		56	

PURCHASE ORDER NUMBER	VEND CODE
56-89	70-73

MRR NUMBER	RIR NUMBER	VENDOR'S HEAT/LOT/BATCH NO.	COUNT QUANTITY	UNITS	PURCH'S OR NO.	RLS/HOLD NO. CODE STATUS	INPUT DATE
74 79	87-85	86-95	96-106		106-111	112-121	122 127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: NCR 11-3354

RESULTS OF INSPECTION/SURVEILLANCE: USE AS IS disposition of NCR-113354 accomplished Satisfactorily.

Hold Tag Removed.

INFORMATION  
**COPY**  
 PPRV

NCR NO. 11-3354

H. Johnson  
 QC ENGINEER/INSPECTOR

4/15/80  
 DATE

Figure 16.1-1

QA RECORD

BROWN & ROOT, INC.  
Quality Assurance Department  
Nonconformance Report (NCR)  
CPSES-35-1195

NCR NO. M-3354

PAGE 1 OF 1

DRAWING/IDENTIFICATION	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
MS-1-076-009-S52K	MS-1-076-009-S52K	839' 5'10" North of 5-S	N/A

NONCONFORMING CONDITION

DOCUMENT VIOLATED: Q1-QAP-11.1-28 REV. 9 PARA. 3.1.1 T/O 3401  
TREND  
CATEGORY M-19

Item number 12, T.S. 1/2"x6"x6", fabbed without QC verification for heat number transfer prior to cutting in Fab Shop. Hanger has been installed and welded.

Heat # C11645

Hold tag applied

*NCR# M-3354 R1  
pg. 10 of 10*

REPORTED BY: H. Johnson	DATE: 3/23/82	REVIEW/APPROVAL <i>[Signature]</i>	DATE: 3/24/82	TIME: 10 AM
ACTION ADDRESSEE J. Finneran		CAR NO.:	ASME CODE ITEM: XX Yes ___ No	

DISPOSITION: Rework \_\_\_ Repair \_\_\_ Use as is XX Scrap \_\_\_ Return to vendor \_\_\_

C11645 is a valid heat number for 6"x 3"x 1/2" T.S..

INFORMATION  
**COPY**  
PPRV

QA RECORD

DATE OF REVIEW	3/24/82
BY	15.1
NCR NO.	M-3354

CON. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 4-8-82	QA/QC REVIEW: <i>[Signature]</i>	DATE: 4/8/82
ENG. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 4-8-82	QA/QC REVIEW: <i>[Signature]</i>	DATE: 4-11-82
QA/QC ENGINEER VERIFICATION: <i>[Signature]</i>	DATE: 4/15/82		
QA CONCURRENCE: John M. Richardson	DATE: 4/15/82		
QA REVIEW/CLOSURE: <i>[Signature]</i>	DATE: 4/15/82		

Figure 16.1-1

QA RECORD

BROWN & ROOT, INC.  
Quality Assurance Department  
Nonconformance Report (NCR)  
CPSES-35-1195

NCR NO. M-3354

PAGE 1 OF 47  
CR

DRAWING/IDENTIFICATION	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
MS-1-076-009-S52K	MS-1-076-009-S52K	839' 5'10" North of 5-S	N/A

NONCONFORMING CONDITION  
DOCUMENT VIOLATED: QI-QAP-11.1-28 REV. 9 PARA. 3.1.1 I/O 3401  
TREND  
CATEGORY M-19

Item number 12, T.S. 1/2"x6"x6", fabbed without QC verification for heat number transfer prior to cutting in Fab Shop. Hanger has been installed and welded.

Heat # C11645

Hold tag applied

REPORTED BY: H. Johnson	DATE: 3/23/82	REVIEW/APPROVAL <i>Frank Lohel</i>	DATE: 3/24/82	TIME: 10 AM
ACTION ADDRESSEE J. Finneran			CAR NO.:	ASME CODE ITEM: XX Yes ___ No

DISPOSITION: REWORK \_\_\_ REPAIR \_\_\_ USE AS IS XX SCRAP \_\_\_ RETURN TO VENDOR \_\_\_

C11645 is a valid heat number for 6"x6"x 1/2" T.S..

ARMS  
INDEXED

DATE: \_\_\_\_\_

QA RECORD

REV. NO.	QA REVIEW
L	04/17/82
FILE NO.	15.1
SUPP. NO.	M-3354



CON. REVIEW/APPROVAL: <i>M. Chantala</i>	DATE: 4-8-82	QA/QC REVIEW: <i>[Signature]</i>	DATE: 4/14/82
ENG. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 4-8-82	QA/QC REVIEW: <i>[Signature]</i>	DATE: 4-14-82
QA/QC ENG. INSP. VERIFICATION: <i>[Signature]</i>	DATE: 4/13/82		
CONCURRENCE: <i>John M. Richardson</i>	DATE: 4/15/82		
QA REVIEW CLOSURE: <i>[Signature]</i>	DATE: 4/15/82		

INFORMATION  
COPY  
PPRV



AS BUILT

NOTES: CALL LOCATIONS DEVICES FOR HIGH STRENGTH BOLTS ARE NOT REQUIRED PER DCA 7402



CPSSES 35-1155 CONTROL COPY DOCUMENT CONTROL CENTER

BRHL ISO CC-2-AB-50 REV. 1  
I.P.D. Iss. CC-2-AB-25-10  
Data Point 2031 PAB16CRO  
Pipe Mat'l 304G GCS

SEE BRHL FOR HGR LOCATION

LOCATION PLAN

THIRD PARTY INSPECTION

ASME III - S

CODE CLASS:

ITEM NO.	PART CALL-OUT	DESCRIPTION	MATERIAL	MIC. NO.	WT.	REV.	DATE	BY	CHKD.	APP'D.	QTY	UNIT	REMARKS
1	ISA 1-517	CONC. ANKERS											
2	ISA 1-517	CONC. ANKERS											
3	ISA 1-517	CONC. ANKERS											
4	ISA 1-517	CONC. ANKERS											
5	ISA 1-517	CONC. ANKERS											
6	ISA 1-517	CONC. ANKERS											
7	ISA 1-517	CONC. ANKERS											
8	ISA 1-517	CONC. ANKERS											
9	ISA 1-517	CONC. ANKERS											
10	ISA 1-517	CONC. ANKERS											
11	ISA 1-517	CONC. ANKERS											
12	ISA 1-517	CONC. ANKERS											
13	ISA 1-517	CONC. ANKERS											
14	ISA 1-517	CONC. ANKERS											
15	ISA 1-517	CONC. ANKERS											
16	ISA 1-517	CONC. ANKERS											
17	ISA 1-517	CONC. ANKERS											
18	ISA 1-517	CONC. ANKERS											
19	ISA 1-517	CONC. ANKERS											
20	ISA 1-517	CONC. ANKERS											
21	ISA 1-517	CONC. ANKERS											
22	ISA 1-517	CONC. ANKERS											
23	ISA 1-517	CONC. ANKERS											
24	ISA 1-517	CONC. ANKERS											
25	ISA 1-517	CONC. ANKERS											
26	ISA 1-517	CONC. ANKERS											
27	ISA 1-517	CONC. ANKERS											
28	ISA 1-517	CONC. ANKERS											
29	ISA 1-517	CONC. ANKERS											
30	ISA 1-517	CONC. ANKERS											
31	ISA 1-517	CONC. ANKERS											
32	ISA 1-517	CONC. ANKERS											
33	ISA 1-517	CONC. ANKERS											
34	ISA 1-517	CONC. ANKERS											
35	ISA 1-517	CONC. ANKERS											
36	ISA 1-517	CONC. ANKERS											
37	ISA 1-517	CONC. ANKERS											
38	ISA 1-517	CONC. ANKERS											
39	ISA 1-517	CONC. ANKERS											
40	ISA 1-517	CONC. ANKERS											
41	ISA 1-517	CONC. ANKERS											
42	ISA 1-517	CONC. ANKERS											
43	ISA 1-517	CONC. ANKERS											
44	ISA 1-517	CONC. ANKERS											
45	ISA 1-517	CONC. ANKERS											
46	ISA 1-517	CONC. ANKERS											
47	ISA 1-517	CONC. ANKERS											
48	ISA 1-517	CONC. ANKERS											
49	ISA 1-517	CONC. ANKERS											
50	ISA 1-517	CONC. ANKERS											

FOR OFFICE AND ENGINEERING USE ONLY

REV.	DATE	BY	DESCRIPTION
1	11/19/90	W.P.	REV AS NOTED PER DCA 7607
2	11/19/90	W.P.	REV AS NOTED PER DCA 7607
3	11/19/90	W.P.	REV AS NOTED PER DCA 7607
4	11/19/90	W.P.	REV AS NOTED PER DCA 7607
5	11/19/90	W.P.	REV AS NOTED PER DCA 7607
6	11/19/90	W.P.	REV AS NOTED PER DCA 7607
7	11/19/90	W.P.	REV AS NOTED PER DCA 7607
8	11/19/90	W.P.	REV AS NOTED PER DCA 7607
9	11/19/90	W.P.	REV AS NOTED PER DCA 7607
10	11/19/90	W.P.	REV AS NOTED PER DCA 7607
11	11/19/90	W.P.	REV AS NOTED PER DCA 7607
12	11/19/90	W.P.	REV AS NOTED PER DCA 7607
13	11/19/90	W.P.	REV AS NOTED PER DCA 7607
14	11/19/90	W.P.	REV AS NOTED PER DCA 7607
15	11/19/90	W.P.	REV AS NOTED PER DCA 7607
16	11/19/90	W.P.	REV AS NOTED PER DCA 7607
17	11/19/90	W.P.	REV AS NOTED PER DCA 7607
18	11/19/90	W.P.	REV AS NOTED PER DCA 7607
19	11/19/90	W.P.	REV AS NOTED PER DCA 7607
20	11/19/90	W.P.	REV AS NOTED PER DCA 7607
21	11/19/90	W.P.	REV AS NOTED PER DCA 7607
22	11/19/90	W.P.	REV AS NOTED PER DCA 7607
23	11/19/90	W.P.	REV AS NOTED PER DCA 7607
24	11/19/90	W.P.	REV AS NOTED PER DCA 7607
25	11/19/90	W.P.	REV AS NOTED PER DCA 7607
26	11/19/90	W.P.	REV AS NOTED PER DCA 7607
27	11/19/90	W.P.	REV AS NOTED PER DCA 7607
28	11/19/90	W.P.	REV AS NOTED PER DCA 7607
29	11/19/90	W.P.	REV AS NOTED PER DCA 7607
30	11/19/90	W.P.	REV AS NOTED PER DCA 7607
31	11/19/90	W.P.	REV AS NOTED PER DCA 7607
32	11/19/90	W.P.	REV AS NOTED PER DCA 7607
33	11/19/90	W.P.	REV AS NOTED PER DCA 7607
34	11/19/90	W.P.	REV AS NOTED PER DCA 7607
35	11/19/90	W.P.	REV AS NOTED PER DCA 7607
36	11/19/90	W.P.	REV AS NOTED PER DCA 7607
37	11/19/90	W.P.	REV AS NOTED PER DCA 7607
38	11/19/90	W.P.	REV AS NOTED PER DCA 7607
39	11/19/90	W.P.	REV AS NOTED PER DCA 7607
40	11/19/90	W.P.	REV AS NOTED PER DCA 7607
41	11/19/90	W.P.	REV AS NOTED PER DCA 7607
42	11/19/90	W.P.	REV AS NOTED PER DCA 7607
43	11/19/90	W.P.	REV AS NOTED PER DCA 7607
44	11/19/90	W.P.	REV AS NOTED PER DCA 7607
45	11/19/90	W.P.	REV AS NOTED PER DCA 7607
46	11/19/90	W.P.	REV AS NOTED PER DCA 7607
47	11/19/90	W.P.	REV AS NOTED PER DCA 7607
48	11/19/90	W.P.	REV AS NOTED PER DCA 7607
49	11/19/90	W.P.	REV AS NOTED PER DCA 7607
50	11/19/90	W.P.	REV AS NOTED PER DCA 7607

FOIA-85-59

cc/201


FOR OFFICE AND  
ENGINEERING USE ONLY

DUPLICATE 1-26-81


AS-BUILT

VENDOR CERTIFIED  
DRAWING REV. NO. 4  
BY DATE/INITIALS

★ CHANGE NOT MADE  
BY CHNG



NOTE:  
1) BY ISSUE OF REV. 2 OF THIS DRAWING THE FOLLOWING DOCUMENTS ARE VOIDED:  
2) 100-1-106-100-3  
3) Loading devices for high strength bolts are not required per DCA 7607



SECTION A-A  
SECTION B-B  
SECTION C-C  
SECTION D-D  
SECTION E-E  
SECTION F-F  
SECTION G-G  
SECTION H-H  
SECTION I-I  
SECTION J-J  
SECTION K-K  
SECTION L-L  
SECTION M-M  
SECTION N-N  
SECTION O-O  
SECTION P-P  
SECTION Q-Q  
SECTION R-R  
SECTION S-S  
SECTION T-T  
SECTION U-U  
SECTION V-V  
SECTION W-W  
SECTION X-X  
SECTION Y-Y  
SECTION Z-Z

THIRD PARTY INSPECTION  
CODE CLASS: ASME III-D

DATE: 1-26-81  
I.P.D. No. SA-1-AD-00-01  
Data Point: 237 / AS-1-81-RO  
Pipe Mat'l: SA065R B  
Insm: SA065R A

TOP 402

ITEM NO.	MATERIALS & OPERATIONS	QUAN	SHIP	REV	DATE	BY	CHK	APP
1	SEISMIC SWAY STRUT ASSEMBLY CONSISTING OF: 1 1/2" x 10" Carbon Steel (SA-516-GR 65) 2x2x2 1/2" x 5 1/2" Hilli Kwik Concrete Anchors 111111	ONE						
2	Fig. 211 "S" SWAY STRUT ASSEMBLY 4 1/2" O.D. SLOPE CARBON STEEL 1/4" x 3 1/8" LOADS 2295 LB	7						
3	Fig. 211 "S" SWAY STRUT ASSEMBLY 4 1/2" O.D. SLOPE CARBON STEEL 1/4" x 3 1/8" LOADS 2297 LB	1						
4	H.S. 63 "C" Carbon Steel (SA-106 GR B) 4" STANCHION 10" PINE DEL-2 1/4" F-0-	1						
5	9 3/8" LASS BASE PLATE TM-88	1						
6	H.S. 63 "C" Carbon Steel (SA-106 GR B) 4" STANCHION 10" PINE DEL-2 1/4" F-1-	1						
7	3 1/8" LASS BASE PLATE TM-134	1						
8	1 1/2" x 5 1/2" HILLI KWIK CONCRETE ANCHORS	1						
9	BY C. BARRERA							
10	SEISMIC ASSEMBLY SKETCH AND ENGINEERING BUNDLE AND TAG MAGA # SW-1-129-045-AA3R							
11	Apply one coat of URGOL ZINC #11 to above mat'l except th'ds which shall be coated w/8 rust preventative.							
12	1/2" THICK 5/8" DIA. FOR SECTION A-A (SA-316) 1/2" THICK 5/8" DIA. FOR SECTION B-B (SA-316)							
13	2.5" DIA. x 2.5" (SA-260-SS-316) (2 ea)							
14	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
15	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
16	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
17	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
18	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
19	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
20	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
21	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
22	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
23	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
24	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
25	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
26	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
27	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
28	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
29	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
30	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
31	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
32	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
33	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
34	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
35	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
36	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
37	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
38	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
39	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
40	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
41	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
42	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
43	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
44	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
45	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
46	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
47	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
48	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
49	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							
50	1.5" DIA. x 1.5" (SA-260-SS-316) (2 ea)							

FOIA-85-59  
CC/202



This is a Duplicate Package Required For Modification Work (NCR 2341-2nd)

CNC LOG	
40020A	VOID 12/3/80
39981A	
39981A	12/03/80

Original In Vault  
MULTIPLE WELD DATA CARD

WDC SERIAL #  
DRAWING # SW-1-027-005-JMSR  
INDEXED LINE # NA

ITEM NO.	WPS NO.	REV.	ICN	WELD FILLER MATERIAL	WELD NOS. DATE	P NO.	FABRICATION CODE & CLASS/ ACC STD ASME III-3
NA	11032	7	1	E7018	NA	1-1	

- NOTES: 1. APPLICABLE QC/ANI HOLD POINTS SHALL BE INDICATED BY CHECKMARK  
2. ANI INSPECTION POINTS INDICATED BY (X).  
3. DENOTE SATISFACTORY INSPECTIONS BY AN "S"; UNSATISFACTORY INSPECTIONS BY A "U".

OPERATION #	OPERATIONS
1	Support Number Identification
2	Size, Configuration, Tolerance/Dwg.
3	Material Correct/Dwg.
4	Fasteners Correct & Complete
5	Location & Elevation/Dwg.
6	Spring Can Stops Installed
7	Spherical Bearings
8	All welds/Dwg. & WPS (V.T.)
9	Installation Complete
10	Final PT/MT (as required)
11	
12	

PRODUCTION RELEASE

WELD NO.	OPERATION	HOLDPOINTS			CONST	SAT OR INSPECTION RESULTS (SIGN & DATE)				NOEP/REV.	MT&E CALIB DUE DATE
		WT	QC	ANI		UNSAT	QC OR WT	NOE CERT. LEVEL	ANI		
NA	1	NA	✓	NC							
NA	2	NA	✓	NC							
NA	3	NA	✓	NC							
NA	4	NA	✓	NC							
NA	5	NA	✓	NC							
NA	6	NA	✓	NC							
NA	7	NA	✓	NC							
NA	8	NA	✓	NC							
NA	9	NA	NA	NC							

Reviewed: B. M... 11-21-80

PERM. PLT RECORD

17.1.04.13  
SW-1-027-005-1031

**MODIFICATION**

STRUT WAS REMOVED PER IRN ID 406R AND NCR 2386. WDC WILL "NA" ALL HOLDPOINTS UNNECESSARY TO THE RE-INSTALLATION OF THE STRUT AND SIGN THE APPROPRIATE ONES. 12/12/80

INFORMATION COPY PPRV

APPROVAL SIGNATURES SHALL BE AFFIXED IN THE LINE IMMEDIATELY BELOW THE LAST STEP IN EACH SEQUENCE.

Final Inspections.

cc/204

FOIA-85-59

NCR 2341-2nd 12/17/80

INFORMATION  
**COPY**  
 PPRV

N<sup>o</sup> 104058

INSPECTED ITEM REMOVAL NOTICE

B&R Job 35-1195. CPSES		
DATE	LOCATION	ITEM DESCRIPTION
11-19-80	SWI.	HAPP/6TR
SYSTEM / STRUCTURE DESIGNATION	IDENTIFICATION	JOB DC NOTIFIED BY
Service Water 798' 9"	SW-1-027-005- <del>20R</del>	JOB DC
REASON FOR REMOVAL	Page 11 21 80	
TO CLOSE NCR'S M 2341 & M-2386		
<b>MODIFIED</b>		
SEE ADDITIONAL CERTIFICATION		
		ARMS
		INDEXED

SW-1-619-105-308  
HANGER NUMBER

MATERIAL IDENTIFICATION LOG

Mat'l Spec	Material Description	Quantity	Heat/ID Number	Salvaged Hanger Number (where applicable)	QC Verification	Date
	Heat Ser A	3728-35		to become SW-1-027-005-308	SW	10-7-80
	See COM-40030			10-6-80	SW	10-7-80
SA36	1 1/4" X 1/4" R	1 (3)	2715 367810	N/A	SW	10-7-80
A500 GRB	1/2" X 1/2" X 11'-0" TS	1	2713 054492	N/A	SW	10-10-80
A500 GRB	1/2" X 35 7/8"	1 (3)	2713 EC8854	N/A	SW	
A500 GRB	PLATE 24X24X1	1	202837	N/A Edward J. Minnie 4/26/82		
	Refer to MR# 9875					

INFORMATION  
**COPY**  
PPRV

Flatted item 15, 13, 9 10-7-80

(3) \* \*

# SWAY STRUT MODIFICATION ONLY

SW-1-027-005-J03R  
TAGGER NUMBER

## MATERIAL IDENTIFICATION LOG

Mat'l Spec	Material Description	Quantity	Host/ID Number	Salvaged Hanger Number (where applicable)	QC Verification & Date	Notes
SRS-10 Buckle ST MAT # 8841-27-4		1 B.B. Beyer	NPR 24	SW-1-027-005-J03R	JFR 12-16-81	

INFORMATION  
**COPY**  
 PPRV

Flashed item 9 per print C-C = 2'-3 1/2" 17-16-81 R.W.

SW-1-027-005-J03R  
INVOICE NUMBER

# SWAY STRUT MODIFICATION ONLY

## MATERIAL IDENTIFICATION LOG

Mat'l Spec	Material Description	Quantity	Host/ID Number	Salvaged Hanger Number (where applicable)	QC Verification & Date	Notes
⑨	USED SALVAGE EYEBOLTS AND SALVAGE BULK BARREL	500-10 STRUT	NP429	4841-27-44-S	B. Left 12-23-81	
	TO BECOME SW-1-027-005		NP428	4841-52-5-S	B. Left 12-23-81	
			J03R PER PRINT C-C-2-92			



FABbed ITEMS PER PRINT 12-23-81 J.R.G.



INFORMATION  
**COPY**  
 HANGER MARK #  
 PPRV

MATERIAL VERIFICATION CHECKLIST

HANGER MARK # SW-1-027-005-J03K

of BRH lists items # 1, 6, 9, 10, 13, 15, 16

△ CMC	<u>39981</u>	REVISED DELETED items #	<u>3, 7, 8, 2, 11</u>	REVISED QUANTITY of ITEM 10 to 6
△ CMC	<u>40020</u>	DELETED items #	<u>2</u>	
△ CMC	<u>39981</u>	ADDED items #	<u>9, 10, 13, 15</u>	
△ CMC	<u>40020</u>	ADDED items #	<u>9</u>	
△ CMC	<u>          </u>	ADDED items #	<u>          </u>	

REVISED BILL OF MATERIAL

ITEM #	QNTY	DESCRIPTION	HEAT, MIC, SALVAGE	QC VERIFIED
1	1	T.S. 1/2 X 6 X 6 X 2'9"	*	
6	1	HT 1 1/4 X 2 X 2	MR# 9875	HT 202831 ✓
9	1	SRS -10- PC	EYE ROD ASSY BARREL	HT NP 429 HT NP 428 ✓
	1	SPC -10-100	MR# 173323	HT 2147 NE ✓
	1	REAR BRACKET	XRB -10	HT NE 1432 ✓
10	6	1 X 12 HUB		HT N/A
13	1	TUBE STEEL 1/2 X 4 X 4		HT EC 8854 ✓
15	1	HT 1 1/4" X 7" X 14 1/2"		HT 3G 7810 ✓
16	1	ASME III NAME PLATE		HT N/A ✓

Comment: Sway Strut Mod. BOTH VENDOR WELDS Modified. (EIA-E-2)


\*no heat MVP

NEED HEAT # FOR ITEM #            *John J. Mansfield E. Lloyd*

ALL ITEMS TRACEABLE ✓ 4/26/32


ITEM NO	QTY REQD	MATERIAL DESCRIPTION	ASTM DESIG.
4	1	TS 4 X 4 X .375 X 0'-6" LONG	A500 GR B
5	1	STUBTEE SMF-1/2, TYPE 50 H5 = 2"; CS = 2";	
6	4	BAR 3/4" $\phi$ X 0'-0 1/2" LG (PER DET. 1.)	SA-36
7	2	PN 3/8" SMPP-06	
8	1	SMRB-1 W/O PIN	

**FOR OFFICE AND  
ENGINEERING USE ONLY**



**DESIGN LOADS (LBS.)**  
 LEVEL A: x = 0  
 LEVEL B: x = 484  
 LEVEL C: x = 612

**PIPE MVMT. (IN.)**  
 $\Delta x = -0.01$   
 $\Delta y = 0.00$   
 $\Delta z = 0.00$



**NOTE:**  
 FOR GEN. NOTES, SEE  
 CP-AA-001

*\* CHANGES NOT MADE  
 BY CMC*


REV	DATE	DWN	CHKD	APPR	DESCRIPTION
3	11-7-83	DR	DR	DR	FINAL REVIEW - REVISED AS NOTED
2	9-19-83	DR	RWE	DR	FINAL REVIEW REVISED AS NOTED
1	3-4-83	DR	DR	DR	FINAL REVIEW & INCORP. CMC 37146 R. 5/8 REDRAWN RELEASED FOR CONSTRUCTION

TEXAS UTILITIES SERVICES INC.  
 COMANCHE PEAK STEAM ELECTRIC STATION  
 PIPE SUPPORT ENGINEERING

DRAWING NO. H-CC-1-EC-007-018-53 3 REV. 1 SHT. -OF 2


FOIA-85-59

CC/205



1/4" MIN  
(MACH AS REQ'D)


SECTION B-E



SEE DETAIL 1

3/8" DIA


SECTION C-C  
(NUMBER OMITTED)



DETAIL 1

0.375"  $\phi$   $\pm 0.015$ "

0.500"  $\phi$   $\pm 0.015$ "



VIEW D-D

**FOR OFFICE AND  
ENGINEERING USE ONLY**

REV	DATE	DWY	CHKD	APPR	DESCRIPTION
3	11-7-83	aw	CG	DM	FINAL REVIEW - REVISED 175 NOTED
2	9-19-83	aw	RNE	CMR	FINAL REVIEW - REV'D AS NOTED
1	3-4-83	DK	CG	PC	FINAL REVIEW & INCORP. CMC 37146 R.56 REDRAWN RELEASED FOR CONSTRUCTION
					TEXAS UTILITIES SERVICE <sup>®</sup> INC. COMANCHE PEAK STEAM ELECTRIC STATION PIPE SUPPORT ENGINEERING
DRAWING NO					H-CC-1-EC-007-018-53
REV					3
					2 SHT 2 -OF


W 3x







NOTE DIRECTION OF NORTH ARROW  
45°



TI  
APERTURE  
CARD

Also Available On  
Aperture Card


8.5

11

17

DP 1405  
 K - DP 1400  
 CB5 - DP 1390  
 02 CB1K - DP 1380  
 63-003-CB1K - DP 1375

M-3214



REV	DATE	DESCRIPTION	DWN	CHKD	APPD
1	7/1/60	ISSUED FOR HANGER IDENTIFICATION AND ACCOUNTABILITY ONLY		MJP	UM
2	7/1/60	REVISED & REDRAWN AS NOTED	LM	UM	UM
3	7/1/60	VERIFIED FOR STRESS PROB #1-054A	LB	UM	UM
4	7/1/60	REVISED BY LTD.	VM	UM	UM

WELD NO	RT	MT	LP	UT

COST CODE	PAINT	FINISH	GL	TRANS
FLOW DIA	COMPOSITE	SPEC.	FORM	CAT.

8607100243-25

TEXAS UTILITIES SERVICES INC.  
 C. P. S. E. S. GLEN ROSE, TEXAS



DRAWING TITLE  
 REACTOR COOLANT

Q	FORWARD NO RFT-M-5501	DWG NO BRHL-RC-1-RB-021	REV 3
---	--------------------------	----------------------------	----------

FOR OFFICE AND  
 ENGINEERING USE ONLY  
 CC/207


FOIA-85-59



BLUELINE: 5 JAN 82

AS-BUILT  
 VENDOR CERTIFIED  
 DRAWING REV. NO. 5  
 BY: [Signature] DATE 11-18-83


REV	DATE	BY	DESCRIPTION
1	11-18-83	[Signature]	AS-BUILT
2			
3			
4			
5			



NOTE:  
 1) Locking devices for high strength bolts are not required per DCA 7607


← N PLAN

K = 0.1631 x 10<sup>6</sup> g/in  
 TO: 5501



SECTION A-A


FIELD REVIEW OF SUPPORT DESIGN  
 AS BUILT CONDITION CPGA 11/17  
 DATE: 12-12-82 REVIEWED BY: W.W.



ITEM NO	NO REQ'D	DESCRIPTION	ASME OR ASTM	QTY	MIC.
1	1	Q) SRS-06-R0 RIGID SWAG STRUT		1	
2	2	RFT-12-013 ROD	SA 36	2	
3	4	CHN-12 HEAVY HEX NUT	SA 307 GR 8	4	
4	4	FB-4"x1"x4" W/1 1/8" HOLE ON 2	SA 307 GR 8	4	
5	1	TS-4"x4"x1/2"	A 500 GR 8	1	
6	1	NAME PLATE		1	
7	1	SPC-06-040 PIPE CLAMP	SA 36	1	

FOR OFFICE AND  
 ENGINEERING USE ONLY

FIELD DRILL (2)  
 1 1/8" Ø HOLE ON CTR OF TUBE



LOAD (LBS)	GRA	THER	HYDRO	OBE	SSE	DESIGN LOADS	WIND	SEISMIC	REFERENCE DRAWINGS	OWNER	PROJECT	ENGINEER	PRODUCTION ORDER	SERIAL NUMBER	SHEET
									BRHL ISOMETRIC RC-1-RB-21 TAB ISOMETRIC RC-1-RB-21	TEXAS UTILITIES SERVICES INC.	COMANCHE PEAK UNITS NO. 1 & 2	GIBBS & HILL INC.	1809	11579	10/1

183 SUPPT 150 NPSI-RC-1-RB-21

REV 2 2323-MI-506  
 REV 5 2323-SI-530


CPSES Brown & Root, Inc.  
 HOUSTON, TEXAS

DRAWN	DATE	CHK'D	DATE	APP'D	DATE
W.S.L.T.	1-15-79	W.D.A.M.	4-9-79	W.D.	4-27-79

P.O. NO. CP-004541 MFG. REL. TC-175



11  
58



DETAIL "A"

FO  
ENGINE

8.5"  
11"

17"



ITEM NO	QTY REQD	MATERIAL DESCRIPTION	DATE	OWN	CHRD.	A.P.D.
1	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
2	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
3	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
4	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
5	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
6	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
7	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
8	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
9	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
10	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
11	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	
12	1	1/4" X 1/2" X 1/2" TUBING - A500 GRB	11/28/83	HW	GRB	





PROBLEM NO. 1718 R1

ASME CODE EDITION 1974  
 ADDENDA: WINTER  
 DESIGN SPEC: MS-46A

PE CERTIFICATION

FOR OFFICE AND ENGINEERING USE ONLY

LOCATION PLAN



NOTES:



1) FOR OFFICE AND ENGINEERING USE ONLY  
 2) DATE 11-20-83  
 BY RW

DATE PT	SUPPORT LOAD (LBS)	PIPE MTS DRCHED	REV	DESCRIPTION	DATE	OWN	CHRD	APPRD
A-70	1000	100	1	DESIGN	11/28/83	HW	GRB	
B-1	1000	100	2	REV	11/28/83	HW	GRB	
C-1	1000	100	3	REV	11/28/83	HW	GRB	

CLIENT	Brown & Root Inc.
PLANT	SHAMANGE PEAK
JOB NO	35-1193
SUPPORT NO	82-X-26-70-153R
SHEET	OF 2 REV. 2






FOR OF  
ENGINEERING



**BLUELINE 19 JAN 82 AS-BUILT**

VENDOR CERTIFIED  
DRAWING REV. NO. 12  
BY: [Signature] DATE: 2-21-84




ITEM NO.	NO. REQ'D	DESCRIPTION	ASME OR ASTM	ID	5	MIC.
1	1	SMA-3-50	SA-36	1.50		
2	1	SPE-10-060 PIPE CLAMP	SA-307	1.50		
3	8	FHN-1 1/2 HVY HEX NUT	SA-307	1.50		
4	1	1" CS PL PER SECT. A-A	SA-36	1.50		
5	3	RFT-12 L10" FULL THD. ROD	SA-36	1.50		
6	1	RFT-12 L-13" FULL THD. ROD	SA-36	1.50		
7	1	ASME NAMEPLATE OR ALTERNATE MARKING				
8	2	3/4 x 3/4 IS 16" LG	A500GRB	2		
9	1	XRD-10 DEAD BRACKET	A500GRB	2		
10	1	1" CS PL PER SECT. A-A	SA36			
11	1	RFT-12 ROD 1" x 17"	SA36			
12	1	TS 4" x 4" x 3/8" x 11"	A500GRB			
13	1	1/2" CS PL 4" x 6"	SA36			2
15	1	1" CS PL PER SECT. B-B	SA36			
16	2	PUN-C60 UBOLT W/NUTS	SA36			
17	1	1" CS PL 4" x 3"	SA36			

NOTE:  
1) Locking devices for high strength bolts are not required per DCA 7607  
THIS SUPPORT VOID SUPERSEDES NPS 1763 MK RC-1-147-003-C6BK.  
O FIELD CUT TO SUIT.

REV.	DATE	DRW.	CHK.	APP.	DESCRIPTION
11-6	83	PH	PH	PH	REV'D VENDOR CERT.
11-30	83	PH	PH	PH	REV VENDOR CERT. REF: MC 4512081
12-8	83	PH	PH	PH	REV VENDOR CERT.

REV.	DATE	DR.	CHK.	APP.	DESCRIPTION
11-24	83	PH	PH	PH	REV'D VENDOR CERT.
11-19	83	PH	PH	PH	REV VENDOR CERTIFICATION
8-20	81	PH	PH	PH	REV VENDOR CERTIFICATION



REV.	DATE	DRW.	CHK.	APP.	DESCRIPTION
11-24	83	PH	PH	PH	REV'D VENDOR CERT.
11-19	83	PH	PH	PH	REV VENDOR CERTIFICATION
8-20	81	PH	PH	PH	REV VENDOR CERTIFICATION

**FOR OFFICE AND ENGINEERING USE ONLY**

LOAD (LBS)	GEAR	THERM	WIND	ICE	SEISMIC	DESIGN LOADS	WIND (LIN.)	SEISMIC	PER. PVT	REFERENCE DRAWINGS	OWNER	PROJECT	ENGINEER
										RC-1-RB-01's	TEXAS UTILITIES SERVICES INC.	COMANCHE PEAK UNITS NO. 1 & 2	GIBBS & HILL INC.

179	SUPPT. 150	NPSI-RC-1-RB-16		
REV. ELECTRICAL	REV. COE/CLAS III/1	DRAWN DATE	CHK'D DATE	APP'D DATE
2	7	2-18-81	F.P.	2-3-81
REV. H.V.A.C.	REV. PAINT/CP 802/10	P.O. NO. CP-0048 41	MFG. REL.	SHEET
2	4			1 of 2
REV. EDITS		3/48	WT. NO RC-1-147-001-C6BK	REV. 12

**Brown & Root, Inc.**  
ENGINEERS AND ARCHITECTS  
MC FOM, TEXAS  
88-1188




AS-BUILT

VENDOR CERTIFIED  
DRAWING REV. NO. 12  
EYE HOLE DATE 2-23-83


ITEM #	NO. REQ'D	DESCRIPTION	ASME/ASTM
18	1	2" CS R. PER SECT. D-D	SA 336
20	1	SMA-10-BA	
21	1	1" CS R. 3" X 5 1/2" LG.	SA 315 SA 315/SA 318
22	2	1 1/4" CS R. 4" X 4" FIELD	SA 336
		NOTCH TO AVOID EXIST. WELD	
23	2	1 1/4" CS R. 4" X 4" FIELD	SA 336
		NOTCH TO AVOID EXIST. WELD	

REV	DATE	DR./CHK/APP	DESCRIPTION
1	8-1	Q	ISSUE FOR AS-BUILT SET
2	8-1	Q	REV'D VENDOR CERT.
3	8-1	Q	REV'D VENDOR CERT.
4	8-1	Q	REV'D VENDOR CERT.
5	8-1	Q	REV'D VENDOR CERT.
6	8-1	Q	REV'D VENDOR CERT.
7	8-1	Q	REV'D VENDOR CERT.
8	8-1	Q	REV'D VENDOR CERT.
9	8-1	Q	REV'D VENDOR CERT.
10	8-1	Q	REV'D VENDOR CERT.
11	8-1	Q	REV'D VENDOR CERT.
12	8-1	Q	REV'D VENDOR CERT.

FIELD DRILL (4)  
1 1/8" Ø HOLES



ST'L EXISTS PER MK.  
#RC-1-099-001-CB6K



FOR OFFICE AND  
ENGINEERING USE ONLY SECTION B-B

SECTION A-A

\*FIELD TRIM TO SUIT

TO # 5301 MK FROM R TO BE FLUSH W/ EDGE OF T.S.

REV	DATE	DR.	CHK.	APP.	DESCRIPTION
1	8-1	Q			REV VENDOR CERTIFICATION
2	8-1	Q			REV VENDOR CERTIFICATION
3	8-1	Q			REV VENDOR CERT.

REV	DATE	DR.	CHK.	APP.	DESCRIPTION
1	8-1	Q			REV'D VENDOR CERT.
2	8-1	Q			REV VENDOR CERT, REF. MK
3	8-1	Q			REV VENDOR CERT.
4	8-1	Q			REV'D VENDOR CERT.

LOAD (LBS)	GRAN.	THER.	HYDRO	OSB	SSB	DESIGN LOADS	MVTS (IN.)	THER.	SEISMIC	REFERENCE DRAWINGS	BRHL ISOMETRIC	REV.	PIPING	REV.	ELECTRICAL	REV.	CODE/CL	SS: 1/1	PAINT	11	ZONE	DRAWN	DATE	CHK'D	DATE	APP'D	DATE
											RC-1-RB-010	4	3333-M		3333-E												
											FAB. ISOMETRIC		3333-S		3333-M												

OWNER TEXAS UTILITIES SERVICES INC.  
PROJECT COMANCHE PEAK UNITS NO. 1 & 2  
ENGINEER GIBBS & HILL INC.

Brown & Root, Inc.  
ENGINEERS AND ARCHITECTS  
HOUSTON, TEXAS

P.O. NO.	CP-0044 A.1	MFG. REL.	PRODUCTION ORDER	SERIAL NUMBER	SHEET
3145					2 of 2

AH-3

that Corrective Action Report No. 41 had been "pencil-whipped" (dispositioned without actually conducting the rework)

[redacted] stated he believed the above described instances constituted intimidation and harassment. [redacted] said he had already testified to many of these concerns before the ASLB and that the NRC was already aware of these issues.


[redacted] stated that his discriminatory termination suit was presently before the U.S. Fifth Circuit Court of Appeals, and that he plans to testify in the next CPSES hearings. [redacted] stated he was presently in possession of color pictures of hangers and supports he believes would lead to the necessary correction of at least a half million dollars worth of steel, which he believed would amount to 3 to 5 million dollars worth of backfit at CPSES. [redacted] stated he had not provided this material to the intervenor, CASE, and was unwilling to provide this information to the U.S. Nuclear Regulatory Commission. [redacted] indicated he would present it to the CPSES ASLB hearing himself.

**BLUELINE** 12-16-83

VENDOR CERTIFIED  
DRAWING REV. NO. 2  
BY DATE 12/16/83

- NOTES**
- 1) PER REVIEW BY GCH SITE ANALYSIS, SUPPORT NEED BE DESIGNED TO DESIGN LOAD ONLY & NOT TO MAX SUBMERGED RATINGS (RTE GTN 46522 & 1007 PSE)
  - 2) VALVE DWS. 35A226 OF LOAD & VALVE INFO. FROM GTN 46522.
  - 3) LOCKING SLEEVES FOR HIGH STRENGTH BOLT ARE NOT REQUIRED PER OCA 7607.

BY GCH



# FIELD TEAM TO SUIT

MOM. OPER DISPL.	MOVEMENTS
DX 1/2"	X 1/2"
DY 1/2"	Y 1/2"
DZ 1/2"	Z 1/2"

PIPE M-1-0406 REV. 10  
FOIL ISO. 45-1-50-03 Rev 1  
S.P.D. ISO. MS-1-56 03 REV. 4  
Data Point 260 / Pipe #BTL-790 R.1  
Pipe Mat'l. SA333 3B6  
Insul. 1/2 Bldg. 8

Grav. B, D - 10, V, mp

ITEM NO.	MATERIALS & OPERATIONS	QUAN.	SHIP	PS	L	CS	TR	K	SEC	MISC
7	5/8" x 3/16" HILTI-MWIK CONC. ANCHORS	6								
8	3/4" THK. C.S. PLATE, PER SECT. D-D (A.M./SA450650)	1								
9	2.5" SWAY STRUT	1								
10	1" x 1/2" SUPER HILTI CONC. ANCHORS	6								
11	1" THK. C.S. PLATE, PER SECT. C-C (A.M./SA450650)	1								
12	1/2" x 1/2" x 1' T.B. 1' x 4" L.B. (A.M./SA450650)	1								
13	1" x 10" x 10" C.S. PLATE (A.M./SA450650)	1								
14	1 1/4" THK. C.S. PLATE PER SECT B-B (A.M./SA450650)	1								
15	1/2" x 1/2" x 1' T.B. 1' x 1" L.B. (A.M./SA450650)	1								
16	3/4" x 1/2" x 1' T.B. 1' x 1" L.B. (A.M./SA450650)	1								
17	2 1/4" x 1/2" x 1' T.B. 1' x 1" L.B. (A.M./SA450650)	1								
18	XEB-03 REAR BRACKET (A.M./SA450650)	1								
19	8M-F-03-80 SUPPORTS L.B. (A.M./SA450650)	1								
20	1 1/2" x 1/2" x 1' T.B. 1' x 1" L.B. (A.M./SA450650)	1								
21	3/4" x 1/2" x 1' T.B. 1' x 1" L.B. (A.M./SA450650)	1								
22	2 1/4" x 1/2" x 1' T.B. 1' x 1" L.B. (A.M./SA450650)	1								

REV	DATE	BY	CHKD	DESCRIPTION
A	12/16/83	RA	RA	REV'D VALID 2 CERTIFIED, REF GTN 46522
B	12/16/83	RA	RA	REV'D VENDOR CERT.
C	12/16/83	RA	RA	REV'D VENDOR CERT. REF: 2-1 M2 2-2 P.547
D	12/16/83	RA	RA	REV'D VENDOR CERTIFICATION

**FOR OFFICE AND ENGINEERING USE ONLY**

FOR MATERIALS AND OPERATIONS SEE SKETCH NO.		SHEET		OF	
FX	FY	FX	FY	MX	MY

CONDITIONS DESIGN NORMAL & UPSET EMERGENCY FAULTED

PIPE: DECD 1254 ELECT: 01-0602 0152 STEEL: 51-0400 R-4 M.V.A.C.: 41,000' 26

REF. DRAWING NUMBERS

DESCRIPTION

REV DATE BY CHKD

REV'D VENDOR CERT. REF: 2-1 M2 2-2 P.547




REV'D VENDOR CERTIFICATION

CUSTOMER: Texas Utilities Service, Inc.  
ORDER OR CONT. NO. CP-0046  
JOB NAME: Comanche Peak 1B 2  
MARK NO. MS-1-076-009-SEE K  
SKETCH NO. \_\_\_\_\_  
SHEET 1 OF 3 REV 7


FOIA-85-59

BLUELINE 12.6.83

VENDOR CERTIFIED  
DRAWING REV. NO. 7  
BY: 34 DATE: 1-23-84



REV	DATE	OWN	CHK	APP	DESCRIPTION
1	12/6/83	W	C	A	REV'D VENDOR CERTIFIED, REF GTW # 005817 45256
4	12/23/83	R	D	P	REV'D VENDOR CERT
5	12/23/83	W	C	A	REV'D AS NOTED, REF: FMHS R-1 175. # NIS - 52, REF: IFA 35461
7	1-23-84	W	C	A	ADD GHT. 3



REV	DATE	OWN	CHK	APP	DESCRIPTION
1	7/6/83	W	C	A	VENDOR CERTIFICATION REF CMC # 2547
2	8/24/83	W	C	A	REV'D VENDOR CERTIFICATION

FOR OFFICE AND  
ENGINEERING USE ONLY

**BROWN & ROOT, INC.**  
ENGINEERS & CONSTRUCTORS

REF. DRAWING NUMBERS  
PIPE: \_\_\_\_\_ ELECT: \_\_\_\_\_  
STEEL: \_\_\_\_\_ HV.A.C.: \_\_\_\_\_

REV	DATE	OWN	CHK	APP	DESCRIPTION
1	12/23/83	W	C	A	ISSUED FOR CONST. REF FMHS
2	1/23/84	W	C	A	REV'D RE-DRAWN, REF: FMHS REV. 1
3	1/23/84	W	C	A	REV'D AS NOTED, REF: CMC-00322-1
4	1/23/84	W	C	A	REV'D AS NOTED, REF: CMC-00322-1
5	1/23/84	W	C	A	REV'D AS NOTED, REF: CMC-00322-1
6	1/23/84	W	C	A	REV'D AS NOTED, REF: CMC-00322-1
7	1-23-84	W	C	A	VENDOR CERTIFIED REF GTW # 005817

CUSTOMER: Texas Utilities Service, Inc.  
ORDER OR CONT. NO. CP-0046  
JOB NAME Comanche Peak 1B2  
MARK NO. MS-1-076-JW-SSCK  
SKETCH NO. \_\_\_\_\_  
SHEET 2 OF 3 REV. 7

THIRD PARTY INSPECTION  
CODE CLASS: B31.1-S

T.O. 3401.

BLUELINE: 12-6-83


VENDOR CERTIFIED

DRAWING REV. NO. 7

BY DATE 1/2/84

★ ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED

BY CHENG



EL. 3/4" OF T.S.

SECTION "E-E"

FOR OFFICE AND ENGINEERING USE ONLY



BROWN & ROOT, INC.  
ENGINEERS & CONSTRUCTORS

REF. DRAWING NUMBERS

PIPE: \_\_\_\_\_  
STEEL: \_\_\_\_\_

ELECT: \_\_\_\_\_  
H.V.A.C: \_\_\_\_\_

CUSTOMER Texas Utilities Services, Inc.

ORDER OR CONT. NO. CP-0046

JOB NAME Comanche Peak 1B 2

MARK NO. 15-1-076-202-555


SKETCH NO. \_\_\_\_\_

SHEET 3 OF 3 REV. 7

REV.	DATE	BY	CHK.	APP.	DESCRIPTION
1	12/6/83	CHENG			ISSUE FOR CONSTRUCTION
2	1/2/84	CHENG			REVISED FOR CONSTRUCTION
3	1/2/84	CHENG			REVISED FOR CONSTRUCTION
4	1/2/84	CHENG			REVISED FOR CONSTRUCTION
5	1/2/84	CHENG			REVISED FOR CONSTRUCTION
6	1/2/84	CHENG			REVISED FOR CONSTRUCTION
7	1/2/84	CHENG			REVISED FOR CONSTRUCTION


THIRD PARTY INSPECTION  
CODE CLASS: D.311-5

10.3401



11"

9.5"



MS-1-076-002-S52R D.P. 1552

MS-1-076-003-S52K D.P. 553

MS-1-076-009-S55K D.P. 1341

MS-1-076-006-S52R D.P. 557

MS-1-076-008-S52R D.P. 557


MS-1-076-007-S55K D.P.



*ITEM #112  
C11645*

8.5"

11"



17"


EN







# REQUISITION / PURCHASE ORDER ( FLOW THRU PURCHASING )



FOIA-85-59

CC/214

4-53

AH-7

DATE : September 15, 1983

STATEMENT

I, [redacted] hereby make the following voluntary statement to H. Brooks GRIFFIN, who has identified himself to me as an Investigator with the U. S. Nuclear Regulatory Commission. I make this statement freely, with no threats or promises of reward having been made to me.

[Large redacted block]

During the time I was employed at Comanche Peak, there were several occasions on which I was threatened with termination if I failed to follow instructions from supervisors which I knew were improper. In about April 1981, [redacted] my foreman, told me to use scrap I-beam to replace a piece in a hanger. I cut a new piece, and attempted to weld it. The new piece was magnetized and would not accept the weld. I told [redacted] it would not work, but he told me to weld it or "there was no need for me to come in tomorrow". I followed [redacted] instructions and welded the hanger.

Most of the time that I worked at Comanche Peak I believed I was doing my work properly, until I started helping [redacted] prepare for [redacted] QC tests. I realized that a "plug weld" that [redacted] told me to perform in about February 1980 was improper. I remember [redacted] even watched for QC while I made the weld. I provided this information to the NRC.

During about September 1980, I remember an incident in which [redacted] threatened my superintendent [redacted] with termination. [redacted] told [redacted] "if you don't finish this pipe line before 5:30PM, you and your crew will be kicking your hats out the front gate". This particular pipe line had been in process for a long time and there had been a lot of problems with it. [redacted] arranged for a lot of welders to start working and they "messed up" much of the work. I believe the pipe was bought off.

In July 1981 [redacted] my foreman, instructed me to make a "down" pass to cover a gouge in a pipe I was welding. I believe [redacted] told me to do this to protect [redacted] job. I told [redacted] I would rather not do it. I called [redacted] and [redacted] suggested we contact another QC inspector to come look at the weld so my supervisor would not know I had notified QC. A QC inspector by the name of [redacted] came to the location, and [redacted] and [redacted] caught me showing [redacted] the gouge. [redacted] the next week, but [redacted] was not. [redacted] liked to [redacted] who said [redacted] had sent a memo saying to fire me. I went to [redacted] office and talked to [redacted] who said to call him the next week back the following week and talked to [redacted] told me he story and would call me. Two weeks later, I called him and he never returned my call. I heard from other employees on site that [redacted] came from [redacted]

CC/215

Interview of [redacted]

On September 15, 1983, [redacted], a former Brown & Root, Inc., welder at CPSES, was interviewed by NRC Investigator H. Brooks GRIFFIN in Arlington, Texas. [redacted] related the following four instances which he represented as intimidation that he had presented in his testimony before the CPSES ASLB:

(1) [redacted] stated that in April 1981, [redacted], his foreman, told him to substitute a scrap piece of I-beam into a hanger, and he [redacted] followed [redacted] instructions.

*NOTED SCRAP FROM EAST WALL  
ADJACENT TO FOUR COMP. # 81-12 3" DIA*

(2) [redacted] stated that in February 1980, [redacted] a supervisor, [redacted] instructed him to perform some improper "plug welds" while he [redacted] watched out for QC.

*HP MILD WOULD  
NOT BE WITHIN HAD  
H IN THE PIECE IT.*

*WARRANT  
#  
TRAMP  
PIECE  
H*

(3) [redacted] said that in about September 1980, [redacted] and [redacted] superintendents, threatened [redacted] (a B&R employee) and his crew (including [redacted]), with termination if they did not finish welding a pipe before 5:30 p.m. [redacted] said the pipe was completed in a hurry with many deficiencies, and he believed the pipe was accepted by QC.

(4) [redacted] said that in July 1981, [redacted] foreman, instructed [redacted] to make an improper "downhill weld" to cover a gouge in a pipe. [redacted] said [redacted] was caught by his foreman showing the gouge to a QC inspector after [redacted] had refused to cover the gouge. [redacted] said [redacted] was [redacted] a few days later.

[redacted] provided the NRC with a signed, sworn statement, Attachment (7), that identified locations of the above described deficiencies. [redacted] technical concerns were forwarded to Region IV staff for evaluation.

7c

70  
ASK BOBBI'S GRIFIN FOR R. MASTERTON

- 1) DO YOU HAVE ANY MORE INFORMATION ABOUT THIS?
- 2) WAS THIS EVER FOLLOWED UP IN A REGION IV IR?
- 3) WHO AT THE NRC TOLD HIM?

BOB STEWART  
1-860-8154

Bob  
GRIFIN DIDNT SHOW UP  
GTM

REGION IV OFFICE HAS BEEN INVESTIGATING  
[REDACTED] ALLEGATIONS FOR 3 OR MORE  
YEARS - BOBBI'S DOESN'T HAVE ANY  
DISCRETE INFO - SUGGESTS THAT  
YOU TALK TO REGION IV

GTM  
8/20/84 pm

CC/217

Record of Telephone Conversation

To: [REDACTED] (Alleger)

From: Ernest G. Thompson  
NRC-TRT

Telephone Number: (501) 832-5477

Date: September 10, 1984

Time: 8:10 to 8:35 p.m.

Subject: 1) Clarification of welding allegations  
2) Clarification of allegation AH-7  
related to welding of magnetized steel.

The substance of the questions addressed to [REDACTED] and his responses are as noted: 7c

Subject #1

1. Were you ever asked to perform welding outside of approved procedures?  
Yes.
2. What kinds of unauthorized welds did you make?
  - a) Plug welding of misdrilled holes.
  - b) Making flare bevel welds with excessive root gap by knocking the flux off a coated electrode and laying the core wire in the gap to fill it, then welding over it.
  - c) Making "downhill" fillet welds on pipe hanger I-beams instead of "uphill" welds. Normally I used a 3/32" diameter electrode to make 5/16" fillet welds.
3. Did you ever "plug weld" mislocated holes which had the edges beveled.  
No.
4. There are several categories of hangers or pipe supports (ASME Class 1, Class 2, Class 3 and B31.1 pipe supports, categories 5 and 6). Which of these types did you weld on?  
All.
5. What welding processes did you personally use to weld hangers?  
Shielded metal-arc welding
6. Did you ever use gas tungsten-arc welding?  
Never. I wasn't qualified for gas tungsten-arc welding.

Record of Telephone Conversation

7. When you lay down a stringer bead of good configuration using shielded metal-arc welding, how wide is it in terms of weld rod diameter?

About 2 times the rod diameter.

8. Did you ever weld a support attachment to an ASME pipe?

Yes. I welded lugs and stanchions to ASME pipe using shielded metal-arc welding.

9. Do you remember what weld procedure specification you used for welding such attachments to ASME pipe?

I think it was WPS 11032.

10. What were your welder's identification letters?

BNU.

11. Do you recall a "pipe line segment" which had to be "completed by 5:30 pm" or the crew was in trouble?

Yes.

12. Was the welding related to the pipe line or to hangers for this pipe line?

To hangers.

13. Can you identify the pipe line?

It is in the south yard tunnel. Walking into the tunnel to head south, you take the elevator to the 790' level. Make a right turn. Go to the ladder near the end of the tunnel (where the elevation changes from 790' to 800'). Go up the ladder. At the top at about chest high on your right you will find a 3" or 4" pipe near the center of the aisle. This is the pipe line in question. Supports for this pipe are made of tube steel and channel iron.

14. According to your testimony, you can "plug weld" a 1 1/4" diameter hole in 2" thick plate with 2 electrodes in 2 minutes. The volume of this hole is such as to require much more than two electrodes.

a) What size electrode did you use?

The largest electrode I ever welded with was 1/8" diameter. The two electrodes is just an estimate. It could have been 5 electrodes.

Record of Telephone Conversation

b) Did you completely fill the hole?

No. It was capped on either face and had slag and an air pocket in the middle.

15. If you "plug welded" a mislocated hole and the new hole drilled in the correct location over-lapped the weld-repaired hole----

You had to weld repair the side of the new hole because the "plug weld would have defects.

Subject #2

1. Did you recall a scrap I-beam which was magnetized and used to repair a hangar?

Yes.

2. Was this hangar in the north pump room?

No. It was in the south yard tunnel at about 820' elevation.

3. Who at the NRC did you make aware of this incident?

Don Driskell

4. Who at the NRC told you that the hangar had been scrapped?

Don Driskell and Richard Herr told me it had been removed because of design changes.

QUESTIONS FOR



1) THE HANGER WITH THE SCRAP I-BEAM IS IN THE NORTH PUMP ROOM ACCORDING TO MY CONVERSATION WITH H. S. ON 2/28/84 CAN HE LOCATE THIS ROOM IN A PARTICULAR BUILDING AND ELEVATION?

2) WERE THESE SPECIFIC TYPES OF PUMPS, SUCH AS FEEDWATER, ETC?

Identify pump type



3) WHO AT THE NRC DID YOU MAKE AWARE OF THIS INCIDENT?

4) WHO AT THE NRC TOLD YOU THAT THE HANGER HAD BEEN SCRAPPED?

Bob Masterson



Subject #2

1. Do you recall a scrap I-beam which was magnetized and used to repair a hangar?

Yes

2. Was this hangar in the north pump room?

No. It was in the south yard tunnel at about 820' elevation.

3. Who at the NRC did you make aware of this incident?

Don Driskell

4. Who at the NRC told you that the hangar had been scrapped?

Don Driskell and Richard Hertz told me it had been removed because of design changes. ~~After I had reported this incident to them they asked me if I had told any one else. I said, "No, why?" They said, "Because it has been removed for design changes."~~

TEXAS UTILITIES GENERATING CO. CPSSES	INSTRUCTION NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QP-11.6-1	6	JUL 14 1982	1 of 45

INSTALLATION INSPECTIONS OF NNS SEISMIC CATEGORY II SUPPORTS FOR CLASS V PIPING

PREPARED BY: William H. Heston 7-13-82  
DATE

APPROVED BY: C. T. [Signature] 7-13-82  
DATE

APPROVED BY: [Signature] 7/13/82  
DATE

**FOR INFORMATION ONLY**

- 1.0 REFERENCES
- 1-A CP-QP-18.0, "Inspection Reports"
- 1-B CP-QP-16.0, "Nonconformances and Deficiencies"
- 1-C QI-QP-16.0-5, "Reporting of Base Metal Defects"

2.0 GENERAL

2.1 PURPOSE AND SCOPE

This Instruction sets forth the criteria and requirements to be used when performing installation inspection of Class 5 pipe supports. If a conflict exists between this Instruction and the support drawing, the drawing shall take precedent. This Instruction does not apply to Class 1, 2 or 3 pipe supports.

2.2 MATERIALS

Hanger materials shall comply with the drawing requirements, e.g., material size and type, etc. Material used in the fabrication of Class 5 pipe supports may be ASTM or ASME material.

2.2.1 Transfer of Protective Coating Unique Identification Number

For all coated bulk steel intended for use in the Reactor Building (as designated by the presence of a "QP" unique identification number, the QC inspector shall verify and document the transfer of the "QP" number (prior to cutting) in accordance with QI-QP-11.4-22.

**HISTORICAL FILE**

FOIA-85-59

COMANCHE PEAK STEAM ELECTRIC STATION

INSPECTION REPORT

SHEET          OF           
 NO. MAS-1-0034702

ITEM DESCRIPTION: CLASS I MAIN SUPPORTS IDENTIFICATION NO. CT-1-073-001-445R SYSTEM / STRUCTURE DESIGNATION CT-74RD TOWER #1 @ 820' - PM#850

SPEC. NO. MS-100 REV. 6 REF Q.C. DOC. & REV. & CHANGE NO. QI-QA-1116.1 30 MEASURE OR TEST EQUIP. IDENT. NO. N/A

IN PROCESS INSPECTION  PRE INSTALLATION VERIFICATION  INSTALLATION INSPECTION  FINAL INSPECTION  PRETEST INSPECTION

INSP. RESULTS  
 INSPECTION COMPLETED, ALL APPLICABLE ITEMS SATISFACTORY  
 INSPECTION COMPLETED, UNSATISFACTORY ITEMS LISTED BELOW

*[Signature]* 22 MAR 84  
 QC INSPECTOR DATE

ITEM NO.	INSPECTION ATTRIBUTES	SAT	UNSAT	DATE	QC SIGNATURE
	ALL REWORK, REINSPECTION TO THE DISPOSITION OF NCR # M.84.00754.S IS COMPLETE.		✓		
	ONE HOLD TAG REMOVED		✓		

INFORMATION  
**COPY**  
 PPRV

FILE NO. F171.48.13  
 SUBFILE NO. CT-1-073-001-445R

ARMS INDEXED  
 DATE: \_\_\_\_\_

REMARKS (DWGS, SPECS, ETC.)  
 THIS I.R. CLOSES NCR # M.84.00754.S.

RELATED NCR NO. M.84.00754.S I.R. CLOSED  DATE N/A SIGNATURE N/A QC INSPECTOR

FOIA-85-59

CC/221

INSPECTION REPORT

IR- NO. MH5-1-0027548

ITEM DESCRIPTION Class V Support Package Document Review IDENTIFICATION NO. CT-1-073-001-445R SYSTEM/STRUCTURE DESIGNATION CT/SG# 10 820 YARD 850  
 SPEC. NO. N/A REV. N/A REF. Q.C. DOC. & REV. & CHANGE NO. QI-QP-11.16-1 Rev. 30 MEASURE OR TEST EQUIP. IDENT. NO. N/A

IN PROCESS INSPECTION  PRE INSTALLATION VERIFICATION  INSTALLATION INSPECTION  FINAL INSPECTION  PRETEST INSPECTION

INSP. RESULTS *Reviewed - Reinspection not required*

INSPECTION COMPLETED, ALL APPLICABLE ITEMS SATISFACTORY *2-27-84*  
 QC INSPECTOR *[Signature]* DATE

INSPECTION COMPLETED, UNSATISFACTORY ITEMS LISTED BELOW

ITEM NO.	INSPECTION ATTRIBUTES	SAT	UNSAT	DATE	QC SIGNATURE
A.	DRAWING REVIEW (Para. 3.16.2.b)				
1.	Drawing No. CT-1-073-001-445R Rev. 3 Reviewed - Reinspection not required.				<i>[Signature]</i>
B.	COMPONENT MODIFICATION CARD REVIEW				
1.	Design required by CMC <i>N/A</i> Rev. <i>N/A</i> Has been satisfactorily accepted by QC.				
<p><i>PER REINSPECTION - NO. SO. DIMENSION @ SOUTH END (COE HILL TO EDGE) NOT PRESENT - LOOK THIS I.R. WITH NCR# M.84.00754.S.</i></p> <p><i>PER REINSPECTION - WELDS GO BEYOND 1" TO EDGE OF EMBED RE - BASE PLATE DIMENSION INCORRECT</i></p>					

INFORMATION COPY

ARMS INDEXED

REMARKS (DWGS, SPECS, ETC.)

REV 1 OF CMC 46762 NEVER INSPECTED  
 REV 0 & 1 OF CMC 34365 NEVER INSPECTED  
 BOTH CMC'S INCORPORATED TO REV 2 OF DRAWING

RELATED NCR NO. M.84.00754.S I.R. CLOSED  DATE 2/27/84 SIGNATURE *[Signature]* QC INSPECTOR

*THIS I.R. SAT PER THE DISPO. TO NCR# M.84.00754.S - DIMENSION SAT PER INSPECTOR ERROR. [Signature]*

RTRN L FILE LOC 77.1.48.13  
 SUBFILE LOC. CT-1-073-001-445R

REPORTING PERSONNEL

UNIT	STRUCTURE/SYSTEM	ITEM/COMPONENT	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
ONE	YARD TOWER / CT	SEISMIC CLASS II PIPE SUPPORT	CT-1-073-001- 445R	YARD TOWER @ B20 RMA B5 D	n/a

NONCONFORMING CONDITION J.R. # MAS-1352 WAS ISSUED PER "CT-1-073-001-445R/A": AND CMC# 46762/A AS SAT ON 12 JAN 81. HOWEVER CMC# 46762/A AND CMC# 34365/A WERE ISSUED AGAINST "BRH/A" ON 20 OCT 80.

BOTH CMC# (A) AND (C) EXIST PER CMC# 34365/A (HILTI I.R. NOT IN PACKAGE), WITH (C) OF HILTI TO (C) OF ATT. PER SAME. WELDING OF BOTH (C) TO EMBED PLATE EXIST PER CMC# 46762/A. BRH/A ISSUED TO INCOR. BOTH CMC'S REV. 1/A, WELD CALLOUT PER BRH/A IS PER CMC# 34365/A ON IT (C) TO E.M. PL WHICH WAS DELETED BY CMC# 46762/A.


DUE TO THE CONFLICT BETWEEN EXISTING FIELD CONDITION, AND DOCUMENTATION THE QUALITY THIS HANGER IS INDETERMINATE.  
ONE HOLD TAG APPLIED.

REFERENCE DOCUMENT 10 CFR 50 APP. B - CRIT. RT / SOP-11.16.1 REV N.A./30 PARA     

REPORTED BY: DOUGLAS MCCALLUM / Deum (Blue) DATE: 7 MAR 84

QE

QE REVIEW/ APPROVAL: [Signature] DATE: 3 18 84  
ACTION ADDRESSEE: B. Goff DEPARTMENT: the E




ACTION ADDRESSEE

DISPOSITION: REWORK \_\_\_\_\_ REPAIR \_\_\_\_\_ USE AS IS

QC to reinspect HGR per latest issue of VCD.  
Review of issue dates for CMC's 46762 Rev. 1 and 34365 Rev. 1 found issue date for both was 10 Oct. 82. not 10 Oct. 80.  
QC program on date of MH IR did not require IR to be put in HGR Pkg.

HOLD TAG REMOVED  
BY DM 21 MAR 84

ORDER J.R. ISSUED [Signature]  
22 MAR 84



ENG. REVIEW/ APPROVAL: [Signature] DATE: 3 20 84

QE REVIEW APPROVAL: [Signature] DATE: 3 20 84

DISPOSITION VERIFICATION & CLOSURE: [Signature] DATE: 4 1 84

COMMENTS:

INSPECTION REPORT

ITEM DESCRIPTION Class V Support Package Document Review IDENTIFICATION NO. CT-1-073-001-44512 Rev. 3 SYSTEM, STRUCTURE, OR DESIGNATION MEASURE OR TEST EQUIP. IDENT. NO. N/A

SPEC. NO. N/A REV. N/A REF. Q.C. DOC. & REV. & CHANGE NO. QI-QP-11.16-1 Rev. 50

IN PROCESS INSPECTION  PRE INSTALLATION VERIFICATION  INSTALLATION INSPECTION  FINAL INSPECTION  PRE TEST INSPECTION

INSP. RESULTS *Review Review CIP#3110*

INSPECTION COMPLETED, ALL APPLICABLE ITEMS SATISFACTORY *W. Blahy* 2-27-84  
QC INSPECTOR DATE

INSPECTION COMPLETED, UNSATISFACTORY ITEMS LISTED BELOW

ITEM NO.	INSPECTION ATTRIBUTES	SAT	UNSAT	DATE	QC SIGNATURE
----------	-----------------------	-----	-------	------	--------------

A. DRAWING REVIEW (Para. 3.16.2.b)

1. Drawing No. CT-1-073-001-44512 Rev. 3  
Reviewed - Reinspection not required.

*FOR INFO ONLY*

B. COMPONENT MODIFICATION CARD REVIEW

1. Design required by CMC N/A Rev. N/A N/A  
Has been satisfactorily accepted by QC.

*PER REINSPECTION - NO. 50. DIMENSION @ SOUTH END (E OF HILL TO EDGE) NOT PRESENT - WORK THIS I.R. WITH NCR# M. 84. 00754-S.*

**INFORMATION COPY**  
PPRV

REMARKS (DWGS, SPECS, ETC.)

REV 1 OF CMC 46762 NEVER INSPECTED  
REV 0 & 1 OF CMC 34365 NEVER INSPECTED  
BOTH CMC'S INCORPORATED TO REV 2 OF DRAWING


RELATED NCR NO. M. 84. 00754-S I.R. CLOSED  DATE \_\_\_\_\_ SIGNATURE \_\_\_\_\_ QC INSPECTOR

**CHECK CURRENT REVISION OF DCA-5021 FOR HANGER CLASSIFICATION.**

**FOR INFO ONLY.**

AS-BUILT


VENDOR CERTIFIED  
DRAWING REV. NO. 3  
BY T.M. DATE 8-27-83



Attaching plates for high strength bolts as required by DCA 7607



TO 4801  
BEHL 150 CT-1-YD-02 R3  
IPD 150 CT-1-YD-02 REV.1  
DATA POINT 125/PRIN THE AIST NISHIKI  
PIPE MAT'L SA 106 GRB  
INSUL — BLDG YD




ITEM NO	MATERIALS & OPERATIONS	QUANTITY	UNIT
SEISMIC PIPE RESTRAINT CONSISTING OF:			
1	Carbon Steel Plate/Section A-A; TH-51#	1	PIECE
2	5/8" x 8 1/2" Hilti Kwik Bolt Concrete Anchors, TH-3#	4	PIECES
3	Hilti, 2'-5 3/4" Long, H-1000, Top Weld to Item #1 as Shown	2	PIECES
4	Hilti, 0'-4 5/8" Long, TH-3#	2	PIECES
SEISMIC ASSEMBLY SKETCH & ENGINEERING BUNDLE & TAG MARK# CT-1-073-001-1045			
Apply one coat of Carbo Zinc 401 to above mat'l except th'de which shall be protected w/3 rust preventative.			
5	1" x 12" CARBON STEEL PLATE 1" THICK LG 34" x 10" HILTI KWIK BOLT CONCRETE ANCHORS	1	PIECE

REV	DATE	OWN	CHK	APP	DESCRIPTION
Δ	8/27/83	TEL	Q	CP	REV'D VENDOR CERTIFIED, REF. 29411

Approved By: DEP  
Date: 3/27/81

FOR MATERIALS AND OPERATIONS SEE SKETCH NO. SHEET OF


Brown & Root, Inc.		CONDITIONS				
REF. DRAWING NUMBERS		Fr	Fy	Fz	Mx	My
PIPE: M1-1206-3	ELECT: —	DESIGN				
STEEL: SA 106 GRB	HV: A-C	NORMAL & UPSET				
DESCRIPTION		EMERGENCY				
ISSUED FOR CONST.		FAULTED				
CUSTOMER: Texas Utilities Service		ORDER OR CONT. NO. CP-00104				
JOB NAME: Comanche Peak 1		MARK NO. CT-1-073-001				
SKETCH NO.		SHEET 1 OF 1				



**CHECK CURRENT REVISION OF DCA-5021 FOR HANGER CLASSIFICATION.**

AS-BUILT

VENDOR CERTIFIED  
DRAWING REV. NO. 3  
BY: [Signature] DATE 8/27/83



NOTES:  
1) Locking devices for high strength bolts are not required per DCA 7607

INFORMATION  
TO: 1801  
BRHL 150 CT-1-YD-02 REV. 1  
TPD. 150 CT-1-YD-02 REV. 1  
DATA POINT 125/BRHB NI AB 1105121  
PIPE MAT'L SA 106 GRB  
INSUL - BLDG YD

SEE BRHL FOR HANGER LOCATION LOCATION PLAN

THIRD PARTY INSPECTION YES  NO

CODE CLASS: B31.1-(5)

ITEM NO	MATERIALS & OPERATIONS	QUANT	SHR
	SEISMIC PIPE RESTRAINT CONSISTING OF:		CNE
1	Carbon Steel Plate/Section A-A, TW=51#	1	
2	5/8"x8 1/2" Hilti Kwik Bolt Concrete Anchors, TW=3#	4	
3	M4x13, 2'-5 3/4" Long, TW=64# Shop Weld To Item #1, as Shown	2	
4	M4x13, 0'-4 5/8" Long, TW=10#	2	
	SEISMIC ASSEMBLY SKETCH & ENGINEERING BUNDLE & TAG MARK# CT-1-073-001-V45R	1	
	Apply one coat of Carbo Zinc #11 to above mat'l except th'ds which shall be coated w/a rust preventative.		
3	1" x 12" CARBON STEEL PLATE 1" THICK LG	1	
7	3/4" x 10" HILTI KWIK BOLT CONCRETE ANCHORS	2	

REV	DATE	OWN	CHK	APP	DESCRIPTION
1	8/27/83	EL	Q	CA	REV'D VENDOR CERTIFIED, REF. CMC 27911

Approved By: [Signature]  
Date: 8/27/83



FOR MATERIALS AND OPERATIONS SEE SKETCH NO. SHEET OF

Brown & Root, Inc.

REF. DRAWING NUMBERS

PIPE: M1-1006-3 ELECT: ---  
STEEL: SA 106 GRB HV-A-G+

CONDITIONS	Fx	Fy	Fz	Mx	My	Mz
DESIGN						
HORIZONTAL & UPSET	-135	-1207	-437			
EMERGENCY/FAULTED	+137	+437	+202			

REV	DATE	OWN	APP	DESCRIPTION
F	8/5/83	EL	CA	ISSUED FOR CONST.
A	2-21-83	L	C	
A	8/31/83	LN		REV'D AS NOTED; REF. CMC 27911, 27912, 27913, 27914, 27915, 27916, 27917, 27918, 27919, 27920, 27921, 27922, 27923, 27924, 27925, 27926, 27927, 27928, 27929, 27930, 27931, 27932, 27933, 27934, 27935, 27936, 27937, 27938, 27939, 27940, 27941, 27942, 27943, 27944, 27945, 27946, 27947, 27948, 27949, 27950, 27951, 27952, 27953, 27954, 27955, 27956, 27957, 27958, 27959, 27960, 27961, 27962, 27963, 27964, 27965, 27966, 27967, 27968, 27969, 27970, 27971, 27972, 27973, 27974, 27975, 27976, 27977, 27978, 27979, 27980, 27981, 27982, 27983, 27984, 27985, 27986, 27987, 27988, 27989, 27990, 27991, 27992, 27993, 27994, 27995, 27996, 27997, 27998, 27999, 28000


CUSTOMER: Texas Utilities Service, Inc.  
ORDER OR CONT. NO: CP-00469  
JOB NAME: Comanche Peak 1 & 2  
MARK NO: CT-1-073-001-V45R  
SKETCH NO: ---  
SHEET 1 OF 1 REV.



CHECK CURRENT REVISION OF DCA-5021 FOR HANGER CLASSIFICATION.

AS-BUILT


VENDOR CERTIFIED  
DRAWING REV. NO. 2  
BY *[Signature]* DATE 3/21/83



NOTES:  
1) Locking devices for high strength bolts are not required per DCA 7607



BRHL 150 CT-1-YD-Q2 R.1)  
IPD 150 (CT-1-YD-Q2 REV.1)  
DATA POINT 125/PROB NO. AB-1-N05(R.0)  
PIPE MAT'L SA 106 GRB  
INSUL - BLD6 YD



THIRD PARTY INSPECTION YES   
CODE CLASS: B31.1.5

ITEM NO	MATERIALS & OPERATIONS	QUANTITY	UNIT
SEISMIC PIPE RESTRAINT CONSISTING OF:		ONE	
1	Carbon Steel Plate/Section A-A, TW-51#	1	
2	3/8" x 8 1/2" HILTI KWIK BOLT CONCRETE ANCHORS, TW-3#	4	
3	M4x13, 2'-5 3/4" Long, W-64# Shop Weld To Item #1, as Shown	2	
4	M4x13, 0'-4 5/8" Long, TW-10#	2	
SEISMIC ASSEMBLY SKETCH & ENGINEERING BUNDLE & TAG		1	
MARK# CT-1-073-001-Y45R		1	
Apply one coat of Carbo Zinc #11 to above mat'l except th'ds which shall be coated w/a rust preventative.			
5	1" x 12" CARBON STEEL PLATE 1'-7 1/2" LG	1	
6	3/4" x 10" HILTI KWIK BOLT CONCRETE ANCHORS	2	

FOR MATERIALS AND OPERATIONS SEE SKETCH NO. SHEET OF

Brown & Root, Inc.		CONDITIONS					
REF. DRAWING NUMBERS		Fx	Fy	Fz	Mx	My	Mz
PIPE: M1-100#-3	ELECT: ---	-157	-134	-508	---	---	---
STEEL: M-0318-7	HWAG	+120	+692	+376	---	---	---
EMERGENCY		-150	-143	-121	---	---	---
FAULTED		+176	+82	+720	---	---	---

REV	DATE	BY	APP	DESCRIPTION	CUSTOMER
1	6/3/79	EL		ISSUED FOR CONST.	Texas Utilities Service, Inc.
2	2-21-83	LN		REV'D AS NTD; REF. CMC 01/20/83, 01/21/83	ORDER OR CONT. NO CP-0046P
3	3-21-83	LN		REV'D DCA 7607 N.L. AS BUILT	JOB NAME Comanche Peak 1 & 2
4	3-21-83	LN		VENDOR CERTIFIED REF. LPP# 25401	MARK NO. CT-1-073-001-Y45R
					SKETCH NO.
					SHEET 1 OF 1 REV 2

COMPONENT MODIFICATION CARD (CMC)

SERIAL NO. N<sup>o</sup> 34365 1

① APPLICATION: PIPE SUPPORTS WELD MOD.   $\frac{1}{16}$    $\frac{1}{8}$   NON-Q  DESIGN CHANGE/BEVIATION

② DWG. NO. BAH N: V 1  
CT-1-073-001-142R

③ LINE NO./COMPONENT NO.  
CT-1-073-001-145R


④ REASON FOR CHANGE:  
INACCESSIBLE WELDS

$\Delta$  AS-BUILT R DIM  
PHDX-2697

⑤ INSTRUCTIONS:

REMOVE  N/A

DELETE ITEM  
#5 & ITEM #2



FOR OFFICE AND  
ENGINEERING  
USE ONLY

⑦ ORIGINATOR  
S. Smith / L. Thompson  
NAME  
 CPPE  
 ORIGINAL DESIGNER

⑧ APPROVED BY:  
Richard Bell 4-28-80  
DATE  
Benny J. Hill 10-20-80  
DATE

DATE  
DATE  
DATE  
DATE

⑨ DISTRIBUTION	DCC CNTL NO.	QTY
TECH SERVICES	INF	2
SITE DAMAGE STUDY GROUP	INF	
SYSTEMS PLANNING	INF	1

ADD

10-1' X 12' X 1-7 5/16" R3/8"

7-3/4" X 10" H1/2"

DRILL (2) 13/16" HOLES

THIS REVISION VOIDS  
AND SUPERSEDES  
DOCUMENT SERIAL NO.  
34365 REV 0

OMANCHE PEAK STEAM  
ELECTRIC STATION (CPSES)

COMPONENT MODIFICATION CARD (CMC)


SERIAL NO.

1) APPLICATION: PIPE SUPPORT  
WELD MOD.  Q  NA NON-Q  DESIGN CHANGE/REVISION   
2) DWG. NO. BRH-R1  
CT-1-073-001-Y45R  
3) LINE NO./COMPONENT NO.  
NA

4) REASON FOR CHANGE: SHOP WELD NEEDS TO BE FW,  
BOLT HOLES DRILLED, INTERFERENCE.  
 $\Delta$  Revid Hilti size, R Hole  $\phi$ ,  
Revid R Dim, Deleted welds to embed R, as  
they are shown on CMC 34365-PHX 2697

7) ORIGINATOR  
DONNIE A. JOYNER  
NAME  
 CPPE  
 NA ORIGINAL DESIGNER

5) INSTRUCTIONS:  
REMOVE  NA



8) APPROVED BY:  
*[Signature]* 1-12-01  
DATE  
 $\Delta$  *[Signature]* 10-10-00  
DATE  
DATE  
DATE  
DATE

9) DISTRIBUTION  
DCC CNTL NO.

TECH SERVICES	INFO
SITE DAMAGE STUDY GROUP	INFO
SYSTEMS PLANNING	INFO

THIS REVISION VOIDS  
AND SUPERSEDES  
DOCUMENT SERIAL NO.  
46762 REV 0

S/R #: C T-1-073-001-Y45R  
 R thickness: 1"  
 Anchor size: 3/4" x 10" Qty: 2  
 Insert exists: yes -- NO


Identification in relation to pipe supp.  
 ITEM 5 (REF.)

INFORMATION  
**COPY**  
 PPRV


FIELD DRILL(2)

13/16" HOLES

TYR 5/16"



This  
Paperwork  
is  
Bought Off



INSPECTION REPORT

SHEET NO. LK-MH5-1353

ITEM DESCRIPTION: CLASS 5 PIPE SUPPORT  
 IDENTIFICATION NO.: CT-1-073-001-445R  
 SYSTEM / STRUCTURE DESIGNATION: CT/820' YARD TUNNEL #1  
 SPEC. NO.: NA  
 REV.: NA  
 REF. Q.C. DOC. & REV. & CHANGE NO.: QI-QP-11.11-1 REV. 5  
 MEASURE OR TEST EQUIP. IDENT. NO.: NA

IN PROCESS INSPECTION  
 PRE INSTALLATION VERIFICATION  
 INSTALLATION INSPECTION  
 FINAL INSPECTION  
 PRE TEST INSPECTION

INSP. RESULTS  
 INSPECTION COMPLETED, ALL APPLICABLE ITEMS SATISFACTORY  
 INSPECTION COMPLETED, UNSATISFACTORY ITEMS LISTED BELOW

QC INSPECTOR: *Brian Belen* DATE: 10/22/82

ITEM NO.	INSPECTION ATTRIBUTES	SAT	UNSAT	DATE	QC SIGNATURE
5.	BASE PLATE DOES NOT MEET REQUIREMENTS OF QI-QP-11.11-1 PARA 3.4; GROUTING IS REQUIRED.	✓	✓	10/22/82	Brian Belen
	LOCATION: 27' 8 3/4" S.W. OF R TANK*				
	* REFUELING WAREHOUSE STORAGE TANK.				

PERM. PLT. RECORD

DATE: 17.1.48.13

FILE LOC: CT-1-073-001-445R



ARMS INDEXED

REMARKS (DWGS, SPECS, ETC.):  
 Surface Temp 66°  
 Celcote 658-N LOT #16

RELATED NCR NO: N/A

I.R. CLOSED

DATE: 10/22/82

SIGNATURE: *Brian Belen*  
 QC INSPECTOR

SHIMS INSTALLED

INSPECTION REPORT

NO. IR-MH5-1352

ITEM DESCRIPTION: NNS SEISMIC CAT. II SUPPORTS FOR CLASS V PIPING  
 CERTIFICATION NO. CT-1-073-001-4458  
 SYSTEM/STRUCTURE DESIGNATION: CT/B20 YARD TURNER #1

SPEC. NO. MS-100  
 REV. 5  
 REF. Q.C. DOC. & REV. & CHANGE NO. QI-QP-11.11-1, Rev. 5  
 MEASURE OR TEST EQUIP. IDENT. NO. NA

IN PROCESS INSPECTION  
 PRE INSTALLATION VERIFICATION  
 INSTALLATION INSPECTION  
 FINAL INSPECTION  
 PRE TEST INSPECTION

INSPECTION RESULTS  
 INSPECTION COMPLETED, ALL APPLICABLE ITEMS SATISFACTORY  
 INSPECTION COMPLETED, UNSATISFACTORY ITEMS LISTED BELOW  
 QC INSPECTOR: [Signature]  
 DATE: [Blank]

ITEM NO.	INSPECTION ATTRIBUTES	SAT	UNSAT	DATE	QC SIGNATURE
----------	-----------------------	-----	-------	------	--------------

A.	FABRICATION				
1.	Check hanger materials for compliance with bill of materials (Paragraph 2.2)	✓			
2.	Support dimensions comply with dwg/instruction (Paragraph 2.2)	✓			
3.	Weld area clear of scale, grease, etc. (Para. 3.2.1)	✓			
4.	Fit-up* per dwg/WPS (Para. 3.1.2)	✓			
5.	Weld free of slag, undercut, porosity (Para. 3.2.2)	✓			
6.	Weld as per drawing (Para. 3.1.2)	✓			
7.	Support level and plumb (Para. 3.7)	✓			
8.	Location (Para. 3.7)	✓			

INFORMATION  
 CNA  
 [Handwritten notes and stamps]

B.	SEISMIC LIMITERS/SWAY STRUTS/SPRING CANS**				
1.	Spherical bearing alignment/condition (Para. 3.8.1; 3.9.1)	NA			
2.	Correct location and orientation (Para. 3.7.2)	NA			
3.	Threads upset (Para. 3.8.2)	NA			
4.	Cold setting as per drawing (Para. 3.9.5)	NA			
5.	Cycle inspection (Para. 3.9.1)	NA			
6.	Hardware correctly installed (Para. 3.8; 3.9)	NA			
C.	RECORD THE FOLLOWING:				
1.	Support Drawing No. CT-1-073-001-4458 Rev. 1	✓			
2.	CMC No. 46762 Rev. 0	✓			
3.	Welder Symbol BTH, BNL HT NO NA	✓			
4.	WFML No. E7018 WPS 11032	✓			

PERM. P.T. RECORD  
 CT-1-073-001-4458  
 [Vertical stamp]

REMARKS (DWGS, SPECS, ETC.)  
 C.3. \* "BMO" AND "AHN" WELDS DELETED BY REVOK. 01/01/01  
 \* Full penetration welds require fit-up inspection prior to weld out.  
 \*\* Spring can travel stops installed. (Para. 3.10)

RELATED NCR NO. NA  
 I.R. CLOSED NA  
 DATE NA  
 SIGNATURE NA  
 QC INSPECTOR NA

# COMPONENT MODIFICATION CARD (CMC)

SERIAL NO. **N: 46762**

CGA. ONE PEAK STEAM, ELECTRIC STATION (CPSES)

1  ORIGINAL DESIGNER

2  CPPE

3  ORIGINAL DESIGNER

4  APPROVED BY: *[Signature]*

DATE	DATE	DATE	DATE	DATE	DATE	DCC CMTI NO.	OT

9 DISTRIBUTION


1 APPLICATION: PIPE WELD MOD.  DESIGN CHANGE/DEVIATION

2 DWG. NO. **CT-1-013-001-Y45R**

3 LINE NO./COMPONENT NO. **NA**

4 REASON FOR CHANGE: **WELD REPAIR TO THE FUL.**

5 NON-O



INSTRUCTIONS

REMOVE **N/A**

ADD **N/A**



Sheet 1 of 2


S/R #: CT-1-073-001-1451

R Thickness: 1"

Anchor size: 3/8" x 3 1/2" Qty: 2

Cast exist: yes no

R. Identification in relation to pipe supp.  
ITEM # 5 (REF.)



FORMATION  
COPY  
PPRV

SECTION 1 OPERATIONS

192E

SEISMIC PIPE RESTRAINT CONSISTING OF

1	Carbon Steel Plate/Section A-A TN-51#	1
2	5/8" x 8 1/2" Milki Bolt Bolt Concrete	4
3	Anchors 14x36 2x5 3/4" Long, 1d-6x4 Snop weld To Item #1 as shown	2
4	M4x13 0v-4 5/8" Long, TN-10	2

SEISMIC ASSEMBLY SPECIFICATION

MARKS CT-1-073-001-Y45K

Apply one coat of Carbo Zinc #11 to above mat'l except th'ds which shall be coated w/1 rust preventative.

Approved By: J.E.P.  
Date: 3/2/81

FOR MATERIALS AND OPERATIONS SEE SKETCH NO. \_\_\_\_\_ SHEET \_\_\_\_\_

DESIGN	CONDITIONS	Fx	Fy	Fz	Mx
NORMAL & UPSET					
EMERGENCY					
FAULTED					

CUSTOMER: Texas Utilities Company  
ORDER OR CONT NO: CP-00166  
JOB NAME: Conanche Post 1 & 2  
MARK NO: CT-1-073-001-Y45K  
SKETCH NO: \_\_\_\_\_  
SHEET 1 OF 1 REV \_\_\_\_\_

REF. DRAWING NUMBERS

PIPE: M1-1006-2 ELECT:  
STEEL: S10-10-2 HVAC


DESCRIPTION

ISSUED FOR CONST.

REV DATE BY APP

FA 3/2/81 J.E.P.

THIRD PARTY INSPECTION YES  NO   
CODE CLASS: 10311(5)



6 IN. 150 CT-1-YD-02 REV 1  
DATE POINT  
PIPE MAT'L SA 106 GR 2  
INSUL — BLDG YD

DOUGLAS COUNTY  
APR 1 1981  
RECEIVED

MAR 5 1981

















COMANCHE PEAK ALLEGATION WORK PACKAGE

MECHANICAL & PIPING Category 18 - Hanger Construction

Allegation Numbers: AH-7, AH-12

Statement of Allegation: Fabrication of hangers including concerns that procedures, incorrect materials, incorrect assembly, and generally poor workmanship occurred.

Reference Documents:

See source documents marked on attached pages from allegation list.

Source of Allegation: Various - see enclosed allegations list

Date Received: 1983 - 1984

The above information prepared by D. M. Hunnicutt 6/4/84  
Name Date

Group Leader \_\_\_\_\_  
Name Date Assigned

Team Members \_\_\_\_\_  
Date Assigned

\_\_\_\_\_  
Date Assigned

\_\_\_\_\_  
Date Assigned

\_\_\_\_\_  
Date Assigned

FOIA-85-59

CC/222

10/12/84

Category #1

Allegation AW-35

7c

[REDACTED] was called at Wolf Creek,  
Kansas on 10/12/84 to determine  
if he had absolute knowledge that this hunger  
had been removed as the allegor said he had been  
advised. [REDACTED] remembered the idea  
but the specific hunger was not identified by  
the allegor and there was no way to determine  
if the hunger had been removed.

Ernest S. [REDACTED]

CC/223