

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel: 309-654-2241

ComEd

SVP-98-031

February 3, 1998

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 97-026, Revision 01, for Quad Cities Nuclear Power Station.


This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(i)(B). The licensee shall report any operation or condition prohibited by the Plant's Technical Specifications.

The following commitments are being made by this letter:

1. QCGP 2-1, "Normal Unit Shutdown" will be revised by 032798 to ensure that IRM checks referenced in QOS 0005-01 are performed prior to entering the applicable Mode.
2. QCGP 1-4 and QCGP 1-5 will be revised by 032798 to ensure that Primary Containment sump flow rate surveillances are performed prior to entering the applicable Mode.

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,


E. S. Kraft, Jr.
Site Vice President
Quad Cities Station

ESK/CP/plm

Enclosure

9802120293 980203
PDR ADOCK 05000254
S PDR

IE22/1

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
M. E. Wagner, Licensing, ComEd
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center

100005

