

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309/654-2241

ComEd

SVP-98-029

February 2, 1998

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 98-001, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(iv). The licensee shall report any event or condition that resulted in manual or automatic actuation of any Engineered Safety Feature.

The following commitments are being made by this letter:

1. All shift Operations personnel will receive training on this event by 051598 including proper interpretation of the term "valid".
2. An off-site evaluation of the binding of the EDG air start motor will be conducted by 093098.
3. System Materials Engineering will evaluate the affect of the tape on the performance of the air start solenoid by 033198.
4. The Maintenance Work Execution Procedure will be revised by 022798 to ensure the procedure comprehensively prohibits such activities as placing and removing relay covers without proper authorization.
5. Maintenance Continuing and Initial Training will be revised by 051598 to include the above expectation.
6. Logic Test procedures will be revised by 032798 to add and sequence steps such that inadvertent actuations are prevented.

110004

9802120304 980202
PDR ADOCK 05000254
S PDR




IE221,

February 2, 1998

7. The operability issues associated with the Unit 1 EDG and the component evaluations identified in items 2 and 3 will be reported in a supplement to this LER by 103198.

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,


E. S. Kraft, Jr.
Site Vice President
Quad Cities Station

ESK/CP/plm

Enclosure

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
M. E. Wagner, Licensing, ComEd
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center