

July 1, 1986

Docket No. 50-395

DISTRIBUTION

Docket File

Mr. D. A. Nauman
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
P.O. Box 764 (Mail Code 167)
Columbia, South Carolina 29218

NRC PDR
Local PDR
PAD#2 Rdg
T. Novak
OELD
E. Jordan
B. Grimes
J. Partlow
N. Thompson, DHFT

J. Hopkins
D. Miller
ACRS (10)
Tech Branch
Gray File

Dear Mr. Nauman:

Subject: V.C. Summer Nuclear Station - Appendix R Reanalysis

By letter dated June 5, 1986, you informed us that the modification completion schedule for the service water booster pump "M" board fire barrier has been changed to 1st Quarter 1987. You also stated that the interim compensatory measure of a roving fire watch will remain in place until the modification is complete. We have reviewed the modification schedule change and the interim compensatory measure and find that they are acceptable.

Sincerely,

JS

Jon B. Hopkins, Project Manager
PWR Project Directorate #2
Division of PWR Licensing-A
Office of Nuclear Reactor Regulation

cc: See next page

A for LA:PAD#2
DMiller
6/30/86

A PM:PAD#2
JHopkins:hc
6/30/86

[Signature] AD:PAD#2
DMcDonald
7/1/86

B607140020 B60701
PDR ADOCK 05000395
F PDR

Mr. D. A. Nauman
South Carolina Electric & Gas Company

Virgil C. Summer Nuclear Station

cc:

Mr. William A. Williams, Jr.
Technical Assistant - Nuclear Operations
Santee Cooper
P.O. Box 764 (Mail Code 167)
Columbia, South Carolina 29218

J. B. Knotts, Jr., Esq.
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 17th Street, N.W.
Washington, D. C. 20036

Resident Inspector/Summer NPS
c/o U.S. Nuclear Regulatory Commission
Route 1, Box 64
Jenkinsville, South Carolina 29065

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Chairman, Fairfield County Council
P.O. Box 293
Winnsboro, South Carolina 29180

Attorney General
Box 11549
Columbia, South Carolina 29211

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201