

July 8, 1986

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-IV-86-22

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region IV staff on this date.

FACILITY: Louisiana Power & Light Company
Waterford 3
Taft, Louisiana
DN: 50-382

Licensee Emergency Classification:
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: PLANT SHUTDOWN GREATER THAN 48 HOURS

The Waterford 3 plant manager reported that he had ordered a plant shutdown due to a continued temperature rise in leak off temperature from Reactor Coolant Pump Seal 2B. Seal deterioration indicated that a reactor shutdown was warranted. The utility plans to be shut down for 10 days to replace the seal. They plan to replace at least one additional seal during the outage.

The licensee does not plan to issue a press release.

The state of Louisiana has been informed.

CONTACT: G. L. Constable (FTS 728-8151)

DISTRIBUTION:

H. St. _____ MNBB _____ E/W _____
Chairman Zech EDO _____ IE _____
Comm. Bernthal PA _____ OIA _____
Comm. Roberts ELD _____ AEOD _____
Comm. Asselstine MPA _____ VIB _____
ACRS
SECY Phillips _____
CA NRR _____
PDR DCS _____

Regional Offices _____

MAIL:
ADM:DMB (Original)
DOT:(Trans only)

FAX:
INPO _____
NSAC _____
RRI _____
SP _____ (Air Rights)

LICENSEE:
(Reactor Licensee)

RIV:DRSP
EHJohnson:cs
7/9/86

RA *hw*
RDMartin
7/9/86

(Transmitted via 5520 - 7/9/86 11:04a -jc)

8607140137 860708
PDR I&E
PNO-IV-86-022 PDR

1E34
012

PRIORITY ROUTING

FIRST SECOND

CA	/	SPBI	/	NMS & SB	/
CRA	/	SA	/	NMS	/
QDC & P	/	FSD	/	SM	/
ORC & S	/	PCS	/	S	/
ORC	/		/	ADD	/
TO	/		/	INT	/
TO	/		/		/
TO	/	KWS, RDD	/		/
TO	/	TRPS	/		/
TO	/	PC	/	FILE	/

blair
JU