

OK *m k*

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-86-37A Date: 07/07/86

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: Arizona Nuclear Power Project
Palo Verde Unit 2
DOCKET NO. 50-529

Emergency Classification
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: REACTOR COOLANT PUMP SEAL REPLACEMENT (UPDATE)

The unit is currently in Mode 5 performing replacement of the 2A and 2B Reactor Coolant Pump seals. The licensee has decided to also replace the 1A and 1B pump seals, largely a preventive measure. Plant restart is projected for the latter part of this week.

This information is current as of 9:00 am, MST, on July 7, 1986.

CONTACT: R. Zimmerman
(602) 386-5760

L. Miller, Jr.
(415) 943-3869

DISTRIBUTION

H St.	MNBE	Phillips	E/W	Willste	Air Rights	2:53	Mail:
Chairman Palladino	EDO	NRR	IE	NMSS			ADM:DMB
Comm. Zech	PA		OIA	RES			DOT:Trans Only
Comm. Bernthal	MPA		AEOD				
Comm. Roberts	ELD						
Comm. Asselstine		Regions:					
SECY		INPO 2:58	NSAC 2:55				
ACRS		Licensee:					
CA		(Reactor Licensees)					
PDR		Resident Inspector					

REGION V: FORM 211
(Revised 3/14/83)

8607140167 860707
PDR I&E
PNO-V-86-037A PDR

IE-34
0/1