

BUILDING 89

CLOSEOUT SURVEY REPORT

8607140309 860708
NMSS LIC30
08-01393-02 PDR

ENCLOSURE (1)

Section I

HISTORICAL

A. From July, 1985 to October, 1985, Afftrex, Ltd. worked at the Naval Research Laboratory, Washington D.C. under Contract no. N00014-85-C-2289. The purpose of this contract was to decontaminate the inactive areas known as Building 89 and "Building 100". The location of these areas are shown in Attachment I.


B. "Building 100" was a term which referred to an area, outdoors, which consisted of forty-one (41) steel storage tubes, ten feet deep and various diameters from four to twelve inches. The tubes were flush-mounted at ground level and were contained within an 8 x 12 ft. concrete slab. This was located within the fenced compound surrounding Building 89. These underground tubes were no longer used for radioactive material storage.

C. Building 89 contained two interconnected Hot Cells, as well as an Operating, or Control Room, a Change Room containing sanitary facilities, and a Loading Room which contained the only access doors to the two hot cells. Located in this Loading Room was a laundry facility for anti-contamination clothing. The laundry facility and floor drains from the hot cells all drained into a 600 gallon steel holding tank buried under the concrete outside Building 89. Also located inside the Loading Room were twenty-eight (28) 2.5 inch diameter by 8 feet deep underground storage tubes, flush-mounted in the concrete floor. The two hot cells were connected to a 4000 CFM ventilation system located on the roof of Building 89. None of the facilities of Building 89 were in active use when the decontamination work was begun.

D. Also included in this contract was the removal of three (3) 650 gallon liquid radioactive waste storage tanks located outside the northwest corner of Building 82, also shown in Attachment I. These three tanks had previously been isolated from all other systems in Building 82. The tanks were not connected to the decommissioning of Building 89 / 100 in any way, but were included in this contract because of their proximity to the Building 89 compound.

TABLE OF CONTENTS


- I. Brief History and Description
 - A. Introduction
 - B. Description of "Building 100"
 - C. Description of Building 89 and Facilities
 - D. Description of Building 82 Storage Tanks
 - Attachment I NRL Site Map and Detail
- II. Work Performed
 - A. Mobilization
 - B. Equipment Removed from Hot Cells
 - C. Ventilation System Removal
 - D. Operating and Change Rooms
 - E. Loading Room
 - F. Piping & Tanks
 - G. "Building 100" Removal
 - H. Building 82 Tanks
- III. Release Survey Data
 - A. Survey Extent
 - B. Radiological Criteria for Release
 - C. Air Monitoring Report
 - Attachment II Release Surveys for Unrestricted Use
- IV. Instrument Calibration Records
 - A. List of Instruments
 - Attachment III Instrument Calibration Certificates



Page 1 of 2

Attachment I

SCALE: 1" = 80'



BUILDING 89
CLOSEOUT SURVEY REPORT

I. INTRODUCTION

The Naval Research Laboratory (NRL) intends to demolish Building 89 and to utilize it, and part of the surrounding area, as a parking lot. In order to prepare the site for unrestricted use, the following objectives were established:

A. Completely decontaminate Building 89 and the associated equipment located within it.

B. Remove and dispose of 28 inground storage tubes inside of Building 89.

C. Remove and dispose of 41 inground storage tubes outside of Building 89. This area is referred to as Building 100.

D. Remove and dispose of 4 underground liquid hold-up tanks (HUT) outside of Building 89.

E. If necessary, remove and dispose of drain lines associated with the various HUTs.

F. No residual contamination exceeding the limits established in paragraph IV shall be left in place. Soil and equipment exceeding the limits shall be disposed of as radiological waste.

Preliminary studies indicated that it would be advantageous to have the required work done by an outside contractor. Aftrex, Ltd., of Finleyville, Pennsylvania, a company specializing in decontamination and health physics services, was awarded a contract to:

A. Survey all areas and equipment associated with the facility.

B. Where possible, decontaminate all areas and associated equipment to levels below established limits.

C. Dispose of all items (including soil) that could not be decontaminated below established limits.

D. Provide a final report to NRL covering the completed work (Appendix B).

II. FACILITIES

A. Building 89

This building was constructed in 1957 and used as a hot cell facility to test irradiated metallurgical specimens until 1965 (page 1 of Appendix A). In addition, the building was also used, at various times, as a radioactive source repository by the Health Physics Staff from 1965 to 1985, and as a laundry facility for contaminated clothing from 1973 to 1985. The building is a one-story structure, 36.5 feet by 41 feet. The exterior walls are hollow concrete blocks, the roof is of flat composition construction, and the floors are concrete covered with fiberglass/epoxy sheathing. Two hot cells within the building are constructed of solid concrete slabs approximately 36 inches thick. In addition to the cells, the building contains two work rooms and restroom facilities. Behind Cell No. 2 were 28 inground steel tubes 8 feet long and 2.5 inches in diameter. These tubes were used for storage of irradiated metallurgical specimens.

B. Building 100

This building was located on the north side of Building 89 (page 2 of Appendix A), and consisted of 41 steel tubes buried in the ground. These tubes were 10 feet in length and varied in diameter from 4 to 12 inches. These tubes were also used to store irradiated metallurgical specimens. Although referred to as a building, there were no structural parts (roof or walls) above ground.

C. Liquid Hold-Up Tanks

1. HUT-89

A 600-gallon steel tank used for holding liquid waste generated in Building 89 operations (page 2 of Appendix A). This tank was located underground on the north side of Building 89. It was rectangular in shape and measured 6 feet x 6 feet x 3 feet. Three penetrations on the sides of the tank served as drain lines for Building 89, and one penetration at the top provided access for a hose line when the contents of the tank were pumped to the sanitary sewer.

2. HUT-82

Three 650-gallon steel tanks were located underground about 100 feet northeast of Building 89 (page 3 of Appendix A). Although these tanks were never associated with activities at 89, they did contain liquids generated inside Building 82. This building was intended to be used as a facility for decontaminating

equipment used in atmospheric weapons testing. Cessation of atmospheric testing occurred before Building 82 was used. Since its construction, the only work in this building involving radioactive material was the laundering of contaminated clothing, decontamination of equipment, and the packaging of rad waste. The decision to remove these tanks was made because the proposed parking lot would be installed over them. The tanks were cylindrical in shape and each measured 4 feet in length and 5 feet in diameter. Each tank had several penetrations that permitted one to select different filling and discharging schemes depending on valve settings. These tanks were emptied and sealed from further use in 1973.

III. CONTAMINATION

In general, the contamination levels observed throughout Buildings 89 and 100, and the HUTS prior to decontamination were:

A. Removable -- less than 200 dpm/100 cm² for beta-gamma, less than 1 dpm/100 cm² for alpha, and radiation levels equal to instrument background.

B. Fixed -- less than 5000 dpm/100 cm² for beta-gamma, less than 100 dpm/100 cm² for alpha, and radiation levels less than 0.1 mrad/hr at 1 cm.

The only exceptions from the general levels were found in the drain lines connecting Cells No. 1 and 2 to HUT-89, and Building 100. In the drain lines, the maximum radiation level was 15.0 mrad/hr at 1 cm with contamination levels being less than 1000 dpm/100 cm². In Building 100, one tube had a radiation level of 4.5 mRad/hr at the top surface of the tube. This level was the result of a small steel slug found at the bottom of the tube. Instrument readings at the surface of the slug indicated radiation levels of 1.5 Rad/hr. The slug was removed from the tube with tongs, placed in a lead container, and transported to our hot cells in Building 71 for storage.

IV. RELEASEABLE LIMITS

Buildings, HUTs, and associated equipment were considered releasable if contamination levels were less than 1000 dpm/100 cm² beta-gamma, 100 dpm/100 cm² alpha, and radiation levels were less than 0.2 mRad/hr at 1 cm. Release of liquid effluents to the sanitary sewer was based on limits found in 10 CFR Part 20, Appendix B, Table II, Column 2. Soil with contamination levels greater than 1×10^{-6} $\mu\text{Ci/gm}$ was excavated and disposed of as radwaste.

V. INSTRUMENTATION

A. Dose rates were measured with an end window G-M survey meter. The G-M tube has a mica window with a thickness of 1.4-2.0 milligrams per square centimeter. This instrument is calibrated every 90 days and has a typical background of 0.03 mRad/hr.

B. Smear surveys were taken with Whatman #50 filter paper. The filters were counted in a gas flow proportional counter for one minute. Efficiencies for this counter were determined with standards traceable to the National Bureau of Standards (NBS).

C. Gamma-ray analysis of samples were made with a germanium-lithium (GeLi) detector. Counting times for samples varied from 100 to 1000 minutes. Efficiencies for the GeLi detector and associate equipment were determined with a mixed gamma-ray reference standard having energies ranging from 88 Kev to 1.836 Mev. The standard is traceable to NBS.

VI. RESULTS

A. Building 89

The hot cells, walls, ceiling, and floors of the building were surveyed, and, where necessary, decontaminated to releasable limits (see pages 4 through 14 of Appendix A). The 28 storage tubes were excavated and surveyed. Levels exceeding releasable limits were found inside the bottom portions of 20 tubes. These tubes were sawed in half and the bottom sections disposed of as radwaste. The top halves, along with the other 8 tubes, were disposed of as regular waste after surveys indicated contamination levels were below releasable limits. Soil samples taken from the outside of the tubes indicated no contamination.

B. Building 100

The 41 storage tubes were excavated and surveyed (pages 15 through 17 of Appendix A). Contamination above releasable limits was detected inside the bottom section of each tube. All of these tubes were sawed in half and the bottom sections were disposed of as radwaste. The top halves were resurveyed, found free of contamination, and disposed of as regular waste. Soil samples taken from around these tubes showed no contamination.

C. HUT-89

Prior to excavating this tank, about 400 gallons of liquid waste, collected during the decontamination of Building 89, were pumped from the tank to the sanitary sewer. Samples taken of the liquid prior to discharging showed activity levels of $9.7 \times 10^{-7} \mu\text{Ci/cc}$ for Co-60 and $6.2 \times 10^{-7} \mu\text{Ci/cc}$ for Cs-137. Total activity released for all decon operations was 2.85 Ci.

After excavation, the tank was cut into smaller pieces and the majority of it was disposed of as radwaste. Surveys made on the pieces of the tank designated for regular waste were below releasable limits (page 18 of Appendix A).

Soil samples from various locations around and under the tank were collected and analyzed. The analysis of the samples taken from the bottom of the excavated pit detected Co-60 ($4.7 \times 10^{-5} \mu\text{Ci/gm}$) and Cs-137 ($4.1 \times 10^{-3} \mu\text{Ci/gm}$) contamination. An inspection of the tank revealed several small rust holes in the tank that matched the location of the contamination in the pit.

A 12-inch layer of soil was removed from the bottom of the pit and packed in 55-gallon drums for disposal as radwaste. The bottom of the pit was resurveyed and the analysis of the samples indicated that all activities were less than $9.3 \times 10^{-7} \mu\text{Ci/gm}$.

D. Drain Lines

✓ L App B. II factors

An inspection of the drain lines from Building 89 revealed plastic liners were inside two of the lines. The liner in the pipe running from the back room to the tank was removed and surveyed for contamination. No activities were detected in the liner and it was disposed of in regular waste. Smear and instrument surveys taken on the inside of the drain line did not detect any contamination or radiation levels above releasable limits.

The plastic liner was also removed from the other pipe that ran from inside Cell 2 to HUT-89. Surveys made on this liner detected trace amounts of activity ($800 \text{ dpm}/100 \text{ cm}^2$) so it was disposed of as radwaste. The interior of the drain line was decontaminated and surveyed by attaching cloth rags to the end of a roto-rooter tool and passing the rags through the entire pipe. Analysis of the rag used in the last pass indicated Co-60 and Cs-137 activities of $80 \text{ dpm}/100 \text{ cm}^2$ and $60 \text{ dpm}/100 \text{ cm}^2$ respectively. Dose rate measurements taken inside the drain line (limited to length of detector cable) were less than 0.07 mRad/hr .

The third drain line, connecting Cell 1 and the laundry drain to the tank, could not be decontaminated to releasable limits. This line was excavated and disposed of as radwaste. Soil samples were collected at various points along the excavated drain system for analysis. Soil contaminated with Co-60 ($900 \text{ dpm}/100 \text{ cm}^2$) and Cs-137 ($8000 \text{ dpm}/100 \text{ cm}^2$) was detected in Cell 1 where the drain line was punctured. The contaminated soil was excavated and disposed of as radwaste. The excavated area was resurveyed and results of samples were below releasable limits. The excavated area from which the drain lines were removed was not backfilled and remains open for inspection.

✓ excavated by till unapplied

E. HUT-82

Before excavating the three tanks, the sludge from each was pumped into drums and solidified for disposal as radwaste. After excavation, the tanks were surveyed, decontaminated where necessary, and then disposed of as regular waste (pages 19 through 22 of Appendix A). Soil samples collected from around the three tanks were analyzed and, except for one sample, were found to be free of contamination. The one sample showing trace amounts of Co-60 ($4.4 \times 10^{-5} \mu\text{Ci/gm}$) was taken from an area where a rupture occurred in a drain line during excavation of the tank. Although the tanks were pumped before excavation, some residual liquids (about 1 gallon) remained in the tank. This liquid was the source of contamination. The soil around the ruptured pipe was collected and disposed of as radioactive waste. Resurveys of this area did not detect any residual contamination in the soil.

VII. SUMMARY


In order to prepare Building 89 for unrestricted use, certain objectives were established by NRL. They were to decontaminate Building 89 and associated equipment, remove and dispose of source storage tubes, remove and dispose of liquid waste hold-up tanks, and decontaminate or remove drain lines associated with the HUTs. The task of meeting these objectives was contracted to Afftrex, Ltd., a company specializing in decontamination and health physics services.


Acceptable contamination and radiation limits were established to determine if areas and/or items were releasable as regular waste. Items that could not be decontaminated to releasable limits were disposed of as radioactive waste.


Survey results of all items disposed of as regular waste are available at NRL for review. The results of items disposed of in radwaste are also available for review. All soil and liquid samples were retained and are available for additional analysis, if necessary. Appendix A of this report is a closeout survey of the area conducted by NRL, while Appendix B is a copy of the final report submitted by Afftrex to NRL.

**BUILDING 89
CLOSEOUT SURVEY**

APPENDIX A








BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff			
ROOM NO.	Front Rm.	PC-5	7	BY	40.4	1.7	49.8	Notice of Results		
TAKEN BY	D. K.	PC-5	7	BY	15	1.02	28	Copy to		
DATE	10/28/85	PC-5	7	BY	.15			Copy to		
SURVEY INSTRUMENT USED		COUNTED BY SS		DATE 10/31/85		COUNTS PER MINUTE (Above background)				
TYPE MODEL NO.	SERIAL NO.	RADN TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	SOFT γ	α	REMARKS
13. Vrm	A 7777	05	0.03 mR/hr	1	FRONT Room		*	*	*	FINAL SURVEY
				2			*	*	*	
				3			*	*	*	
				4			*	*	*	
				5			*	*	*	
				6			*	*	*	
				7			*	*	*	
DOSE RATE MEASUREMENTS (mR/hr)										
POINT MEASURED	DIST	READING								
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
See Map (page 5)										
FRONT ROOM										

* Indicates that the sample count is not statistically different from background



BUILDING 89 - FRONT ROOM


DOSE RATES - BACKGROUND RADIATION

0 - INDICATES SMEAR OF WALL

NOT TO SCALE

BUILDING	E9	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE		
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff					
ROOM NO.	Rest Room											
TAKEN BY	JK	PC-5	7	B2	43.9	18	44.8					
DATE	10/24/85	11	11	A	0.1	263	26					
						COUNTS PER MINUTE (Above background)						
SURVEY INSTRUMENT USED			COUNTED BY <u>JK</u>			DATE <u>10/24/85</u>			REMARKS			
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT \times or $\beta\gamma$	a			
Div.	AT333	33	0.±3 mR/h	1	Rest Room	*	*	*	*	<u>Final Survey</u>		
				2		*	*	*	*			
				3		*	*	*	*			
				4		*	*	*	*			
				5		*	*	*	*			
				6		*	*	*	*			
				7		*	*	*	*			
DOSE RATE MEASUREMENTS (mR/hr)												
POINT MEASURED	DIST	READING										
		9										
		10										
		11										
		12										
		13										
		14										
		15										
		16										
		17										
		18										
		19										
		20										
		21										
		22										
		23										
		24										
		25										
		26										
		27										
		28										

* Indicates that the sample count is not statistically different from background



BUILDING 89 - REST ROOM

DOSE RATES - BACKGROUND RADIATION

0 - INDICATES SMEAR OF WALL

BUILDING	89	LABORATORY COUNTING INSTRUMENT					ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
ROOM NO.	<u>Back Ptn</u>	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notice of Results		
TAKEN BY	<u>D/K</u>	<u>PC-5</u>	<u>7</u>	<u>B,Y</u>	<u>434</u>	<u>18</u>	<u>49.8</u>	<input checked="" type="checkbox"/> File	<input checked="" type="checkbox"/> R. Drvu	
DATE	<u>10/22/85</u>	<u>11</u>	<u>11</u>	<u>A</u>	<u>0.1</u>	<u>0.93</u>	<u>28</u>	<input checked="" type="checkbox"/> Copy to	<input checked="" type="checkbox"/> E.O.J	
								<input checked="" type="checkbox"/> Copy to		
								<input checked="" type="checkbox"/> Copy to		
								<input checked="" type="checkbox"/> Post		
								Leak Test Records		
SURVEY INSTRUMENT USED					COUNTED BY <u>S.E.</u>	DATE <u>10/22/85</u>	COUNTS PER MINUTE (Above background)			REMARKS
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	α	
<u>β, trn</u>	<u>A3930</u>	<u>137</u>	<u>0.03</u>	<u>1</u>	<u>Back Ab</u>		*	*	*	
			<u>m.s./hr</u>	<u>2</u>			*	*	*	
				<u>3</u>			*	*	*	
				<u>4</u>			*	*	*	
				<u>5</u>			*	*	*	
				<u>6</u>			*	*	*	
				<u>7</u>			*	*	*	
DOSE RATE MEASUREMENTS (mR/h)										
POINT MEASURED	DIST	READING								
<u>Sc. Map (page 9)</u>										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										


*Indicates that the sample count is not statistically different from background

BUILDING 89 - BACK ROOM

DOSE RATES - BACKGROUND RADIATION

0 - INDICATES SMEAR OF WALL

N
↑




BUILDING	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
	ROOM NO.	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level			
Cell # 1	DC-5	17	βγ	43.1	17	49.8	✓	File R. Davis (6073)	
P. K.	DC-5	17	β	30	26	28	✓		
10-28-85							Copy to		
							Copy to		
							Copy to		
							Post		
SURVEY INSTRUMENT USED			COUNTED BY SS DATE 4/18/85			COUNTS PER MINUTE (Above background)			REMARKS
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x or βγ	a
Bicron 139TS	139TS	βγ	1	Cell # 1		*	*	*	
		0.93 major	2			*	*	*	
			3			*	*	*	
			4			*	*	*	
			5			*	*	*	
Cal:	8/zr/p5		6			*	*	*	
			7			*	*	*	
			8			*	*	*	
			9			*	*	*	
			10			*	*	*	
			11	Cell # 1		*	*	*	
			12			*	*	*	
			13			*	*	*	
			14			*	*	*	
			15			*	*	*	
			16			*	*	*	
			17			*	*	*	
			18			*	*	*	
			19			*	*	*	
			20			*	*	*	
			21			*	*	*	
			22			*	*	*	
			23			*	*	*	
			24			*	*	*	
			25			*	*	*	
			26			*	*	*	
			27			*	*	*	
			28			*	*	*	

*Indicates that the sample count is not statistically different from background

BUILDING	E9	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.	Cell #2							Notice of Results			
TAKEN BY	JK	PC-5	2	B _Y	41.5	17	44.0	Copy to P. Davis			
DATE	10/29/85	11	11	D	0.25	1.32	28	Copy to File			
						COUNTS PER MINUTE (Above background)					
SURVEY INSTRUMENT USED			COUNTED BY <u>JK</u>			DATE <u>10/29/85</u>					REMARKS
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x or β y	a	
<u>β, γ etc</u>	A373A	$\beta\gamma$	0.53 mR/hr	1	Cell #2		*	*	*	<u>Final Survey</u>	
				2			*	*	*		
				3			*	*	*		
				4			*	*	*		
				5			*	*	*		
				6			*	*	*		
				7			*	*	*		
DOSE RATE MEASUREMENTS (mR/hr)											
POINT MEASURED	DIST	READING	9								
			10								
			11								
			12								
			13								
			14								
			15								
			16								
			17								
			18								
			19								
			20								
			21								
			22								
			23								
			24								
			25								
			26								
			27								
			28								

*Indicates that the sample count is not statistically different from background




BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff			
ROOM NO.										
TAKEN BY	P.K.	PC-5	7	30	43.1	177	428	✓	F. E. Davis (6073)	
DATE	10-28-85	PC-5	7	2	30	26	28	✓		
						Post			Leak Test Records	
SURVEY INSTRUMENT USED			COUNTED BY	SS	DATE	11/18/85	COUNTS PER MINUTE (Above background)			REMARKS
TYPE	SERIAL NO.	RAD'N TYPE	SAMPLE NO.	DESCRIPTION OF SAMPLE			β	γ	α	
Survey	AT313	At me/mc	1	OUTSIDE			*	*	*	
			2				*	*	*	
			3				*	*	*	
			4				*	*	*	
			5				*	*	*	
			6				*	*	*	
			7				*	*	*	
DOSE RATE MEASUREMENTS (mR/hr)			8				*	*	*	
POINT MEASURED	DIST	READING	9				*	*	*	
			10				*	*	*	
			11				*	*	*	
			12				*	*	*	
			13				*	*	*	
			14				*	*	*	
			15				*	*	*	
			16				*	*	*	
			17				*	*	*	
			18				*	*	*	
			19				*	*	*	
			20				*	*	*	
			21				*	*	*	
			22				*	*	*	
			23				*	*	*	
			24				*	*	*	
			25				*	*	*	
			26				*	*	*	
			27				*	*	*	
			28				*	*	*	

*Indicates that the sample count is not statistically different from background

BUILDING 89

Dose Rates = Background Radiation



BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff.			
ROOM NO.										
TAKEN BY	RND	PC-5	8	BY	39.2	17	51			
DATE	9-4-85	PC-5	8	D	.05	0.59	24			
SURVEY INSTRUMENT USED		COUNTED BY <u>SHB</u>		DATE <u>9-4-85</u>		COUNTS PER MINUTE (Above background)				
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT α or β	REMARKS
<u>ECI-17</u> <u>6111</u>	<u>A394B</u>	<u>BY</u>	<u>0.03</u>	1	<u>Tubes</u>		*	*	*	<u>Containment check at</u>
				2	<u>"</u> <u>Top half</u>		*	*	*	<u>41 tubes from service</u>
				3	<u>"</u> <u>#2</u>		*	*	*	<u>graben (B. 100). for tubes</u>
				4	<u>"</u> <u>"</u>		*	*	*	<u>tube</u>
				5	<u>"</u> <u>#3</u>		*	*	*	<u>dispersed as general</u>
				6	<u>"</u> <u>"</u>		*	*	*	<u>waste</u>
				7	<u>"</u> <u>#4</u>		*	*	*	
				8	<u>"</u> <u>"</u>		*	*	*	
				9	<u>"</u> <u>#5</u>		*	*	*	
POINT MEASURED	DIST	READING								
<u>Line of contact</u> <u>Long side</u> <u>at tubes</u>	<u>contact</u> <u>< 0.08</u>	<u>0.03</u>	10	<u>"</u>	<u>"</u>	<u>#6</u>				<u>RND 9-4-85</u>
			11	<u>"</u>	<u>"</u>	<u>#1</u>				
			12	<u>"</u>	<u>"</u>	<u>#7</u>				
			13	<u>"</u>	<u>"</u>	<u>#1</u>				
			14	<u>"</u>	<u>"</u>	<u>#8</u>				
			15	<u>"</u>	<u>"</u>	<u>#9</u>				
			16	<u>"</u>	<u>"</u>	<u>#10</u>				
			17	<u>"</u>	<u>"</u>	<u>#11</u>				
			18	<u>"</u>	<u>"</u>	<u>#12</u>				
			19	<u>"</u>	<u>"</u>	<u>#13</u>				
			20	<u>"</u>	<u>"</u>	<u>#14</u>				
			21	<u>"</u>	<u>"</u>	<u>#15</u>				
			22	<u>"</u>	<u>"</u>	<u>#16</u>				
			23	<u>"</u>	<u>"</u>	<u>#17</u>				
			24	<u>"</u>	<u>"</u>	<u>#18</u>				
			25	<u>"</u>	<u>"</u>	<u>#19</u>				
			26	<u>"</u>	<u>"</u>	<u>#20</u>				
			27	<u>"</u>	<u>"</u>	<u>#21</u>				
			28	<u>"</u>	<u>"</u>	<u>#22</u>				

*Indicates that the sample count is not statistically different from background

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff			
ROOM NO.										
TAKEN BY	RND	Re-5	8	B2	40.9	17	51			
DATE	9-6-85	Re-5	8	A	0.1	0.83	24			
SURVEY INSTRUMENT USED		COUNTED BY <u>JBD</u>		DATE <u>9-6-85</u>		COUNTS PER MINUTE (Above background)				
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT α or $\beta\gamma$	REMARKS
<u>Eutron C-111</u>	<u>A34B</u>	<u>B</u>	<u>0.03</u>	1	<u>Tube #1577n</u>		*	*	*	<u>Contamination Check</u>
				2	"		"	"	*	<u>Test tubes at sinks</u>
				3	"		"	"	*	<u>disperse as general dust</u>
				4	"		"	"	*	
				5	"		"	"	*	
				6	"		"	"	*	
				7	"		"	"	*	
				8	"		"	"	*	
				9	"		"	"	*	
				10	"		"	"	*	
				11	"		"	"	*	
				12	"		"	"	*	
				13	"		"	"	*	
				14	"		"	"	*	
				15	"		"	"	*	
				16	"		"	"	*	
				17	"		"	"	*	
				18	"		"	"	*	
				19	"		"	"	*	
				20	"		"	"	*	
				21	"		"	"	*	
				22	"		"	"	*	
				23	"		"	"	*	
				24	"		"	"	*	
				25	"		"	"	*	
				26	"		"	"	*	
				27	"		"	"	*	
				28	"		"	"	*	

*Indicates that the sample count is not statistically different from background

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff			
ROOM NO.								Notice of Results		
TAKEN BY	RND	PC-5	7	B2	42.9	17	50	Copy to		
DATE	9-6-65	PC-5	7	A	0.2	1.18	.21	Copy to		
								Post		
								Leak Test Records		
SURVEY INSTRUMENT USED										
TYPE	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT x or βγ	α	REMARKS
Digital Li	1341	B	0.03	1	Tube # 29	*	*	*	*	Counting taken check.
Lid	7-32-85			2	" "	*	*	*	*	This tube is used as general waste.
				3	" "	*	*	*	*	
				4	" "	*	*	*	*	
				5	" "	*	*	*	*	
				6	" "	*	*	*	*	
				7	" "	*	*	*	*	
				8	" "	*	*	*	*	
POINT MEASURED	DIST	READING								
All 14' from center of 20' 8" tubes				9	" "	33				
				10	" "	"				
				11	" "	34				
				12	" "	"				
				13	" "	35				
				14	" "	"				
				15	" "	36				
				16	" "	"				
				17	" "	37				
				18	" "	"				
				19	" "	38				
				20	" "	"				
				21	" "	39				
				22	" "	"				
				23	" "	40				
				24	" "	"				
				25	" "	41				
				26	" "	"				
				27						
				28						

*Indicates that the sample count is not statistically different from background

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff			
ROOM NO.	89 HUTT									
TAKEN BY	PK	PC-5	7	$\beta\gamma$	41.2	17	50			
DATE	10/8/85			α	0.1	0.83	21			
										Leak Test Records
SURVEY INSTRUMENT USED		COUNTED BY <u>PK</u>		DATE <u>10-8-85</u>		COUNTS PER MINUTE (Above background)				REMARKS
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT \times or $\beta\gamma$	a
151-1000	A 948	$\beta\gamma$	0.03 major	1	Rusted Metal TANK		*	*	*	CONTAMINATION CHECK
				2			*	*	*	
				3			*	*	*	
				4			*	*	*	
				5			*	*	*	
				6			*	*	*	
Cal. Factor <u>7/30/85</u>				7			*	*	*	
				8			*	*	*	
				9			*	*	*	
				10			*	*	*	
<u>Rusted metal tank</u>		<u>CONTACT</u>		11			*	*	*	
				12			*	*	*	
				13			*	*	*	
				14			*	*	*	
				15			*	*	*	
				16			*	*	*	
				17			*	*	*	
				18			*	*	*	
				19			*	*	*	
				20			*	*	*	
				21			*	*	*	
				22			*	*	*	
				23			*	*	*	
				24			*	*	*	
				25			*	*	*	
				26			*	*	*	
				27			*	*	*	
				28			*	*	*	

*Indicates that the sample count is not statistically different from background

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
ROOM NO.	H.U.T. 82 #1	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notice of Results Copy to Copy to Copy to Post	89 close-out file Leak Test Records	
TAKEN BY	R.N.DAVIS	PC	14	PY	22.9	12	50			
DATE	9-5-85	PC	9	X	0	-	27			

SURVEY INSTRUMENT USED				COUNTED BY RND	DATE 9-5-85		COUNTS PER MINUTE (Above background)			REMARKS	
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x or $\beta\gamma$	a	
Bicron GM metr	A34B	PY	0.03	1	See diagram		*	*	*		Contamination check
Cal	7-30-85			2			x	x	x		
				3			x	x	x		
				4			x	x	x		
				5			x	x	x		
				6			x	x	x		
				7			x	x	x		
				8			x	x	x		
				9			x	x	x		
				10	INNER TANK		*	*	*		
				11			x	x	x		
				12			x	x	x		
				13	OUT. TANK		x	x	x		
				14			x	x	x		
				15							
				16							
				17							
				18							
				19							
				20							
				21							
				22							
				23							
				24							
				25							
				26							
				27							
				28							

*Indicates that the sample count is not statistically different from background

Disposed as general waste
RND 9-6-85

BUILDING	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
	ROOM NO.	H.U.T. #	Type of Counter	Serial No.	Type of Activity	Bkd. C/M				Critical Level
	H.U.T. 82 #2									
TAKEN BY	PND	PC-55	7	B,Y	41.8	17	50			
DATE	9-6-85	PC-55	7	A	.15	1.02	21			
						COUNTS PER MINUTE (above background)				
SURVEY INSTRUMENT USED			COUNTED BY <u>JES</u>		DATE <u>7-18-85</u>					REMARKS
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT α or $\beta\gamma$		
Brill. 111	A364B	Bf	0.03	1	Steel Strips	*	*	*		
Ci. 1	7-30-85			2	" "	*	*	*		
				3	" "	*	*	*		
				4	" "	*	*	*		
				5	Steel piece	*	*	*		
				6	" "	*	*	*		
				7	" "	*	*	*		
				8	" "	*	*	*		
DOSE RATE MEASUREMENTS (mR/hr)										
POINT MEASURED	DIST	READING								
All points contact < 2.25		10								
		11								
		12								
		13								
		14								
		15								
		16								
		17								
		18								
		19								
		20								
		21								
		22								
		23								
		24								
		25								
		26								
		27								
		28								

*Indicates that the sample count is not statistically different from background

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		ROOM NO.	H.U.T. #2	Type of Counter	Serial No.	Type of Activity	Bkd. C/M			
TAKEN BY	RND	Pc-5	8	B2	39.2	17	51			
DATE	9-1-85	Pc-5	8	0	0.5	0.59	24	Pass		Leak Test Records
SURVEY INSTRUMENT USED	COUNTED BY	DATE		COUNTS PER MINUTE (Above background)					REMARKS	
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT \times or $\beta\gamma$	a	
Dose rate G.R.Meter	A31913	B5	0.03	1	HULL # 2 (MHS)	*	*	*	*	Contamination check of steel parts at Hull H. Parts suspended as gamma source.
G.R.I.	7-30-85			2		*	*	*	*	
				3		*	*	*	*	
				4		*	*	*	*	
				5		*	*	*	*	
				6	2 plates 8"	*	*	*	*	
				7	11" diameter	*	*	*	*	
DOSE RATE MEASUREMENTS (mR/hr)										
POINT MEASURED	DIST	READING								
All points contact 0.05		8								
	9	**								
	10	**								
	11	**								
	12	**								
	13	**								
	14	**								
	15	**								
	16	**								
	17	**								
	18	**								
	19	**								
	20	**								
	21	**								
	22	**								
	23	**								
	24	**								
	25	**								
	26	**								
	27	**								
	28	**								

* indicates that the sample count is not statistically different from background

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.	H.U.T. #3										
TAKEN BY	RND	PC-5	7	B,Y	41.8	17	50				
DATE	9-6-85	PC-5	7	A	0.15	1.02	21				
						COUNTS PER MINUTE (Above background)					
SURVEY INSTRUMENT USED				COUNTED BY	DATE	TIME				REMARKS	
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x or β/γ	a	
BECKMAN A354B C-11 Model 730-85	354B 730-85	0.02	Steel parts (6)	1	Steel parts (6)		*	*	*	Contamination check on	
		0.02		2			*	*	*	Steel parts of H.U.T. B	
		0.02		3			*	*	*	Parts disposed as scrap	
		0.02		4			*	*	*		
		0.02		5			*	*	*		
		0.02		6			*	*	*		
		0.02		7			*	*	*		
		0.02		8			*	*	*		
DOSE RATE MEASUREMENTS (mR/hr)											
POINT MEASURED	DIST	READING									
All parts tested	< 0.05										
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											

*Indicates that the sample count is not statistically different from background

BUILDING 89
AFFTREX CLOSEOUT SURVEY

APPENDIX B



412/348-9211

BOX 21 ABER ROAD R.D. 4
FINLEYVILLE, PA 15332

FINAL RELEASE REPORT

DECONTAMINATION OF BUILDING 89

Naval Research Laboratory

Washington D.C.

Section II

WORK PERFORMED

A. Upon mobilization, Afftrex, Ltd. performed contamination surveys in the work areas in order to characterize the radiological conditions on which to base future decontamination methods and techniques. In order to minimize radioactive waste, decontamination, rather than disposal, was to be used to the greatest extent practicable.

B. Afftrex, Ltd. then began to remove various fixtures inside or connected to the Hot Cells. This included four mechanical manipulators, two in each cell, which were controlled from the Operating Room and one electrically controlled "General Mills" manipulator which was suspended from tracks overhead. Also removed from the Hot Cells were all work tables, light fixtures and conduit, and an overhead door which, when raised, gave access to the "General Mills" manipulator allowing it to be moved along its tracks from one Hot Cell to the other. Cell #1 contained a lead lined cask which was removed. After washing the interior of the two Hot Cells with a steam generator in order to remove any loose contamination, the stainless steel sheets covering the lower portions of the walls were removed and the newly exposed wall areas also decontaminated. The dividing wall between Cell #1 and #2 consisted of solid concrete blocks stacked and then sheathed in plywood; the entire wall was removed when the wood was discovered to be contaminated. The epoxy floor covering in both cells was removed to permit examination of the concrete beneath it. Isolated areas were finally scabbled, removing any remaining contamination.

C. On the roof, the HEPA filters were removed from the ventilation system, and the filter housing and blower disassembled and decontaminated as necessary. The ventilation ducts from the Hot Cells to the filter housing were removed, with the exception of two short sections of duct which were buried in the concrete Hot Cell foundation. These short sections were cleaned out and decontaminated, as necessary. When a hole was discovered in one of these short sections, soil samples were taken under both ducts for analysis by NRL although field instruments could not detect any soil contamination. No soil removal was required, based on the results of these samples.

D. The only contamination found in the Operating Room and the Change Room consisted of one very small spot on the Change Room floor and a 1 foot long section on the threshold of the Operating Room outside door. Extensive surveys in these areas after removal confirmed that no other contamination existed. The suspended ceilings in all rooms were taken down and surveyed, allowing access to the areas above.

E. The Loading Room contained a few isolated spots on its north wall having some alpha contamination - the only alpha contamination found throughout this contract. Historical investigation revealed that there had once been a work table located against that wall on which Radium samples were handled. Paint removal took off most of the contamination, although a few spots finally had to be scabbled. The twenty-eight 2.5 inch diameter storage tubes were each pulled out of the ground after the surrounding concrete was found to be radiologically clean and then broken up. No external contamination was found on the tubes, although most of the pipes were disposed of due to possible internal contamination. Soil samples, analyzed by NRL were taken from each void after tube removal. No additional soil was removed, based on the results of these samples. The suspended ceiling tiles were removed from the Loading Room as in the other rooms, and a few tiles required disposal because of small, but detectable amounts of contamination. Access to the two Hot Cells was controlled by two large shielded doors located in the Loading Room. Some door surfaces facing the Hot Cells required decontamination as well. The laundry facility consisted of a normal washer and dryer, both of which were completely disassembled and all parts either cleaned and released, when possible, or disposed of as radioactive waste. As a result, this greatly decreased the volume of waste generated from the laundry facility.

F. The 600 gallon holding tank described in Section I,C. was fed by three 4 inch pipes leading into Building 89. Two of these pipes, one leading to Cell #2 and the other to the east end of the Loading Room, had been installed with plastic liners which were finally pulled out of the pipes. The pipes were then swiped out by forcing rags, on the end of an auger, through the pipe. Additional rag/swipes were collected for NRL concurrence. When no loose contamination could be found, G-M probes were inserted as far as possible from either end, with no fixed activity detected. The third pipe was highly contaminated as found by swiping out as described above. Therefore, this pipe run was dug out of the ground from the holding tank to its source. This pipe branched off to the washing machine drain, to Cell #1, and eventually to two plugged drains under the Change Room floor.

Two holes were found in this pipe, one under the Cell #1 floor and the other under the south foundation of Cell #1. Soil samples were taken along this pipe with extra samples taken near the two holes as they were discovered, to be analyzed by NRL. Approximately 1 cu. ft. of soil had to be disposed of under Cell #1 as a result of these samples. The holding tank itself was found to be extremely corroded and in very poor condition, although that could not be known until the concrete surface and three feet of soil were removed to uncover it. As a result, the surrounding soil was removed manually, with frequent contamination surveys and soil samples for NRL analysis. Approximately 105 cu. ft. of soil had to be disposed of as a result of these samples. The tank itself, when removed from the excavation, was cut into manageable pieces. Some pieces could be decontaminated while others, most notably the tank bottom, were disposed of as radioactive waste.

G. The concrete pad around "Building 100" was surveyed and then broken up to allow removal of the forty-one storage tubes. One small spot on the northwest corner of the pad was found to be contaminated, and that concrete was disposed of. The storage tubes were each pulled out of the ground, and soil samples for NRL analysis were taken from each void after tube removal. No additional soil was removed, based on the results of these samples. No external contamination was found on any of the tubes, and many of the tubes were found to be clean internally, as well, at least in the upper half. Therefore, in order to minimize radioactive waste, many of the tubes were cut in half with only the contaminated lower half being disposed of as waste. After removal, "Building 100" was restored to original condition, as required by this contract.

H. The Building 82 tanks were in much better condition than the Building 89 holding tank, with no visible corrosion damage to any of the three tanks. After removal of any standing liquids in the tanks, a backhoe was used to dig around the tanks. Frequent contamination surveys and soil samples for NRL analysis were taken during excavation, with no additional soil removed based on the results from these samples. The tanks were cut into manageable pieces after removal and some pieces decontaminated as with the Building 89 tank above. After removal, the excavation was backfilled and the area restored to its original condition as required by this contract.

Section III

Release Survey Data

A. Comprehensive contamination surveys were performed in the Operating Room and the Change Room which consisted of one reading per 3 sq. ft. of surface on walls and ceiling, etc. and one reading per 1 sq. ft. on the floors. When the two contaminated spots described in Section II, D. were found, 100% of the floor areas within a 3 ft. radius were surveyed, although no additional contamination was found. Contamination surveys were performed on 100% of the surfaces in the Loading Room and the two Hot Cells, as well as the concrete pad in "Building 100" and the ventilation system housing on the roof. All equipment or items which were released received a 100% survey prior to removal from contaminated areas.

B. Surveys were always performed for both alpha as well as beta-gamma contamination although the emphasis was placed on beta-gamma surveys, as alpha contamination was found only on the north wall of the Loading Room as described in Section II, E. The limit for release of material for uncontrolled use were set at:

1. < 50 pCi/100 cm², alpha, and < 450 pCi/100 cm², beta-gamma, for loose surface contamination. Occasionally, larger area wipes were used, but the limits remained at < 50 pCi/swipe, alpha, and < 450 pCi/swipe, beta-gamma.
2. < 50 pCi/probe, alpha, and < 450 pCi/probe, beta-gamma, for fixed activity. This method was used most often and required no additional swipes if the limits were not exceeded.
3. For areas of the building which were inaccessible by probe, swipes were taken as in #1 above and then radiation readings checked to confirm that no fixed activity was present. When objects had areas which were completely inaccessible by any means, the object was disposed of as radioactive waste.
4. Soil was checked as in #2 above during excavation, and soil samples analyzed by NRL to confirm the readings.

It should be noted that no material was released without NRL overcheck and concurrence.

C. Air samples were taken routinely during work in contaminated areas using a Staplex TF1A high volume air sampler, with the samples counted using field instruments and analyzed for activity levels. At no time did airborne contamination levels exceed, or even approach applicable limits. These limits were set at 1E-9 uci/ml for beta-gamma emitters and 2E-11 uci/ml for alpha emitters. Occasionally, readings approached a limit initially, but on recounting later it was confirmed to be due to radon daughters by virtue of the short half-life and the presence of both alpha and beta-gamma emitters. At no time, however, did this exceed 3E-9 uci/ml when radon was identified.

ATTACHMENT II

RELEASE SURVEYS FOR
UNRESTRICTED USE

A1

BUILDING	89	LABORATORY COUNTING INSTRUMENT				ACTION INDICATED		RECIPIENT (NAME & CODE)	ACTION COMPLETE
ROOM NO.	OPERATING ROOM	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notica of Results	
TAKEN BY	CLR							Copy to R. Davis	C-073
DATE	7/17/85							Copy to	
								Copy to	
								Post	Leak Test Records

SURVEY INSTRUMENT USED				COUNTED BY CLR	DATE 7/17/85	COUNTS PER MINUTE (Above background)				REMARKS		
TYPE	SERIAL NO.	RADN TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β γ	SOFT γ or $\beta\gamma$	α	DIRECT	PULSE SURVEY	OF READING	
E/HORN	1246	$\beta\gamma$	60	1	FLOOR	*			*			
E/HORN	1217	$\beta\gamma$	60	2	DOOR THICK BOARD	8000			*			
E/S20	3832	$\beta\gamma$	0.02	3								
LUDWIG	4			4	DESK	*			*			
MODEL 3/8	30732	α	0	5								
				6								
				7								
				8								
POINT MEASURED	DIST	READING		9								
HIGH UP AIR				10								
HIGH WALL	CONTACT	0.60		11								
LOW UP AIR	-			12								
LOW WALL	CONTACT	0.60		13								
				14								
				15								
				16								
				17								
				18								
				19								
				20								
				21								
				22								
				23								
				24								
				25								
				26								
				27								
				28								

* Indicate that the sample count is not statistically different from background

INSURANCE RECORDS ON SPARES

BUILDING	LABORATORY COUNTING INSTRUMENT			ACTION INDICATED			RECIPIENT (NAME & CODE)		ACTION COMPLETE	
	ROOM NO.	OPERATING ROOM	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notice of Results	
TAKEN BY CLR								Copy to		
DATE 7/1/85								Copy to		
								Pass		
								Leak Test Records		

SURVEY INSTRUMENT USED			COUNTED BY CLR		DATE 7/1		COUNTS PER MINUTE (Above background)		
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT α or $\beta\gamma$
E140N *	1256	BY	66	1	SOUTH WALL EXCEPT		*		
E520	1257	BY	66	2	FOR UNOPEN RADIATOR				
LUX-LM	3832	BY	0.03	3	(SEE PAGE AC)				
Model # 8	20722	α	0	4					
				5					
				6					
				7					

DOSE RATE MEASUREMENTS (mR/hr)		
POINT MEASURED	DIST	READING
AIR COUNTING	10	
DISTS	11	
	12	BYCO
	13	
	14	
	15	
	16	
	17	
	18	
	19	
	20	
	21	
	22	
	23	
	24	
	25	
	26	
	27	
	28	

*Indicates that the sample count is not statistically different from background
** CALCULATED 6-27-85

A3

BUILDING	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
	OPERATING ROOM	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level			
TAKEN BY CLR									
DATE 7/17/85									
						COUNTS PER MINUTE (Above background)			
SURVEY INSTRUMENT USED			COUNTED BY CLR	DATE $\gamma/7$					REMARKS
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x or $\beta\gamma$ a
E1401 *	1296	$\beta\gamma$	60	1	EAST WALL EXCLUDING		*		*
E5200 *	1297	$\beta\gamma$	60	2	2 VENTS INTO				
L2010 *	3832	$\beta\gamma$	0.03	3	BATHROOM				
Model 18	30722	α	0	4					
				5					
				6					
				7					
				8					
DOSE RATE MEASUREMENTS (mR/hr)									
POINT MEASURED	DIST	READING							
INSIDE			10						
UPPER URNS' CONTACT			11						
INSIDE			12						
LOWER URNS' CONTACT			13						
			14						
			15						
			16						
			17						
			18						
			19						
			20						
			21						
			22						
			23						
			24						
			25						
			26						
			27						
			28						

*Indicates that the sample count is not statistically different from background

* CALCULATED 5-28-85

BUILDING	OPERATING	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.	Room							Notice of Results			
TAKEN BY	CLR							Copy to R. Oquis	CO73		
DATE	7/17/85							Copy to			
								Copy to			
								Post			
								Leak Test Records			
SURVEY INSTRUMENT USED						COUNTED BY CLR	DATE 7/17	COUNTS PER MINUTE (Above background)			REMARKS
TYPE	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT α or $\beta\gamma$		
E1400	1296	$\beta\gamma$	60	1	WEST WALL	*				Direct Probe	
*	1297	$\beta\gamma$	60	2							
F500	3832	$\beta\gamma$	0.03	3							
Luxtron	Model 18	$\beta\gamma$	0	4							
				5							
				6							
				7							
DOSE RATE MEASUREMENTS (mR/hr)											
POINT MEASURED	DIST	READING	9								
Door frame contact	blk60		10								
			11								
			12								
			13								
			14								
			15								
			16								
			17								
			18								
			19								
			20								
			21								
			22								
			23								
			24								
			25								
			26								
			27								
			28								

*Indicates that the sample count is not statistically different from background

*CALIBRATED 5-21-85

HEALTH PHYSICS MONITORING REPORT
NDW-NRL-5101/3004 (Rev. 9-80)

A5

BUILDING	LABORATORY COUNTING INSTRUMENT				ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTS COMPLETE		
	OPERATING ROOM	Type of Counter	Serial No.	Type of Activity				Bkd. C/M	Critical Level
TAKEN BY CLR									
DATE 8/1/85									
SURVEY INSTRUMENT USED				COUNTED BY CLR		DATE 8/1/85	COUNTS PER MINUTE (Above background)		
TYPE MODEL NO.	SERIAL NO.	RADN TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	SOFT X or β γ	α	REMARKS
E/40W *	1244C	$\beta\gamma$	90	1	100% SURVEY OF CILING ABUT. SUPPORTED	*			* Construction of Direct Phase & Survey
E/40W *	1277	$\beta\gamma$	40	2	CILING FRAME INCURV. 4 WALL ABUT. FRAME	*			-
F/520	3832	$\beta\gamma$	0.02	5					
				6					
				7					
				8					
DOSE RATE MEASUREMENTS (mR/hr)				9					
POINT MEASURED	DIST	READING	10						
CEILING - CONCRETE	8' ELO		11						
			12						
			13						
			14						
			15						
			16						
			17						
			18						
			19						
			20						
			21						
			22						
			23						
			24						
			25						
			26						
			27						
			28						

*Indicates that the sample count is not statistically different from background
* All others count 50% &

A6

BUILDING	LABORATORY COUNTING INSTRUMENT				ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
	OPERATING ROOM NO.	Type of Counter	Serial No.	Type of Activity				Bkd. C/M
89	Alpha							
							Copy to R. Davis 6075	
							Copy to	
							Copy to	
							Post	
							Leak Test Records	
DATE	7/17/85							

SURVEY INSTRUMENT USED			COUNTED BY	CLR	DATE	7/17/85	COUNTS PER MINUTE (Above background)		
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	$\times \alpha, \beta, \gamma$	SOFT	a
* 1040L	1046	BY	60	1 WALL	*	*	*	*	*
* 1040L	1047	BY	60	2 "	*	*	*	*	*
* FS20	3852	BY	0.03	3 "	*	*	*	*	*
Calutron		BY		4 "	*	*	*	*	*
Model 11		BY		5 "	*	*	*	*	*
		BY		6 "	*	*	*	*	*
		BY		7 "	*	*	*	*	*
		BY		8 "	*	*	*	*	*
		BY		9 "	*	*	*	*	*
		BY		10 "	*	*	*	*	*
Thermocell			11	UPPER RADIATOR (SOUTH WALL)	*	*	*	*	*
Open bottom contact (of 2nd)		1.5	12	"	*	*	*	*	*
Floor radiator contact		5K60	13	"	*	*	*	*	*
			14	"	*	*	*	*	*
			15	"	*	*	*	*	*
			16	"	*	*	*	*	*
			17	"	*	*	*	*	*
			18	"	*	*	*	*	*
			19	"	*	*	*	*	*
			20	DISON THERMOMETER	*	*	*	*	*
			21	DOOR EFFECT	*	*	*	*	*
			22	DOOR NIGHT	*	*	*	*	*
			23	ELECTRICAL FLOOR (NORTH WALL)	*	*	*	*	*
			24	" "	*	*	*	*	*
			25	" "	*	*	*	*	*
			26	" "	*	*	*	*	*
			27	ELECTRICAL COUNT	*	*	*	*	*
			28	" "	*	*	*	*	*


REMARKS

*Indicates that the sample count is not statistically different from background

**Assumptions CALIBRATION 5-2P-S5

OPERATING ROOM
C.R. / 7/17/55

A 6 A



BUILDING	OPERATING			LABORATORY COUNTING INSTRUMENT			ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
	ROOM NO.	TYPE OF COUNTER	SERIAL NO.	TYPE OF ACTIVITY	BKD. C/M	Critical Level			
TAKEN BY	CLF							R DAVIS 6073	
DATE	7/17/82							Leak Test Records	
							Post		
SURVEY INSTRUMENT USED									
COUNTED BY		DATE		DESCRIPTION OF SAMPLE		COUNTS PER MINUTE (Above background)		REMARKS	
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTOR	β	γ	SOFT x or $\beta\gamma$	a
#	1246	02	60	1	BASE OF MAMM #1	*	*	*	Sample + Direct Probe
#	1247	32	60	2	ROUND CASE IND WALL "	*	*	*	Sample
				3	LEGS CLOTHES DRAWN "	*	*	*	Direct Probe
				4	ALL EXTERIOR PARTS "	*	*	*	Sample + Direct Probe
E20	3852	32	0.03	5					
				6	BASE OF MAMM #2	*	*	*	Sample + Direct Probe
				7	ROUND CASE INTO WALL "	*	*	*	Sample
				8	LEGS COMING DOWN "	*	*	*	Direct Probe
				9	ALL EXTERIOR PARTS "	*	*	*	Sample + Direct Probe
				10					
ROUND CASES				11	BASE OF MAMM #3	*	*	*	Sample + Direct Probe
MANIPULATOR	1	COMPT	0.03	12	ROUND CASE L-TH WALL "	*	*	*	Sample
				13	LEGS CLOTHES DRAWN "	*	*	*	Direct Probe
				14	ALL EXTERIOR PARTS "	*	*	*	Sample + Direct Probe
				15					
				16	BASE OF MAMM #4	*	*	*	Sample + Direct Probe
				17	ROUND CASE M-TH WALL "	*	*	*	Sample
				18	LEGS CLOTHES DRAWN "	*	*	*	Direct Probe
				19	ALL EXTERIOR PARTS "	*	*	*	Sample + Direct Probe
				20					
				21					
				22					
				23					
				24					
				25					
				26					
				27					
				28					


*Indicates that the sample count is not statistically different from background
* All last. cal on 5-21-82

A7 A

REPRESENTATION

OF A
MANIPULATING
ARM

CONTROLLERS
IN
OPERATING
ROOM



BUILDING	BATH	LABORATORY COUNTING INSTRUMENT					ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level			
ROOM NO.	Room								
TAKEN BY	CLR								
DATE	7/16/85								
SURVEY INSTRUMENT USED		COUNTED BY CLR	DATE 7/16	COUNTS PER MINUTE (Above background)					
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β Y	SOFT x or β γ	a	REMARKS
E140	129C	β Y	40	1	NORTH WALL	*			DIRECT PROBE PLUS SWEEP
E140	1297	β Y	40	2					DOSE OF VENT + RADIATOR
E140	3832	β Y	0.02	3					
EVACUUM	20722	α	0	4					
Model 18				5					
				6					
				7					
DOSE RATE MEASUREMENTS (mR/hr)									
POINT MEASURED	DIST	READING	9						
VENT	COMPTER	BKGD	10						
RADIATOR	COMPTER	BKGD	11						
DAIRY	FRAME CONTACT	BKGD	12						
			13						
			14						
			15						
			16						
			17						
			18						
			19						
			20						
			21						
			22						
			23						
			24						
			25						
			26						
			27						
			28						

*Indicates that the sample count is not statistically different from background
¶ CALCULATED 5-91-15

HEALTH PHYSICS MONITORING REPORT

NDW-NRL-5101/6004 (Rev. 9-80)

B2

BUILDING	89	LABORATORY COUNTING INSTRUMENT				ACTION INDICATED		RECIPIENT (NAME & CODE)	ACTION COMPLETE
ROOM NO.	BATH Room	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notice of Results	
TAKEN BY	CLR							Copy to	7. DAUS G073
DATE	7/16/85							Copy to	
								Copy to	
								Post	Leak Test Records
SURVEY INSTRUMENT USED				COUNTED BY	CLR	DATE 7/16	COUNTS PER MINUTE (Above background)		
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x α+βγ
E140N	1296	βY	40	1	SOOTH WALL		*		*
E526	1297	βY	40	2	TAKEN AROUND SINK, TOILET & CLOSET				
LUMIUM	3.832	βY	0.03	3					
Model 18	30722	α	0	4					
				5					
				6					
				7					
DOSE RATE MEASUREMENTS (mR/hr)									
POINT MEASURED	DIST	READING							
SINK PIPES	CONTACT	BR60	9						
FLOOR BOARD	CONTACT	BR60	10						
			11						
			12						
			13						
			14						
			15						
			16						
			17						
			18						
			19						
			20						
			21						
			22						
			23						
			24						
			25						
			26						
			27						
			28						

*Indicates that the sample count is not statistically different from background
CALIBRATED 5-98-85

B3

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bld. C/M	Critical Level	% Eff				
ROOM NO.	Geiger Room							Notice of Results	R. DAVIS 6073		
TAKEN BY	CLR							Copy to			
DATE	7/16/85							Copy to			
								Copy to			
								Post			
								Leak Test Records			
SURVEY INSTRUMENT USED						COUNTED BY CLR		DATE 7/16		COUNTS PER MINUTE (Above background)	
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT x or $\beta\gamma$	α	REMARKS	
E1404	#1296	$\beta\gamma$	40	1	EAST WALL	*				PURET ALONE	
E1404	#1297	$\beta\gamma$	40	2							
E520	#3852	$\beta\gamma$	0.03	3							
LUDLUM	#			4							
MARCEL 18	#20209	α	0	5							
				6							
				7							
DOSE RATE MEASUREMENTS (mR/hr)											
POINT MEASURED	DIST	READING	9								
GENERAL AREA	Counter	3460	10								
			11								
			12								
			13								
			14								
			15								
			16								
			17								
			18								
			19								
			20								
			21								
			22								
			23								
			24								
			25								
			26								
			27								
			28								

*Indicates that the sample count is not statistically different from background
CLR/CALIBRATION 5-28-85

BUILDING	5	LABORATORY COUNTING INSTRUMENT				INDICATED	RECIPIENT (NAME & CODE)	'ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level		
ROOM NO.							R. DAVIS	6073
TAKEN BY	CLR						Copy to	
DATE	7/16/85						Copy to	
							Post	
							Leak Test Records	
SURVEY INSTRUMENT USED	COUNTED BY	CLR	DATE	γ/k	COUNTS PER MINUTE (Above background)			REMARKS
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β γ	SOFT x or βγ	α
EMI 200 127%	1247	βγ	40 40	1	WEST wall	*		
ESQO LUDLUM Model 18	3852 30732	βγ α	0.03 6	2 3 5 6 7				
DOSE RATE MEASUREMENTS (mr/hr)	POINT MEASURED	DIST	READING					
VENT	CONTACT	βketo		9				
				10				
				11				
				12				
				13				
				14				
				15				
				16				
				17				
				18				
				19				
				20				
				21				
				22				
				23				
				24				
				25				
				26				
				27				
				28				

* Indicates that the sample count is not statistically different from background
** CALIBRATED 52F-85


BUILDING	89	LABORATORY COUNTING INSTRUMENT							ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bld. C/M	Critical Level	% Eff	Notice of Results			
ROOM NO.	WADY Room								R. Davis 6073		
TAKEN BY	CUR										
DATE	7/6/85								Copy to Copy to Copy to Post Leak Test Records		
SURVEY INSTRUMENT USED	COUNTED BY	CIA	DATE	7/6	DESCRIPTION OF SAMPLE	β	γ	SOFT x or βγ	a	REMARKS	
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.							
E1402	1294	βY	40	1	FLOOR	*	*	*	*	DIRECT PROBE	
	1297	βY	40	2	MATERIAL ON FLOOR					DIRECT PROBE (SFC MAP - BSA)	
F520	35832	βY	0.03	3	" "	*	*	*	*	Surface & Occurred to Factor - PC II	
LUMA				4							
METER 18	30722	α	0	5							
				6							
				7							
DOSE RATE MEASUREMENTS (mR/hr)	POINT MEASURED	DIST	READING								
IN AIR @			9								
FLOOR SPOT:	CONTACT	0.04	10								
OTHER PART	CONTACT	0.04	11								
ON-MATERIAL	CONTACT	0.04	12								
			13								
			14								
			15								
			16								
			17								
			18								
			19								
			20								
			21								
			22								
			23								
			24								
			25								
			26								
			27								
			28								

*Indicates that the sample count is not statistically different from background

CALCULATED 5-8-85

B5A

WASH ROOM
FLOOR
DATE 7/14/85




B6

BUILDING	BUILDING	LABORATORY COUNTING INSTRUMENT				ACTION INDICATED				ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notice of Results	Copy to	
ROOM NO.	BATH Room CEILING								TR. PAUS 6073	
TAKEN BY	CLR								Copy to	
DATE	8/6/85								Copy to	
									Post	
									Leak Test Records	
SURVEY INSTRUMENT USED	COUNTED BY	CUR	DATE	8/6				COUNTS PER MINUTE (Above background)		
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE			β	SOFT x or β /	REMARKS
E140N	124C 1297	BY	60	1	WALLS + CEILING Above SUB PANELED CEILING, PLASTER					
E520	3832	BY	0.03	2	SUB PANELED CEILING, PLASTER	*				Comments and/or Direct Photo, Sub. Plaster
Co-60	1168	Co	0	3	FLATIRON + QUARTZ ORE					
MyoPdC	34722	Co	0	4						
				5						
				6						
				7						
DOSE RATE MEASUREMENTS (mR/hr)										
POINT MEASURED	DIST		READING							
HIGHER LEVEL	CONTACT		10							
MEDIUM	CONTACT		11							
GENERAL AREA	CONTACT		12							
			13							
			14							
			15							
			16							
			17							
			18							
			19							
			20							
			21							
			22							
			23							
			24							
			25							
			26							
			27							
			28							

*Indicates that the sample count is not statistically different from background
▲ All instruments calculated ≤ 25

B6A



HEALTH PHYSICS MONITORING REPORT
NDW-NRL-5101/0004 (Rev. 9-80)

C 1


BUILDING	89	LABORATORY COUNTING INSTRUMENT				INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE		
		ROOM NO.	BACK ROOM NORTH WALL	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notice of Results
TAKEN BY	CAR, DOT, PFT									Copy to Copy to Copy to Post
DATE	8/1/85									Leak Test Records
SURVEY INSTRUMENT USED	COUNTED BY CLR	DATE 8/1/85	COUNTS PER MINUTE (Above background)						REMARKS	
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT \times or $\beta\gamma$	a	
*				1	SEE DIAGRAM	600			220	DIRECT PROBE
E140U	1296	$\beta\gamma$	80	2		*			30	SWIPE / DECAY TO FOLLOW (PAGE II)
*				3		2000			1400	DIRECT PROBE
F520	3832	$\beta\gamma$	0.02	4		*			10	SWIPE / DECAY TO FOLLOW
Ludlum	*	$\beta\gamma$	0	5		2000			600	DIRECT PROBE
Model 16	015368	α	0	6		*			*	SWIPE
				7		2000			1000	DIRECT PROBE
						*			40	SWIPE / DECAY TO FOLLOW
DOSE RATE MEASUREMENTS (mR/hr)										
POINT MEASURED	DIST	READING								
THIN PIPE										
ON WALL (SWIPE)	0.444	11								
ABOVE FAN		12								
ON BACK WALL (SWIPE)	0.03	13								
PIPE BACK WALL SEE DIAGRAM		14								
END 13	CONTACT	15								
		16								
		17								
		18								
END 3	CONTACT	19								
		20								
END 15	CONTACT	21								
		22								
END 81	CONTACT	23								
		24								
		25								
		26								
		27								
		28								

*Indicates that the sample count is not statistically different from background

ALL INSTRUMENTS (ALIBI TEST)
5-08-85

NORTH WALL
Back Room
Oct 8/1/85

C 1 A



C2

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.	Black Room							R. DAVIS G073			
TAKEN BY	CLR							Copy to			
DATE	7/24/85							Copy to			
									Post		
									Leak Test Records		
SURVEY INSTRUMENT USED			COUNTED BY	CLA	DATE	β/γ	COUNTS PER MINUTE (Above background)				
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT \times or $\beta\gamma$	a	REMARKS
# 1296	1296	$\beta\gamma$	80	1	SOUTH WALL		*		*	*	DIRECT PROBE
# 1257	1257	$\beta\gamma$	80	2	VENT		*		*	*	SCALING
# 3832	3832	$\beta\gamma$	0.03	3							
LUDLUM MODEL #1	20722	α	0	4							
				5							
				6							
				7							
DOSE RATE MEASUREMENTS (mR/hr)											
POINT MEASURED	DIST	READING	9								
VENT	CONTACT	Block D	10								
VENT C-RATE WALL	CONTACT	Block D	11								
LEAD CELL #1	CONTACT	Block D	12								
		Block D	13								
		Block D	14								
		Block D	15								
		Block D	16								
		Block D	17								
		Block D	18								
		Block D	19								
		Block D	20								
		Block D	21								
		Block D	22								
		Block D	23								
		Block D	24								
		Block D	25								
		Block D	26								
		Block D	27								
		Block D	28								

*Indicates that the sample count is not statistically different from background
† CALIBRATION 5-28-85

C3

BUILDING	89	LABORATORY COUNTING INSTRUMENT					ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		TYPE of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level				
ROOM NO. Room										
TAKEN BY CLR										
DATE 7/24/85										
SURVEY INSTRUMENT USED					COUNTED BY CLR	DATE 7/24	COUNTS PER MINUTE (Above background)			
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT α or $\beta\gamma$	REMARKS
E1400	* 1246	$\beta\gamma$	80	1	EAST Wall	*				DIRECT PROBE
E500	* 3852	$\beta\gamma$	0.03							
LURUM	* 30722	α	0							
MIDC	18									
DOSE RATE MEASUREMENTS (mR/hr)					8					
POINT MEASURED	1	DIST	READING	9						
WEAR	10			10						
FINE FST.	11			11						
COUPL	12			12						
6kCo	13			13						
	14			14						
	15			15						
	16			16						
	17			17						
	18			18						
	19			19						
	20			20						
	21			21						
	22			22						
	23			23						
	24			24						
	25			25						
	26			26						
	27			27						
	28			28						

* Indicates that the sample count is not statistically different from background
** CALCULATIO 5-PP-85


C4

BUILDING	89	LABORATORY COUNTING INSTRUMENT					ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level			
ROOM NO.	BACK Room							R. DAVIS 6073	
TAKEN BY	CLR								
DATE	7/24/85							Look Test Records	-
SURVEY INSTRUMENT USED		COUNTED BY CLR		DATE 7/24		COUNTS PER MINUTE (Above background)			
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT x or $\beta\gamma$	REMARKS
E140A	1296	$\beta\gamma$	80	1	WEST WALL	*		*	DIRECT PROBE
E140A	1277	$\beta\gamma$	80	2	Door Threshold LEAD				
ESQ	3822	$\beta\gamma$	0.03	3	AUTO CELL #1	100		*	DIRECT PROBE (DECEASED TO FOLLOW)
ESQ	30792	α	0	4		*		*	SOURCE
Model 18	30792	α	0	5					
Model 18	30792	α	0	6					
Model 18	30792	α	0	7					
DOSE RATE MEASUREMENTS (mR/hr)									
POINT MEASURED	DIST	READING							
Door (INT)		10							
Cell (OP32)	(3000)	0.45							
Door (INT)		11							
Cell (OP32)	(3000)	0.45							
Door (INT)		12							
Cell (OP32)	(3000)	0.45							
Door (INT)		13							
Cell (OP32)	(3000)	0.45							
Door (INT)		14							
Cell (OP32)	(3000)	0.45							
Door (INT)		15							
Cell (OP32)	(3000)	0.45							
Door (INT)		16							
Cell (OP32)	(3000)	0.45							
Door (INT)		17							
Cell (OP32)	(3000)	0.45							
Door (INT)		18							
Cell (OP32)	(3000)	0.45							
Door (INT)		19							
Cell (OP32)	(3000)	0.45							
Door (INT)		20							
Cell (OP32)	(3000)	0.45							
Door (INT)		21							
Cell (OP32)	(3000)	0.45							
Door (INT)		22							
Cell (OP32)	(3000)	0.45							
Door (INT)		23							
Cell (OP32)	(3000)	0.45							
Door (INT)		24							
Cell (OP32)	(3000)	0.45							
Door (INT)		25							
Cell (OP32)	(3000)	0.45							
Door (INT)		26							
Cell (OP32)	(3000)	0.45							
Door (INT)		27							
Cell (OP32)	(3000)	0.45							
Door (INT)		28							

*Indicates that the sample count is not statistically different from background
**CALIBRATION 5-28-85

C 4 A

BACK ROOM
WEST WALL
7/24/85
CIA



C5

BUILDING	89	LABORATORY COUNTING INSTRUMENT					ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		ROOM NO.	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notice of Results
TAKEN BY	CLR								R. Davis G072
DATE	7/24/85								Copy to Copy to Copy to Post Leak Test Records
SURVEY INSTRUMENT USED	COUNTED BY	CLR	DATE	7/24	COUNTS PER MINUTE (Above background)				
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT α or $\beta\gamma$	REMARKS
E1400	1296	βY	80	1	CEILING ABOVE	*			DIRECT PROBE (PICKUP TO FACILITY)
E520	1297	βY	80	2	SUSPENDED CEILING ROCK	*			DIRECT PROBE (PICKUP TO FACILITY)
Loctron	38332	βY	0.02	3	CEILING TILE	60			DIRECT PROBE (PICKUP TO FACILITY)
Model A	30122	α	0	4	CEILING TILE	140			SUMPES ON ASBESTOS CEILING TILE
				5		*			
				6					
				7					
DOSE RATE MEASUREMENTS (mR/hr)	POINT MEASURED	DIST	READING						
8				8					
9				9					
10				10					
11				11					
12				12					
13				13					
14				14					
15				15					
16				16					
17				17					
18				18					
19				19					
20				20					
21				21					
22				22					
23				23					
24				24					
25				25					
26				26					
27				27					
28				28					

*Indicates that the sample count is not statistically different from background
for calibration of meter, 6-87-85
④ CONTAMINATED CELLS TILES DISPOSED
OF AS RAD WASTE


C6

BUILDING	89	LABORATORY COUNTING INSTRUMENT					ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level			
ROOM NO.	BACK Room						Notice of Results		
TAKEN BY	CLR						Copy to R. DAVIS 6075		
DATE	8-7-85						Copy to		
							Copy to		
							Copy to		
							Post	Leak Test Records	
COUNTS PER MINUTE (Above background)									
SURVEY INSTRUMENT USED		COUNTED BY CLR		DATE 8/7		REMARKS			
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT X OR β γ	α
*	1296	3Y	80	1	100% $\beta\gamma$ SURVEY ON CEILING + WALL ABOVE SUSPENDED CEILING RACK	X			
E1404	1297	3Y	80	2	CEILING + WALL ABOVE SUSPENDED CEILING RACK	X			Combination of Direct Probe & Survey
E520	3852	3Y	0.02	3					
460/cm				4					
Model #18	30722	OC	0	5					
				6					
				7	SAR CHECK FOR α ON CEILING + WALL ABOVE SUSPENDED CEILING RACK	X			
DOSE RATE MEASUREMENTS (mR/hr)				8					
POINT MEASURED	DIST	READING		9					
				10					
				11					
				12					
				13	100% α SURFACE OR	X			
				14	CEILING FIXTURES	X			
				15					
				16					
				17					
				18					
				19					
				20					
				21					
				22					
				23					
				24					
				25					
				26					
				27					
				28					

*Indicates that the sample count is not statistically different from background
LAST CALIBRATED 6-28-85

C 6 A

BACK ROOM
ALPHA SURVEY
8/7/85
CLR



C7


BUILDING	89	LABORATORY COUNTING INSTRUMENT				ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M				
Room							R. Davis C073		
TAKEN BY	CIR ODT								
DATE	7/1/85						Leak Test Records		
SURVEY INSTRUMENT USED				COUNTED BY	ODT	DATE 7/9	COUNTS PER MINUTE (Above background)		
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT α or $\beta\gamma$	REMARKS
E1404	1296	BY	80	1	CONCRETE next to Jude	*	*	*	DIRECT PROBE (ODT on follow up probe) SWIPE
E530	3332	BY	0.03	2	CONCRETE next to Jude	*	*	*	DIRECT PROBE (ODT on follow up probe) SWIPE
Ludum Model 15	2022	A	0	4	CONCRETE next to Jude	*	*	*	DIRECT PROBE (ODT on follow up probe) SWIPE
				5	CONCRETE next to Jude	*	*	*	DIRECT PROBE (ODT on follow up probe) SWIPE
				6	600	*	*	*	DIRECT PROBE SWIPE
				7	tracks	*	*	*	DIRECT PROBE SWIPE
DOSE RATE MEASUREMENTS (mR/hr)				8					
POINT MEASURED	DIST	READING		9	CONCRETE floor				
Sample 1	Counter	0.04		10		*	*	*	DIRECT PROBE SWIPE
	"	0.09		11	CONCRETE floor from 3'0"	*	*	*	DIRECT PROBE SWIPE
	"	0.09		12		*	*	*	DIRECT PROBE SWIPE
	"	0.09		13	Floor/Floor off cell #1	*	*	*	DIRECT PROBE SWIPE
	"	0.09		14		*	*	*	DIRECT PROBE SWIPE
	"	0.09		15	" " "	*	*	*	DIRECT PROBE SWIPE
	"	0.09		16	" " "	*	*	*	DIRECT PROBE SWIPE
	"	0.09		17	" " "	*	*	*	DIRECT PROBE SWIPE
	"	0.05		18	" " "	*	*	*	DIRECT PROBE SWIPE
	"	0.09		19	" " "	*	*	*	DIRECT PROBE SWIPE
	"	0.09		20	" " "	*	*	*	DIRECT PROBE SWIPE
	"	0.01		21	RIGHT CORNER of room 3x3'	*	*	*	DIRECT PROBE SWIPE
	"	0.01		22					
	"	0.01		23					
	"	0.01		24					
	"	0.01		25					
	"	0.01		26					
	"	0.01		27					
	"	0.01		28					

*Indicates that the sample count is not statistically different from background
#OACIATED 5-2F-5


C7A

Back Room
Floor Survey
7/19/85
DOT

N



C 8 A
Back Room
Storage Putes



NOTE: 20 of 28 tubes were empty -
these tubes were cut in half with top half
removed, decommissioned and released and
lower half disposed of as solid waste


8 storage tubes were concrete-filled -
these were cut open at bottom cap and
survived for residual contamination, then
released - NRC retained 8 bottom caps

DOOR TO
CELL #2

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff			
ROOM NO.	Back Room								R. Davis 6073	
TAKEN BY	OH CLR									
DATE	8/13/85								Leak Test Records	
SURVEY INSTRUMENT USED	COUNTED BY	ACR	DATE P/S	COUNTS PER MINUTE (Above background)				REMARKS		
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT α or $\beta\gamma$		
E140H	1297	BY	80	1	STORAGE TUBE	X	X	X	External	Direct
E520	3832	BY	0.03	2	" "	X	X	X	External	Direct
Model 18	20722	O	O	3	" "	X	X	X	External	Direct
				4	" "	X	X	X	External	Direct
				5	" "	X	X	X	External	Direct
				6	" "	X	X	X	External	Direct
				7	" "	X	X	X	External	Direct
				8	" "	X	X	X	External	Direct
				9	" "	X	X	X	External	Direct
				10	" "	X	X	X	External	Direct
				11	" "	X	X	X	External	Direct
				12	" "	X	X	X	External	Direct
				13	" "	X	X	X	External	Direct
				14	" "	X	X	X	External	Direct
				15	" "	X	X	X	External	Direct
				16	" "	X	X	X	External	Direct
				17	" "	X	X	X	External	Direct
				18	" "	X	X	X	External	Direct
				19	" "	X	X	X	External	Direct
				20	" "	X	X	X	External	Direct
				21	" "	X	X	X	External	Direct
				22	" "	X	X	X	External	Direct
				23	" "	X	X	X	External	Direct
				24	" "	X	X	X	External	Direct
				25	" "	X	X	X	External	Direct
				26	" "	X	X	X	External	Direct
				27	" "	X	X	X	External	Direct
				28	" "	X	X	X	External	Direct

*Indicates that the sample count is not statistically different from background
CALIBRATED 5-28-85

C 8 A
Back Room
STORAGE TUBES




NOTE: 20 of 28 tubes were empty -
these tubes were cut in half with top half
removed, decontaminated, and released and
lower half disposed of as medical waste

DOOR TO
CELL #2

BUILDING	ROOM NO.	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff			
O	CELL #1								R. DAUS C073	
TAKEN BY	O. TYCOR									
DATE	9-6-85								Leak Test Records	
SURVEY INSTRUMENT USED			COUNTED BY	OOT	DATE 9-6	COUNTS PER MINUTE (Above background)		REMARKS		
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT γ or $\beta\gamma$	α	
E-140	1348	$\beta\gamma$	100	1	WINDOW Rim	x	x	x	x	DIRECT PROBE
LUDCUM MODEL 1F	50799	α	0	2	FAIRY WAY	x	x	x	x	" "
E-520	3832	$\beta\gamma$.04	4	WEST WALL TO ROOF	x	x	x	x	" "
				5	NORTH WALL UP TO LEDDGE	x	x	x	x	" "
				6	LEDDGE	x	x	x	x	" "
DOSE RATE MEASUREMENTS (mR/hr)				7	EXTERIOR SPOT #1	600	x	x	x	/ DIRECT TO SCALES (PROBE)
POINT MEASURED	DIST	READING		8	" SPOT #2	600	x	x	x	/ DIRECT TO SCALES (PROBE)
SOUTH WALL				9	" SPOT #3	x	x	x	x	SWEEP
WEST CORNER CONTACT	0.07			10	SPOT #4	x	x	x	x	SWEEP
ExHAUST Duct				11	SOUTH WALL UP TO LEDDGE	x	x	x	x	DIRECT PROBE
FLOOR				12	FAST SWEEP EXCEPT FINE	x	x	x	x	
WINDOW EDGE	0.13			13	FAST SWEEP	x	x	x	x	
CONTACT				14	J - BEAM	x	x	x	x	
				15	J-6CAM	1000	x	x	x	
				16	" "	x	x	x	x	
				17	COMPLETE LEAD AROUND ROOF	x	x	x	x	
				18	ROOF	x	x	x	x	
				19	" "	x	x	x	x	
				20	COMPLETE ROOM ABAR	x	x	x	x	
				21	LEDDGE	x	x	x	x	
				22	C ELLS	x	x	x	x	
				23						
				24						
				25						
				26						
				27						
				28						

*Indicates that the sample count is not statistically different from background

DIA



BLOC 89
CELL #
3 SIDES

D2

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.	Cell #1							R. DAVIS CORR			
TAKEN BY	D Tybar										
DATE	9-3-85							Leak Test Records			
SURVEY INSTRUMENT USED						COUNTED BY	DET	DATE 9-3	COUNTS PER MINUTE (Above background)		
TYPE MODEL NO.	SERIAL NO.	RADN TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT \times or $\beta\gamma$	a	REMARKS	
1400	1377	BF	100	1	Stainless Steel	260					
4200	3832	BF	.02	2	"						
4200	3832	BF	.02	3	"						
435	30722	BF	0	4	"						
				5	"						
				6	"						
				7	"						
DOSE RATE MEASUREMENTS (mR/hr)						POINT MEASURED	DIST	READING			
Shavers	Steel	Contact	.02			10	1.1	1.1			
						11	1.1	1.1			
						12	1.1	1.1			
						13	1.1	1.1			
						14	1.1	1.1			
						15	1.1	1.1			
						16	1.1	1.1			
						17	-	-			
						18	-	-			
						19	-	-			
						20	-	-			
						21	-	-			
						22	-	-			
						23	-	-			
						24	-	-			
						25	-	-			
						26	-	-			
						27	-	-			


*Indicates that the sample count is not statistically different from background
Instrument calibrated

8-24-85

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE		
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff					
ROOM NO.	CELL #1											
TAKEN BY	CLR											
DATE	9-26-85											
						COUNTS PER MINUTE (Above background)						
SURVEY INSTRUMENT USED			COUNTED BY	CLR	DATE 9/26							
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x or $\beta\gamma$	a	REMARKS		
F140	1398	$\beta\gamma$	60	1	DIVIDER TOP BE LUMEN					* DIRECT PROBE - DECAY VS. FOLLOW		
E500	3652	$\beta\gamma$	602	2	CELL #1 + CELL #2	600				* DIRECT PROBE		
600m	Model # 3	$\beta\gamma$	6	4	WALL CELL #1		*			* DIRECT PROBE		
			5	5	WALL CELL #2		*					
			6	6	IRONS LEADS FILTERS		*					
			7									
DOSE RATE MEASUREMENTS (mR/hr)												
POINT MEASURED	DIST	READING										
DIVIDER TOP CONTACT	0.00	11	HIGHEST READING —									
External Divider Contact	0.10	12										
		13	OTHER BLOCKS									
		14										
		15	FLAT LUMEN BLOCKS									
		16										
		17										
		18										
		19										
		20										
		21										
		22										
		23										
		24										
		25										
		26										
		27										
		28										

*Indicates that the sample count is not statistically different from background

D 3 A
CFL DIVISION
WALL



E 1


BUILDING		89		LABORATORY COUNTING INSTRUMENT					ACTION INDICATED		RECIPIENT (NAME & CODE)		ACTION COMPLETE	
ROOM NO.	C ELL #2	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notice of Results						
TAKEN BY	C L Room							Copy to R. Davis 6073						
DATE	9-C-85							Copy to						
								Copy to						
								Post						
SURVEY INSTRUMENT USED		COUNTED BY CCR		DATE 9-C		COUNTS PER MINUTE (Above background)								
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT α or $\beta\gamma$	a			REMARKS	
E 140 Model 18	1348 20792	BY C	1/0 0	1	Extray by Excep. for Floor		1000	1000			DIRECT PROBE			
E 520	3832	BY	0.02	2	Extray way floor		200	200			" "			
				3	Extray way floor						SLIDE			
				4	North wall						SEE in AP			
				5	Just below edge		170	170			DIRECT PROBE (fixed) Dose to floor (PTI)			
				6	Just below edge		200	200			" "			
				7	North wall		220	220			" "			
				8	Above edge		180	180			" "			
				9	Wall up to		250	250			" "			
				10	Ceil		180	180			" "			
				11	Ceil		220	220			" "			
				12	Ceil						SEE in AP			
				13	Ceil						SEE in AP			
				14	Ceil						SEE in AP			
				15	South wall						SEE in AP			
				16	(As indicated on map E1B)		180	180			DIRECT PROBE - Dose to floor (PTI)			
				17			200	200			" "			
				18			160	160			" "			
				19			200	200			" "			
				20			250	250			" "			
				21			300	300			" "			
				22			350	350			" "			
				23			500	500			" "			
				24							Indicates that the sample count is not statistically different from background			
				25										
				26							Continued on NEXT PAGE (E1A)			
				27										
				28										

E1 A

BUILDING	ROOM NO.	LABORATORY COUNTING INSTRUMENT					ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level			
89	CELL #2								
	TAKEN BY CLR								
	DATE 7-6-65								
					COUNTS PER MINUTE (Above background)				
SURVEY INSTRUMENT USED			COUNTED BY		DATE				
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	SOFT γ or $\beta\gamma$	α	REMARKS
			1	CONTINUOUS FLUX E1					
			2	60Co SOURCE Room		400			Dose to Farmer
			3A	60Co SOURCE Room					
			4	Room Above SOURCE					
			5	CEILING		X			
			6						
			7						
DOSE RATE MEASUREMENTS (mR/hr)									
POINT MEASURED	DIST	READING	9						
			10						
			11						
			12						
			13						
			14						
			15						
			16						
			17						
			18						
			19						
			20						
			21						
			22						
			23						
			24						
			25						
			26						
			27						
			28						

*Indicates that the sample count is not statistically different from background

E / B



BLOC 89
CELL #2
3 SIDES

N

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.	Cell #2								R D A H S 6023		
TAKEN BY	D Tybor								Copy to		
DATE	9-4-85								Copy to		
									Copy to		
									Post		
									Leak Test Records		
SURVEY INSTRUMENT USED						COUNTED BY	ODT	DATE 9-4	COUNTS PER MINUTE (Above background)		
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT x or $\beta\gamma$	a	REMARKS	
E140D NP240T	1377 81	8	8	1	Stainless Steel	*	*	*	*	3-pie sheet - Direct Proje	
E520 NP220	3832481	.02		2	" "	*	*	*	*		
464415 43-35	302222	D		3	" "	*	*	*	*		
				4	Partial steel sheet	*	*	*	*		
				5	" "	*	*	*	*		
				6	" "	*	*	*	*		
				7	" "	*	*	*	*		
				8	" "	*	*	*	*		
				9	" "	*	*	*	*		
				10	" "	*	*	*	*		
				11	" "	*	*	*	*		
				12	Small pieces & strips	*	*	*	*		
SHARPNESS	CONTACT THIN BED	READING									
STICK	NO HIGHER										
SMALL PIECES	" "										
* STRIPS											
				13	" "	*	*	*	*		
				14	" "	*	*	*	*		
				15	" "	*	*	*	*		
				16	" "	*	*	*	*		
				17	" "	*	*	*	*		
				18	" "	*	*	*	*		
				19	" "	*	*	*	*		
				20	" "	*	*	*	*		
				21	" "	*	*	*	*		
				22	" "	*	*	*	*		
				23	" "	*	*	*	*		
				24	" "	*	*	*	*		
				25	" "	*	*	*	*		
				26	" "	*	*	*	*		
				27	" "	*	*	*	*		
				28	" "	*	*	*	*		

3-pie sheet - Direct Proje

Small pieces & strips



*Indicates that the sample count is not statistically different from background
and therefore not definitive

8-24-85

F1

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.	ROOF							Notice of Results			
TAKEN BY	OH/PFT							Copy to	R Davis 6073		
DATE	7-19-85							Copy to			
								Copy to			
								Post	Leak Test Records		
SURVEY INSTRUMENT USED	COUNTED BY OH	DATE 7/19	COUNTS PER MINUTE (Above background)								
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT x or $\beta\gamma$		REMARKS	
EL400	1296	BY	40	1	INSIDE FILTER/HORN) HATCH 610	*	*	*		DIRECT PROBE	
	1297	BY	40	2	INSIDE PREFILTER "	*	*	*		DIRECT PROBE	
				3	PRE-FILTER HOODERS "	*	*	*		SWIPE	
ES20	3832	BY	0.02	4	" "	40	*	*		DIRECT PROBE	
LIAISON	30723	OR	0	5	SIDE OF HORN FILTER (HEPA)	*	*	*		DIRECT PROBE	
MOUL	18	30723	OR	6	BEHAC FILTER (HEPA)	*	*	*		DIRECT PROBE	
				7	ROOF SURFACE/FLOOR OF LATRINE	*	*	*		DIRECT PROBE	
DOSE RATE MEASUREMENTS (mR/hr)	POINT MEASURED	DIST	READING	9							
1.0m. PIPE	11										
From Farm Contact	12										
OFF-PIST	13										
Pipe Contact	14										
Above Contact	15										
Ground Contact	16										
	17										
	18										
	19										
	20										
	21										
	22										
	23										
	24									*Indicates that the sample count is not statistically different from background	
	25									# (A1, B1) = 528.55	
	26										
	27										
	28										

F1A



BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.	Cells 1 + 2								R. DAUDE 6072		
TAKEN BY	DSSU										
DATE	10-9-85										
SURVEY INSTRUMENT USED		COUNTED BY		DATE		COUNTS PER MINUTE (Above background)					
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x or $\beta\gamma$	alpha	REMARKS
E-140-N	1398	$\beta\gamma$	60	1	Cell #1 Ventilation Duct		*	*	*	*	Swipe
E-520	3832	$\beta\gamma$.02	2	(Remaining in Floor)						Swipe
E-600LN	39898	α	.0	3	Cell #2 Ventilation Duct						
				4							
				5							
				6							
				7							
DOSE RATE MEASUREMENTS (mR/hr)											
POINT MEASURED	DIST	READING									
Cell #1 Dust Contact	.08	10									
Cell #2 Dust Contact	.04	11									
		12									
		13									
		14									
		15									
		16									
		17									
		18									
		19									
		20									
		21									
		22									
		23									
		24									
		25									
		26									
		27									
		28									

*Indicates that the sample count is not statistically different from background

1. $8-24-86$

2. $5-23-85$

3. $9-9-85$

HEALTH PHYSICS MONITORING REPORT
NDW-NRL-5101/6004 (Rev. 9-80)

BUILDING		SURVEY INSTRUMENT USED			LABORATORY COUNTING INSTRUMENT			ACTION INDICATED		RECIPIENT (NAME & CODE)		ACTION COMPLETE
ROOM NO.	<i>radiation system</i>	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notice of Results				
TAKEN BY	DH/PFT							Copy to				
DATE	8-20-85							Copy to				
								Copy to				
								Post				
								COUNTS PER MINUTE (Above background)				
POINT MEASURED		COUNTED BY		DATE		DESCRIPTION OF SAMPLE		β	γ	SOFT α or $\beta\gamma$	a	REMARKS
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK- GROUND	SAMPLE NO.								
E140 N 1297	1297	A	40	1	<i>bungee antenna direct</i>		<i>x</i>	<i>x</i>	<i>x</i>	<i>x</i>	<i>ventilation filter housing</i>	
L-18	30722	A	5	2	<i>bungee antenna direct</i>		<i>x</i>	<i>x</i>	<i>x</i>	<i>x</i>	<i>bungee antenna</i>	
				3	<i>bungee antenna</i>		<i>x</i>	<i>x</i>	<i>x</i>	<i>x</i>		
				4			<i>x</i>	<i>x</i>	<i>x</i>	<i>x</i>		
				5			<i>x</i>	<i>x</i>	<i>x</i>	<i>x</i>		
				6			<i>x</i>	<i>x</i>	<i>x</i>	<i>x</i>		
				7			<i>x</i>	<i>x</i>	<i>x</i>	<i>x</i>		
				8			<i>x</i>	<i>x</i>	<i>x</i>	<i>x</i>		
POINT MEASURED	DIST	READING	9									
			10									
			11									
			12									
			13									
			14									
			15									
			16									
			17									
			18									
			19									
			20									
			21									
			22									
			23									
			24									
			25									
			26									
			27									
			28									

* Indicates that the sample count is not statistically different from background

BUILDING	OutSide Building	LABORATORY COUNTING INSTRUMENT					ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level			
ROOM NO.	0015105						Notice of Results		
TAKEN BY	D. Tabor						Copy to R. Davis 6023		
DATE	8-27-60						Copy to		
							Copy to		
							Post		
							Leak Test Records		
SURVEY INSTRUMENT USED		COUNTED BY		DATE		COUNTS PER MINUTE (Above background)			REMARKS
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT \times or $\beta\gamma$	
C100	1296 07	B Y	100	1	Tank	240	240	240	See G 2
E520	3832 07	B Y	.02	2	Tank	240	240	240	See G 2
140270				3	Tank	240	240	240	See G 2
				4	Pipe	240	240	240	
				5	Pipe	240	240	240	
				6	Pipe	240	240	240	
				7	Airt. Plastic	240	240	240	
				8	Yellow Plastic	240	240	240	
				9	Pipe above ground	240	240	240	
				10		240	240	240	
DOSE RATE MEASUREMENTS (mR/hr)									
POINT MEASURED	DIST	READING							
Tank 1	Content	0.12							
Tank 2	"	0.12							
μ pipe 1	"	0.02							
μ pipe 2	"	0.09							
μ pipe 3	"	0.03							
Apt. above 1	"	0.03							
Pipe Above 2	"	0.01							
Tank 3	"	0.12							
Pipe 4	"	0.03							

REMARKS:
Samples above are the types used for the tank. The types of the tank could be seen above ground.

* Indicates that the sample count is not statistically different from background

All instruments calibrated

8-24-65




G2

BUILDING		89		LABORATORY COUNTING INSTRUMENT				ACTION INDICATED		RECIPIENT (NAME & CODE)		ACTION COMPLETE	
ROOM NO.	OUTSIDE	Type of Counter		Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff	Notice of Results				
TAKEN BY	CLL								Copy to	R PAUL GOTO			
DATE	9/20/85								Copy to				
									Copy to				
									Post				
SURVEY INSTRUMENT USED				COUNTED BY CL		DATE 1/20		COUNTS PER MINUTE (Above background)					
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT α or $\beta\gamma$	a	REMARKS		
E1401 *	1398	$\beta\gamma$	40	1	TOP OF TANK NO 2		*	*	*	*	DIRECT EXPOSE SURVEY		
E500	2812	$\beta\gamma$	0.02	2	SIDE OF TANK NO 2		1040				DISPOSED AS RAO WASTE		
bottom	Model #3	39898	0	3	BOTTOM OF TANK NO 2		800				"		
				4	SMALL UPPER PART (TANK 1)		600				"		
				5	SMALL LOWER PART (TANK 1)		600				"		
				6	TOP OF TANK NO 2		*	*	*	*	DIRECT PAPER SURVEY		
				7	2.0E OF TANK NO 2		400				"		
				8	BOTTOM OF TANK NO 2		600				DIRECT PAPER SURVEY		
				9	SMALL UPPER PART TANK NO 2		*	*	*	*	DIRECT PAPER SURVEY		
				10	SMALL LOWER PART TANK NO 2		300				DIRECT PAPER SURVEY		
DOSE RATE MEASUREMENTS (mR/hr)													
POINT MEASURED	DIST	READING											
Tank No. 1 CONTACT	0.09	12					*	*	*	*			
Tank No. 2 CONTACT	0.06	13					*	*	*	*			
Tank No. 2	0.02	14					*	*	*	*			
Tank No. 2	0.02	15					*	*	*	*			
		16					*	*	*	*			
		17											
		18											
		19											
		20											
		21											
		22											
		23											
		24											
		25											
		26											
		27											
		28											

*Indicates that the sample count is not statistically different from background
CALIBRATION 8-24-85

C 2 A
BLOCK 82

TANKS



G 3

BUILDING	ROOM NO.	LABORATORY COUNTING INSTRUMENT					ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level				% Eff
TAKEN BY	DH									
DATE	10-10-85	*								
					COUNTS PER MINUTE (Above background)					
SURVEY INSTRUMENT USED			COUNTED BY		DATE					
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x or β γ	REMARKS
E140 N	1398 5J	60	1	large shielded	large shielded		x	x	x	large shielding case (direct)
L-18	30722 J	0	2	middle case shell	middle case shell		x	x	x	middle case shell (direct)
			3	am. case mid point	am. case mid point		x	x	x	small shielding case (direct)
			4	surface by case	surface by case		x	x	x	large case (unshielded)
			5							
			6							
			7							
DOSE RATE MEASUREMENTS (mR/hr)										
POINT MEASURED	DIST	READING	9							
		10								
		11								
		12								
		13								
		14								
		15								
		16								
		17								
		18								
		19								
		20								
		21								
		22								
		23								
		24								
		25								
		26								
		27								
		28								

*Indicates that the sample count is not statistically different from background

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bld. C/M	Critical Level	% Eff				
ROOM NO.											
TAKEN BY	CLR										
DATE	8-8-85										
SURVEY INSTRUMENT USED						COUNTED BY	CLR	DATE 8/8	COUNTS PER MINUTE (Above background)		
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE			β	γ	SOFT α or β γ	REMARKS
E140 N	1296	$\beta\gamma$	60	1	RELEASE SURVEYS OF THE FOLLOWING ITEMS						
E520	3832	$\beta\gamma$	0.03	2							
LUDLUM	18	α	0	3							
PROFL #18	30722	α	0	4	PENISCOPE INTO CELL #1						
DOSE RATE MEASUREMENTS (mR/hr)						5	OPERATING ROOM SIDE	*	*	*	
POINT MEASURED	DIST	READING		6	LEAD PLUG FOR ACCESS			*	*		
				7	LEAD PLUG FOR ACCESS			*	*		
				8	TUBE INTO CELL #2			*	*		
				9							
				10	1 1/2 INCH ELECTRICAL						
				11	CABLE TO CUE TROLEY			*	*		
				12	w/ RUBBER CASING						
				13							
				14							
				15							
				16							
				17							
				18	LIGHT SOCKETS *						
				19	ELECTRICAL BOXES IN						
				20	CELLS NO 1 + 2			*	*		
				21							
				22							
				23	FORWARD FILTERS (BARRIER)			*	*		
				24							
				25							
				26							
				27							
				28							

*Indicates that the sample count is not statistically different from background

H2

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.											
TAKEN BY	CLR										
DATE	8-8-85										
						COUNTS PER MINUTE (Above background)					
SURVEY INSTRUMENT USED				COUNTED BY CLR	DATE 8/8		REMARKS				
TYPE MODEL NO.	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x or $\beta\gamma$	a	
EHTON E520	1296	$\beta\gamma$	60	1	RELEASE SURVEYS OF THE FOLLOWING ITEMS						
Model #16	1297	$\beta\gamma$	0.03	2							
Column	3832	$\beta\gamma$	0.03	3							
Model #15	38722	α	0	4	GENERAL MILL MANIPULATOR		*				
				5	IN CELL #2		*				
				6							
				7							
DOSE RATE MEASUREMENTS (mR/hr)											
POINT MEASURED	DIST	READING									
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											

DECONTAMINATED ALL PARTS SUCCESSFULLY EXCEPT FOR WOMAN GEAR WHICH WAS DISPOSED OF AS RADIOPACTIVE WASTE.

*Indicates that the sample count is not statistically different from background

H3

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.								Notice of Results			
TAKEN BY	CLR							Copy to R. Davis G073			
DATE	8-8-85							Copy to			
								Copy to			
								Post			
								Leak Test Records			
SURVEY INSTRUMENT USED						COUNTED BY CLR		DATE 8/8		COUNTS PER MINUTE (Above background)	
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT α or $\beta\gamma$	REMARKS	
E140N	1296	$\beta\gamma$	60	1	RELEASE SURVEYS OF THE FOLLOWING ITEMS						
E520	3832	$\beta\gamma$	0.03	2	TABLES FROM CELL #2		X			DECONTAMINATED LEG ON 1 TABLE OF 180 cpm FIXED.	
LUDLUM MODEL M/8	3072A	α	0	3	METAL TABLE TOP FROM CELL #2		X				
				4	METAL TABLE TOP FROM CELL #2		X				
				5							
				6							
				7							
DOSE RATE MEASUREMENTS (mR/hr)						POINT MEASURED		DIST	READING		
All Objects	On List	compact	<0.1	10	INSIDE METAL CYLINDERS						
				11	INSIDE BLOCK, BACK ROOM		X				
				12							
				13	MOTOR #1 USED TO OPERATE METAL BELT		X				
				14							
				15							
				16							
				17	MOTOR #2 USED TO OPERATE CELL TRAY		X				
				18							
				19							
				20	ASSORTED LEAD BRICKS		X				
				21	FROM CELLS #1 + #2		X				
				22							
				23							
				24							
				25							
				26							
				27							
				28							

*Indicates that the sample count is not statistically different from background

BUILDING	89	LABORATORY COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.											
TAKEN BY	CLR										
DATE	9/27/85										
SURVEY INSTRUMENT USED			COUNTED BY	CLR	DATE 9/27	COUNTS PER MINUTE (Above background)					
TYPE MODEL NO.	SERIAL NO.	RADN TYPE	BACK- GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT α or β γ	REMARKS		
E140N	1398	$\beta\gamma$	40	1	RELEASE SURVEYS OF THE FOLLOWING ITEMS						
E520	3532	$\beta\gamma$	0.03	2							
COLUM MODEL #3	39898	α	0	3							
				4	STAINLESS STEEL FROM CELL #2 DOOR	*	*	*	DIRECT PROBE + SOURCE		
				5							
				6							
				7	TOP HALF OF ALL DIVISION STORAGE TUBES	*	*	*			
				8							
				9	(BAGS WERE CUT INTO HALFS)						
DOSE RATE MEASUREMENTS (mR/hr)											
POINT MEASURED	DIST	READING									
10											
11		LEAD STORAGE Pk #1	*								
12											
13											
14		LEAD STORAGE Pk #2	*								
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											

*Indicates that the sample count is not statistically different from background

BUILDING	LABORATORY COUNTING INSTRUMENT					ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE
	Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level			
ROOM NO.								
TAKEN BY	CLR							
DATE	8/01 - 10/01							
					COUNTS PER MINUTE (Above background)			
SURVEY INSTRUMENT USED			COUNTED BY CLR	DATE				
TYPE MODEL NO.	SERIAL NO.	RADN' TYPE	SAMPLE NO.	DESCRIPTION OF SAMPLE	β	γ	SOFT α or $\beta\gamma$	REMARKS
			PAC					
			1	A1 - DOOR THRESHOLD	*			DECONTAMINATED 9/21/85
			2	B5 - MOPP OF FLOOR	*			CONTAMINATED TILE DISPOSED AS RAM 9/20/85
			3	C1 - NORTH WALL - BACK REIN	*			DECONTAMINATED 9/27/85
			4	C4 - DOOR THRESHOLD	*			"
			5	C5 - CEILING TILE	*			CEILING TILE DISPOSED AS RAM 9/4/85
			6	C6 - LIGHT FIXTURES	*			SEE EXPLANATION - PAGE C6
			7	C7 - CONCRETE BEAM TO TUBE	*			DECONTAMINATED 8/10/85
			8	C8 - STORAGE TUBES	*			RAM INSIDE TUBES DISPOSED OF 8/21/85
			9	D1 - SPOTS ON NORTH WALL	*			
			10	D1 - SOUTH WALL J-BEAM	*			DECONTAMINATED 10/02/85
			11	D1 - COMPLETE L-EAVE	*			"
			12	E1 - ENTRANCE FLOOR	*			DECONTAMINATED 9/27/85
			13	E1 - NORTH WALL	*			"
			14	E1 - ABOVE LEDGE ROOF	*			DISPOSED OF AS RAM 10/01/85
			15	E1 - SOUTH WALL	*			DECONTAMINATED 9/27/85
			16	E1A - LEDGE	*			"
			17	E2 - C2 - TANKS	*			DISPOSED OF AS RAM 9/27/85
			18	O3 - OVEN TOP	*			DISPOSED OF AS RAM 9/25/85
			19	O3 - CEMENT BLOCKS	*			DECONTAMINATED 9/27/85
			20	O3 - FLOOR UNDER BEAMS	*			"
			21					
			22					
			23					
			24					
			25					
			26					
			27					
			28					

*Indicates that the sample count is not statistically different from background

72

BUILDING	89	LABORATORY COUNTING INSTRUMENT							ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE											
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Ef/	Notice of Results														
ROOM NO.									R. DAVIS 6073													
TAKEN BY	DSV																					
DATE	10-8-85								Leak Test Records													
							COUNTS PER MINUTE (Above background)															
SURVEY INSTRUMENT USED				COUNTED BY DSV		DATE 10-5																
TYPE MODEL NO.	SERIAL NO.	RADIN TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	SOFT x or $\beta\gamma$	a	REMARKS											
E140 N	1398	61	60	1	Concrete Block Radon		x	x	x	x	Swings											
E520	3932	91	0.02	2	acrylic 1/4"		x	x	x	x												
4060	3989	2	0	3			x	x	x	x												
				4			x	x	x	x												
				5			x	x	x	x												
				6			x	x	x	x												
				7			x	x	x	x												
DOSE RATE MEASUREMENTS (mR/hr)																						
POINT MEASURED	DIST	READING	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28

*Indicates that the sample count is not statistically different from background

8-24-85 CALIBRATION

2 5-2-85

5.9.2.85

BUILDING	89	LABORATORY: COUNTING INSTRUMENT						ACTION INDICATED	RECIPIENT (NAME & CODE)	ACTION COMPLETE	
		Type of Counter	Serial No.	Type of Activity	Bkd. C/M	Critical Level	% Eff				
ROOM NO.	Net Cells							Notice of Results			
TAKEN BY	DH /DSU							Copy to			
DATE	10-9-85							Copy to			
								Copy to			
								Post			
								Leak Test Records			
SURVEY INSTRUMENT USED			COUNTED BY		DATE		COUNTS PER MINUTE (above background)			REMARKS	
TYPE	SERIAL NO.	RAD'N TYPE	BACK-GROUND	SAMPLE NO.	DESCRIPTION OF SAMPLE		β	γ	α		
E140N	139865	65	60	1	Cell floor backplane small area		#	#	#	high fast reading	
E520	383261	61	6.03	2			#	#	#	high fast reading	
L-18	388982	0	0	3						high fast reading	
				4							
				5							
				6							
				7							
DOSE RATE MEASUREMENTS (mR/hr)											
POINT MEASURED	DIST	READING	9								
backplane contact	0.03	0.03	10								
			11								
			12								
			13								
			14								
			15								
			16								
			17								
			18								
			19								
			20								
			21								
			22								
			23								
			24								
			25								
			26								
			27								
			28								

*Indicates that the sample count is not statistically different from background

SECTION IV

Calibration of Instruments

A. During the course of work under this contract, the following field instruments were used.

Instrument	Serial #	Use
Eberline E-140N/HP-210T	1296	Beta-Gamma Contamination Survey
Eberline E-140N/HP-210T	1297	Beta-Gamma Contamination Survey
Eberline E-140N/HP-210T	1377	Beta-Gamma Contamination Survey
Eberline E-140N/HP-210T	1398	Beta-Gamma Contamination Survey
Ludlum 18/43-5	30722	Alpha Contamination Survey
44-9		Beta-Gamma Contamination Survey
44-9		Beta-Gamma Radiation Survey
Eberline E520	3832	Beta-Gamma Radiation Survey
Ludlum 3/43-5	39873	Alpha Contamination Survey

B. All instruments listed above were calibrated within 3 months of use. Calibration procedures for these instruments met all standards as set forth in ANSI N.323 (1978), Radiation Protection Instrumentation Test and Calibration. * In addition to routine calibration, all instruments were source checked regularly by Radiological Control Personnel when in use by comparing their response to known quantity source.

* Calibration certificates for the instruments listed above are attached to this section. It should be noted that not all instruments were used throughout the entire work.

Attachment III

Instrument Calibration Certificates



CALIBRATION CERTIFICATE

"This Certificate will be accompanied by Calibration Charts or Readings where applicable"

CUSTOMER INFORMATION		INSTRUMENT INFORMATION	
Customer Name:	Afftrex LTD.	Instrument Manufacturer	Eberline
Customer Address:	Aber Road RD #4 Finleyville, PA 15332	Model	E-140N
Customer P.O.#	85-142K	External Probe(s)	HP-210
Service W.O.#	I-85-06-235	Serial Number	1296
		Serial #	1296
		Calibration Method	MP-1 s/n 301
			137Cs s/n 107

INSTRUMENT CALIBRATION INFORMATION

Instrument Range	Calibration Standard Value	Instrument Response		Comment
		Before Calib.	After Calib.	
1 X1	100 CPM		100 CPM	A11 Calibrations Btn. + & - 10%
2	200		210	
3	400		420	Reads 3700 CPM in 1 mR/hr field 137Cs
4 X10	TK		TK	
5	2K		2.1K	
6	4K		4.2K	
7				
8 X100	10K		10K	
9	20K		21K	
10	40K		42K	
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				

STATEMENT OF CERTIFICATION

We Certify that the instrument listed above was calibrated and inspected prior to shipment and that it met all of the Manufacturers published operating specifications. We further certify that our Calibration Measurements are traceable to the National Bureau of Standards (We are not responsible for damage incurred during shipment or use of this instrument).

Instrument Calibrated by: Martin A. Lavelle
(Signed)
Calibration Date: 05-28-85
Next Calibration Due: 11-28-85

I certify that the above information is correct:
Authorized Agent Theresa M. Spina
Title Admin. Coordinator Date 05-28-85



CALIBRATION CERTIFICATE

"This Certificate will be accompanied by Calibration Charts or Readings where applicable"

CUSTOMER INFORMATION		INSTRUMENT INFORMATION	
Customer Name:	Afftrex LTD.	Instrument Manufacturer	Eberline
Customer Address:	Aber Road RD #4 Finleyville, PA 15332	Model	E-140N
Customer P.O.#	85-142K	Serial Number	1297
Service W.O.#	I-85-06-235	External Probe(s)	HP-210
		Serial #	1297
		Calibration Method	MP-1 s/n 301 Cs s/n 107

INSTRUMENT CALIBRATION INFORMATION

Instrument Range	Calibration Standard Value	Instrument Response		Comment
		Before Calib.	After Calib.	
1 X1	100 CPM		105 CPM	All Calibrations Btn. + & - 1
2	200		210	
3	400		420	Reads 3700 CPM in 1 mR/hr field T37Cs
4 X10	1K		1.05K	
5	2K		2.1K	
6	4K		4.2K	
8 X100	10K		10.5K	
9	20K		21K	
10	40K		42K	
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				

STATEMENT OF CERTIFICATION

We Certify that the instrument listed above was calibrated and inspected prior to shipment and that it met all of the Manufacturers published operating specifications. We further certify that our Calibration Measurements are traceable to the National Bureau of Standards (We are not responsible for damage incurred during shipment or use of this instrument).

Instrument Calibrated by:

Marilyn L. Lawler
(Signed)

Calibration Date: 05-28-85

Next Calibration Due: 11-28-85

I certify that the above information is correct:

Authorized Agent

Title Admin. Coordinator Date 05-28-85

Theresa M. Sandoval

Eberline

A DIVISION OF
Thermo Electron
CORPORATION

CERTIFICATION OF CALIBRATION

Instrument E-140N / Hp-210T

Serial No. 1377

Type of Source Eberline MP-1 S/N 378
CS-157, ET-120

Range	Calibration Point	Reading
X100 @ 40K cpm	40K cpm	40K cpm
X10 @ 4K cpm	4K cpm	4K cpm
X1 @ 400 cpm	400 cpm	400 cpm
X100 @ 10K cpm	10K cpm ± 10%	10K cpm
X10 @ 1K cpm	1K cpm ± 10%	1K cpm
X1 @ 100 cpm	100 cpm ± 10%	100 cpm
Hp-210T @ X10 @ 1MR/h	3,600 ± 1,000 cpm	4,000 cpm

Calibration sources used have calibration traceable to the National Bureau of Standards.

Date 11/24 Signature S. O. LIE

P.O. Number E5-165K2

Eberline

A DIVISION OF
Thermo
Electron
CORPORATION

CERTIFICATION OF CALIBRATION

Instrument E-140N / Hf-210T

Serial No. 1377

Type of Source Eberline MP-1 S/N 378
CS-157, ET-120

Range	Calibration Point	Reading
X100 @ 40K cpm	40K cpm	40K cpm
X10 @ 4K cpm	4K cpm	4K cpm
X1 @ 400 cpm	400 cpm	400 cpm
X100 @ 10K cpm	10K cpm ± 10%	10K cpm
X10 @ 1K cpm	1K cpm ± 10%	1K cpm
X1 @ 100 cpm	100 cpm ± 10%	100 cpm
Hf-210T @ X10 @ 1mR/h	3,600 ± 1,000 cpm	4,600 cpm

Calibration sources used have calibration traceable to the National Bureau of Standards.

Date 1/24

Signature John E. Miller

P.O. Number

E5-165K2



CALIBRATION CERTIFICATE

"This Certificate will be accompanied by Calibration Charts or Readings where applicable"

CUSTOMER INFORMATION		INSTRUMENT INFORMATION	
Customer Name:	Afftrex LTD.	Instrument Manufacturer	Ludlum
Customer Address:	Aber Road RD #4 Finleyville, PA 15332	Model	18
Customer P.O.#	85-142K	External Probe(s)	43-5
Service W.O.#	I-85-06-235	44-9 PR-015533	44-6
		Calibration Method	MP-1 s/n 301
		137 Cs s/n 107	99 Tc s/n 1256
			230 Th s/n 11623

INSTRUMENT CALIBRATION INFORMATION

Instrument Range	Calibration Standard Value	Instrument Response		Comment
		Before Calib.	After Calib.	
1 X1	100 CPM		100 CPM	All Calibrations Btn. + & - 10%
2	200		200	
3	400		390	
4 X10	1K		1K	
5	2K		2K	
6	4K		4K	
7				
8 X100	10K		10K	
9	20K		21K	
10	40K		42K	
11				
12 X1K	100K		100K	
13	200K		200K	
14	400K		400K	
15				
16				
17				
18				
19				
20				
21				
22				
23				

STATEMENT OF CERTIFICATION

We Certify that the instrument listed above was calibrated and inspected prior to shipment and that it met all of the Manufacturers published operating specifications. We further certify that our Calibration Measurements are traceable to the National Bureau of Standards (We are not responsible for damage incurred during shipment or use of this instrument).

Instrument Calibrated by:

Marilyn A. Luecke
(Signed)

Calibration Date: 05-28-85

Next Calibration Due: 11-28-85

I certify that the above information is correct:

Teresa M. Sando
Authorized Agent
Title Admin., Coordinator Date 05-28-85



CALIBRATION CERTIFICATE

"This Certificate will be accompanied by Calibration Charts or Readings where applicable"

CUSTOMER INFORMATION		INSTRUMENT INFORMATION	
Customer Name:	Afftrex LTD.	Instrument Manufacturer:	Eberline
Customer Address:	Aber Road RD #4 Finleyville, PA 15332	Model:	E-520 Serial Number 3832
Customer P.O.#	85-142K	External Probe(s)	Serial #
Service W.O.#	I-85-06-235	Calibration Method	MP-1 s/n 301 137 Cs s/n 107

INSTRUMENT CALIBRATION INFORMATION

Instrument Range	Calibration Standard Value	Instrument Response		Comment
		Before Calib.	After Calib.	
X0.01	40 CPM		40 CPM	All Calibrations Btn. + & - 10%
1	80		80	
2	160		160	
3				
4	X0.1	0.5 mR/hr	0.5 mR/hr	
5				
6				
7				
8	X1	5	5	
9				
10	10		10	
11	15		15	
12	X10	50	55	
13				
14	100		100	
15	150		138	
16	X100	500	525	
17				
18	1,000		1,050	
19	1,500		1,500	
20				
21				
22				
23				

STATEMENT OF CERTIFICATION

We Certify that the instrument listed above was calibrated and inspected prior to shipment and that it met all of the Manufacturers published operating specifications. We further certify that our Calibration Measurements are traceable to the National Bureau of Standards (We are not responsible for damage incurred during shipment or use of this instrument).

Instrument Calibrated by:

Ernest G. Lavelle
(Signed)

Calibration Date: 05-28-85

Next Calibration Due: 11-28-85

I certify that the above information is correct:

Authorized Agent

Title Admin. Coordinator Date 05-28-85

Teresa M. Spina