

**From:** Frank Ashe  
**To:** OWFN\_DO.owf4\_po.SXD  
**Date:** Wed, Jan 27, 1999 4:28 PM  
**Subject:** Millstone Unit 2 Electrical Modifications TAC No. MA4361

To: S. Dembek

Regarding the Millstone Unit 2 plant electrical modifications (additions), please arrange for a conference call with the licensee to discuss the following items.

1. Flowpaths for the primary and backup methods for simultaneous hot and cold leg injection ( Refer to Figures 1 and 2 provided in the submittal. ).
2. Calculations performed that demonstrate increased loading of alternate power sources has no impact on the ability of these sources to supply the required loads.
3. Design criteria used for the electrical modifications and verification that the design criteria used is consistent with and conforms to that provided in the UFSAR.

Please arrange the conference call as soon as you can. Thanks !

F. Ashe 1/27/99

**CC:** ASG,OPC

9902030027 990128  
PDR ADDOCK 05000336  
P PDR