



**Duquesne Light**

Nuclear Group  
P.O. Box 4  
Shippingport, PA 15077-0004

Telephone (412) 393-6000

July 11, 1986

Director of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Attn: Mr. Peter S. Tam, Project Manager  
Project Directorate No. 2  
Division of PWR Licensing - A  
Washington, DC 20555  
- Mail Stop 340 -

Reference: Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Proposed Operating License Change Request No. 128

Gentlemen:

Enclosed are:

1. Three (3) originals and thirty-seven (37) copies of an Application for Amendment to our operating license to revise Design Feature Section 5.3.1 by removing the fuel rod weight limitation, the statement following which limits the maximum enrichment for the initial core loading and a statement has been incorporated to allow the insertion of reconstituted fuel assemblies into the core.
2. Forty (40) copies of documents designated Attachments A and B which set forth the change in technical specifications and its no significant hazards determination.

A check in the amount of \$150.00 will be forwarded under separate cover as payment of the license amendment application fee in accordance with 10 CFR 170.

Very truly yours,

*J. J. Carey* / JDS  
J. J. Carey  
Vice President, Nuclear

8607160139 860711  
PDR ADOCK 05000334  
P PDR

Acc'd  
1/1