

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Clay C. Warren
Vice President & Chief Operating Officer

FEB 1 1999

WO 99-0010

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555


Subject: Docket No. 50-482: Licensee Event Report 1998-009-00

Gentlemen:

The enclosed Licensee Event Report (LER) 1998-009-00 is being submitted, pursuant to 10 CFR 50.73(a)(2)(ii)(b), 10 CFR 50.73(a)(2)(v) and License Condition 2.F., regarding the inability to locally control an Atmospheric Relief Valve following a safe shutdown fire scenario, due to an error made during a maintenance activity. The attachment to this letter identifies actions committed to by Wolf Creek Nuclear Operating Corporation in the enclosed LER.

If you should have any questions regarding this submittal, please contact me at (316) 364-4048, or Mr. Michael J. Angus at (316) 364-4077.

Very truly yours,


Clay C. Warren

CCW/rlr

Enclosure

Attachment

cc: W. D. Johnson (NRC), w/e, w/a
E. W. Merschoff (NRC), w/e, w/a
K. M. Thomas (NRC), w/e, w/a
Senior Resident Inspector (NRC), w/e, w/a

9902050324 990201
PDR ADDCK 05000482
S PDR

0035

IE22 1/1