

EVALUATION RESEARCH CORPORATION

CONTROLLED COPY  
CONTROL NO. DF-061

COMANCHE PEAK RESPONSE TEAM

QUALITY INSTRUCTION FOR ISSUE-SPECIFIC ACTION PLAN VII.c

INSTRUCTION NO.: QI-032

REVISION: 2

ISSUE DATE: 06/27/86

DOCUMENTATION REVIEW OF CONTAINMENT LINER

AND TANK STAINLESS STEEL LINERS

Prepared by: Neil Banerjee Date: 6/25/86

Approved by: Albert A. Patten Date: 6/26/86  
Issue Coordinator

Approved by: R. D. Zell Date: 6/26/86  
On-Site QA Representative

Approved by: J. L. Hause Date: 6/26/86  
QA/QC Review Team Leader

## 1.0 PURPOSE

This instruction provides the methods and accept/reject criteria for the performance of a documentation review for the Containment Liner and Tank Stainless Steel Liners.

## 2.0 APPLICABILITY

This Quality Instruction applies to the performance of an independent review of the documentation for the containment liner and tank stainless steel liners. It applies to the sample selected from the Category I liner population as required per Action Plan VII.c.

## 3.0 REFERENCES

- 3.1 Memorandum (QA/QC-RT-291) to A. A. Patterson, providing basis for document review requirements including specific sources for attributes and exclusions.
- 3.2 CPP-009, "Performance of Reinspection and Documentation Reviews."

## 4.0 GENERAL

Document reviews are performed and documented in accordance with established CPRT procedures and instructions. This procedure establishes the attributes and accept/reject criteria for the documentation review of liners. Reference 3.2 addresses the method to perform and document the documentation reviews.

### 4.1 Responsibilities

#### 4.1.1 QA/QC Discipline Engineers

The QA/QC Discipline Engineers prepare the Quality Instruction delineating reinspection requirements and attributes.

#### 4.1.2 QA/QC Inspectors

QA/QC Inspectors perform documentation review/verificaiton in accordance with this procedure and record results and deviation.

#### 4.0 GENERAL (Cont'd)

##### 4.2 Policy

Activities performed under this procedure shall conform to the policies contained in the latest Comanche Peak Response Team Action Plan VII.c.

#### 5.0 INSTRUCTION

Using the information below, perform the documentation reviews on the items in this population and document the results on the checklist (Attachment 6.1).

NOTE: All CB&I documentation mentioned hereafter are maintained in the Permanent Plant Records Vault (PPRV). These documentations are to be reviewed in PPRV.

##### 5.1 Record Drawings

The record drawing (Section 8.5 of CB&I documentation List of Records, see attachments 6.2.a, b for examples) shall be verified to have (a) joint identification numbers for the sample weld seam. The record drawing shall also be verified to list (b) welder identifications for the weld joint identifications listed for the weld seam.

If the joint and welder identification is contained on the record drawing, the checklist shall be marked accept. If joint or welder identification information is missing, the checklist shall be marked reject and the missing information identified by a deviation report.

##### 5.2 Material Traceability

The record drawing (Section 8.5 of CB&I documentation List of Records, See Attachment 6.2a & b for sample) and Material Verification Summary Sheet and Material Records (Section 5.1 and 5.2 of CB&I documentation List of Records, See Attachment 6.2c, & d for sample) shall be reviewed to verify that:

- a. The material is certified as SA-537 Cl. 2 for containment liner, ASTM-A240 Cl. 304L for stainless steel tank liner, and ASTM-A312 Materials for penetration pipe.

NOTE: Polar crane & inspection platform support brackets are supplied by Bostrom-Bergen. Some piece marks, which cannot be found in Sections 5.1 and 5.2 could be part of an assembly. The verification of these piece marks will require tracing them in CB&I Final Certified Drawings (Section 4.1.5) and shop release checklists (Section 8.16.1), and then verifying them in Sections 5.1 and 5.2 above.

5.0 INSTRUCTION (Cont'd)

5.2 Material Traceability (Cont'd)

Information relating to the material traceability are to be found in PPRV.

- b. The Material Identification Verification was made during the installation inspection and shown by a check mark under "Material I.D", in record drawings.

If the material traceability is checked and found complete, the checklist shall be marked accept. If the material traceability cannot be verified then the checklist shall be marked reject and lack of material traceability shall be identified by a deviation report.

5.3 Welding

The record drawing (Section 8.5 of CB&I documentation List of Records, see attachments 6.2a,b,c & d for examples) shall be reviewed to verify that:

- a. The weld procedure is identified for each weld joint.
- b. The weld fit-up, welding and finish joint column are initialed and dated.
- c. The weld procedures applicable to SA-537 class 2 are listed on the weld procedure list, Attachment 6.7.
- d. The weld procedure is approved by Engineers-Gibbs & Hill/TUSI. (See attachment 6.7 for example).
- e. The "Complete" column of the record drawing (Attachment 6.2a, b, is initialed and dated.

NOTE: If this column is initialed and dated, it will indicate that proper weld filler material was utilized.

If the weld joint sign offs are complete for the items "a" thru "e" above, the checklist shall be marked accept. If the weld joints are not initialed and dated, or the procedure was not previously approved, the checklist shall be marked reject and the lack of signoff, or lack of approval, shall be identified by a deviation report.

5.4 Welder/Welding Operator Qualification

Qualification records of the welders/welding operators for the weld joints identified for the sample weld shall be reviewed to verify that:

5.0 INSTRUCTION (Cont'd)

5.4 Welder/Welding Operator Qualification (Cont'd)

a. The welder/welding operators qualifications (Section 8.10 of CB & I documentation list of records, see attachment 6.4 a, b for examples) are valid for the period the weld was performed.

b. The welder/welding operators qualification are valid for the weld procedure listed.

NOTE: The date of welding checked on the record drawing is to be within three (3) months after the welders/welding operators qualifications date.

If not within three months after the qualification date, verify that the interval between welds, as shown by the Record of Utilization on welder's/welding operator's qualification test (Section 8.10 of CB&I Documentation List of Records, see attachments 6.4.a, b for examples), during the period from weld qualification through date of welding, did not exceed three months.

If the welders qualifications did not exceed the three month period and the qualifications are valid for the weld procedures performed, the checklist shall be marked accept. If the welders qualifications were not valid for the period of performance of welding or not valid for the weld procedure identified, the checklist shall be marked reject and the welder identification shall be identified by a deviation report.

5.5 Nondestructive Examination (NDE)

The record drawing shall be reviewed to verify that the weld joints for the sample weld have the NDE examinations listed, initialed, dated, procedure identified, and record report number recorded.

The NDE examination reports (Section 7.3 to 7.10 of CB&I List of Records, see Attachments 6.5.a, b, c, d, e, f-two pages for examples) shall be reviewed to verify that:

- a. The weld joint is identified or the report is traceable to the weld joint.
- b. The NDE examination reports are identifiable to the NDE procedure and revision number.
- c. The NDE interpreter/evaluator has signed the report as acceptable.
- d. The radiographic film accepted and the report is signed off by a qualified interpreter.

5.0 INSTRUCTION (Cont'd)

5.5 Nondestructive Examination (NDE) (Cont'd)

NOTE: All welds are not radiographed. If a weld record references a spot radiographic report, the weld is radiographed within the 2% spot radiographic test (SRT) frequency, and is acceptable.

- e. The Vacuum Box Test column in Record Drawing (see 8.5 of CB&I List of Documentation) is initialed and dated, and the Vacuum Box Test Report (Attachment 6.5f) is signed by a Level II.

5.6 NDE Operator and Inspector Certification

Certification records of the NDE operators/Evaluators and Inspectors listed on the NDE examination report shall be reviewed to verify that:

- a. The NDE operator/Evaluators and Inspector for visual examination & VB testings certification (Section 8.12 of CB&I documentation list of records, see attachment 6.6 a, b, c, d and e for examples) are valid for the period that the NDE/visual examination was performed.
- b. The NDE operators certifications are valid for the NDE process.
- c. The NDE operator/Evaluator shall be listed as a Level II, or if the NDE was performed by a Level I and under the guidance of a Level II.

NOTE: If these attributes are rejected, determine if the person that signed as NDE Operator/Evaluator and Inspector was ever certified. If the inspector was certified, record the time period of certification, otherwise state that the person was never certified.

If the NDE operator/Inspector's certifications are valid for the period of performance of NDE/Inspection, method of NDE, and the operator/Evaluator is a Level II the checklist shall be marked accept. If the NDE operator/Inspector's certifications are not valid for period of performance of NDE/inspection, method of NDE, or the operator/Evaluator is not a Level II, the checklist shall be marked reject and it shall be identified by a deviation report.

6.0 ATTACHMENTS

6.1 Checklist

6.2 Example record drawing

- a. Example record drawing
- b. Example record drawing
- c. Example Material Verification Summary Sheet
- d. Vendor Material Records

6.3 Example weld Procedure

- a. Record of Welding Procedure Qualification
- b. Impact Test Date

6.4 Example welder's/welding operator's qualification test

- a. Welders Qualification Test
- b. Performance Qualification Test

6.5 Example NDE examination report

- a. Radiographic Examination Report
- b. Magnetic Particle Examination Report
- c. Liquid Penetrant Examination Report
- d. Ultrasonic Examination Report
- e. Report of Radiography Examination
- f. Vacuum Box Test Report (2 sheets)

6.6 Example NDE operators Certification

- a. NDE Performance Qualification and Certification
- b. NDE Certification Annual Visual Test Record
- c. Record of Nondestructive Examination Performance (2 pages)
- d. NDE Performance Qualification and Certification (Vacuum Box)
- e. NDE Performance Qualification and Certification (visual)

6.7 Weld & NDE Procedures (3 pages)

COMANCHE PEAK RESPONSE TEAM  
CHECKLIST

POPULATION DESC	VERIFICATION PKG NO.		PAGE 1 OF <u>2</u>
QUALITY INSTRUCTION QI-032	<input type="checkbox"/> REINSPECTION <input checked="" type="checkbox"/> DOCUMENTATION REVIEW		<input type="checkbox"/> UNIT 1 <input type="checkbox"/> UNIT 2 <input type="checkbox"/> COMMON
ATTRIBUTE	VERIFICATION		REMARKS
	ACCEPT	REJECT	
5.1 Record Drawing a Joint Identification			
b Welder Identification			
5.2 Material Traceability a Material Certified as SA-537 CL.2/A240-304L			
b Material I.D. is verified by inspection			
5.3 Welding a Weld procedure identified			
b Finished weld initialed and dated			
c Weld procedure applicable to SA-537 CL-2 (GR-B) (containment only)			
d Weld procedure approved by Gibbs & Hill			
e Weld Complete Column initialed and dated			
PREPARED BY:		APPROVED BY:	
DISCIPLINE ENGR.	DATE	LEAD DISCIPLINE ENGR.	DATE
INSPECTED BY:		APPROVED BY:	
INSPECTOR	DATE	LEAD INSPECTOR	DATE

COMANCHE PEAK RESPONSE TEAM  
CHECKLIST

POPULATION DESC	VERIFICATION PKG NO.			PAGE <u>2</u> OF <u>2</u>
ATTRIBUTE	VERIFICATION			REMARKS
	ACCEPT	REJECT	DATE	
5.4 <u>Welders/welding Operators Qualification</u> a Valid for period of welding				
b Valid for weld Procedure				
5.5 <u>Nondestructive Examination (NDE)</u> a NDE report traceability to weld joint				
b NDE Report traceability to NDE procedure				
c NDE evaluator signed off				
d Radiographic film evaluated and signed off.				
e Vacuum Box Test				
5.6 NDE Operators/ Inspector Certification a Certification valid for period of NDE				
b Certification valid for NDE Process/Inspection				
c Operator/Evaluator is a Level II				


CHECKLIST

COMANCHE PEAK RESPONSE TEAM CHECKLIST			
POPULATION DESC	VERIFICATION PKG NO.		PAGE 1 OF <u>2</u>
QUALITY INSTRUCTION QI-032	<input type="checkbox"/> REINSPECTION <input checked="" type="checkbox"/> DOCUMENTATION REVIEW		<input type="checkbox"/> UNIT 1 <input type="checkbox"/> UNIT 2 <input type="checkbox"/> COMMON
ATTRIBUTE	VERIFICATION		
	ACCEPT	REJECT	DATE
5.1 Record Drawing a Joint Identification			
b Welder Identification			
5.2 Material Traceability a Material Certified as SA-537 CL-2/A240-304L			
b Material I.D. is verified by inspection			
5.3 Welding a Weld procedure identified			
b Finished weld initialed and dated			
c Weld procedure applicable to SA-537 CL-2 (GR-B) (containment only)			
d Weld procedure approved by Gibbs & Hill			
e Weld Complete Column initialed and dated		-	
PREPARED BY:		APPROVED BY:	
DISCIPLINE ENGR.	DATE	LEAD DISCIPLINE ENGR.	DATE
INSPECTED BY:		APPROVED BY:	
INSPECTOR	DATE	LEAD INSPECTOR	DATE


CHECKLIST (cont'd)

COMANCHE PEAK RESPONSE TEAM CHECKLIST				
POPULATION DESC	VERIFICATION PKG NO.		PAGE <u>2</u> OF <u>2</u>	
ATTRIBUTE	VERIFICATION			REMARKS
	ACCEPT	REJECT	DATE	
5.4 Welders/welding Operators <u>Qualification</u> a Valid for period of welding				
b Valid for weld Procedure				
5.5 Nondestructive Examination (NDE) a NDE report traceability to weld joint				
b NDE Report traceability to NDE procedure				
c NDE evaluator signed off				
d Radiographic film evaluated and signed off.				
e Vacuum Box Test				
5.6 NDE Operators/ Inspector Certification a Certification valid for period of NDE				
b Certification valid for NDE Process/Inspection		-		
c Operator/Evaluator is a Level II				

### EXAMPLE RECORD DRAWING



EXAMPLE RECORD DRAWING



EXAMPLE MATERIAL VERIFICATION SUMMARY SHEET



METAL MATERIAL VERIFICATION SUMMARY SHEET

Copy to Engineering - By \_\_\_\_\_ Date \_\_\_\_\_

Contract No. 74-74-7  
Sheet 6 of 40

No. of Cuts For Customer \_\_\_\_\_

NO. OF PCS ITEM NO.	SUPPLIER'S NAME OR OTHER IDENTIFICATION NUMBER	SUPPLIER'S SLAB NUMBER	MATERIAL SPEC. AND THICKNESS FOR PLATES	CAR OR TRUCK NUMBER AND SUPPLIER	MATERIAL RECD. CHECKED BY	INSPECTION REPORT CHECKED BY	METAL RECD. ON STORES RELEASED REPORT CHECKED BY	UNLOADING ENGR. SIGN DATE	SERIAL NUMBER NO. OF PIECES FABRICATED	DATE INITIAL NO.	REMARKS
12427-1	Sienco	50537	C12	(1156052)							IS (OKL.)
D-16-1	Bottom, Main Bottom	T 2 1/4	3-31-72	JP 520029	S8	S2	5/8	43	18-3-6	1	1
-	"	P32653	"	"	S8	S1	5/8	4	18-2-6	1	1
-	"	P32654	"	"	S8	S3	5/8	4	18-2-6	1	1
-	"	P32655	"	"	S8	S4	5/8	4	18-2-6	1	1
-	"	P33407	"	"	S8	S5	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S6	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S7	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S8	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S9	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S10	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S11	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S12	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S13	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S14	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S15	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S16	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S17	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S18	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S19	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S20	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S21	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S22	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S23	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S24	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S25	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S26	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S27	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S28	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S29	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S30	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S31	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S32	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S33	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S34	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S35	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S36	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S37	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S38	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S39	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S40	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S41	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S42	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S43	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S44	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S45	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S46	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S47	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S48	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S49	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S50	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S51	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S52	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S53	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S54	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S55	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S56	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S57	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S58	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S59	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S60	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S61	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S62	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S63	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S64	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S65	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S66	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S67	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S68	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S69	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S70	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S71	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S72	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S73	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S74	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S75	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S76	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S77	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S78	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S79	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S80	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S81	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S82	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S83	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S84	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S85	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S86	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S87	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S88	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S89	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S90	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S91	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S92	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S93	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S94	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S95	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S96	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S97	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S98	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S99	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S100	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S101	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S102	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S103	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S104	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S105	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S106	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S107	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S108	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S109	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S110	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S111	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S112	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S113	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S114	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S115	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S116	5/8	4	18-2-6	1	1
-	"	P33405	"	"	S8	S117	5/8	4	18-2-6	1	1
-	"	P33									

## EXAMPLE MATERIAL RECORDS

CERTIFICATE OF TESTS												ARMCO - Armco Steel Corporation					
OUR ORDER NO.		CUST ORDER NO.		SHIPPED VIA		CAR/INITIAL AIR/HD NO.		DATE SHIPPED		SHIP REC. NO.		DATE ARR.		P-			
TRS 9941		2427-2 REPL				BN 614285		5/29/75		7112893		5/30/75		CM			
DESCRIPTION		BAR OR PLATE NO.		No.	YIELD PSI	TENSILE PSI	% ELONG.	% REDUCT.	BEND TEST	FRACT TEST	BRINELL	IMPACT	TYPE	NOTCH	SIZE		
PLTS PV QAT ASME SA537 CL 2 TO CBI MS 6052 REV O & QAS 254 REV O ASME B&PV CODE SEC II & III CIMC W/73 ADDENDA & CODE CASE 1637																	
HEAT: 65875 3/8 x 123 x 425"		P37425		1	75800 <sup>/</sup> 75200 <sup>/</sup>	85700 <sup>/</sup> 89200 <sup>/</sup>	25.0 <sup>/</sup> 25.0 <sup>/</sup>		ok <sup>/</sup>								
<p style="text-align: center;">PLTS &amp; TEST ONS WERE AUSTENITIZED @ 1650°F, TIME @ TEMP: 30 MINUTES, AND TEMPERED @ 1260°F, TIME @ TEMP: 30 MINUTES &amp; AIR COOLED.</p> <p>The material covered by this certification was manufactured and tested in accordance with <u>CBSI Specification M5-6052 Hcvo</u> We certify that alternative samples of the above material have been tested and the results conform to the requirements outlined in the <u>CBSI Specification M5-6052 Hcvo</u>.</p>																	
HEAT	C	Mn	P	S	Si	Cr	Ni	Mo	Cu	Ti	V	B	Cb	Al	N	GRAIN	
6875	.19	1.26	.010	.023	.46	.18	.15	.05	.22							19	
THE CHEMICAL, PHYSICAL OR MECHANICAL TESTS REPORTED HEREWITHE ARE CORRECT AS CONTAINED IN THE RECORDS OF THE CORPORATION.																	
CHICAGO BRIDGE & IRON P O BOX 687 SALT LAKE CITY, UTAH 84110																	
SIGNED <u>O. Robert</u> METALLURGICAL DEPT																	
THIS CERTIFIED TEST REPORT HAS BEEN DELIVERED TO A CONSIGNEE OF MATERIAL PURCHASED FROM ARMCO STEEL CORPORATION. TO AVOID THE POSSIBILITY OF ITS MISUSE, ON THE REDELIVERY OF THIS REPORT TO A THIRD PARTY IT MUST BE RECERTIFIED BY AND UNDER THE NAME OF SUCH CONSIGNEE. (15)																	

EXAMPLE WELD PROCEDURE

Weld Procedure No.



Page \_\_\_\_\_  
Contract \_\_\_\_\_

RECORD OF WELDING PROCEDURE QUALIFICATION  
TO ASME SECTION IX

PART II ESSENTIAL VARIABLES

Qualified No. \_\_\_\_\_ Date \_\_\_\_\_  
Process \_\_\_\_\_ Manual or Machine \_\_\_\_\_  
Material specification \_\_\_\_\_  
ASME p no. \_\_\_\_\_ To ASME p no. \_\_\_\_\_  
Thickness of pipe, dia and wall thick. \_\_\_\_\_  
Thickness range in test qualities \_\_\_\_\_  
Filler metal group no. \_\_\_\_\_  
Weld metal analysis no. \_\_\_\_\_  
ASME specification no. \_\_\_\_\_  
AWS specification no. \_\_\_\_\_

FLUX OR ATMOSPHERE

Flux trade name \_\_\_\_\_  
Inert gas composition \_\_\_\_\_  
Flow rate \_\_\_\_\_  
Is backing strip used? \_\_\_\_\_  
Preheat temperature range \_\_\_\_\_  
Postheat treatment \_\_\_\_\_

WELDING PROCEDURE

Single or multiple pass \_\_\_\_\_ Single or multiple arc \_\_\_\_\_ Position of groove \_\_\_\_\_

Electrode \_\_\_\_\_ Filler wire diameter \_\_\_\_\_  
Type of backing \_\_\_\_\_ Welding current \_\_\_\_\_

Consult PART III: WELDING VARIABLES for joint dimensions, welding current settings

TEST RECORDS

Reduced Spec or Sample Results

Specimen No.	Dimensions		Area	Ultimate Total Load Lb	Ultimate Unit Stress PSI	Character of Failure and Location
	Width	Thickness				

Guided Bend Test

TVDR	Result	Type	Result

Welder's name \_\_\_\_\_ Social Security no. \_\_\_\_\_ Welder's Symbol \_\_\_\_\_  
Who by virtue of these tests meets welder performance requirements

We certify that the statements in this record are correct and that the test weld was prepared, welded and tested in accordance with the requirements of Section IX of the ASME code.

Signed CHICAGO BRIDGE & IRON COMPANY Date \_\_\_\_\_  
(MANUFACTURERS)

Laboratory testing no. \_\_\_\_\_ By \_\_\_\_\_

Remarks \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

## IMPACT TEST DATA



#### IMPACT TEST DATA

**“TYPE OF NOTCH.”**

REMARKS: \_\_\_\_\_

---

---

---

SIGNED: \_\_\_\_\_ BY: \_\_\_\_\_

EXAMPLE WELDERS/WELDING OPERATORS QUALIFICATIONS



WELDERS QUALIFICATION TEST

In Accordance With Section IX of the ASME Code - Latest Edition  
SHIELDED METAL ARC PROCESS

Thickness Range Qualified For _____		Material Thickness _____	RECORD OF UTILIZATION		
Material - Specification _____	to _____	of P No _____ to P No. _____	EN	TYPE	INITIALS
Procedure Specification Number _____			Month	Year	
Filler Metal (F No.) F _____		Filler Metal (A No. Ref.) A _____			
Filler Metal (SFA) Specification SFA _____					
Back gouge to clean metal and weld over head.		5/32" This test qualifies range 1/16" to max. to be welded.	<b>TEST METHOD</b> Two bends per DW-462 2a Result 1 Result 2  Two Radiographs of 6" of test plate Result 1 Result 2		
		OVERHEAD - BOTH SIDES			
Back gouge to clean metal and weld horizontal.		7/8" 5/32" 1/8" This test qualifies range 1/16" to max. to be welded.	<b>TEST METHOD</b> Two bends per DW-462 2a Result 1 Result 2  Two Radiographs of 6" of test plate Result 1 Result 2		
		HORIZONTAL - BOTH SIDES			
Back gouge to clean metal and weld vertical.		5/32" All passes up hill, except first pass and may pass which may be run downhill.	<b>TEST METHOD</b> Two bends per DW-462 2a Result 1 Result 2  Radiography of 6" of test plate Result		
		VERTICAL - BOTH SIDES			
Back gouge to clean metal and weld vertical.		1/8" 13/32" All passes are to be run downhill. This test qualifies range 3/16" to 13/32".	<b>TEST METHOD</b> Two bends per DW-462 2a Result 1 Result 2  Radiography of 6" of test plate Result		
		13/32" SINGLE BEVEL BUTT VERTICAL			
1. Qualification on butt welds also qualifies welder for fillet welds and butt welds with back-up bars. 2. Qualification with F-5, F-42 & F-43 electrodes may be made on P-1 test plates. 3. Radiography of a 6" section of plate may be used in lieu of bend test. 4. Qualification with F-4 electrode also qualifies for F-3, F-2, and F-1.					
Plates Tested	Date	Location	Social Security	Birth Date	Started CB: Specimen Mark
				Year	
WE CERTIFY THAT THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED AND TESTED IN ACCORDANCE WITH SECTION IX OF THE ASME CODE - LATEST EDITION.			Home Address _____		
CHICAGO BRIDGE & IRON COMPANY			City _____ State _____		
By _____ CBI Representative _____			First _____ Middle _____ Last _____		
			X - X-Ray P - Print V - Visual		

EXAMPLE WELDERS/WELDING OPERATORS QUALIFICATIONS



**PERFORMANCE QUALIFICATION TEST**  
In Accordance with Section IX of the ASME Code - Latest Edition  
**AUTOMATIC SUBMERGED ARC PROCESS**

Thickness Range Qualified For _____		Material Thickness _____	RECORD OF UTILIZATION			
Material - Specification _____	to _____	of P No _____ to P No _____	Month _____	Type _____ Time _____		
Procedure Specification Number _____						
Filler Metal (F No) F _____		Filler Metal (A No. Ref.) A _____				
Filler Metal (SFA) Specification SFA _____		Flux _____				
<b>AUTOMATIC GIRTH WELDER</b>		<b>AUTOMATIC FLATDOWN WELDING</b>				
<p>This test qualifies range 3/16" to maximum to be welded. See Note 1</p> <p><i>REDUCED</i></p>		<b>TEST METHOD (See Note 4)</b> Radiography Two bends Full-length of 36" of per 6" of production weld. OW4G2 21st Test Plate Result 1 Result Result Result 2				
<p>This test qualifies range 3/16" to maximum to be welded. See Note 1</p> <p><i>CAN</i></p>		<b>TEST METHOD (See Note 4)</b> Radiography Two bends Full-length of 36" of per 6" of production weld. OW4G2 21st Test Plate Result 1 Result Result Result 2				
<p><b>Examination:</b> Welds made in test assemblies may be examined by radiography (OW 302.2) or by bend tests. Alternatively, a three foot length of the first production weld made by the welding operator in accordance with a qualified WPS may be examined by radiography.</p> <p>(a) The radiographs of the joint shall meet the requirements of UW 51, Section VIII, Division 1.</p> <p>(b) When bend tests are employed for performance qualifications of a welding operator, they shall meet the requirements of OW 160.</p> <p>1. Joint detail for qualification on production work will be per contract drawings.            2. Qualification on butt welds also qualifies welding operator for filler welds.            3. Qualification with F 6 (A 8) electrodes may be made on F 1 test plates.            4. Radiography of a 6" section of test plate or 36" of production weld may be used in lieu of bend test.</p>						
Plates Tested	Date	Location	Social Security	Birth Date	Started CBI	Specimen Mark
					Year	
WE CERTIFY THAT THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED AND TESTED IN ACCORDANCE WITH SECTION IX OF THE ASME CODE - LATEST EDITION			Home Address _____			
CHICAGO BRIDGE & IRON COMPANY			City _____ State _____			
BY _____ CBI Representative			Full Name _____			
			First	Middle	Last	X - X-Ray P - Plus V - Vertical

EXAMPLE NDE EXAMINATION REPORT

EXAMPLE NDE EXAMINATION REPORT

NUCLEAR



MAGNETIC PARTICLE EXAMINATION REPORT

Location \_\_\_\_\_  
Shop  Field   
Contract Number \_\_\_\_\_  
Report or  
Sequence  
Number \_\_\_\_\_

CUSTOMER INFORMATION

DESCRIPTION & STAGE OF  
PART OR WELD  OUTSIDE  
 INSIDE

PROCEDURE AND REV. NO.  PRODS  
 YOKE MFR OR BRAND PROD OR POLE SPACING AMPS  DC  
 AC CALIBRATION DATE

MACHINE MFR OR RATING PARTICLES  DRY  
 WET COLOR & MFR

Record all non conforming indications which were not removed during examination and/or evaluation. (These in base material must be accurately located and referenced to some definable point.)

SAMPLE

The initial examination covered by this report has been performed in accordance with applicable procedure.

OPERATOR LEVEL DATE

Item is: Acceptable   
Unacceptable

All indications have been evaluated in terms of applicable acceptable standards.  
Relevant non conforming indications have been noted on above sketch and have been reported to the Quality Assurance supervisor.

EVALUATION LEVEL DATE

Relevant, non conforming indications, other than shown in above sketch, have been removed in accordance with approved procedure GRP Rev. Para \_\_\_\_\_  
the area re-examined, and found to be acceptable.

QA SUPERVISION DATE

Examination and evaluations have been performed to my satisfaction

Witnessed and accepted by

Witnessed by

FOR MAN

CUSTOMER

AUTHORIZED INSPECTOR

EXAMPLE NDE EXAMINATION REPORT

NUCLEAR



LIQUID PENETRANT EXAMINATION REPORT

Location _____	Shop <input type="checkbox"/> Field <input type="checkbox"/>	Contract Number _____	Report or Sequence Number _____
CUSTOMER INFORMATION			
DESCRIPTION & STAGE OF PART OR WELD		OUTSIDE <input type="checkbox"/> INSIDE <input type="checkbox"/>	
PROCEDURE AND REV NO.		Cleaned after Examination <input type="checkbox"/> Cleaned after Re-Examination <input type="checkbox"/>	NO <input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> YES <input type="checkbox"/>
		INITIAL EXAMINATION	
Penetrant	Brand Name & Type	Batch Number	RE-EXAMINATION
Penetrant Remover			Brand Name & Type
Emulsifier			Batch Number
Developer			
Water			
Record all non conforming indications which were not removed during examination and/or evaluation. [Those in base material must be accurately located and referenced to some definable point.]			
<b>SAFETY REDUCED</b>			
The initial examination covered by this report has been performed in accordance with applicable procedure:		OPERATOR LEVEL DATE	
All indications have been evaluated in terms of applicable acceptability standards. Non conforming indications have been noted on above sketch and have been reported to the Quality Assurance supervisor.		Item is Acceptable <input type="checkbox"/> Unacceptable <input type="checkbox"/>	
		EVALUATOR LEVEL DATE	
Relevant, non conforming indications, other than shown in above sketch, have been removed in accordance with approved procedure GRP Rev. Para _____, the area re-examined and found to be acceptable.		QA SUPERVISOR DATE	
Examination and evaluations have been performed to my satisfaction.		Withheld and Received By _____	Witnessed By _____
FORUMAN		CUSTOMER	AUTHORIZED INSPECTOR
GEIA REV 1.1			

EXAMPLE NDE EXAMINATION REPORT

NUCLEAR



ULTRASONIC EXAMINATION REPORT

Location \_\_\_\_\_ Shop  Field  Contract Number \_\_\_\_\_ Report or Sequence Number \_\_\_\_\_

Customer Information

Description & Stage of Part or Weld

Procedure and Rev No.

Couplant

Instrument No.

Calibration Date

Mfg. Transducer

Size

Angle

Frequency

Record indications specified by procedure.

SAMPLE  
REDUCED

The initial examination covered by this report has been performed in accordance with applicable procedure.	Operator _____	Level _____	Date _____
All indications have been evaluated in terms of applicable standards. Non-conforming indications noted on above sketch and have been reported to the Quality Assurance Supervisor.	Item is: Acceptable <input type="checkbox"/> Unacceptable <input type="checkbox"/>		
Examinations and evaluations have been performed to my satisfaction.	Evaluator _____	Level _____	Date _____
Witnessed and accepted by:	Witnessed by:		
Customer _____	Authorized Inspector _____		

EXAMPLE NDE EXAMINATION REPORT

REPORT OF RADIOGRAPHY EXAMINATION									
Chart No.	Proc. No.	Rev.	Week Ending	WELDING POSITION		EXPOSURE		REASON FOR REJECTION	
Report No.	First	Intermediate	Final	Outer Tank	Inner Tank	Outer Tank	Inner Tank	Outer Tank	Inner Tank
Description	WELDER'S NAME	Date A	Film Number	Print Date	Exposure Position	Exposure	Reason for Rejection	Comments	Reason for Rejection
1	Welder's Name	1/10/80	100	1/10/80	NON C	100	NON C	Comments	Reason for Rejection
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
Remarks									
THE RADIGRAPHY COVERED BY THIS REPORT HAS BEEN PERFORMED IN ACCORDANCE WITH THE APPLICABLE PROCEDURE					ALL INDICATIONS HAVE BEEN EVALUATED IN TERMS OF APPLICABLE ACCEPTANCE STANDARDS				
RADIOGRAPHER IS					INTERPRETER IS				
NO. FILMS - THIS PAGE ACCEPTED _____ REJECTED _____					RADIOPHARMACY AND EVALUATION HAVE BEEN PERFORMED TO MY SATISFACTION				
TOTAL FILMS REPORTED TO DATE _____					EDITORIAL				
DATE OF REPORT _____					REVIEWED AND ACCEPTED BY				
					CUSTOMER		DATE		
					AUTHORIZE EDITORIAL		DATE		

EXAMPLE NDE EXAMINATION REPORT



VACUUM BOX TEST REPORT

Contract No. \_\_\_\_\_ Customer \_\_\_\_\_ Report or Sequence # \_\_\_\_\_  
Job Location \_\_\_\_\_ Proc. No. \_\_\_\_\_ Rev. \_\_\_\_\_  
Pressure Gauge Manufacturer \_\_\_\_\_ Model \_\_\_\_\_  
Pressure Gauge \_\_\_\_\_ Range \_\_\_\_\_ S/N or ID \_\_\_\_\_  
Last Calibration Date \_\_\_\_\_ Recalibration Due \_\_\_\_\_  
Leak Detector Solution \_\_\_\_\_  
*Red Joe ed*

Description of Areas Covered by This Report

Examinations covered by this report have been acceptably completed.

Evaluator (S) \_\_\_\_\_ Level \_\_\_\_\_ Date \_\_\_\_\_

Examination and evaluations have Witnessed and Witnessed  
been performed to my satisfaction Accepted By By

Foreman

Customer

Authorized  
Inspector

EXAMPLE NDE EXAMINATION REPORT (cont'd)

CBT LEAK TEST REPORT			Page <u>1</u> of <u>1</u>					
Contract No. <u>74-2427 U</u>	Location <u>GLEN ROSE TX</u> <input type="checkbox"/> Shop <input checked="" type="checkbox"/> Field	Report or Sequence No. <u>236</u>						
Customer <u>BPOUN &amp; Root FOR TUS!</u> Leak Detector (Mfg., Type & Model) <u>WINTON PRODUCTS</u>		Procedure & Rev. <u>VTP-74-2427/A-4B Rev 3</u> Leak Detector Solution(s) <u>SEAMTEST CONCENTRATE</u>						
Assm. or Area ID	Assm. or Area ID	Pressure Gauge ID <u>11/F</u>	Enter Date & Evaluators Initials					
			<u>① VACUUM R13</u>		<u>①</u>		<u>①</u>	
		Acceptable	Unacceptable	Acceptable	Unacceptable	Acceptable	Unacceptable	
<u>SRG NC-19A</u>	<u>PV-1</u>	<u>1-14-81</u>	<u>Q5</u>					
<u>NC-222 NC-202</u>	<u>PV-1</u>	<u>1-14-81</u>	<u>Q5</u>					
Remarks: SEE REPAIR CHECK LIST PAGES 44 & 45								
<div style="text-align: center;"> <b>INFORMATION</b>  <b>COPY</b> </div> <p>Tests were performed and evaluated per the referenced procedure.      MT <input type="checkbox"/> or PT <input type="checkbox"/> of welded repairs made during testing has been completed and found acceptable (includes repair cavity).      See MT or PT Report No. <u>PPRV</u>.</p>								
<p>No leaks detected during testing.</p> <p>Defects or potential defects not repaired during testing are recorded above.</p> <p>All other tested areas included in this report were found acceptable.</p>								
<u>D. Williams</u> <small>OPERATOR/EVALUATOR</small>			<u>II</u>	<u>1-14-81</u>				
Report results reviewed and accepted by:			<u>D. Williams</u> <small>LEVEL</small>			<u>II</u>	<u>1-14-81</u>	
Reviewed and accepted by:								
CUSTOMER'S INSPECTOR			DATE	ANALYST			DATE	<u>236</u>

(1) Enter applicable test methods such as "Vacuum Box Test", etc.  
 INSTRUCTIONS: When an entry is made under any "Unacceptable" column, make a new entry for that assembly or area and repeat documentation. Make new entry lines until all tests for that assembly or area are acceptable.

EXAMPLE NDE OPERATORS CERTIFICATION



NDE PERFORMANCE QUALIFICATION AND CERTIFICATION  
(Check One)  Initial Certification     Recertification

Name \_\_\_\_\_ Soc Sec # \_\_\_\_\_

CBI LEVELS I AND II

Method \_\_\_\_\_ CBI Level \_\_\_\_\_

Practical Performance Test: Procedure No. \_\_\_\_\_ Date \_\_\_\_\_ Location \_\_\_\_\_

Practical Grade \_\_\_\_\_ Administered By \_\_\_\_\_ Signature \_\_\_\_\_

Written Examination Grades: Date \_\_\_\_\_ Location \_\_\_\_\_

General \_\_\_\_\_ Specific \_\_\_\_\_ Administered By \_\_\_\_\_ Signature \_\_\_\_\_

Composite Grade \_\_\_\_\_ \* [(General Grade) (.1) + (Specific Grade) (.1) + (Practical Grade) (.5)]

\* Percentile weights as shown on attached written NDE examination

Recertification based on continuing satisfactory performance

Method \_\_\_\_\_ CBI Level \_\_\_\_\_ Date \_\_\_\_\_ Verified \_\_\_\_\_ Signature \_\_\_\_\_

CHICAGO BRIDGE & IRON COMPANY CERTIFIES THAT THE ABOVE NAMED EMPLOYEE HAS SATISFACTORILY COMPLETED THE PHYSICAL AND TECHNICAL QUALIFICATIONS REQUIRED BY THE CBI NONDESTRUCTIVE EXAMINATION PERSONNEL TRAINING, QUALIFICATION AND CERTIFICATION MANUAL IN ACCORDANCE WITH SNT-TC-1A AND THAT THE EMPLOYEE IS QUALIFIED FOR THE METHOD AND LEVEL INDICATED

QA Manager, Reg. of Plant

Manager, Inspection & Testing

CBI LEVEL III

Method \_\_\_\_\_ Date \_\_\_\_\_ Requested By \_\_\_\_\_ Signature \_\_\_\_\_

CHICAGO BRIDGE & IRON COMPANY CERTIFIES BY APPOINTMENT BASED ON RESUME THAT THE ABOVE NAMED EMPLOYEE SATISFACTORILY MEETS THE PHYSICAL AND TECHNICAL QUALIFICATIONS REQUIRED BY THE CBI NONDESTRUCTIVE EXAMINATION PERSONNEL TRAINING, QUALIFICATION AND CERTIFICATION MANUAL IN ACCORDANCE WITH SNT-TC-1A AND THAT THE EMPLOYEE IS QUALIFIED FOR CBI LEVEL III IN THE METHOD INDICATED

Director of Welding & Quality Assurance

Manager, Inspection & Testing

Effective Date \_\_\_\_\_

CBI Level \_\_\_\_\_

Method \_\_\_\_\_

Requesting No. \_\_\_\_\_

Qualification Levels

CBI Level I Equivalent to SNT-TC-1A, LEVEL I  
CBI Level II Equivalent to SNT-TC-1A, LEVEL II  
CBI Level III Equivalent to SNT-TC-1A, LEVEL III } as defined per CBI Training Manual

Certification Methods

UT - Ultrasonic Examination	SFT - Surface Flaw Testing
RT - Radiographic Examination	HT - High Intensity Testing
MFL - Magnetic Particle Examination	APT - Alternating Pressure Testing
ET - Liquid Penetrant Examination	MT - Metallographic Testing

REduced

Seal

W-19 REV 2001-75

EXAMPLE NDE OPERATORS CERTIFICATION



NDE CERTIFICATION  
ANNUAL VISION TEST RECORD

Note: The CBT Nondestructive Examination Training Program Manual, in accordance with SNT-TC-1A, provides as follows: "An examination to assure natural or corrected near distance acuity such that the applicant is capable of reading a minimum of Jaeger Number 1 letters at a distance of not less than 12 inches (30.5 cm) on a standard Jaeger or equivalent type test chart for near vision. The ability to perceive an Ortho Rater minimum of 8 or similar test patterns is acceptable. The examination shall be on an annual basis."

Name of Technician \_\_\_\_\_ Location \_\_\_\_\_

Soc. Sec. Co.

Administered by  
(Give Name and Title)

Date Administered (Month Year)	Result of Test		Corrective Lenses		Administered by (Give Name and Title)
	Passed	Failed	Yes	No	
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					

INSTRUCTIONS: This form is to be submitted only once for each individual at the time when that individual is first commencing the certification for the first time for any of the examination methods. No applicant can be considered for certification prior to the first year of the initial examination. Subsequently, the various Construction Offices or Plants will be responsible for regular monitoring the annual test of all certified operators and submitting the report to Welding Services I & T on the WS-102 form provided. Construction Offices or Plants are to record an annual vision test. This is on the copy of this form retained in their files.

## EXAMPLE NDE OPERATORS CERTIFICATION



RECORD OF NONDESTRUCTIVE EXAMINATION PERFORMANCE

Date \_\_\_\_\_

Page 1 of \_\_\_\_\_

Name \_\_\_\_\_ So. Sec. # \_\_\_\_\_

**Permanent Address** \_\_\_\_\_

Cyber-Essential-EdOvers-Tutorials

**NO CLASSES ATTENDED & DATES & HOURS**

Call for Papers: Journal of Clinical Psychology in Asia

Other \_\_\_\_\_

~~NO TRAINING & EXPERIENCE~~

**EXAMPLE NDE OPERATOR CERTIFICATION (cont'd)**

WLS-REV-22  
(Continuation Sheet) RECORD OF NONDESTRUCTIVE EXAMINATION PERFORMANCE  
CHICAGO BRIDGE & IRON COMPANY

Page \_\_\_\_ of \_\_\_\_

Name \_\_\_\_\_ Soc. Sec. # \_\_\_\_\_

#### **IND TRAINING & EXPERIENCE (Cont'd)**

EXAMPLE NDE OPERATOR CERTIFICATION

WJ-2 REV 2-72

PERFORMANCE QUALIFICATION AND CERTIFICATION  
CHICAGO BRIDGE & IRON COMPANY



Date March 28, 1974

NONDESTRUCTIVE EXAMINATIONS

Name Virgil E. Aker Es. Sec. # 308-44-0445

Type & Level of Certification: LDT (SFT) / A  
(Type) (Level)

Practical Performance Test: Procedure No. VTP-43 Date 3/28/74 Location Essexville, Mich.

Grade 100% Administered By William P. Wagner  
(Signature)

Written Examination: Date 3/28/74 Location Essexville, Michigan

Grade 100% Administered By William P. Wagner  
(Signature)

Composite Grade 100% = [(Written grade) (.5) + (Practical grade) (.5)]

CHICAGO BRIDGE & IRON COMPANY CERTIFIES THAT THE ABOVE NAMED EMPLOYEE HAS SATISFACTORILY COMPLETED THE PHYSICAL AND TECHNICAL QUALIFICATIONS REQUIRED BY CBI'S NONDESTRUCTIVE EXAMINATION PERSONNEL TRAINING, QUALIFICATION AND CERTIFICATION MANUAL IN ACCORDANCE WITH SNT-TC-1A AND THAT THE EMPLOYEE IS QUALIFIED FOR THE METHOD AND LEVEL INDICATED ABOVE.

J. M. Marshall  
CA Manager, Region or Plant

Charles N. Sherlock  
Manager, Inspection & Testing

Seal:  
Certification:  
Effective Date 3-28-74  
Level A  
Type LDT (SFT)  
Registrant No. 122


Qualification Levels:

A<sub>1</sub>, A<sub>2</sub> & A<sub>3</sub> Equivalent to SNT-TC-1A, LEVEL I  
A Equivalent to SNT-TC-1A, LEVEL II  
S Equivalent to SNT-TC-1A, LEVEL II  
S (Manager or Instructor)  
Equivalent to SNT-TC-1A, LEVEL III

} as defined per CBI Training Program

Type Qualification:

UT Ultrasonic Examination  
RT Radiographic Examination  
MPT Magnetic Particle Examination  
LPT Liquid Penetrant Examination  
LDT Leak Detection Examination



EXAMPLE NDE OPERATOR CERTIFICATION



NDE PERFORMANCE QUALIFICATION AND CERTIFICATION

(Check One)  Initial Certification  Recertification

Name DENNIS G. WILLIAMS Soc. Sec. # 459-70-3847 Method VT

(Check One) CBI LEVEL I  II

Practical Performance Test: Procedure No. VTS Date 1/22/79 Location Glen Rose, Texas

Practical Grade 97% Administered By Michael Jiffrey II  
SIGNATURE & LEVEL

Written Examination Grades: Date 1/23/79 Location Glen Rose, Texas

General 100% Specific 100% Administered By Michael Jiffrey II  
SIGNATURE & LEVEL  
.30 .20

Composite Grade 98.5% = [(General Grade) (.\*) + (Specific Grade) (\*) + (Practical Grade) (.S)]  
\* Weight factors as shown in program and on applicable written NDE examination.

Recertification based on continuing satisfactory performance:

Date 1/23/79 Verified By Charles V. Shalock  
QA Manager, Region or Plant  
Signature & Level / OR TITLE  
Manager, Inspection & Testing

CBI LEVEL III

Written Examination Grades: Date \_\_\_\_\_ Location \_\_\_\_\_

Basic \_\_\_\_\_ Verified or Administered By \_\_\_\_\_ SIGNATURE & LEVEL / OR TITLE

Date \_\_\_\_\_ Location \_\_\_\_\_

Method Composite \_\_\_\_\_ Administered By \_\_\_\_\_ SIGNATURE & LEVEL / OR TITLE

Method Composite Grade = [General Grade] (0.50) + [Specific Grade] (0.30) + Practical Grade (0.20)

Recertification based on continuing satisfactory performance:

Date \_\_\_\_\_ Verified By \_\_\_\_\_ SIGNATURE & LEVEL / OR TITLE

Director of Welding & Quality Assurance

Manager, Inspection & Testing

CHICAGO BRIDGE & IRON COMPANY CERTIFIES THAT THE ABOVE NAMED EMPLOYEE HAS SATISFACTORILY COMPLETED THE PHYSICAL AND TECHNICAL QUALIFICATIONS REQUIRED BY THE CBI NONDESTRUCTIVE EXAMINATION PERSONNEL TRAINING, QUALIFICATION AND CERTIFICATION PROGRAM DEVELOPED IN ACCORDANCE WITH SNT-TC-1A AND ANSI 45.2.6 AND THAT THE EMPLOYEE IS QUALIFIED FOR THE METHOD AND LEVEL INDICATED.

Effective Period Jan. 23, 1979 to Jan. 23, 1982

CBI Level II

Method VT

Registrant No. 200

Qualification Methods:

UT Ultrasonic Examination  
RT Radiographic Examination  
MT Magnetic Particle Examination  
PT Liquid Penetrant Examination  
VT Visual Examination

SFT Solution Film Testing  
HST Halogen Sniffer Testing  
APT Absolute Pressure Testing  
APT(L) Absolute Pressure Testing (Limited)  
MST Mass Spectrometer Testing

INFORMATION  
COPY  
PPRV

Seal

1/23/79

#### WELD & NDE PROCEDURES

The following is a list of weld and nondestructive examination procedures that are contained in the CB&I Quality Assurance Manual which have been approved by Engineers.

##### Containment Liner

###### General Repair Procedures (GRP)

GRP-(74-2427/8)-C	Rev. 0	
GRP-(74-2427/8)	Rev. 1	Materials and Welds
GRP-(74-2427/8)-17	Rev. 1	
GRP-(74-2427/8)-18	Rev. 1	Weld Metal Defects
GRP-(74-2427/28)-200	Rev. 1	
GRP-(74-2427/28)-400	Rev. 1	

###### General Welding Procedures (GWPS)

GWPS-(74-2427/8)-GMA	Rev. 1	Gas Metal Arc Process
GWPS-(74-2427/8)-GTA	Rev. 1	Gas Tungsten Arc Process
GWPS-(74-2427/8)-SAW	Rev. 1	Automatic Submerged Arc Process
GWPS-(74-2427/8)-SMA	Rev. 1	Shielded Metal Arc Process
MTP-(74-2427/8)-1	Rev. 1	Continuous Prod Magnetic Particle Examination Utilizing Dry, Visible Particles
MTP-(74-2427/8)-2	Rev. 1	Continuous Yoke Magnetic Particle Examination Utilizing Dry, Visible Particles
MTP-(74-2427/8)-12B	Rev. 1	Magnetic Particle Examination By The Prod Method
MTP-13B	Rev. 12	Magnetic Particle Examination Proc. By The Yoke Method
PTP-(74-2427/8)-10B	Rev. 2	Liquid Penetrant Examination Proc.
PTP-(74-2427/8)-12B	Rev. 3	Solvent-Removable Liquid Penetrant Examination
PTP-(74-2427/8)-18	Rev. 2	Color Contrast, High Temperature Liquid Penetrant Examination
RTP-(74-2427/8)	Rev. 8	Radiographic Examination Procedure
RTP-(74-2427/8)-1	Rev. 1	Radiographic Examination Procedure
RTP-(74-2427/8)-9B	Rev. 2	Radiographic Examination Procedure for welds

###### Special Repair Procedures (SRP)

SRL	Rev. 0	WPS-E8018-C1
SRM	Rev. 0	WPS-E8018-C1
SRN	Rev. 0	WPS-E8018-C1
SRO	Rev. 0	WPS-E8018-C1

WELD & NDE PROCEDURES  
(Cont'd)

SRQ	Rev. 1	WPS-E8018-C1
SRP-(74-2427)-A	Rev. 0	WPS-E8018-C1
SRP-(74-2427)-B	Rev. 0	WPS-E8018-C1
SRP-(74-2427)-C	Rev. 1	WPS-E8018-C1
SRP-(74-2427)-D	Rev. 0	WPS-E8018-C1
SRP-(74-2427)-E	Rev. 0	WPS-E8018-C1
SRP-(74-2427)-F	Rev. 0	WPS-E8018-C1
SRP-(74-2427)-G	Rev. 0	WPS-E8018-C1
SRP-(74-2427)-H	Rev. 0	WPS-E8018-C1
SRP-(74-2427)-I	Rev. 0	WPS-E8018-C1
SRP-(74-2428)-J	Rev. 0	WPS-E8018-C1
UTP-(74-2427/8)-47	Rev. 1	Straight Beam Ultrasonic Examination of Steel Plates
VEP-1B	Rev. 2	Visual Examination Procedure
VTP-(74-2427/28)-4B	Rev. 4	Vacuum Box Test of Welds
WPAT-(7402427/8)	Rev. 7	Welding Procedure Application Table

<u>Welding Procedure Specification</u>		(WPS)
	<u>Base Material</u>	<u>Weld Filler Metal</u>
WPS-DS 85 C-1/74-2427/8U	Rev. 0	SA537 CL2 (GRB)
WPS-W18/860 74-2427/8	Rev. 4	SA537 CL2 (GRB)
WPS-E7018 74-2427/8	Rev. 1	SA537 CL2 (GRB)
WPS-E8018-C1 (74-2427/8)	Rev. 4	SA537 CL2 (GRB)
WPS-E8018-C1(Re)74-2427/8	Rev. 0	SA537 CL2 (GRB)
WPS-E308L/83420	Rev. 0	304 (p-8 GP-1)
WPS-E309/83420	Rev. 0	A-36 (P-1) to 304 (P-8)
WPS-E7018/83420	Rev. 0	A-36 (P-1)

Tank Stainless Steel Liners

SR1	Rev. 0	Special Repair Procedure
SR2	Rev. 0	Special Repair Procedure
VB3	Rev. 2	Vacuum Box Test Procedure
VT10	Rev. 4	Visual Inspection Procedure
WPAT	Rev. 0	Welding Procedure Application Table
PT20	Rev. 2	Liquid Penetrant Examination Proc. Color Contrast, Solvent Removable, Wet Developer
GRP-17	Rev. 4	General Repair of Materials
GRP-18	Rev. 5	General Repair of Weld Metal Defects
GWPS-SMAW (WPS-800)	Rev. 10	General Welding Proc. Spec. for the Shielded Metal Arc Process

WELD & NDE PROCEDURES  
(Cont'd)

Welding Procedure Specification (WPS)

		<u>Base Material</u>	<u>Weld Filler Metal</u>
WPS-E308L/83420	Rev. 0	304 (P-8 GP-1)	E308L-15 & E308L-16
WPS-E309/83420	Rev. 0	A-36 (P-1) to 304 P-8)	E309-15 & E309-16
WPS-E7018/83420	Rev. 0	A-36 (P-1)	E7018