

EVALUATION RESEARCH CORPORATION

CONTROLLED COPY
CONTROL NO. DF-001

COMANCHE PEAK RESPONSE TEAM

QUALITY INSTRUCTION FOR ISSUE-SPECIFIC ACTION PLAN VII.c

INSTRUCTION NO.: QI-039

REVISION: 1

EFFECTIVE DATE: 02/20/86

REINSPECTION OF HVAC DUCTS AND PLENUMS

Prepared by: F. Bossmung Date: FEB. 11, 1986
QA/QC Discipline Engineer

Approved by: Albert A. Patterson Date: 2-14-86
Issue Coordinator

Approved by: E. C. Bajan Date: 2/19/86
On-Site QA Representative

Approved by: J. L. Hanel Date: 2/19/86
QA/QC Review Team Leader

1.0 PURPOSE

This instruction provides direction and accept/reject criteria for each attribute listed on the reinspection checklists which will be used for the field reinspection of HVAC ducts and plenums.

2.0 APPLICABILITY

This instruction is applicable to safety related hardware constructed and final QC accepted at Comanche Peak Unit 1 and common, and Unit 2. The population is described in the Population Description for HVAC Ducts and Plenums.

3.0 REFERENCES

- 3.1 Description Memorandum for Reinspection of HVAC Ducts and Plenums, QA/QC-RT-393, dated August 21, 1985, J. Schauf to A. Patterson
- 3.2 CPP-009, "Performance of Reinspection and Documentation Review."
- 3.3 QI-QP-11.18-4, "Ultrasonic Examination of HILTI Bolts", TUGCO

4.0 GENERAL

4.1 Responsibilities

Reinspections are performed and documented in accordance with established project procedures and instructions. This instruction established the attributes and accept/reject criteria for reinspection of HVAC ducts and plenums. Reference 3.2 provides the instructions for performing, documenting, and processing the results of the reinspections.

4.2 Policy

Activities performed under this instruction shall conform to the policies contained in the latest Comanche Peak Response Team Program Plan and Issue-Specific Action Plan(s).

5.0 INSTRUCTION

General

The samples that make up this population are:

- a. Sheet metal duct section.
- b. Plenum.
- c. Flexible connection.

5.0 INSTRUCTION (Cont'd)

This section describes each sample and instructions for performing its reinspection. Verification of the attributes to be inspected will be recorded on the Comanche Peak Response Team Checklist, Attachment 6.1.

Note that alphanumeric before the attributes refer to the checklist number.

When measuring components for location, a measuring device with increments of not greater than $\frac{1}{4}$ inch is required. When measuring size or length, increments of not greater than $\frac{1}{16}$ inch are required. When measuring sheet metal gage, increments of not greater than $\frac{1}{64}$ inch are required. For additional measurement information on welding, see Section 3, Welding.

Attachment 6.52, Inspection Tools and Codes, provides a list of standard inspection tools and their corresponding codes. Record on Attachment 6.53, Inspection Tools Used, the corresponding code of the inspection tools used for inspecting each attribute as applicable.

1. Sheet Metal Duct Section

General

The sample is identified by being marked on the appropriate 2323-M1(2)-XXXX BSC/HAN drawing which accompanies the Verification Package. In cases where the sample is located in a straight run which is made up of identical sections in area but with several sections of different lengths, e.g., six $40\frac{1}{2}$ inch long sections and one $19\frac{1}{2}$ inch long filler piece, the installed sequence of sections may not match that as pictorially represented on the BSC/HAN drawing. For example, the $19\frac{1}{2}$ inch filler piece may be installed at any location in this portion of the duct run. Locate the sample following the guideline as noted on the drawing, e.g., the third $40\frac{1}{2}$ inch section south of fan, disregarding the filler piece should it be installed between the fan and the sample.

The sample may include one or more of the accessories described in sections 4-13 of this procedure. When included, inspect the sample to the appropriate section.

1.a. Elevation

Verify that the sample is installed within ± 6 inches of the elevation as shown on the BSC/HAN drawing.

5.0 INSTRUCTION (Cont'd)

1.b. Location perpendicular to air flow

Verify that the sample is installed within ± 6 inches of the dimension as shown on the drawing which is perpendicular to air flow.

1.c. Area

Verify that the internal cross sectional area dimensions are equal to those shown on the BSC/HAN drawing. Tolerance is $\pm 1/8$ inches. Deduct material thicknesses from outside skin measurements. If the sheet metal thickness cannot be measured, the sheet metal thickness is to be obtained from the sample's Material Requisition Form or equivalent.

1.d. Length

Verify length of section from the material requisition form, (shop drawing, see sample Attachment 6.3, Material Requisition Form included in the Verification Package). Tolerance is $\pm 1/4$ inch.

Sheet Metal Construction

Inspection tolerances for sheet metal construction are to be determined from Attachment 6.2, Fabrication Tolerances for Rectangular and Round Ductwork

The ductwork construction level 2 or 3 is determined from Attachment 6.4, Duct Construction Classification Summary. With this level, verify that the following attributes are in accordance with the Material Requisition Form and the referenced attachment:

1.e. Duct gage

Level 2 rectangular - Attachment 6.5

Level 3 and 4 rectangular - Attachment 6.6

Round - Attachment 6.7

If the duct gage cannot be measured, note this on the Checklist.

1.f. Reinforcing angle size

Level 2 rectangular - Attachment 6.5

Level 3 and 4 rectangular - Attachment 6.6

1.g. Reinforcing angle spacing

All ductwork - Attachment 6.2

5.0 INSTRUCTION (Cont'd)

1.h Companion angle size

Level 2 rectangular - None, see Attachment 6.10 for connection.

Level 3 and 4 rectangular - Attachment 6.6

Round - Attachment 6.7

1.i. Longitudinal seam

Level 2 rectangular - Attachment 6.5

Level 3 and 4 rectangular - Seal Welded

Round, all levels - Seal Welded

1.j. Tie rod spacing

Level 2 - Attachment 6.8

Level 3 and 4 - Attachment 6.9

1.k. Tie rod diameter

3/8 inch diameter. Tolerance equals $\pm 1/16$ inch.

Connecting Joint

Inspect the downstream (air flow direction) connection only.

1.l. Gasket

Verify that the gasket is in place. For level 2 duct joints refer to Attachment 6.10, Typical Flanged Joint, and for level 3 joints refer to Attachment 6.11, Typical Companion Angle Flanged Joint.

1.m. Nuts and Bolts

Verify that nuts and bolts are installed. To verify bolt tightness, visually inspect that the lock washer is compressed. For level 2 and 3 references, see 1.l.

2. Wall Penetration

For a duct section that passes through a wall, inspect as follows:

2.a. Minimum length

Verify that the minimum length is in accordance with Attachment 6.12, DCA 0719.

2.b. Maximum extension

Verify that the maximum extension is in accordance with Attachment 6.12.

5.0 INSTRUCTION (Cont'd)

2.c. Gasket

Verify that the gasket is in place in accordance with 1.1 above.

2.d. Nuts and bolts

Verify that the nuts and bolts are installed in accordance with 1.m above.

3. Welding

General

The following typical welded connections for sheet metal duct sections with attached accessories are to be inspected when they are located in a given sample and in accordance with the referenced attachment.

<u>Connection</u>	<u>Level</u>	<u>Attachment</u>
Typical Longitudinal Welded Seam	2	6.13
	3 & 4	6.14
Corner Detail - Flanged Duct	2	6.15
	3 & 4	6.16
Typical Reinforcing Angle Connections	2	6.17
	3 & 4	6.18
Vane Details	2, 3 & 4	6.19
Typical "Spliced Joint" Rectangular & Round Duct Construction	2	6.20
	3 & 4	6.21
Typical Companion Angle Flanged Joint (Rectangular Duct)	3 & 4	6.22
Typical Companion Angle Flanged Joint (Round Duct)	2, 3 & 4	6.24,
		6.25
Typical "Tie Rod" Installation	3 & 4	6.23

Prior to the start of inspection assure that welds are clean of any foreign material which would impede an adequate visual inspection. Do not remove any sealant which covers a portion of a weld. In these cases note this on the checklist which welds could not be inspected.

5.0 INSTRUCTION (Cont'd)

Coatings need not be removed unless an inspector believes that due to excessive and/or uneven coating application he is unable to provide an adequate inspection of the weld. Then he shall contact the level III inspector and with his concurrence only then may the coating be removed.

Where it is necessary to measure weld dimensions during the course of an inspection, such dimensions should be determined as accurately as is practically achievable using standard weld inspection tools. Inspect each weld to the following:

3.a. Location

Verify that the weld configurations (fillets only) and location are as specified per the detailed drawing.

3.b. Weld size

Verify that the weld size meets the requirements of the applicable drawings except that:

- ° For bevel welds which are not accessible from the back side, the size is verified by assuring that the joint is welded flush.
- ° Oversized fillet welds shall be acceptable if the oversized weld does not interfere with mating parts.
- ° Weld sizes 1/8" and greater may be undersized to a maximum of 1/16" provided that the undersized portion(s) do not exceed 1/4 of the weld length.

3.c. Weld Length

Verify that the weld length complies with the referenced drawing with the following allowances:

- °

<u>Weld Length Specified On Drawing</u>	<u>Permissible Underlength</u>
< 3"	1/8"
≥ 3"	1/4"
- ° Weld lengths may be longer than specified.
- ° The spacing of intermittent welds may vary within 1" of the location specified on the drawing.

5.0 INSTRUCTION (Cont'd)

3.d. Fusion

Verify that if any incomplete fusion is visible it complies with the following:

- ° For fillet welds 3/8" maximum incomplete fusion in any 4" segment and 1/4" maximum incomplete fusion in welds less than 4" long.
- ° For groove welds no incomplete fusion is permitted.

3.e. Craters

Verify that the weld size is met on all welds with underfilled craters. Craters outside the specified weld length are irrelevant provided there are no cracks visible through the coated surface.

3.f. Weld profiles

Verify that the weld profiles are acceptable per Attachment 6.26, Fillet Weld Profiles.

3.g. Undercut

Verify that any undercut present does not exceed the following criteria:

- ° For base material less than 1/8", no undercut is permitted.
- ° For base material 1/8" and greater the following requirements apply:
 - (1) When the member is welded from both sides and the undercut is in the same plane, the following undercut is permitted.
 - ° 1/32" for 1/2 the length of the total* weld or
 - ° 1/32" for 1/4 the length of the total* weld and 1/16" for 1/8 the length of the total* weld.

* Total weld equals the cumulative length of both sides.

5.0 INSTRUCTION (Cont'd)

- (2) For all other welds the permitted undercut is:
- ° 1/32" for the full length of the weld or
 - ° 1/32" for 1/2 the length of the weld and 1/16" for 1/4 the length of the weld.

3.h. Porosity

Considering that only surface porosity whose major surface dimension exceeds 1/16" shall be considered relevant, verify the following:

- ° The sum of the diameters of porosity do not exceed 3/8" in any linear inch of weld and shall not exceed 3/4" in any 12" of weld.

3.i. Overlap

If overlap is present verify that the required weld size and the fusion acceptance criteria are met. If fusion in the overlap length cannot be verified, then verify that the overlap length, whose fusion cannot be verified, does not exceed 3/8" in any 4" segment or 1/4" in welds less than 4" long.

3.j. Surface slag

Verify that the major surface dimensions of the slag does not exceed 1/8" or 1/4" for any isolated surface slag. (Slag is considered to be isolated when it does not occur more frequently than once in a 3" weld segment.)

3.k. Cracks

Verify that there are no cracks visible through the coated surface.

3.l. Touch-up galvanizing

Verify that galvanizing removed during the welding process and the weld have been touch-up painted.

4. Splitter Damper

5.0 INSTRUCTION (Cont'd)

4.a. Installation

Verify that the splitter damper is installed in accordance with Attachment 6.27, Splitter Damper. If an access door is not located suitable to perform this inspection, note on the checklist.

4.b. Nuts and bolts

Verify that all nuts and bolts are in place and finger tight.

4.c. Damper locked in place

Verify that the damper is set and securely locked in place. Caution: do not change setting of damper. Note its position prior to inspection.

5. Extractor

5.a. Installation

Externally, verify that the extractor is supported per Attachment 6.28, Seismic Volume Extractor. If an access door is available, inspect that the internal arrangement of the extractor is per Attachment 6.28. If this inspection cannot be made, note this on the Checklist.

5.b. Angle Size

Verify that the angles are of the proper size per Attachment 6.28.

5.c. Bolts

Verify that all bolts are in place and finger tight.

6. Turning Vane

6.a. Installation

Verify that a turning vane has been installed and check by hand to assure that it is mounted securely in place. If an access door is not available to make this verification, note this on the checklist.

5.0 INSTRUCTION (Cont'd)

6.b. Geometry

Verify geometry, e.g. blade spacing, is in accordance with Attachment 6.19, Typical - Short Radius Vaned Elbow.

6.c. Gage

Verify material gage is per Attachment 6.19.

7. Grille, register and diffuser

7.a. Location

Verify that the item is installed \pm 6 inches to the plan and elevation dimensions as shown on the BSC/HAN drawing.

7.b. Installation

Verify that the grille or register has been installed in accordance with Attachment 6.29, Typical Installation of Grills & Registers. For diffusers, verify the same attribute to the manufacturer's data sheet included in the Verification Package.

7.c. Gaskets

Verify that the gasket has been installed in accordance with Attachment 6.29.

7.d. Nuts and Bolts

Verify that the nuts and bolts are installed in accordance with Attachment 6.29 and that the nuts are finger tight.

8. Volume Damper

For any sample that has a volume damper attached to it's downstream connection, the following inspection is to be performed.

8.a. Installation

Verify that the damper is installed in accordance with Attachment 6.30, Manual Volume Damper.

8.b. Gaskets

Verify that the gaskets have been installed in accordance with Attachment 6.30.

5.0 INSTRUCTION (Cont'd)

8.c. Nuts and bolts

Verify that the nuts and bolts are installed in accordance with Attachment 6.30 and that the nuts are finger tight.

8.d Verify that the damper is set and securely locked in place. Caution: do not change setting of damper. Note its position prior to inspection.

9. Access Door

9.a. Installation

For rectangular ducts verify that the access door is installed in accordance with Attachment 6.31, Typical Access Door Arrangement and in accordance with Attachment 6.32, Duct Access Panel Details. For round ducts refer to Attachment 6.33, Access Panel Assembly and Attachment 6.34, Bolted Access Panel Assembly.

9.b. Gasket

Verify that the gasket has been installed in accordance with the referenced attachments in 9.a..

9.c. Nuts and bolts

Verify that the nuts and bolts have been installed in accordance with the referenced attachments in 9.a. and that the accessible nuts or bolts are finger tight.

10. Instrument Test Holes

10.a. Caps

Verify that the caps have been installed in accordance with Attachments 6.35, Ventlock Instrument Test Hole and that the caps are finger tight.

10.b. Gasket

Verify that the gasket has been installed in accordance with Attachment 6.35.

10.c. Bolts and nuts

Verify that the nuts and bolts have been installed in accordance with Attachment 6.35 and that the nuts are finger tight.

5.0 INSTRUCTION (Cont'd)

11. Tubing Connection

11.a. Installation

Verify that the installation of mounting bracket for temperature elements, instrument connections and miscellaneous test connections is in accordance with Attachment 6.36, Typical Mounting Bracket. Note any discrepancies on the checklist. Inspect any welds per section 3., Welding.

11.b. Nuts and bolts

If the mounting bracket of 11.a is bolted to the duct, verify that they are installed in accordance with Attachment 6.36 and that the nuts are finger tight.

12. Pipe Connection

12.a. Pipe size

Verify that the pipe size is in accordance with the BSC/HAN drawing.

12.b. Pipe length

Verify that the pipe length is in accordance with Attachment 6.37, Pipe Connections. Inspect welding in accordance with Section 3., Welding.

13. Instrument Mounting

13.a. Installation

Verify that instruments are mounted and installed in accordance with the following attachments as applicable:

- ° Attachment 6.38, Chlorine Leak Detector Sensor
- ° Attachment 6.39, Smoke Detector
- ° Attachment 6.40, Mounting Bracket Detail for Thermostat Sensing Bulb and Instrument Probe
- ° Attachment 6.41, DCA No. 12,636, Revision 1 for listed Instrumentation Tag Numbers
- ° Attachment 6.51, Radiation Monitor

13.b. Mounting bracket

Verify that any mounting brackets are installed to the appropriate attachments referenced in 13.a.

5.0 INSTRUCTION (Cont'd)

13.c. Nuts, bolts and washers

Verify that all nuts, bolts, and washers are installed in accordance with the appropriate attachment referenced in 13.a. For bolts with lockwashers, visually inspect that the lockwasher is compressed. For other nuts and bolts, verify finger tightness.

14. Plenum

The sample is identified by being marked on the appropriate BSC/HAN drawing which accompanies the Verification Package. Construction is to be in accordance with the plenum fabrication drawing also included in the Verification Package. Weld inspection is to be performed in accordance with 3. Welding. For fabrication tolerances, see Attachment 6.2. If portions of this inspection cannot be made due to inaccessibility, this should be noted on the checklist.

14.a. Location

Verify that the sample is located within ± 6 inches of the dimensions as shown on the BSC/HAN drawing.

14.b. Sheet metal gage

Verify that the sheet metal gage is in accordance with the fabrication drawing.

14.c. Reinforcing angle size

Verify that the size of any reinforcing angles or members, are in accordance with the fabrication drawing.

14.d. Reinforcing angle spacing

Verify that any reinforcing angle or member spacing is in accordance with the fabrication drawing.

14.e. Gasket

For any duct connected to the plenum sample, verify that a gasket is installed in accordance with 1.1, Gasket.

5.0 INSTRUCTION (Cont'd)

14.f. Nuts and bolts

For any duct connected to the plenum sample, verify that the nuts and bolts are installed in accordance with I.M., Nuts and bolts.

15. Flexible Connection

The sample is identified by being marked on the appropriate BSC/HAN drawing which accompanies the Verification Package.

15.a. Location

Verify that the sample is located within ± 6 inches the dimensions as shown on the drawing.

15.b. Companion angle size

Verify that the companion angle size is in accordance with Attachments 6.42, Rectangular Flex, 6.43, Flex Connection Installation Typical Arrangement Rectangular Duct for rectangular duct and Attachment 6.44, Flex Connection Installation, Typical Arrangement Round Duct for round duct.

15.c. Nuts, bolts and washers

Verify that all nuts, bolts and washers are in place. For bolts with lockwashers, usually inspect that the lockwasher is compressed. For all others, verify finger tightness.

15.d. Misalignment

Verify that the joint is not misaligned in accordance with the misalignment tolerances of Attachment 6.43 for rectangular duct or 6.44 for round duct. Measuring tolerance is $\pm 1/8$ inch.

Deleted
Section 5.16

APP
2/13/86

6.0 ATTACHMENTS

- 6.1 Comanche Peak Response Team Reinspection Checklist
- 6.2 Fabrication Tolerance for Rectangular and Round Ductwork
(DFP-TUSI-001, pg. 36)
- 6.3 Material Requisition Form
(DFP-TUSI-001, pg. 52)
- 6.4 Duct Construction Classification Summary
(DFP-TUSI-001, pgs. 5,6)
- 6.5 Construction Level 2 Rectangular Ductwork
(DFP-TUSI-001, pgs. 10, 11)
- 6.6 Construction Level 3 and 4 Rectangular Ductwork
(DFP-TUSI-001, pgs. 24, 25)
- 6.7 Construction Data for Round Ductwork
(DFP-TUSI-001, pg. 42)
- 6.8 Duct Construction Level 2 Supply Duct
(DFP-TUSI-001, pgs. 16, 17)
- 6.9 Duct Construction Level 3 and 4 Supply Duct
(DFP-TUSI-001, pgs. 31, 32)
- 6.10 Typical Flanged Joint
(DFP-TUSI-001, pg. 12)
- 6.11 Typical Companion Angle Flanged Joint
(DFP-TUSI-001, pg. 26)
- 6.12 DCA No. 0719
- 6.13 Typical Longitudinal Welded Seam - Level 2
(DFP-TUSI-001, pg. 13)
- 6.14 Typical Longitudinal Welded Seam - Level 3 and 4
(DFP-TUSI-001, pg. 29)
- 6.15 Corner Detail - Flanged Joint
(DFP-TUSI-001, pg. 14)
- 6.16 Typical Companion Angle
(DFP-TUSI-001, pg. 27)

Note: References in parenthesis are to Bahnson Service Company, Inc. procedures.

6.0 ATTACHMENTS (Cont'd)

- 6.17 Typical Reinforcing Angle - Level 2
(DFP-TUSI-001, pg. 15)
- 6.18 Typical Reinforcing Angle - Level 3 and 4
(DFP-TUSI-001, pg. 28)
- 6.19 Typical - Short Radius Vaned Elbow
(DFP-TUSI-001, pg. 18)
- 6.20 Typical Splice Joint Level 2
(DFP-TUSI-001, pg. 19)
- 6.21 Typical Splice Joint Level 3 and 4
(DFP-TUSI-001, pg. 34)
- 6.22 Typical Flange Detail Level 3 and 4
(DFP-TUSI-001, pg. 26)
- 6.23 Typical Tie Rod Installation
(DFP-TUSI-001, pg. 30)
- 6.24 Typical Companion Angle Flanged Joint - Round Duct
Construction
(DFP-TUSI-001, pg. 43)
- 6.25 Typical Round FLange Details
(DFP-TUSI-001, pg. 45)
- 6.26 Fillet Weld Profiles
- 6.27 Splitter Damper
(DFP-TUSI-008, pg. 8)
- 6.28 Seismic Volume Extractor
(DFP-TUSI-008, pg. 7)
- 6.29 Typical Installation of Grills and Registers
(DFP-TUSI-008, pg. 4)
- 6.30 Manual Volume Damper
(DFP-TUSI-008, pg. 9)
- 6.31 Typical Access Door Arrangement
(DFP-TUSI-008, pgs. 10, 11)
- 6.32 Duct Access Panel Details
(DFP-TUSI-008, pg. 14)
- 6.33 Access Panel Assembly
(DFP-TUSI-008, pg. 15)

6.0 ATTACHMENTS (Cont'd)

- 6.34 Bolted Access Panel Assembly
(DFP-TUSI-008, pg. 16)
- 6.35 Ventlock Instrument Test Hole
(DFP-TUSI-008, pg. 28)
- 6.36 Typical Mounting Bracket
(DFP-TUSI-008, pg. 21)
- 6.37 Pipe Connections
- 6.38 Chlorine Leak Detector Assembly
(DFP-TUSI-008, pg. 22)
- 6.39 Smoke Detector
(DFP-TUSI-008, pg. 22)
- 6.40 Mounting Bracket Detail for Thermostat Sensing
Bulb Instrument and Probe
(DFP-TUSI-008, pg. 23)
- 6.41 DCA No. 12,636
- 6.42 Rectangular Flex
(DFP-TUSI-008, pg. 17)
- 6.43 Flex Connection Installation-Typical Arrangement Rectangular
Duct
(DFP-TUSI-008, pg. 18)
- 6.44 Flex Connection Installation-Typical Arrangement Round Duct
(DFP-TUSI-008, pg. 19)
- 6.45 (Deleted)
- 6.46 (Deleted)
- 6.47 (Deleted)
- 6.48 (Deleted)
- 6.49 (Deleted)
- 6.50 (Delet 1)
- 6.51 Mounting for Radiation Monitor
- 6.52 Inspection Tools and Codes
- 6.53 Inspection Tools Used

COMANCHE PEAK RESPONSE TEAM
CHECKLIST

POPULATION DESC HVAC Ducts and Plenums	VERIFICATION PKG NO. I-M-DUPL-	PAGE 1 OF <u>3</u>		
QUALITY INSTRUCTION QI-039	<input checked="" type="checkbox"/> REINSPECTION	<input type="checkbox"/> UNIT 1		
EQUIPMENT MARK/TAG NO.	<input type="checkbox"/> DOCUMENTATION REVIEW	<input type="checkbox"/> UNIT 2		
		<input type="checkbox"/> COMMON		
ATTRIBUTE	VERIFICATION			REMARKS
	ACCEPT	REJECT	DATE	
<u>1. Sheet Metal Duct</u> a. Elevation b. Location Perpendicular to Air Flow c. Area d. Length e. Duct Gage f. Reinforcing Angle Size g. Reinforcing Angle Spacing h. Companion Angle Size i. Longitudinal Seam j. Tie Rod Spacing k. Tie Rod Diameter l. Gasket m. Nuts and Bolts <u>2. Wall Penetration</u> a. Minimum Length b. Maximum Extension c. Gasket d. Nuts and Bolts <u>3. Welding</u> a. Location b. Weld Size c. Length d. Fusion e. Craters				
PREPARED BY: _____		APPROVED BY: _____		
DISCIPLINE ENGR. _____	DATE _____	LEAD DISCIPLINE ENGR. _____	DATE _____	
INSPECTED BY: _____		APPROVED BY: _____		
INSPECTOR _____	DATE _____	LEAD INSPECTOR _____	DATE _____	

COMANCHE PEAK RESPONSE TEAM
CHECKLIST

POPULATION DESC HVAC Ducts and Plenums	VERIFICATION PKG NO. I-M-DUPL-			PAGE <u>2</u> OF <u>3</u>
ATTRIBUTE	VERIFICATION			REMARKS
	ACCEPT	REJECT	DATE	
<ul style="list-style-type: none"> f. Weld Profiles g. Undercut h. Porosity i. Overlap j. Surface Slag k. Cracks l. Touch-up Galvanizing 4. <u>Splitter Damper</u> <ul style="list-style-type: none"> a. Installation b. Nuts and Bolts c. Locked in Place 5. <u>Extractor</u> <ul style="list-style-type: none"> a. Installation b. Angle Size c. Bolts 6. <u>Turning Vane</u> <ul style="list-style-type: none"> a. Installation b. Geometry c. Gage 7. <u>Grille, register and Diffuser</u> <ul style="list-style-type: none"> a. Location b. Installation c. Gaskets d. Nuts and Bolts 8. <u>Volume Damper</u> <ul style="list-style-type: none"> a. Installation b. Gaskets c. Nuts and Bolts d. Locked in Place 9. <u>Access Door</u> <ul style="list-style-type: none"> a. Installation b. Gasket c. Nuts and Bolts 10. <u>Instrument Test Holes</u> <ul style="list-style-type: none"> a. Caps b. Gasket c. Bolts 				

COMANCHE PEAK RESPONSE TEAM
CHECKLIST

POPULATION DESC HVAC Ducts and Plenums	VERIFICATION PKG NO. I-M-DUPL			PAGE <u>3</u> OF <u>3</u>
ATTRIBUTE	VERIFICATION			REMARKS
	ACCEPT	REJECT	DATE	
11. <u>Tubing Connection</u> a. Installation b. Nuts and bolts 12. <u>Pipe Connection</u> a. Pipe Size b. Pipe Length 13. <u>Instrument Mounting</u> a. Installation b. Mounting Bracket c. Nuts, Bolts and Washers 14. <u>Plenums</u> a. Location b. Sheet Metal Gage c. Reinforcing Angle Size d. Reinforcing Angle Spacing e. Gasket f. Nuts and Bolts 15. <u>Flexible Connection</u> a. Location b. Companion Angle Size c. Nuts, Bolts and Washers d. Misalignment 16. <u>Concrete Expansion Anchors</u> a. Size and Number b. Embedment c. Bolt Spacing d. Angularity e. Concrete Damage f. Nut Engagement and Bearing				

IV-I FABRICATION TOLERANCES FOR RECTANGULAR AND ROUND DUCTWORK

A. Sheet Metal

1. All dimensional tolerances and measurements shall be inside dimensions unless otherwise noted. (Refer to attached sketch)
2. Where the shortest side or diameter of a joint of duct is greater than 6", the following tolerances shall be held:

<u>Dimension</u>	<u>Tolerances (inches)</u>
Length (L)	$\pm 1/4$
Width (W)	$\pm 1/8$
Height (H)	$\pm 1/8$
Diameter (D)	$\pm 1/8$
Diagonal (d_1) = Diagonal (d_2)	$\pm 1/8$ Level 2 $\pm 3/16$

B. Companion Angle

1. The companion angle shall be sheared to the designated lengths, (A_1 & A_2), within a tolerance of $\pm 1/16$ ".
2. Bolt holes shall be punched or drilled in the companion angles as designated within a tolerance of $\pm 1/16$ ".

C. Reinforcing Angle

1. The intermediate reinforcing angle shall be sheared to the designated lengths, (A_1 & A_2), within a tolerance of $\pm 1/16$ ".
2. The reinforcing angle shall be located at the midpoint (M) of the duct length, or as shown on the drawings in special cases, within a tolerance of $\pm 1/4$ ".
3. The reinforcing angle shall be positioned flush on each side of the duct and shall be perpendicular to the longitudinal centerline.
4. If a design change is issued, to shorten a joint of duct, the reinforcing angle will remain at its original location.
5. Duct reinforcing angles may be permanently removed to allow installation of expansion joints, dampers, registers, etc.

D. Ells, Transitions, Offsets, and Special Construction

1. The same sheet metal, companion angle, and reinforcing angle tolerance limits will apply to the manufacturer of ells, transitions, offsets, and special construction.

12

CORNER TAB WELDED IN ON TWO SIDES (TYP 4 CORNERS)


GROUP NO.
DUCT TAKE OFF
DWG. NO.
STATION NO.
CUBE NO.
HEAT NO.

PE

$9 \frac{1}{8}'' \phi$ HOLES AOC

2'' (TYP)

CUSTOMER: TUSI - Comanche Peak
Glen Rose, Texas 760



DUCT NO.	DIMENSIONS	SIDE VIEW A/R	PLAN VIEW A/R	Q.C INSP	DATE	TACK	W/O	OTHER	MATERIAL REQUISITION					
									PART NO.	NO. PCS.	DESCRIPTION	WIDTH	LE	

SAMPLE

" ATTACHMENT # 1 "

Attachment 6.3
OI-039
Rev. 1
Page 1 of 1

PROCEDURE NO. DEP-TUSI-001 REV. 12
 DATE APR 28 1985 PAGE 52 OF 52

DUCT CONSTRUCTION CLASSIFICATION SUMMARY

- I. Reference ORNL NSIC 65
ERDA 76021 SMACNA 1969

BUILDING SYSTEM	DUCTWORK CONSTRUCTION LEVEL	QA PROGRAM APPLICABLE	SEISMIC CATEGORY
<u>AUXILIARY</u>			
1. Primary Plant Vent Supply	2	FULL	I
2. Primary Plant Vent Exhaust	3	FULL	I
3. Containment Purge Supply	2	FULL	I
4. Containment Purge Exhaust	3	FULL	I
5. Office & Service Area Supply & Exhaust	2	FULL	I
6. Office & Service Area Controlled Exhaust	3	FULL	I
7. Control Room A/C	2	FULL	I
8. Control Room A/C Ductwork between isolation dampers & environs	3	FULL	I
9. Uncontrolled Access Area Ventilation	2	FULL	I
10. Battery Room Exhausts	2	FULL	I
11. Hydrogen Purge Supply Duct (Between Outdoor Air Intake & Filter Unit)	2	FULL	I
12. Roof Vent Exhaust	2	NON-QA	N/A
<u>SAFEGUARDS</u>			
1. Primary Plant Vent Supply	2	FULL	I
2. Primary Plant Vent Exhaust	3	FULL	I
3. Uncontrolled Access Area Vent Supply & Exhaust	2	FULL	I

QA 43-77
REV. 0

PROCEDURE NO. DEP-INST-001 REV. 12
DATE APR 15 1985 PAGE 5 OF 52

DUCT CONSTRUCTION CLASSIFICATION SUMMARY

cont'd....

1. Reference: ORNL NSIC 65
 ERDA 76021 SMACNA 1969

BUILDING SYSTEM	DUCTWORK CONSTRUCTION LEVEL	QA PROGRAM APPLICABLE	SEISMIC CATEGORY
<u>MISCELLANEOUS AREAS</u>			
1. Main Steam & Feedwater Vent			
a. Piping Area	2	NON-QA	N/A
b. Electrical Area	2	FULL	I
2. Diesel Generator Vent	2	FULL	I
3. Turbine Building Vent	2	NON-QA	N/A
4. Office & Service Area Supply & Exhaust (Turbine Building)	2	NON-QA	N/A
5. Office & Service Area Controlled Exhaust (Turbine Building)	2	NON-QA	N/A
6. Distribution Room Ventilation Exhaust Chemical Feed and Storage Area	2	NON-QA	N/A
<u>CONTAINMENT BUILDING</u>			
1. Containment Air Recirc. & Cooling	2	FULL	I
2. Containment Preaccess Filtering	2	FULL	I
3. Containment Purge Exhaust (inside containment)	2	FULL	I
4. CRDM Ventilation	4	FULL	I
5. Neutron Detector Well Cooling System	4	FULL	I
6. Reactor Coolant Sleeve Cooling System	2	FULL	I
<u>FUEL HANDLING BUILDING</u>			
1. Supply	2	FULL	I
2. Exhaust	3	FULL	I
<u>SERVICE WATER INTAKE STRUCTURE</u>			
1. Service Water Pump Exhaust Fans	2	FULL	I
2. Fire Pump Area Exhaust Fan	2	FULL	I

QA 43-77
 REV. 0

PROCEDURE NO. DEP-1051-001 REV. 12
 DATE APR 16 1985 PAGE 6 OF 52

CONSTRUCTION LEVEL 2 RECTANGULAR DUCTWORK
 (UP TO 10" W.G. POSITIVE PRESSURE)
SUPPLY SYSTEM DUCTWORK

<u>Largest Side Of Duct</u>	<u>Sheet Metal Gauge</u>	<u>Reinforcing Angle Size</u>	<u>Longitudinal Seam Type</u>	<u>Tie Rod Spacing</u>
Up to 12"	18	None	Pittsburgh	None
12½" to 24"	18	None	Pittsburgh	None
24½" to 36"	18 (ref. note 9.)	1½" x 1½" x 3/16"	Pittsburgh	None
36½" to 48"	18 (ref. note 9.)	1½" x 1½" x 3/16"	Pittsburgh	None
48½" to 60"	16	2" x 2" x 3/16"	Pittsburgh	None
60½" to 72"	16	2" x 2" x 3/16"	Welded	1 on C.L.
72½" to 84"	16	2" x 2" x 3/16"	Welded	1 on C.L. 2 equally spaced
84½" to 96"	16	2" x 2" x 3/16"	Welded	2 equally spaced
96½" to 120"	14	2" x 2" x 3/16"	Welded	2 equally spaced

Notes:

1. Full face gasketed flanged joints.
2. Pittsburgh seams flooded with silicone sealant.
3. No cross breaking or cross beading required.
4. All tie rods are 3/8" diameter.
5. All four sides of duct shall be constructed of same gauge metal.
6. No reinforcing angles required on duct joints 24" or shorter.
7. Ductwork used strictly for outdoor air intake shall conform to this schedule.
8. Longitudinal seams in transitions may be welded in lieu of Pittsburgh lock.
9. 2" x 2" x 3/16" may be used.

QA 43-77
REV. 0

PROCEDURE NO. 100
 DATE APR 1 6 1985
 P.E. USJ-001
 PAGE 10 OF 52
 REV. 12

CONSTRUCTION LEVEL 2 RECTANGULAR DUCTWORK
 (UP TO 10" W.G. NEGATIVE PRESSURE)
RETURN OR EXHAUST SYSTEM DUCTWORK

<u>Largest Side of Duct</u>	<u>Sheet Metal Gauge</u>	<u>Reinforcing Angle Size</u>
Up to 12"	16	None
12½" to 24"	16	None
24½" to 36"	16	(ref. note 6.) 1½" x 1½" x 3/16"
36½" to 48"	14	2" x 2" x 3/16"
48½" to 60"	14	2" x 2" x 3/16"
Over 60"	12	2" x 2" x 3/16"

Notes:

1. Full face gasketed flanged joints.
2. Seal welded longitudinal seams.
3. No Tie Rods, cross breaking or cross beading permitted on negative pressure ductwork.
4. All four sides of duct shall be constructed of same gauge metal.
5. No reinforcing angles required on duct joints 24" or shorter.
6. 2" x 2" x 3/16" may be used.

QA 43-77
 REV. 0

PROCEDURE NO. DFP-TUST-001 REV. 12
 DATE APR 16 1985 PAGE 11 OF 52

CONSTRUCTION LEVEL 3 & 4 RECTANGULAR DUCTWORK
 (UP TO 12" W.G. NEGATIVE PRESSURE)
RETURN OR EXHAUST SYSTEM DUCTWORK

<u>Largest Side of Duct</u>	<u>Sheet Metal Gauge</u>	<u>Companion Angle Size</u>	<u>Reinforcing Angle Size</u>
Up to 12"	16	2" x 2" x 3/16"	None
12 1/2" to 24"	16	2" x 2" x 3/16"	None
24 1/2" to 36"	12	2" x 2" x 3/16"	* 1 1/2" x 1 1/2" x 3/16"
36 1/2" to 48"	12	2" x 2" x 3/16"	* 1 1/2" x 1 1/2" x 3/16"
48 1/2" to 60"	12	2" x 2" x 3/16"	2" x 2" x 3/16"
Over 60"	10	2" x 2" x 3/16"	2" x 2" x 3/16"

Notes:

1. Full face gasketed companion angle joints.
2. Seal welded longitudinal seams.
3. No tie rod, corss breaking or cross beading permitted on negative pressure ductwork.
4. All four sides of duct shall be constructed of same gauge metal.
5. No reinforcing angles required on duct joints 24" or shorter.
- * 6. 2" x 2" x 3/16" may be used.

CONSTRUCTION LEVEL 3 & 4 RECTANGULAR DUCTWORK
 (UP TO 12" W.G. POSITIVE PRESSURE)
SUPPLY SYSTEM DUCTWORK

<u>Largest Side of Duct</u>	<u>Sheet Metal Gauge</u>	<u>Companion Angle Size</u>	<u>Reinforcing Angle Size</u>	<u>Tie Rod Spacing</u>
Up to 12"	16	2" x 2" x 3/16"	None	None
12 1/2" to 24"	16	2" x 2" x 3/16"	None	None
24 1/2" to 36"	12	2" x 2" x 3/16"	* 1 1/2" x 1 1/2" x 3/16"	None
36 1/2" to 48"	12	2" x 2" x 3/16"	* 1 1/2" x 1 1/2" x 3/16"	None
48 1/2" to 60"	12	2" x 2" x 3/16"	2" x 2" x 3/16"	None
Over 60"	10	2" x 2" x 3/16"	2" x 2" x 3/16"	See Detail

Notes:

1. Full face gasketed companion angle joints.
2. Seal welded longitudinal seams.
3. No cross breaking or cross beading required.
4. All tie rods are 3/8" diameter.
5. All four sides of duct shall be constructed of same gauge metal.
6. No reinforcing angles required on duct joint 24" or shorter.
- * 7. 2" x 2" x 3/16" may be used.

CONSTRUCTION DATA FOR ROUND DUCTWORK


<u>Duct Diameter</u>	<u>Sheet Metal Gauge</u>	<u>Companion Angle Size</u>
8" through 18"	16	2" x 2" x 1/4"
19" through 36"	14	2" x 2" x 1/4"
37" through 48"	12	2" x 2" x 1/4"
49" and up	12	2" x 2" x 14/"

Notes:


1. Full face gasketed companion angle joints.
2. Seal welded longitudinal seams.
3. Lighter gauge material may be substituted if angle reinforcement is provided as required in "SMACNA Round Industrial Duct Construction Standards".

QA 43-77
 REV. 0


PROCEDURE NO. DEP-TIIST-001 REV. 12
 DATE APR 1 6 2005 PAGE 42 OF 52




DUCT CONSTRUCTION
"LEVEL-2" SUPPLY DUCT




DUCT CONSTRUCTION "LEVEL 2"
SUPPLY SYSTEM




DUCT CONSTRUCTION-
"LEVEL 3 & 4"
SUPPLY SYSTEM




DUCT CONSTRUCTION "LEVEL 3 & 4"
SUPPLY SYSTEM




TYPICAL "FLANGED" JOINT
DUCT CONSTRUCTION LEVEL-2



"TYPICAL PITTSBURGH LONGITUDINAL SEAM"
DUCT CONSTRUCTION LEVEL-2



"TYPICAL FLANGE DETAIL"
COMPANION ANGLE FLANGED JOINT
DUCT CONSTRUCTION LEVEL 3 & 4



"TYPICAL COMPANION ANGLE"
FLANGED JOINT
DUCT CONSTRUCTION LEVEL 3 & 4

12

Figure 1.7

COMANCHE PEAK STEAM ELECTRIC STATION
DESIGN CHANGE/DESIGN DEVIATION AUTHORIZATION

(WILL) ~~(WILL)~~ BE INCORPORATED
IN DESIGN DOCUMENTS.

AUTHORIZATION NO. 7490 Rev. 1

SAFETY RELATED: YES NO

1. DESCRIPTION OF CHANGE/ ~~XXXXXXXXXXXXXXXXXXXX~~

A. APPLICABLE SPEC/ ~~DC/ DDA-719~~ 2323-MS-85 1 5-1-76
Rev. Issue Date

THIS DOCUMENT SUPERSEDES AND VOIDS DC/DDA-719

~~B. DETAILS~~ Problem: Requirements for wall penetration are unclear.

Solution: Add the following guidelines to the Specification:

- 2.8.2.H.1) Ductwork penetrations should have a minimum length of 12".
- 2.8.2.H.2) The penetrations should have a maximum extension from the wall of 6".
- 2.8.2.H.3) Penetrations shall be flanged to connect to adjoining ductwork.

2. SUPPORTING DOCUMENTATION
DALM-214



JOB NO. 35-1195

RECEIVED
DEC 09 1977

RECEIVED

3. SIGNATURES ^{G.L.M.} G.L.M./akh 12-8-77

- A. APPROVED BY: Date 12-8-77
- B. APPROVED BY: Date 12/8/77
- C. APPROVED BY: Date 12-8-77



STANDARD DISTRIBUTION


- TUSI Dallas (1)
- TUSI Field (1)
- TUGCO Site QA (1)
- G&H New York (1)
- G&H Dallas (1)
- B&R Field (1)
- B&R Houston (1)
- B&R Site QA (1)
- B&R Houston QA (1)

5. DOCUMENT CONTROL


- ___ FOR RECORD ONLY
- ___ FOR CLARIFICATION ONLY
- ___ NEED TO KNOW
- ALL (AFFECTED) DOCUMENT HOLDERS
- ___ PER ATTACHED LIST

NOTE:

1/2" RETURN INDICATED APPLIES TO 16 GAUGE AND LIGHTER METAL. METAL 14 GAUGE AND HEAVIER SHALL HAVE CORNER JOINT



"TYPICAL LONGITUDINAL WELDED SEAM"
DUCT CONSTRUCTION LEVEL-2




NOTE:
 1/2" RETURN INDICATED APPLIES
 TO 16 GAUGE AND LIGHTER METAL.
 METAL 14 GAUGE & HEAVIER SHALL
 HAVE CORNER JOINT.

TYPICAL "LONGITUDINAL" WELDED SEAM
DUCT CONSTRUCTION "LEVEL 3 & 4"




BAHNSON

WELD INSERT EQUAL TO
DOUBLE FOLD OF DUCT METAL.
GRIND FLANGE FACE FLUSH &
COVER WITH TOUCH UP PAINT.




"CORNER DETAIL"
FLANGED DUCT
DUCT CONSTRUCTION -
"LEVEL-2"


DUCTWORK FABRICATION PROCEDURE




TYPICAL "COMPANION" ANGLE
FLANGED JOINT - CORNER DETAIL
DUCT CONSTRUCTION "LEVEL 3 & 4"



TYPICAL INTERMEDIATE REINFORCING ANGLE
WELDED TO DUCT
DUCT CONSTRUCTION "LEVEL 2"




TYPICAL REINFORCING ANGLE CORNER CONNECTION
DUCT CONSTRUCTION "LEVEL 2"





TYPICAL INTERMEDIATE REINFORCING ANGLE WELDED TO DUCT

DUCT CONSTRUCTION "LEVEL 3 & 4"



TYPICAL REINFORCING ANGLE CORNER CONNECTION
DUCT CONSTRUCTION "LEVEL 3 & 4"




SPLITTERS IN TRANSITION WILL BE WELDED 1" ON 6" MAX., STAGGERED WELD SIZE 3/32"


* WELD SIZE TO BE THICKNESS OF THINNER MEMBER

ALTERNATE CONSTRUCTION

TYPICAL-TURN VANE DETAIL




METAL GAUGE AND TYPE OF VANES WILL BE SAME AS JOINT IN WHICH INST.




TYPICAL-SHORT RADIUS VANED ELBOW
 (WHEN R RADIUS IS LESS THAN $1/2 \times$ DUCT WIDTH)

TYPICAL "SPLICED JOINT"
LEVEL 2 - RECTANGULAR & ROUND DUCT CONST.



SECTION A-A

STRAP TO BE SAME GA. AS EXISTING METAL & MAY BE PLACED ON INSIDE OR OUTSIDE




NOTE 1

WELD MAY BE OMITTED IF INACCESSIBLE & WELD ON OTHER SIDE EXISTS.


NOTE 2

EXISTING FLANGES MAY BE LEFT IN PLACE WHERE SEAL WELD OR STRAP IS PLACED ON THE INSIDE OF DUCT.

TYPICAL "SPLICED JOINT"
LEVEL 3 & 4 - RECTANGULAR & ROUND DUCT CONST.




SECTION A-A




SECTION B-B

NOTE 1
WELD MAY BE OMITTED IF INACCESSIBLE & WELD ON OTHER SIDE EXISTS.

NOTE 2
EXISTING FLANGES MAY BE LEFT IN PLACE WHERE SEAL WELD OR STRAP IS PLACED ON THE INSIDE OF DUCT.




"TYPICAL FLANGE DETAIL"
COMPANION ANGLE FLANGED JOINT
DUCT CONSTRUCTION LEVEL 3 & 4




"TYPICAL COMPANION ANGLE"
FLANGED JOINT
DUCT CONSTRUCTION LEVEL 3 & 4

12









TYPICAL "TIE ROD" INSTALLATION
DUCT CONSTRUCTION "LEVEL 3 & 4"
SUPPLY SYSTEM DUCT



TYPICAL "COMPANION ANGLE"
FLANGED JOINT
"ROUND DUCT CONSTRUCTION"


* PREFERRED WELD — WELD MAY BE CONTINUOUS




1/4" FULLFACE NEOPRENE GASKET 1/4"

TYPICAL ROUND FLANGE DETAILS


FILLET WELD PROFILES




Acceptable Convexity



SPLITTER DAMPER HINGES
MOUNT WITH 5/16" Ø NUTS &
BOLTS.




"PLAN VIEW"
WITH TOP OF DUCT REMOVED



"SIDE ELEVATION"


SPLITTER DAMPER (TYP. INSTALLATION)

QA 43-77
REV. 0




NOTES:

1. EXTRACTOR TO BE ADJUSTABLE AS REQUIRED FOR PROPER AIR FLOW.
2. SIMILAR ARRANGEMENT USED WHERE REQUIRED ON BRANCH DUCT.



SEISMIC VOLUME EXTRACTOR
SEISMIC CATEGORY I DUCTWORK

PROCEDURE NO. DEP-TJST-008 REV. 29
 DATE AUG 08 1971 PAGE 7 OF




TYPICAL INSTALLATION OF GRILLS & REGISTERS
(WITHOUT EXTRACTORS)


QA 43-77
REV. 0

PROCEDURE NO. DEP-TUST-008 REV. 7
DATE 09 08 1991 PAGE 4 OF 29


NOTE: OPERATOR/QUADRANT SHALL BE FIELD LOCATED ON ACCESSIBLE SIDE OF DUCT.




MANUAL VOLUME DAMPER (TYPICAL INSTALLATION)



TYPICAL ACCESS DOOR ARRANGEMENT




SECTION - A
TYPICAL ACCESS DOOR ARRANGEMENT




"DUCT ACCESS PANEL DETAILS"

ROUND DUCT
"ACCESS PANEL ASSEMBLY"




NOTE:
 A = LENGTH OF DUCT JOINT
 PER TAKE-OFF SHEETS
 B = DUCT ϕ + 4"
 COLLAR TO BE CONTINUOUSLY
 WELDED @ DUCT



"CROSS
SECTION

QA 43-77
REV. 0


PROCEDURE NO. DEP-TUSI-008 REV. 29
DATE AUG 08 1975 PAGE 16 OF




**ROUND DUCT
BOLTED ACCESS PANEL ASSEMBLY**

- NOTE:
1. DIM. $\pm 1/4$ " UNLESS NOTED.
 2. REF. DEP-TUSI-001 FOR CORNER TAB WELDS ONLY.

USE $\frac{5}{16}$ " x $\frac{1}{4}$ " BOLTS (MAX)
 $\frac{1}{2}$ " x $\frac{3}{4}$ " BOLTS (MIN.)
 W/ NUTS & WASHERS




VENTLOCK INSTRUMENT TEST HOLE





MOUNTING FOR RADIATION MONITOR

TYPICAL MOUNTING BRACKET FOR TEMPERATURE ELEMENT AND INSTRUMENT CONNECTIONS




TYPICAL MOUNTING BRACKET FOR MISCELLANEOUS TEST CONNECTIONS






6" & LARGER PIPE TO DUCT CONNECTION




5" & SMALLER PIPE TO DUCT CONNECTION




CHLORINE LEAK DETECTOR SENSOR
TYPICAL INSTALLATION

2" x 2" x 1/4" STIFFNER
HORIZONTAL OR
VERTICAL




SMOKE DETECTOR
TYPICAL INSTALLATION




CHLORINE LEAK DETECTOR SENSOR
TYPICAL INSTALLATION

2" x 2" x 1/4" STIFFNER
HORIZONTAL OR
VERTICAL



SMOKE DETECTOR
TYPICAL INSTALLATION



MOUNTING BRACKET DETAIL
FOR THERMOSTAT SENSING BULB AND INSTRUMENT PROBE

SPEC, HAH, TUGCO, A, (4)

FIGURE 1.

COMANCHE PEAK STEAM ELECTRIC STATION
DESIGN CHANGE AUTHORIZATION

(WILL) ~~(WILL NOT)~~ BE INCORPORATED IN DESIGN DOCUMENTS

DCA NO. 12,636 R. 1

1. SAFETY RELATED DOCUMENT: XX YES NO

2. ORIGINATOR: CPPE XX ORIGINAL DESIGNER

3. DESCRIPTION:

A. APPLICABLE SPEC/DWG DOCUMENT 2323-MS-85

B. DETAILS THIS DCA VOIDS & SUPERSEDES DCA 12,636 R. 1
Problem: Duct mounted instrumentation as currently listed cannot

be removed without entering the duct.

Solution: Mount the instrumentation as shown on pages 2 & 3.

Justification: To permit instrument calibration without entering
potentially radioactive air flow.

▲ Added page 3. Revised probe mtg. detail on page 2. Added instrument
no's.

4. SUPPORTING DOCUMENTATION:

TDCR #852

5. APPROVAL SIGNATURES: ^{R+} LT:ch

4-27-82

A. ORIGINATOR: [Signature]

DATE 4-28-82

B. DESIGN REPRESENTATIVE: [Signature]

DATE 4/28/82

6. VENDOR TRANSMITTAL REQUIRED: YES NO XX



7. STANDARD DISTRIBUTION:

- ARMS (Original) (1)
- Quality Engineering (1)
- TS for Orig. Design. (1)
- Westinghouse-Site (1)

JOB NO. 35-1195

RECEIVED
APR 30 1982
RECEIVED

DCA FORM 11-80



TEXAS UTILITIES SERVICES INC.
COMANCHE PEAK S.E.S.

Agent For

DALLAS POWER & LIGHT COMPANY
TEXAS ELECTRIC SERVICE COMPANY
TEXAS POWER & LIGHT COMPANY

DCA - 12636 R1
Pg 2

Filing Code _____

Sheet No. 1 of 1

G & H Job No. _____

Rel. Dwg./Spec. No. MS-85 Rev 1

Date 2-11-82


Calc By L.T.

Chk'd/Apprd. By _____

Subject DUST MTD. INSTRUMENTS

PENN MODEL NO 1
TYPE A72AE

OUTSIDE



JYP MTG FOR
INSTR:

- 1-TIS-5573A
- 1-TIS-5976A
- 2-TIS-5573A
- 2-TIS-5976A
- X-TIS-6180A
- X-TIS-6187A
- X-TIS-6194A
- X-TIS-6201A
- X-TIS-6208A
- X-TIS-6215A
- X-TIS-6222A
- X-TIS-6229A
- X-TIS-6249

FORM DHE-5

TEXAS UTILITIES SERVICES INC.
COMANCHE PEAK S.E.S.

DCA-12636 A.1

Agent For

PG. 3

DALLAS POWER & LIGHT COMPANY
TEXAS ELECTRIC SERVICE COMPANY
TEXAS POWER & LIGHT COMPANY

Filing Code N/A

Date 4-27-82

Calc By L.T.


Sheet No. 1 of 1

Chk'd/Apprd. By N/A

G & H Job No. _____

Subject DUST MFG. INSTRUMENT


Rel. Dwg./Spec. No. MS-55 Rev 1




TYPICAL MTG. FOR INSTR:

- 1-TIS-5573
- 1-TIS-5607
- 1-TIS-5616
- 1-TIS-5976
- 2-TIS-5573
- 2-TIS-5607
- 2-TIS-5616
- 2-TIS-5976
- X-TIS-5931
- X-TIS-6180
- X-TIS-6187
- X-TIS-6194
- X-TIS-6201
- X-TIS-6208
- X-TIS-6215
- X-TIS-6222
- X-TIS-6229
- X-TIS-6249 A
- X-TIS-5931 A


BARBER-COLEMAN
Model TC-292-3C




RECTANGULAR FLEX
TYPICAL INSTALLATION




CROSS SECTION
RECTANGULAR FLEX CONNECTION DETAILS



STEP 1




STEP 2



STEP 3


"CORNER MAKE-UP"

SCALE = NONE




FLEX CONNECTION INSTALLATION
TYPICAL ARRANGEMENT
RECTANGULAR DUCT

ACCEPTABLE MISALIGNMENT TOLERANCES
 1/2" AT 10" FULL ELONGATION
 1" AT 9" NEUTRAL POSITION
 1 1/2" AT 8" PARTIAL COMPRESSION
 2" AT 7" FULL COMPRESSION



SECTION A-A



FLEX CONNECTION INSTALLATION
TYP. ARRANGEMENT
ROUND DUCT


ACCEPTABLE MISALIGNMENT TOLERANCES

- 1/2" AT 10" FULL ELONGATION
- 1" AT 9" NEUTRAL POSITION
- 1 1/2" AT 8" PARTIAL COMPRESSION
- 2" AT 7" FULL COMPRESSION




SECTION AA

USE $\frac{5}{16}$ " x $\frac{1}{4}$ " BOLTS (MAX.)
 $\frac{1}{4}$ " x $\frac{3}{4}$ " BOLTS (MIN.)
W/ NUTS & WASHERS



VENTLOCK INSTRUMENT TEST HOLE



MOUNTING FOR RADIATION MONITOR

INSPECTION TOOL AND CODES

<u>CODE</u>	<u>TOOL</u>
AF	Angle Finder
BL	Bubble Level
BS	Boroscope
BW	1/32", 1/16", 3/32", 1/8" Wire
CG	Contour Gauge
DF	Dry Film Thickness Gage
FG	Feeler Gages
FL	Flashlight
FM	Fibre Metal Fillet Gages
GG	GAL Fillet Gages
HL	Hi-Low Gage
MG	Magnifying Glass
MI	Micrometers
MM	Mirror
MN	Magnet
PB	Plum Bob
PR	Protractor
SC	Slide Caliper
SR	6" Rule
ST	Steel Tape Measure
TG	Taper Gage
TW	Torque Wrench
UD	Undercut Gage (Dial)
UP	Undercut Gage (Pit)
VC	Vernier Caliper
VT	Visual Inspection

INSPECTION TOOLS USED

<u>ATTRIBUTE</u>	<u>TOOL CODE</u>	<u>SERIAL NO/CALIBRATION DUE DATE</u>
1. <u>Sheet Metal Duct</u> a. Elevation b. Location Perpendicular to Air Flow c. Area d. Length e. Duct Gage f. Reinforcing Angle Size g. Reinforcing Angle Spacing h. Companion Angle Size i. Longitudinal Seam j. Tie Rod Spacing k. Tie Rod Diameter l. Gasket m. Nuts and Bolts		
2. <u>Wall Penetration</u> a. Minimum Length b. Maximum Extension c. Gasket d. Nuts and Bolts		
3. <u>Welding</u> a. Location b. Weld Size c. Length d. Fusion e. Craters f. Weld Profiles g. Undercut h. Porosity i. Overlap j. Surface Slag k. Cracks l. Touch-up Galvanizing		
4. <u>Splitter Damper</u> a. Installation b. Nuts and Bolts c. Locked in Place		

INSPECTION TOOLS USED

<u>ATTRIBUTE</u>	<u>TOOL CODE</u>	<u>SERIAL NO/CALIBRATION DUE DATE</u>
5. <u>Extractor</u> a. Installation b. Angle Size c. Bolts		
6. <u>Turning Vane</u> a. Installation b. Geometry c. Gage		
7. <u>Grille, register and Diffuser</u> a. Location b. Installation c. Gaskets d. Nuts and Bolts		
8. <u>Volume Damper</u> a. Installation b. Gaskets c. Nuts and Bolts d. Locked in Place		
9. <u>Access Door</u> a. Installation b. Gasket c. Nuts and Bolts		
10. <u>Instrument Test Holes</u> a. Caps b. Gasket c. Bolts		
11. <u>Tubing Connection</u> a. Installation b. Nuts and bolts		
12. <u>Pipe Connection</u> a. Pipe Size b. Pipe Length		

INSPECTION TOOLS USED

<u>ATTRIBUTE</u>	<u>TOOL CODE</u>	<u>SERIAL NO/CALIBRATION DUE DATE</u>
13. <u>Instrument Mounting</u> a. Installation b. Mounting Bracket c. Nuts, Bolts and Washers		
14. <u>Plenums</u> a. Location b. Sheet Metal Gage c. Reinforcing Angle Size d. Reinforcing Angle Spacing e. Gasket f. Nuts and Bolts		
15. <u>Flexible Connection</u> a. Location b. Companion Angle Size c. Nuts, Bolts and Washers d. Misalignment		
16. <u>Concrete Expansion Anchors</u> a. Size and Number b. Embedment c. Bolt Spacing d. Angularity e. Concrete Damage f. Nut Engagement and Bearing		

INSPECTOR _____