

EVALUATION RESEARCH CORPORATION

CONTROLLED COPY

CONTROL NO. OE-001

COMANCHE PEAK RESPONSE TEAM

QUALITY INSTRUCTION FOR ISSUE-SPECIFIC ACTION PLAN VII.c

CHANGE NOTICE: 001

INSTRUCTION NO: QI-014

REVISION NO: 1

ISSUE DATE: 03/12/86

REINSPECTION OF CABLES/I-E-CABL

Prepared by: Frank R. Perrino Date: 3/10/86

Approved by: Albert A. Patters. Date: 3/12/86
Issue Coordinator

Approved by: E.C. Baiada Date: 3/12/86
On-Site QA Representative

Approved by: J. L. Havel Date: 3/12/86
QA/QC Review Team Leader

8607170228 860711
PDR ADOCK 05000445
A PDR

1. Change Paragraph 5.6 Note 4 to read as follows:
 4. Where raceway identification cannot be visually verified, it may be verified by crosschecking the cable and raceway schedule with the raceway drawings. The use of drawings and drawing numbers shall be noted on the Checklist.
2. Change Paragraph 5.111 to read as follows:
 1. Where cables terminate on terminal blocks in junction boxes (terminal boxes) that the following criteria is met:

Weidmuller SAK10 shall be utilized when terminating two No. 10 AWG cables. Weidmuller SAK 6N shall be utilized when terminating one cable (No. 10 AWG thru No. 16 AWG) and when terminating two cables (No. 12 AWG thru No. 16 AWG). In any case, the maximum conductor size terminated on Weidmuller terminal blocks shall be No. 10 AWG.