## EVALUATION RESEARCH CORPORATION

CONTROLLED COPY CONTROL NO. DE-COL

### COMANCHE PEAK RESPONSE TEAM

QUALITY INSPECTION FOR ISSUE-SPECIFIC ACTION PLAN VII.c

CHANGE NOTICE: 002

INSTRUCTION NO.: QI-023

REVISION NO.: 2

ISSUE DATE: 05/13/86

# REINSPECTION OF HVAC EQUIPMENT INSTALLATION

The QI identified above is hereby changed as shown on the attached page of this notice.

Prepared by:	Keny Bowler	Date:	5-13-86
Approved by:	Issue Coordinator	Date: _	5/13/86
Approved by:	Sc. Barada On-Site QA Representative	Date: _	5/13/86
Approved by:	QA/Or Review Team Leader  8607170258 860711 PDR ADDCK 05000445	Date: _	5/13/86

PDR

## ITEM

### CHANGE TO QUALITY INSTRUCTION

1.

Page 4 Item 4.b.1

Change:

Verify that the gasket is visible between flanges around the entire

perimeter

TO:

Verify that a gasket and/or silicone sealant is visible between flanges around the entire

perimeter.