

LICENSEE: Duquesne Light Company February 4, 1999

FACILITY: Beaver Valley Power Station, Units 1 and 2

SUBJECT: SUMMARY OF MEETING WITH DUQUESNE LIGHT COMPANY (DLC) STAFF
CONCERNING CURRENT AND ANTICIPATED LICENSING ISSUES FOR
BEAVER VALLEY POWER STATION, UNITS 1 AND 2 (BVPS-1 and BVPS)

On January 19, 1999, Nuclear Regulatory Commission (NRC) staff met with representatives of DLC to have a general discussion regarding current and anticipated licensing issues for BVPS-1 and BVPS-2. The licensee had requested this meeting. Enclosure 1 is a list of meeting attendees. Enclosure 2 is a copy of the handout material.

The meeting attendees initially discussed the licensing actions currently under NRC review for which DLC would prefer to have reviews completed first. This list is included at the front of Enclosure 2. The licensee noted that their priorities for these were established based on need for an upcoming outage, need for resolving operator workarounds, or need for closing out voluntarily instituted administrative controls. The NRC staff noted that a timely response by DLC to any requests for additional information will be required in order for the technical staff to complete the reviews in a time frame which supports DLC's schedule.

The open licensing issues for BVPS-1, BVPS-2 and DLC's plans for near-term license amendment request (LAR) submittals were subsequently discussed. NRC staff noted that open licensing actions which are more than 2 years old are receiving heightened attention within the NRC to ensure these reviews are completed this year. This primarily affects BVPS-2 since the open BVPS-1 licensing actions are all less than 2 years old. Regarding DLC's plans for near-term LAR submittals, DLC noted that all LARs for BVPS-1 which resulted from the multi-discipline analysis team's (MDAT) reviews in 1998 have been submitted to the NRC. There are 2 LARs for BVPS-2, which were identified during the MDAT reviews, that will be submitted to the NRC in March 1999. DLC also noted that they will be submitting 2 or 3 Quality Assurance Program Changes, which affect both units, for NRC review.

Original signed by:

Daniel S. Collins, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

Enclosures: 1. List of Attendees
2. Licensee Handouts

cc w/encls: See next page

DISTRIBUTION:

See next page

000067

NRC FILE CENTER COPY

DOCUMENT NAME: G:\BEAVER\BVMTGMIN.WPD

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDI-1	E	LA:PDI-1	D:PDI-1				
NAME	DCollins/rsi		MO'Brien	SBajwa				
DATE	02/4/99		02/4/99	02/11/99				

9902100132 990204
PDR ADOCK 05000334
P PDR

Official Record Copy



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

February 4, 1999

LICENSEE: Duquesne Light Company

FACILITY: Beaver Valley Power Station, Units 1 and 2

SUBJECT: SUMMARY OF MEETING WITH DUQUESNE LIGHT COMPANY (DLC) STAFF
CONCERNING CURRENT AND ANTICIPATED LICENSING ISSUES FOR
BEAVER VALLEY POWER STATION, UNITS 1 AND 2 (BVPS-1 and BVPS)

On January 19, 1999, Nuclear Regulatory Commission (NRC) staff met with representatives of DLC to have a general discussion regarding current and anticipated licensing issues for BVPS-1 and BVPS-2. The licensee had requested this meeting. Enclosure 1 is a list of meeting attendees. Enclosure 2 is a copy of the handout material.

The meeting attendees initially discussed the licensing actions currently under NRC review for which DLC would prefer to have reviews completed first. This list is included at the front of Enclosure 2. The licensee noted that their priorities for these were established based on need for an upcoming outage, need for resolving operator workarounds, or need for closing out voluntarily instituted administrative controls. The NRC staff noted that a timely response by DLC to any requests for additional information will be required in order for the technical staff to complete the reviews in a time frame which supports DLC's schedule.

The open licensing issues for BVPS-1, BVPS-2 and DLC's plans for near-term license amendment request (LAR) submittals were subsequently discussed. NRC staff noted that open licensing actions which are more than 2 years old are receiving heightened attention within the NRC to ensure these reviews are completed this year. This primarily affects BVPS-2 since the open BVPS-1 licensing actions are all less than 2 years old. Regarding DLC's plans for near-term LAR submittals, DLC noted that all LARs for BVPS-1 which resulted from the multi-discipline analysis team's (MDAT) reviews in 1998 have been submitted to the NRC. There are 2 LARs for BVPS-2, which were identified during the MDAT reviews, that will be submitted to the NRC in March 1999. DLC also noted that they will be submitting 2 or 3 Quality Assurance Program Changes, which affect both units, for NRC review.

A handwritten signature in dark ink, appearing to read "Daniel S. Collins", is positioned above the typed name.

Daniel S. Collins, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

Enclosures: 1. List of Attendees
2. Licensee Handouts

cc w/encls: See next page

LICENSEE: Duquesne Light Company February 4, 1999

FACILITY: Beaver Valley Power Station, Units 1 and 2

SUBJECT: SUMMARY OF MEETING WITH DUQUESNE LIGHT COMPANY (DLC) STAFF
CONCERNING CURRENT AND ANTICIPATED LICENSING ISSUES FOR
BEAVER VALLEY POWER STATION, UNITS 1 AND 2 (BVPS-1 and BVPS-2)

On January 19, 1999, Nuclear Regulatory Commission (NRC) staff met with representatives of DLC to have a general discussion regarding current and anticipated licensing issues for BVPS-1 and BVPS-2. The licensee had requested this meeting. Enclosure 1 is a list of meeting attendees. Enclosure 2 is a copy of the handout material.

The meeting attendees initially discussed the licensing actions currently under NRC review for which DLC would prefer to have reviews completed first. This list is included at the front of Enclosure 2. The licensee noted that their priorities for these were established based on need for an upcoming outage, need for resolving operator workarounds, or need for closing out voluntarily instituted administrative controls. The NRC staff noted that a timely response by DLC to any requests for additional information will be required in order for the technical staff to complete the reviews in a time frame which supports DLC's schedule.

The open licensing issues for BVPS-1, BVPS-2 and DLC's plans for near-term license amendment request (LAR) submittals were subsequently discussed. NRC staff noted that open licensing actions which are more than 2 years old are receiving heightened attention within the NRC to ensure these reviews are completed this year. This primarily affects BVPS-2 since the open BVPS-1 licensing actions are all less than 2 years old. Regarding DLC's plans for near-term LAR submittals, DLC noted that all LARs for BVPS-1 which resulted from the multi-discipline analysis team's (MDAT) reviews in 1998 have been submitted to the NRC. There are 2 LARs for BVPS-2, which were identified during the MDAT reviews, that will be submitted to the NRC in March 1999. DLC also noted that they will be submitting 2 or 3 Quality Assurance Program Changes, which affect both units, for NRC review.

Original signed by:

Daniel S. Collins, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

Enclosures: 1. List of Attendees
2. Licensee Handouts

cc w/encls: See next page

DISTRIBUTION:
See next page

DOCUMENT NAME: G:\BEAVER\BVMTGMIN.WPD

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PD1-1	E	LA:PD1-1	D:PD1-1				
NAME	DCollins/rsd		MO'Brien	SBajwa				
DATE	02/4/99		02/4/99	02/4/99				

Official Record Copy

Meeting Summary Distribution

E-Mail (Enclosure 1)

S. Collins/R. Zimmerman
B. Boger
J. Zwolinski
S. Bajwa
S. Little
G. Shear
P. Eselgroth, RGN I
D. Screnci

Hard Copy (all enclosures)

Docket File
PUBLIC
PDI-1 R/F
D. Collins
OGC
ACRS

cc: Licensee & Service List (with all enclosures)

Meeting Summary Distribution

E-Mail (Enclosure 1)

S. Collins/R. Zimmerman
B. Boger
J. Zwolinski
S. Bajwa
S. Little
G. Shear
P. Eselgroth, RGN I
D. Screnci

Hard Copy (all enclosures)

Docket File
PUBLIC
PDI-1 R/F
D. Collins
OGC
ACRS

cc: Licensee & Service List (with all enclosures)

Duquesne Light Company

Beaver Valley Power Station, Units 1 & 2

cc:

Jay E. Silberg, Esquire
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW.
Washington, DC 20037

Director-Safety and Licensing
Department (BV-A)
Duquesne Light Company
Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077

Commissioner Roy M. Smith
West Virginia Department of Labor
Building 3, Room 319
Capitol Complex
Charleston, WV 25305

Director, Utilities Department
Public Utilities Commission
180 East Broad Street
Columbus, OH 43266-0573

Director, Pennsylvania Emergency
Management Agency
Post Office Box 3321
Harrisburg, PA 17105-3321

Ohio EPA-DERR
ATTN: Zack A. Clayton
Post Office Box 1049
Columbus, OH 43266-0149

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Duquesne Light Company
Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077
ATTN: Kevin L. Ostrowski, Division Vice
President, Nuclear Operations Group
and Plant Manager (BV-SOSB-7)

Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
ATTN: Michael P. Murphy
Post Office Box 2063
Harrisburg, PA 17120

Mayor of the Borough of
Shippingport
Post Office Box 3
Shippingport, PA 15077

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 298
Shippingport, PA 15077

Duquesne Light Company
Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077
ATTN: S. C. Jain, Senior Vice President
Nuclear Services (BV-A)

Mr. J. E. Cross
President - Generation Group
Duquesne Light Company
Post Office Box 4
Shippingport, PA 15077

Mr. J. A. Hultz, Manager
Projects & Support Services
First Energy
76 South Main Street
Akron, OH 44308

LIST OF ATTENDEES
DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION, UNITS 1 AND 2
JANUARY 19, 1999

NAME

D. Collins
M. Ackerman
L. Berry
R. Hruby

ORGANIZATION

NRC/NRR
DLC
DLC
DLC

BVPS TAC List by Priority No.
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA4149	BV-1 - Extend SG Tube inspection Surveillance Interval from 6/26/99 to 13th Refueling Outage	11/11/98	NRC	K. Pointer		1	LAR 1A-261 Requested amendment by 12/31/98.
MA0746	BV-2 - USQ for Increased Control Room Operator Radiological Doses	01/29/98	NRC	R. Ireland		2	LAR 2A-120; submitted additional information by letter L-98-195 dated 11/9/98. BCO 2-98-001 due restart 2R7.
MA2324	BV-1 - Revise Reactor Trip Setpoint for Operation with Inoperable Main Steam Safety Valves	07/09/98	NRC	Pointer/Berry		3	LAR 1A-214 BCO 1-98-008 expires 1R13.
MA2325	BV-2 - Revise Reactor Trip Setpoint for Operation with Inoperable Main Steam Safety Valves	07/09/98	NRC	Pointer/Berry		3	LAR 2A-81 BCO 2-98-007 expires 4/28/99.
MA0622	BV-1 - Review of UFSAR Change for Increase in Control Room Operator Dose	01/17/98	NRC	F. Lipchick		4	LAR 1A-250; submitted additional information on 11/9/98 by letter L-98-196. BCO 1-98-001 expires 7/17/99.
MA4440	BV-1 - TS & Bases changes to remove rod pos., deviation, insertion limit, & axial flux diff. monitors	12/24/98	NRC	R. Ireland		5	LAR 1A-262 Operations requests amendment by 7/21/99

BVPS TAC List by Priority No. (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA4441	BV-2 - TS & Bases changes to remove rod pos. deviation, insertion limit, & axial flux diff. monitors.	12/24/98	NRC	R. Ireland		5	LAR 2A-135 Operations requests amendment by 7/21/99.
MA3839	BV-1 - Revise TS to Modify Reporting Requirements and Make Administrative Changes	10/15/98	NRC	R. Ireland		6	LAR 1A-246 Letter L-98-250 dated 12/14/98 forwarded typed pages. CARF 971578-02 requires amendment by 12/31/99.
MA3840	BV-2 - Revise TS to Modify Reporting Requirements and Make Administrative Changes	10/15/98	NRC	R. Ireland		6	LAR 2A-116 Typed pages forwarded by L-98-250 dated 12/14/98. CARF 971578-02 requires amendment by 12/31/99.
MA3837	BV-1 - Revise TS Bases to Provide Tolerances for RPS Time Constants	10/15/98	NRC	L. Berry		7	LAR 1A-260; letter (L-98-204) dated 10/23/98 forwarded typed pages NRC reissuing pages (Not on current TAC list)
MA3838	BV-2 - Revise TS Bases to Provide Tolerances for RPS Time Constants	10/15/98	NRC	L. Berry		7	LAR 2A-133; L-98-204 dated 10/23/98 forward typed pages NRC to reissue pages (Not on current TAC list)

BVPS TAC List by Priority No. (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA0333	BV-2 - 2nd Ten Year ISI Plan with ten ISI Relief Requests	12/09/97	NRC	F. Lipchick		8	(L-97-069); RAI on 6/1/98; Reply to RAI on 7/29/98 by letter (L-98-163)
MA4438	BV-1 - TS 3/4.8.1 "AC Sources" changes for EDG fuel oil vol., load rejection, and frequency rqmts.	12/24/98	NRC	K. Pointer		9	LAR 1A-258 BCO 1-98-010 and BCO 1-98-011 expire 1/31/2000
MA4439	BV-2 - TS 3/4.8.1 "AC Sources" changes for EDG fuel oil vol., load rejection, and frequency rqmts.	12/24/98	NRC	K. Pointer		9	LAR 2A-129 BCO 2-98-009 and BCO 2-98-010 expire 2-28-2000. BCO 2-98-012 expires 3/12/2000.
M98137	BV-2 - TS 3.4.5 to Allow Steam Generator Tube Sleeving Use CE Process	03/10/97	NRC	R. Ireland		10	LAR 2A-111 RAI response by letter L-97-023 dated 9/17/97. May request DLC to revise RAI response. Engineering would like amendment in Spring 2000.

BVPS Unit 1 TAC List
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
M83590	BV-1 - IPEEE for External Events (GL 88-20) Supplement 4	06/30/95	NRC	J. Maracek		N/A	RAI response to NRC by letter L-98-073 dated 4/19/98
M93429	BV-1 - GL 95-07 - Pressure Locking and Thermal Binding of Safety-related Power-operated Gate Valves	10/16/95	NRC	J. Maracek		N/A	180 Day Response provided by letter dated 2/13/96
M96777	BV-1 - Assurance of Equipment Operability and Containment Integrity, GL 96-06	10/29/96	DLC	R. Fedin	1/31/99	N/A	RAI response by letter L-98-129 dated 6/30/98 Letter to NRC to correct statement in L-98-129
M97015	BV-1 - GL 96-05 MOV Capability Periodic Verification	11/18/96	NRC	J. Maracek		N/A	Updated response provided by letter L-98-072 dated 4/13/98
M98545	BV-1 - Degradation of CRD Mech. Nozzles & Other Vessel Closure (GL 97-01)	04/30/97	NRC	B. Sepelak		N/A	Original response provided by letter dated 7/30/97. Response to RAI was due by 11/25/98, requested extension to 1/15/99. RAI submitted by letter L-99-001 dated 1/7/99.

BVPS Unit 1 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
M99959	BV-1 - Assur. of Suff. NPSH for ECCS & Containment Heat Removal Pump	11/06/97	NRC	J. Maracek		N/A	(GL 97-04); Response provided to NRC on 1/6/98 (ND3NSM:8025) Meeting with NRC 1/19/99
MA0525	BV-1 - RAI on Reactor Vessel Integrity (follow-up to MPA L201G)	07/09/98	NRC	R. Ireland		N/A	Submitted by letter L-98-133
MA0622	BV-1 - Review of UFSAR Change for Increase in Control Room Operator Dose	01/17/98	NRC	F. Lipchick		4	LAR 1A-250; submitted additional information on 11/9/98 by letter L-98-196. BCO 1-98-001 expires 7/17/99.
MA0895	BV-1 - Degradation of Steam Generator Internals (GL 97-06)	03/30/98	NRC	R. Ireland		N/A	Response provided by letter L-98-009
MA1665	BV-1 - Part Length CRDM Housing Issue	04/28/98	NRC	R. Fedin		N/A	Response provided by letter (L-98-084)
MA1806	BV-1 - Year 2000 Readiness of Computer Systems at Nuclear Power Plants (GL 98-01)	08/06/98	DLC	J. Maracek	7/1/99	N/A	Follow-up response due to NRC by 7/1/99

BVPS Unit 1 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA2324	BV-1 - Revise Reactor Trip Setpoint for Operation with Inoperable Main Steam Safety Vaives	07/09/98	NRC	Pointer/Berry		3	LAR 1A-214 BCO 1-98-008 expires 1R13.
MA3839	BV-1 - Revise TS to Modify Reporting Requirements and Make Administrative Changes	10/15/98	NRC	R. Ireland		6	LAR 1A-246 Letter L-98-250 dated 12/14/98 forwarded typed pages. CARF 971578-02 requires amendment by 12/31/99.
MA4149	BV-1 - Extend SG Tube inspection Surveillance Interval from 6/26/99 to 13th Refueling Outage	11/11/98	NRC	K. Pointer		1	LAR 1A-261 Requested amendment by 12/31/98.
MA4376	BV-1 - QA Program change; conditional release of material pending documentation receipt	12/8/98	NRC	G. Beatty		N/A	Submitted by letter L-98-221 dated 12/8/98. 60 day response required by NRC.
MA4438	BV-1 - TS 3/4.8.1 "AC Sources" changes for EDG fuel oil vol., load rejection, and frequency rqmts.	12/24/98	NRC	K. Pointer		9	LAR 1A-258 BCO 1-98-010 and BCO 1-98-011 expire 1/31/2000

BVPS Unit 1 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA4440	BV-1 - TS & Bases changes to remove rod pos., deviation, insertion limit, & axial flux diff. monitors	12/24/98	NRC	R. Ireland		5	LAR 1A-262 Operations requests amendment by 7/21/99
	BV-1 - QA Program description change (Limit QS review)	12/24/98	NRC	G. Beatty		N/A	Submitted by letter L-98-224 dated 12/24/98. 60 day response required by NRC. (Not on current TAC list)
MA3837	BV-1 - Revise TS Bases to Provide Tolerances for RPS Time Constants	10/15/98	NRC	L. Berry		7	LAR 1A-260; letter (L-98-204) dated 10/23/98 forwarded typed pages NRC reissuing pages (Not on current TAC list)
M72264	BV-1 - Licensee Performance Evaluation		NRC			N/A	PM Activity
M72383	BV-1 - Headquarters Focal Point for Information & Communication		NRC			N/A	PM Activity
M72503	BV-1 - SALP Report Preparation & Meeting Attendance		NRC			N/A	PM Activity
MA2514	BV-1 - PM Regional Interface		NRC			N/A	PM Activity

BVPS Unit 1 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA2622	BV-1 - PM Support to EDO/Commission		NRC			N/A	PM Activity
MA2730	BV-1 - PM Event Follow-up		NRC			N/A	PM Activity
MA2838	BV-1 - PM Support for Information Systems		NRC			N/A	PM Activity
MA2946	BV-1 - PM Visits to Site, Region, Licensee		NRC			N/A	PM Activity
MA3054	BV-1 - PM Effort Expended on FSAR/50.59 Report/Commitment Poll		NRC			N/A	PM Activity
MA3162	BV-1 - PM Budgeting Activities		NRC			N/A	PM Activity
MA4017	BV-1 - Potential for Degradation of ECCS/CSS after LOCA GL-98-04		NRC			N/A	PM Activity

BVPS Unit 1 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
M69428	BV-1 - GL 87-02 - Seismic Qualif. of Mech. & Elec. Equip. in Operating Plants	09/22/92	DLC	B. Sepelak	End of 1R13	N/A	SER received 12/9/98. Resolve outliers by end of 1R13. Forward completion letter to NRC
M95792	BV-1 - Editorial Changes for Steam Generator TS Regarding Requirements of GL 95-05	06/18/96	Complete	R. Ireland		N/A	LAR 1A-235; Typed pages submitted by L-98-177 on 9/8/98 and L-98-193 on 9/30/98 Amendment 219 issued 12/21/98
M98139	BV-1 - Use Framatome Process for Steam Generator Tank Sleeving	03/10/97	Complete	R. Ireland		N/A	LAR 1A-242; withdrawn by letter L-98-198 dated 10/13/98
M99673	BV-1 - Third 10 Year Interval ISI Plan with 11 Relief Requests	09/17/97	Complete	F. Lipchick		N/A	(L-97-024); RAI on 4/16/98; Reply to RAI (L-98-126) on 6/18/98 SER dated 12/29/98
MA0182	BV-1 - Two New and Four Revised ISI Relief Requests	11/24/97	Complete*	F. Lipchick	2/28/99	N/A	Telecon 3/11/98; new RRs submitted on 5/12/98 (L-98-098) NRC issued 11/12/98 *DLC to submit letter to correct SER
MA0611	BV-1 - Modify Source Range Neutron Flux TS Requirements to Allow Use of Alternate Detectors	12/19/97	Complete	R. Ireland		N/A	Amendment 217

BVPS Unit 1 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA1337	BV-1 - ISI Relief Request for Pressurizer Nozzle to Safe End Welds	03/25/98	Complete*	F. Lipchick	2/28/99	N/A	*DLC will submit letter to clarify erroneous statement in SER (Not on current TAC list)

BVPS Unit 2 TAC List
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
M83591	BV-2 - IPEEE for External Events (GL 88-20) Supplement 4	09/30/97	NRC	J. Maracek		N/A	RAI response forwarded to NRC by letter (L-98-218) dated 11/12/98 Projected SER date is June 2000.
M93430	BV-2 - GL 95-07; Pressure Locking and Thermal Binding of Safety-related Power-operated Gate Valves	10/16/95	NRC	J. Maracek		N/A	180 Day Response provided by letter dated 2/13/96
M95793	BV-2 - Implementation of GL 95-05 Requirements for Voltage-based SG Tube Repair Criteria	06/18/96	DLC	R. Ireland	1/31/99	N/A	LAR 2A-109; submit revised dose calculations to NRC
M96778	BV-2 - Assurance of Equipment Operability and Containment Integrity, GL 96-06	10/29/96	DLC	R. Fedin	1/31/99	N/A	RAI response provided in letter L-98-129 dated 6/30/98 Letter to correct L-98-129 statement
M97016	BV-2 - GL 96-05 MOV Capability Periodic Verification	11/18/96	NRC	J. Maracek		N/A	Updated response provided by L-98-072 dated 4/13/98
M98137	BV-2 - TS 3.4.5 to Allow Steam Generator Tube Sleeving Use CE Process	03/10/97	NRC	R. Ireland		10	LAR 2A-111 RAI response by letter L-97-023 dated 9/17/97. May request DLC to revise RAI response. Engineering would like amendment in Spring 2000.

BVPS Unit 2 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
M98546	BV-2 - Degradation of CRD Mech. Nozzles & Other Vessel Closure (GL 97-01)	04/30/97	NRC	B. Sepelak		N/A	Original response provided by letter dated 7/30/97. Response to RAI due by 11/25/98, will request extension to 1/15/99. RAI response submitted by letter L-99-001 dated 1/7/99.
M99828	BV-2 - Reduce RCS Specific Activity Limit from 1.0 to 0.35 Microcuries Per Gram	10/22/97	DLC	R. Ireland	1/31/99	N/A	LAR 2A-115; submit revised dose calculations
MA0333	BV-2 - 2nd Ten Year ISI Plan with ten ISI Relief Requests	12/09/97	NRC	F. Lipchick		8	(L-97-069); RAI on 6/1/98; Reply to RAI on 7/29/98 by letter (L-98-163)
MA0526	BV-2 - RAI on Reactor Vessel Integrity (Follow-up to MPA L201G)	07/09/98	NRC	R. Ireland		N/A	Submitted by letter L-98-133
MA0746	BV-2 - USQ for Increased Control Room Operator Radiological Doses	01/29/98	NRC	R. Ireland		2	LAR 2A-120; submitted additional information by letter L-98-195 dated 11/9/98. BCO 2-98-001 due restart 2R7.

BVPS Unit 2 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA0896	BV-2 - Degradation of Steam Generator Internals (GL 97-06)	03/30/98	NRC	R. Ireland		N/A	Response provided by letter L-98-009
MA1666	BV-2 - Part Length CRDM Housing Issue	04/28/98	NRC	R. Fedin		N/A	Response provided by letter (L-98-084)
MA1807	BV-2 - Year 2000 Readiness of Computer Systems at Nuclear Power Plants (GL 98-01)	08/06/98	DLC	J. Maracek	7/1/99	N/A	Follow-up response due to NRC by 7/1/99
MA2325	BV-2 - Revise Reactor Trip Setpoint for Operation with Inoperable Main Steam Safety Valves	07/09/98	NRC	Pointer/Berry		3	LAR 2A-81 BCO 2-98-007 expires 4/28/99.
MA3840	BV-2 - Revise TS to Modify Reporting Requirements and Make Administrative Changes	10/15/98	NRC	R. Ireland		6	LAR 2A-116 Typed pages forwarded by L-98-250 dated 12/14/98. CARF 971578-02 requires amendment by 12/31/99.
MA4377	BV-2 - QA Program change: conditional material release pending documentation receipt	12/8/98	NRC	G. Beatty		N/A	Submitted by letter L-98-221 dated 12/8/98. 60 day response required by NRC.

BVPS Unit 2 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA4439	BV-2 - TS 3/4.8.1 "AC Sources" changes for EDG fuel oil vol., load rejection, and frequency rqmts.	12/24/98	NRC	K. Pointer		9	LAR 2A-129 BCO 2-98-009 and BCO 2-98-010 expire 2-28-2000. BCO 2-98-012 expires 3/12/2000.
MA4441	BV-2 - TS & Bases changes to remove rod pos. deviation, insertion limit, & axial flux diff. monitors.	12/24/98	NRC	R. Ireland		5	LAR 2A-135 Operations requests amendment by 7/21/99.
	BV-2 - QA Program description change (Limit QS review)	12/24/98	NRC	G. Beatty		N/A	Submitted by letter L-98-224 dated 12/24/98. 60 day response required by NRC. (Not on current TAC list)
	BV-2 - Emergency Response Data Systems (ERDS)	11/27/98	NRC	J. Maracek		N/A	Submitted by letter L-98-226 (Not on current TAC list)
MA3838	BV-2 - Revise TS Bases to Provide Tolerances for RPS Time Constants	10/15/98	NRC	L. Berry		7	LAR 2A-133; L-98-204 dated 10/23/98 forward typed pages NRC to reissue pages (Not on current TAC list)
M72265	BV-2 - Licensee Performance Evaluation		NRC			N/A	PM Activity

BVPS Unit 2 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
M72384	BV-2 - Headquarters Focal Point for Information & Communication		NRC			N/A	PM Activity
M72504	BV-2 - SALP Report Preparation & Meeting Attendance		NRC			N/A	PM Activity
MA2515	BV-2 - PM Regional Interface		NRC			N/A	PM Activity
MA2623	BV-2 - PM Support to EDO/Commission		NRC			N/A	PM Activity
MA2731	BV-2 - PM Event Follow-up		NRC			N/A	PM Activity
MA2839	BV-2 - PM Support for Information Systems		NRC			N/A	PM Activity
MA2947	BV-2 - PM Visits to Site, Region, Licensee		NRC			N/A	PM Activity

BVPS Unit 2 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA3055	BV-2 - PM Effort Expended on FSAR/50.59 Report/Commitment Poll		NRC			N/A	PM Activity
MA3163	BV-2 - PM Budgeting Activities		NRC			N/A	PM Activity
MA4018	BV-2 - Potential for Degradation of ECCS/CSS after LOCA GL-98-04		NRC			N/A	PM Activity
M94646	BV-2 - Testing of Safety Related Logic Circuits (GL 96-01)	04/04/96	Complete	J. Maracek		N/A	Response provided by letter L-98-191 dated 10/13/98
M98140	BV-2 - Use Framatome Process for Steam Generator Tube Sleaving	03/10/97	Complete	R. Ireland		N/A	LAR 2A-113 withdrawn by letter L-98-198 10/13/98
MA0183	BV-2 - Two New and Four Revised ISI Relief Requests	11/24/97	Complete*	F. Lipchick	2/28/99	N/A	Telecon 3/11/98; new RRs submitted on 5/12/98 (L-98-098) issued 11/12/98 *DLC to submit letter to correct SER

BVPS Unit 2 TAC List (Cont.)
(As of 1/11/99)

Task No.	Task Description	Application Date	Required Action By	Responsible DLC person	Date DLC Action to be Completed	NRC Priority No.	Comments
MA0612	BV-2 - Modify Source Range Neutron Flux TS Requirements to Allow Use of Alternate Detectors	12/19/97	Complete	R. Ireland		N/A	Amendment 94
MA1347	BV-2 - Ampacity Derating of Conduits Wrapped with Thermo-Lag 330-1	10/13/97	Complete	J. Maracek		N/A	(GL 92-08) SER received 10/1/98
MA2200	BV-2 - Review 10 CFR 50.59 Annual Report for Period of 11/1/96 - 10/31/97	06/18/98	Complete	L. Berry		N/A	Forwarded to NRC by letter L-98-122