

Northeast
Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

FEB - 1 1999

Docket No. 50-336
B17599

Re: 10 CFR 50.73(a)(2)(i)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555


Millstone Nuclear Power Station Unit No. 2
Licensee Event Report 97-009-01
Insufficient ESFAS Surveillance Testing
(Generic Letter 96-01 Review)

This letter forwards Licensee Event Report (LER) 97-009-01, documenting a condition that was discovered at Millstone Nuclear Power Station, Unit No. 2 on March 25, 1997. This LER supplement provides an update on the analyses for this condition, including the identification of additional deficiencies identified during the investigation of this condition. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(i).

The Northeast Nuclear Energy Company's (NNECO) commitments made within this letter are included in Attachment 1.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY


J. A. Price

Director - Millstone Unit No. 2

cc: see page 2

9902100174 990201
PDR ADQCK 05000336
S PDR

Attachments: 1. List of Regulatory Commitments
2. LER 97-009-01

cc: H. J. Miller, Region I Administrator
S. Dembek, NRC Project Manager, Millstone Unit No. 2
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2
E. V. Imbro, Director, Millstone ICAVP Inspections

Docket No. 50-336
B17599

Attachment 1

Millstone Nuclear Power Station, Unit No. 2

Commitments

February 1999

Attachment 1

Regulatory Commitment Enclosure
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document.

| REGULATORY COMMITMENT | COMMITTED DATE OR OUTAGE |
|---|----------------------------|
| B17599.01: Operational surveillances (which perform the functional tests required by the facility TS) associated with deficiencies identified under the GL 96-01 review will be revised prior to entry into Mode 4 from the current outage to ensure that TS functional requirements are satisfied. | Mode 4 from current outage |

Docket No. 50-336
B17599

Attachment 2

Millstone Nuclear Power Station, Unit No. 2

LER 97-009-01

February 1999