

Northeast  
Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385 0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

December 5, 1997

Docket No. 50-423  
B16865

Re: 10 CFR 50.73(a)(2)(ii)(B)

Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Millstone Nuclear Power Station Unit 3  
Licensee Event Report 97-056-00  
Submitted Pursuant to 10 CFR 50.73(a)(2)(ii)(B)

This letter forwards Licensee Event Report 97-056-00, documenting a condition that was determined reportable at Millstone Unit No. 3 on November 7, 1997. This LER is submitted pursuant to 10 CFR 50.73(a)(2)(ii)(B). NNECO's commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. David A. Smith at (860) 437-5840.


Very truly yours,

NORTHEAST NUCLEAR ENERGY  
COMPANY

G. D. Hicks  
Unit Director, Millstone Unit No. 3

IE221,

9712150023 971205  
PDR ADOCK 05000423  
S PDR



U.S. Nuclear Regulatory Commission  
B16865/Page 2

Attachment: 1) INNECO's commitments in response to LER 97-056-00  
2) LER 97-056-00

cc: H. J. Miller, Region I Administrator  
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3  
J. W. Andersen, NRC Project Manager, Millstone Unit No. 3  
W. D. Travers, Dr., Director, Special Projects  
Corrective Action Group Files (CR M3-97-3788)

SCN:

Docket No. 50-423  
B16865

Attachment 1

Millstone Nuclear Power Station, Unit No. 3  
NNECO's Commitments  
In Response To  
(LER 97-056-00)

December 5, 1997

Enclosure  
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
B16865-01	A design modification will be implemented to ensure that sufficient Service Water system pressure is available to refill the control building air conditioning condensers following a design basis accident.	Prior to entry into Mode 4

Docket No. 50-423  
B16865

Attachment 2

Millstone Nuclear Power Station, Unit No. 3  
NNECO's Submittal of  
(LER 97-056-00)

December 5, 1997