

S023-411-57-15 R/O

TEST REPORT

SEISMIC QUALIFICATION OF  
THE SAN ONCFRE, UNITS 2 & 3  
MNSA CLAMPS FOR PRESSURIZER INSTRUMENT NOZZLES  
AND RTD HOT LEG NCZZLES

RECEIVED CDM

JUL 25 1997

SITE FILE COPY

Prepared By: Karl H. Haslinger Date: 6/24/97

K. H. Haslinger, Supervisor Structural Integrity & Testing

Reviewed By: FVR Date: 7/4/97

F. V. Rossano, Structural Integrity & Testing

Date of Issue: 7/3/97

VPL No.	5023-411-57-15-0		
<input checked="" type="checkbox"/> 1. APPROVED - Mfg. may proceed. Quality Class: <u>1</u>			
<input type="checkbox"/> 2. APPROVED EXCEPT AS NOTED - Make changes and resubmit. Mfg. may proceed.			
<input type="checkbox"/> 3. NO: APPROVED - Correct and resubmit for review. Not to be used for field use.			
<input type="checkbox"/> 4. REFERENCE DOCUMENT - "Information Only"			
SOUTHERN CALIFORNIA EDISON COMPANY			
Drawings are reviewed and approved for arrangements and conformance to specification only. Approval does not relieve the submitter from the responsibility of adequacy and suitability of design, materials, and/or equipment represented.			
Quality Classification Ref. Doc. No. <u>10111A</u>			
* DM or OTHER as required by DRAOM			
DATE	REVIEWED	APPROVED	7/5/97
DATE	REVIEWED	APPROVED	7/16/97
DATE	REVIEWED	APPROVED	

9712160319 971212  
PDR ADDCK 05000361  
P PDR

SCE 37-336 REV 0 580 (REFERENCE 50123-XXIV-37-3-10)

Page 1 of 47

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

## Design-Related Testing Checklist

### Section 3 – TEST REPORT

Document Title: Test Report Seismic Qualification of the San Onofre MNSA Clamps for Pressurizer Instrument Nozzles and RTD Hot Leg Nozzles

Document Number: TR-I /G-033 Revision: 00

	Yes	N/A
1 Is the test purpose stated?	<input checked="" type="checkbox"/>	
2 Are the test procedures listed?	<input checked="" type="checkbox"/>	
3 Are the test results listed?	<input checked="" type="checkbox"/>	
4 Is the test request document number included on the test report cover page?	<input checked="" type="checkbox"/>	
5 Has the test report been signed and dated by the author?	<input checked="" type="checkbox"/>	
6 Has provision been made for approval by the manager of the testing organization?	<input type="checkbox"/>	
7 Has provision been made for a statement of acceptance by the Cognizant Engineer?	<input checked="" type="checkbox"/>	

#### Comments/Remarks:

---

---


---

---


Reviewed by:

Frank V. Rossano

Printed Name



Signature

  
7/2/97

Date

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

RECORD OF REVISIONS

NO.	DATE	PAGES INVOLVED	PREPARED BY	APPROVALS
0	07/ 03/97	All	K. H. Haslinger	F. V. Ro. P. Leombruni K. Margotta

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

The information contained in this Report No. TR-PENG-033, Rev. 00 has been reviewed and approved as documented herein.

Approved By: CJ Shinnick for PL Date: 7/3/97  
Manager, Primary Systems

The tests described in this report are accepted as meeting the objectives and instructions described in the referenced test request/test procedures.

Accepted By: K.V.MARCOSTA X.Y.JT Date: 7/3/97  
Cognizant Engineer

## TABLE OF CONTENTS

<u>Section</u>	<u>Description</u>	<u>Page No.</u>
	TABLE OF CONTENTS	5
	LIST OF TABLES	6
	LIST OF FIGURES	6
	LIST OF APPENDICES	8
1.0	INTRODUCTION	9
2.0	OBJECTIVE	9
3.0	SUMMARY	9
4.0	TEST DESCRIPTION	11
	4.1 Test Specimens and Mounting	11
	4.2 Equipment and Instrumentation	12
	4.3 Calibrations	13
	4.4 Sine Sweep Test Procedure	13
	4.5 Simulation of Seismic Environment	13
5.0	DISCUSSION	14
	5.1 General	14
	5.2 Sine Sweep Testing	15
	5.3 Seismic Qualification Testing	15
6.0	RECORD RETENTION	17
7.0	REFERENCES	17

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

**ABB/COMBUSTION ENGINEERING**  
**PRIMARY SYSTEMS**

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

**LIST OF TABLES**

<u>Table No.</u>	<u>Description</u>	<u>Page No.</u>
1	EQUIPMENT AND INSTRUMENTATION	19
2	TEST MATRIX, OFF-LINE ANALYSIS AND DATA FILE IDENTIFICATION	20
3	REQUIRED RESPONSE SPECTRUM LEVELS AT 1/6th OCTAVE ANALYSIS FREQUENCIES	21

**LIST OF FIGURES**

<u>Figure No.</u>	<u>Description</u>	<u>Page No.</u>
1	REQUIRED RESPONSE SPECTRA	22
2	REPRESENTATIVE MNSA CLAMP DETAILS	23
3	REPRESENTATIVE TEST FIXTURE AND MOUNTING DETAILS	24
4	HYDRAULIC VIBRATION TEST FACILITY	25
5	HOT LEG RTD AND PZR SIDE MOUNTED NOZZLES WITH MNSAs DURING SEISMIC TEST	26
6	PZR SIDE MOUNTED NOZZLE SEISMIC TEST SET-UP	27
7	VIEW OF PRESSURE GAUGES AND HAND PUMP	27
8	HOT LEG RTD NOZZLE WITH MNSA, SEISMIC TEST SET-UP	28
9	HOT LEG RTD NOZZLE WITH MNSA, VERTICAL & HORIZONTAL RESPONSE ACCELEROMETER	28
10	BOTTOM MOUNTED INSTRUMENTED NOZZLE WITH MNSA, FREE STANDING	29
11	BOTTOM MOUNTED INSTRUMENTED NOZZLE WITH MNSA, SUPPORTED	29

TR-PENG-033 Rev. 00 Ref. T.R. No. TS071A	ABE/COMBUSTION ENGINEERING PRIMARY SYSTEMS	Contract No. 2007241 Total of Text 47 Pages Appendices 89 Pages
--	---	---

## LIST OF FIGURES

<u>Figure No.</u>	<u>Description</u>	<u>Page No.</u>
12	BOTTOM MOUNTED INSTRUMENTED NOZZLE WITH MNSA, RESPONSE ACCELEROMETER MOUNTING BLOCK AT VALVE MASS TOP	30
13	BOTTOM MOUNTED INSTRUMENTED NOZZLE WITH MNSA, RESPONSE ACCELEROMETER AT NOZZLE TOP AND TOP MNSA PLATE	30
14	DVCS INPUT PARAMETERS FOR SINE SWEEP RESONANCE SURVEYS USING SN21T VERSION 04	31
15	TRANSFER FUNCTION PLOTS, PRESSURIZER-TEMPERATURE NOZZLE, TEST ORIENTATION A	32
16	TRANSFER FUNCTION PLOTS, PRESSURIZER LOWER LEVEL INSTRUMENTATION NOZZLE, TEST ORIENTATION A, FREE STANDING	33
17	TRANSFER FUNCTION PLOTS, PRESSURIZER LOWER LEVEL INSTRUMENTATION NOZZLE, TEST ORIENTATION D, FREE STANDING	34
18	TRANSFER FUNCTION PLOTS, PRESSURIZER LOWER LEVEL INSTRUMENTATION NOZZLE, TEST ORIENTATION A, SUPPORTED	35
19	TRANSFER FUNCTION PLOTS, PRESSURIZER LOWER LEVEL INSTRUMENTATION NOZZLE, TEST ORIENTATION D, SUPPORTED	36
20	TRANSFER FUNCTION PLOTS, HOT LEG TEMPERATURE RTD NOZZLE, TEST ORIENTATION A	37
21	DVCS INPUT PARAMETERS FOR OBE AND SSE TEST EVENTS	38
22	TEST ORIENTATIONS FOR SEISMIC QUALIFICATION TEST	39
23	HORIZONTAL CONTROL ACCELEROMETER TIME HISTORY, TEST ORIENTATION A, OBE EVENT NO. 5	40
24	VERTICAL CONTROL ACCELEROMETER TIME HISTORY, TEST ORIENTATION A, OBE EVENT NO. 5	41

## LIST OF FIGURES

<u>Figure No.</u>	<u>Description</u>	<u>Page No.</u>
25	HORIZONTAL CONTROL ACCELEROMETER TRS & RRS, TEST ORIENTATION A, OBE EVENT NO. 5	42
26	VERTICAL CONTROL ACCELEROMETER TRS & RRS, TEST ORIENTATION A, OBE EVENT NO. 5	43
27	HORIZONTAL CONTROL ACCELEROMETER TIME HISTORY, TEST ORIENTATION A, SSE EVENT	44
28	VERTICAL CONTROL ACCELEROMETER TIME HISTORY, TEST ORIENTATION A, SSE EVENT	45
29	HORIZONTAL CONTROL ACCELEROMETER TRS & RRS, TEST ORIENTATION A, SSE EVENT	46
30	VERTICAL CONTROL ACCELEROMETER TRS & RRS, TEST ORIENTATION A, SSE EVENT	47

## LIST OF APPENDICES

<u>Appendix</u>	<u>Description</u>	<u>Page No.</u>
A	DATA SHEETS AND LOG SHEETS	A1 - A11
B	I VOLT PEAK SIGNAL CALIBRATION, OFF-LINE ANALYSIS SYSTEM	B1 - B3
C	CALIBRATION RECORDS	C1 - C14
D	OFF-LINE ANALYSIS -RESULTS GRAPHS & TABULATIONS	D1 - D61

<b>TR-PENG-033</b> <b>Rev. 00</b> <b>Ref. T.R. No. TS071A</b>	<b>ABB/COMBUSTION ENGINEERING</b> <b>PRIMARY SYSTEMS</b>	<b>Contract No. 2007241</b> <b>Total of Text 47 Pages</b> <b>Appendices 89 Pages</b>
---	---	--

## 1.0 INTRODUCTION

The Testing Services Group of the Primary Systems Department of ABB/CENO had been requested to perform a seismic qualification test on three specimens of MNSA Clamps with simulated cracks for the San Onofre Nuclear Power Plant. Reference 1, which incorporates the requirements, was the controlling document for the seismic qualification program. Testing was to demonstrate that the components could meet or exceed their specified performance characteristic when subjected to the stipulated seismic events. This report documents the seismic environments that were generated during this program and reports the leak resistance performances of the specimens.

These tests were performed in the Dynamic Test Facility at ABB/Combustion Engineering, Windsor CT, from June 10, 1997 through June 18, 1997.

The Quality Class 1 subject test program was conducted in compliance with Quality Assurance guidelines of QPM-101, QP 3.6 (Reference 13) as Design Verification per requirements of the Test Request (Reference 1) and the Project Plan (Reference 21). The testing was performed by personnel qualified for this work per Reference 19.

## 2.0 OBJECTIVE

The objective of this seismic test was to demonstrate that the San Onofre Pressurizer and Hot Leg MNSA nozzle assemblies, with simulated 180° cracks, can maintain their physical and functional integrity during and following exposure to a Safe Shutdown Earthquake (SSE) preceded by five Operating Basis Earthquakes (OBEs).

## 3.0 SUMMARY

Representative samples of the San Onofre MNSA designs, in conjunction with simulations of the Pressurizer (PZR) Temperature Nozzle, the Pressurizer Lower Level Instrumentation Nozzle, and the Hot Leg Temperature RTD Nozzle, all with simulated 180° cracks, were provided by ABB/FSME for seismic qualification testing. These components were tested as mounted in special fixtures that were provided by ABB/FSME and assembled specifically for the seismic test by ABB/CENO.

TR-PENG-033 Rev. 00 Ref. T.R. No. TS071A	ABB/COMBUSTION ENGINEERING PRIMARY SYSTEMS	Contract No. 2007241 Total of Text 47 Pages Appendices 89 Pages
--	---	---

Exploratory low level sine sweep tests, conducted prior to seismic qualification testing, demonstrated that two of the three test assemblies, as mounted on the seismic simulator, were rigid within the seismic frequency range (1 to 33 Hertz). The free-standing Bottom Mounted PZR Instrumentation Nozzle with MNSA exhibited a nozzle resonance at 33 Hertz and a MNSA structure resonance at 38 Hertz. The sine sweep transfer functions are shown in Figures 16 and 17. To avoid unnecessary conservatism due to a seismic table resonance, the Bottom Mounted PZR Instrumentation Nozzle was first tested in a supported fashion. With regards to the MNSA qualification, this was determined to be acceptable (Section 5.1). There were no critical fixture resonances below 50 Hertz with exception of the MNSA resonance at 38 Hertz. The sine sweep transfer functions for the supported nozzle test configuration are shown in Figures 18 and 19.

Biaxial (vertical and horizontal) seismic base excitations were introduced to the test specimens in either one or in four test orientations to ensure the possibility of the test specimens to respond in all of their horizontal, vertical or torsional vibration modes, if any, located within the seismic frequency range. Qualification was conducted using modified Generic Floor Test curves that enveloped both sets of Plant Specific curves.

Artificial seismic time histories were synthesized with random multifrequency intensities that enveloped the stipulated OBE and SSE Required Response Spectra (RRS) curves of Figure 1. The leakage performance of all specimens was monitored after each event simulation. There were no observed leaks. Consequently, the test specimens provided are qualified to the seismic intensity levels represented by the specified seismic curves. Typical Time Histories and the resulting Test Response Spectra (TRS) are shown in Figures 23 through 30. A more comprehensive set of results is included in Appendix D. The Bottom Mounted PZR Instrumentation Nozzle with MNSA was tested first in the supported configuration and then in the free standing configuration. Because of the seismic table resonance being near the nozzle resonance, the latter configuration was a very conservative test. Nevertheless, the specimen was capable of withstanding these strong seismic responses without damage or loss of pressure.

All horizontal and vertical control and response accelerometer time histories were stored on magnetic tape and were simultaneously acquired by a PC-based Data Acquisition System. The data were subsequently analyzed off-line at 1% damping. These results are presented in Appendix D. For the free standing Bottom Mounted PZR Instrumentation specimen, horizontal Top Nozzle and MNSA Top Plate time history and response spectra were also generated and are provided in Appendix D for the four SSE level events. On-line spectrum analysis plots are not included in this report because of the narrower (1 to 50 Hertz) analysis range. They are, however, retained as raw data.

The physical integrity of the three specimen types was verified throughout the seismic testing. No damage was observed at any time, as indicated on the data sheets of Appendix A. Leak performance evaluations were performed by ABB/CENO test personnel before and after each seismic event.

TR-PENG-033 Rev. 00 Ref. T.R. No. TS071A	ABB/COMBUSTION ENGINEERING PRIMARY SYSTEMS	Contract No. 2007241 Total of Text 47 Pages Appendices 89 Pages
--	---	---

## 4.0 TEST DESCRIPTION

### 4.1 Test Specimens and Mounting

One test specimen each was provided for the three test nozzle configurations with MNSA clamps. The drawings of References 2 through 4 and 14 provide details of the MNSA clamps. Reference 15 provides details of the test fixtures. Each MNSA clamp was assembled using the appropriate procedure of Reference 16 using calibrated torque wrenches. Minor adjustments were made to two of the seals which are reflected in the final sets of drawings and assembly procedure. One of these adjustments was the use of a spacer between the comparison collar and grafoil seal of the Bottom Mounted PZR Nozzle seal. This resulted in a drawing change, but did not affect the validity of the seismic test. The specimens were furnished already with weights that simulated the RTD heads and/or the valve that are present in the field installation. Each nozzle was inserted into an appropriately sized socket and a 180° crack was simulated by seal welding only a 180° arc rather than the entire 360° circumference. The bore below the nozzle was plugged and the top of each test nozzle was furnished with appropriate fittings to allow for internal pressurization during testing. The simulated piping or pressurizer wall pieces were welded onto 16x16x1 inch base plates that accommodated the bolting pattern of the seismic test table and permitted simple rotating of the test specimen in 90° increments. The Bottom Mounted PZR Instrumentation Nozzle was supported near its top using a Unistrut/Plate support structure. This support did not affect the MNSA, which was free to move. This specimen was subsequently also tested without this support.

Small diameter tubing was connected to a hand pump and to shut-off valves/pressure gauges to permit monitoring of internal pressures. The gauges and hand pump were located off the seismic table, using generous loops in the pressure tubing, in order to accommodate large relative table movements. Specimens were inspected for any physical defects prior to test, after each seismic event, and following completion of all qualification sequences. No damage was observed throughout this entire test program.

Symmetry of the test fixture bolting pattern allowed for simple re-orientation of the test fixture/specimen assemblies in any of the four required test orientations. The location of the test fixture was near the center of the table, in close proximity to the vertical and horizontal control accelerometers. Sine sweep testing was performed to determine the rigidity of the test fixtures within the extended seismic range of 1-50 Hertz. Photographic documentation of the mechanical setup is provided in Figures 5 through 13. Several figures show the placement of the response accelerometers during the sine sweep testing.

#### 4.2 Equipment and Instrumentation

Seismic testing was performed in the Dynamic Test Facility using the seismic simulation shaker table. Figure 4 shows a block diagram of the general instrumentation hookup of the hydraulic test facility that was used in this test.

The excitation axis of the simulator is inclined at 45 degrees and, therefore, provides phase coherent motions of equal magnitudes in the vertical axis and in one horizontal axis. Two control accelerometers (Unholtz-Dickie 100-PA), mounted to the seismic table in a mutually perpendicular arrangement adjacent to the test fixture, were used to monitor the excitation levels in the horizontal and vertical axes during all testing. The control accelerometer signals were conditioned by Unholtz-Dickie 2216X Signal Conditioners. The horizontal and vertical response accelerometers (Unholtz-Dickie 75D21PA) used during sine sweep and seismic testing were mounted on standard aluminum fixturing blocks that were glued to selected equipment locations. Unholtz-Dickie D22H charge amplifiers were used to condition the response accelerometer signals.

For sine sweep testing, the "SN21T Version 04" software package (Reference 7) of the Digital Vibration Control and Analysis System (DVCA) was employed. The input listing for this program is shown as Figure 14. For synthesis and on-line analysis of the table motions of the generated seismic environments, the "WAE 3.0 Decade" software package of the DVCA was used. The permanent file identification of this code is WAE0V1.TSL, and the synthesized SRS on-line analysis function has been Q.A. verified by Reference 8. The input listings for this program are shown as Figure 21.

For each seismic event simulation, on-line analysis was performed for the horizontal motion of the table. These data were used to assure envelopment of the Required Response Spectra (RRS) by the achieved Test Response Spectra (TRS). For this qualification effort, the event duration was 32 seconds, yielding on-line test response spectra from 1 to 50 Hertz. Time history recordings of the table motions were used to verify adequacy of achieved Zero Period Acceleration (ZPA) levels.

In addition to performing on-line response spectrum analyses of the horizontal control accelerometer signals (at the specified damping of 1%), horizontal and vertical control accelerometer signals, and for selected events also up to two response accelerometers, were recorded by a magnetic tape recorder (Racal Store 7DS). In addition, a P.C. based computer program was used to acquire table time history records and to perform off-line analyses (1-100 Hertz range) from these recorded motions using the "SRSKHH" program of Reference 11. The referenced off-line analysis program was used to compute SRS analyses at the specified damping of 1% and to display the results in both graphical and tabular form (see Appendix D).

A list of all equipment used during this test program is given in Table 1.

#### 4.3 Calibrations

Calibrations were required for the accelerometers, the signal conditioners, the charge amplifiers, the multimeter, the pressure gauges, and the torque wrenches. Required calibrations were accomplished in accordance with the guidelines of Reference 11. A signal calibration was performed on the tape recorder, using the multimeter and a signal source, as well as the full range calibration signals from the charge amplifiers. A 1 volt input signal check was used to verify the "Hands-off" autocalibration of the P.C. based data acquisition system. Time records of these signal calibrations are included in Appendix B. Table 1 lists accuracies and calibration dates of all equipment. Copies of pertinent calibration records are included in Appendix C.

#### 4.4 Sine Sweep Test Procedure

Sine sweep resonance surveys were performed in either one or in two test Orientations A and B with response accelerometers mounted near the top of each test specimen. For the two axis symmetric nozzle specimens testing was limited to Orientation A only. Orientations are defined in Figure 22. Additional details are illustrated in the photographic records of Figures 5 through 13.

During resonance surveys, the specimens were excited over a frequency range of 1 to 50 Hertz at a sweep rate of 0.83 octaves per minute (0.25 decades per minute). The test intensity ranged between 0.1 and 0.2 Gs (a ramp from 0.1 G at 1 Hertz to 0.2 G at 2 Hertz and a constant 0.2 G above 2 Hertz). Several test runs were made using a constant 0.1 G excitation level over the same frequency range. Data runs were displayed on the CRT terminal in the form of transfer function graphs (horizontal response over horizontal input or vertical response over vertical input) and hard copies were made. Results of these surveys are shown in Figures 15 through 20.

#### 4.5 Simulation of Seismic Environment

Seismic qualification was performed in accordance with the documented Modified Generic Response spectra that enveloped the two sets Plant Specific requirements. The test specimens were subjected to a minimum of five consecutive OBE level events in either one or in each of the four orthogonal test orientations, as specified in Reference 18. For the two axis symmetric

TR-PENG-033 Rev. 00 Ref. T.R. No. TS071A	ABB/COMBUSTION ENGINEERING PRIMARY SYSTEMS	Contract No. 2007241 Total of Text 47 Pages Appendices 89 Pages
--	---	---

nozzle specimens testing was limited to Orientation A only. This was followed by one SSE level event in each test orientation. For each event, on-line monitoring of the horizontal control accelerometer was performed and results were evaluated to ensure that clear envelopment of the Required Response Spectra (RRS) had been achieved. In addition, for each event, the outputs from both the horizontal and the vertical control accelerometers were recorded on magnetic tape and stored via the P.C. based Data Acquisition System.

During the seismic events, the test specimens were pressurized to  $3.175 \pm 50$  psig. Monitoring of the test pressures was performed by ABB/CENO personnel before and after the seismic event.

## 5.0 DISCUSSION

### 5.1 General

At the time of testing, it was decided to test the Hot Leg RTD Nozzle and the Side Mounted PZR Nozzle together, but separate from the Bottom Mounted PZR Instrument Nozzle. This decision was based on the fact that the first two nozzles are symmetric about the vertical axis, and thus needed to be tested only in one orientation on the seismic table. Furthermore, the Bottom Mounted PZR Instrument Nozzle required some special attention to deal with the fact that the nozzle resonance of about 33 Hertz coincided with the oil-column resonance of the seismic table. Since the Bottom Mounted PZR Instrumentation Nozzle had already been seismically qualified by analysis in Reference 20, emphasis was at first placed on removing unnecessary conservatism in qualifying the MNSA seal. Whereas the seismic SSE response spectrum intensity level for the pressurizer near the nozzle frequency of 33 Hertz was determined from Reference 18, Figure A-17, as approximately 4.8 Gs, the table resonance situation would have increased this level to approximately 35 Gs. Since the primary objective of this test was to qualify the MNSA seal, it was justifiable to stiffen the nozzle and to shift its natural frequency away from the table resonance peak, as long as it could be demonstrated that the Zero Period Acceleration (ZPA) level of the actual test motion is greater than the Required Response Spectrum level at the natural frequency of the nozzle with MNSA. According to Appendix A of Reference 18, respective OBE and SSE requirements at a frequency of 33 Hertz are 2.4 Gs and 4.6 Gs. As is demonstrated by the response spectra and time histories enclosed in this report, achieved ZPA levels for OBE and SSE events typically exceeded respective levels of 2.6 and 5.1 Gs, which met the stated requirement for this test. It should be noted here that these ZPA levels are obtained from the time histories and that the spectrum levels shown in the Test Response Spectra actually indicate higher levels up to 100 Hertz.

Since testing of the Bottom Mounted PZR Instrument Nozzle with support was successful, it was decided to also test this specimen in the free-standing configuration. This resulted in a very conservative, second seismic qualification test for this specimen. Maximum G levels of approximately 20 Gs were monitored near the nozzle top. However, the test specimen was shown

able to accept even these extremely conservative input motions without any loss of pressure or physical integrity.

### 5.2 Sine Sweep Testing

The transfer functions from the sine sweep surveys, which are shown in Figures 15 through 20, allow the following conclusions:

- The Side Mounted PZR Nozzle and the Hot Leg RTD Nozzle, both with MNSA seal installed, showed no horizontal or vertical resonances within the frequency sweep range of 1-50 Hertz. There was some motion amplification towards 50 Hertz in the horizontal monitoring directions which would indicate resonances somewhere between 60 and 80 Hertz.
- The unsupported Bottom Mounted PZR Instrumentation Nozzle with MNSA demonstrated a significant nozzle resonance peak near 33 Hertz and a MNSA structural resonance near 38 Hertz, as shown in Figures 16 and 17. As discussed above, it was decided to support the top of the nozzle and, thereby, forcing an upwards shift of the natural frequency of the nozzle. This was achieved successfully, as seen by the sine sweep plots of Figures 18 and 19. The sine sweep plots included in these figures show the response behavior of the nozzle and the MNSA hold-down plate in the horizontal direction and of the asymmetric valve simulation in both horizontal and vertical directions. Due to non-symmetry, sine sweep testing for this specimen was performed in two orientations. Seismic qualification of the MNSA seal for the Bottom Mounted PZR Instrumentation Nozzle was performed at first in the supported configuration followed by testing in the free-standing configuration.

### 5.3 Seismic Qualification Testing

As mentioned previously, OBE and SSE motion syntheses were performed using the Required Response Spectra (RRS) curves shown in Figure 1. Documentation of the adequacy of the components for these requirements is based in this document on the results from the off-line analyses. On-line analyses were also performed during the course of the testing to assure envelopment of the RRS curves by the achieved Test Response Spectra (TRS). The on-line analyses results are not included in this report. However, they are being retained as raw data.

Figures 23 through 26 show the waveform time histories and the resulting off-line analysis outputs for a typical OBE event (Orientation A) for the MNSA clamp seismic intensity requirements. Figures 27 through 30 provide the same complement of results, however this

TR-PENG-033 Rev. 00 Ref. T.R. No. TS071A	ABB/COMBUSTION ENGINEERING PRIMARY SYSTEMS	Contract No. 2007241 Total of Text 47 Pages Appendices 89 Pages
--	---	---

time for a typical SSE event (Orientation A). As can be observed, the Required Response Spectra are always cleanly enveloped by the control accelerometer Test Response Spectra in both the vertical and horizontal directions.

Appendix D contains all pertinent off-line analyses, performed for the two control accelerometers. For the Hot Leg RTD and the PZR Side Mounted nozzle specimens, all five OBE events and the SSE event are included. For the Bottom Mounted PZR Instrument Nozzle, one OBE and one SSE event analyses are included for each test orientation of both the supported and the free-standing test configurations. There were no requirements to analyze any response accelerometer locations, however the horizontal MNSA hold-down plate and nozzle top motions were evaluated for the Bottom Mounted PZR Instrument Nozzle in the free-standing test configuration.

In viewing the previously mentioned time histories, the top portion always represents the "as digitized" signal, sampled at 1,000 Hertz. The bottom portion represent the same trace, however digitally RC low-pass filtered at 100 Hertz. This measure enables visual determination of the signal content within the analysis frequency range of 1 to 100 Hertz. The filtered time histories are the bases for the off-line analysis results. The unfiltered traces are usable for determination of actual Zero Period Acceleration (ZPA) levels. During respective OBE and SSE event simulations, ZPA levels in the horizontal direction were approximately 2.7 Gs (Figure 23) and 5.5 Gs (Figure 27). In the vertical direction, respective OBE and SSE event ZPA levels were 2.8 Gs (Figure 24) and 5.1 Gs (Figure 28). Specified ZPA levels, per Figure 1, were 1.5 Gs and 3.0 Gs for OBE and SSE events, respectively.

Table 3 identifies the required response spectrum levels for the 1/6th octave spaced off-line analysis frequencies. This information may be helpful in evaluating any of the tabulated spectrum results. Furthermore, Table 2 identifies the test runs and the data analysis file names. This facilitates cross referencing between the log sheets contained in Appendix A, the Table 2 test matrix, and the attached graphical and tabulated spectrum results included as Appendices D.

The spectral data are mostly self explanatory and any observed "peaking" phenomena evident in the TRSes are confined to the table resonance peak near 30 Hertz. There are some higher order frequency peaks, however, with regard to the qualification in general, these are considered irrelevant. The response spectra for the hold-down plate and the top nozzle (Bottom Mounted PZR Instrument Nozzle) reflect the respective natural frequencies of the MNSA and the test nozzle.

In summary it is stated that the requirements for envelopment of both horizontal and vertical RRSs by the TRSs were met during all seismic event simulations (20 OBEs and 4 SSEs for Bottom Mounted PZR Instrumentation Nozzle each for the supported and the free-standing test

configurations and 5 OBEs and 1 SSE for Hot Leg RTD and Side Mounted PZR Nozzles, all with MNSA clamps installed) documented herein for each of the specified sets of seismic requirements.

Since the selected, modified Generic Floor RRS curves completely enveloped those for the specific plant locations, the test specimens have been demonstrated to exceed all stipulated seismic requirements. With regard to the development/justification of the Test Response Spectrum requirements, one is referred to Appendix A of the applicable Test Procedure, Reference 18. Since, in addition, there was no observance of leaks or significant pressure drops in any one of the three test specimens, it is concluded that the seismic qualification test described has demonstrated full compliance with all acceptance criteria for the MNSA clamps, as stipulated in Reference 18.

## 6.0 RECORD RETENTION

Test records, raw data and original data sheets were assembled and transmitted to the Primary Systems (Testing Services Group) custodian of original raw data for storage. All pertinent test records are included in the test report. Magnetic tape recordings of test data are stored in the Seismic Laboratory for a minimum of five (5) years. There is no need to store the digital files since they can be regenerated from the analog tape recordings. The calibration records for instruments used to record test data are stored in accordance with the laboratory procedure of Reference 10. Copies of pertinent calibration records are included in Appendix C. Copies of the original test procedure and test report will be stored in the Primary Systems (Testing Services Group) files for a minimum of five (5) years. Q.A. Record Storage of the subject document is the responsibility of ABB-CENO/FSME.

## 7.0 REFERENCES

1. Test Request TS071A, Supplement 00.
2. ABB C-E Drawing E-MNSA-228-001, Rev. 02, "Bottom Pressurizer Mechanical Nozzle Seal Assembly".
3. ABB C-E Drawing E-MNSA-228-002, Rev. 02, "Side Pressurizer RTD Mechanical Nozzle Seal Assembly".
4. ABB C-E Drawing E-MNSA-228-003, Rev. 02, "Hot Leg RTD Mechanical Nozzle Seal Assembly".
5. IEEE Std. 323-1974 & 1983, "General Guide for Qualifying Class 1E Equipment for Nuclear Power Generating Stations."

<b>TR-PENG-033</b> Rev. 00 Ref. T.R. No. TS071A	<b>ABB/COMBUSTION ENGINEERING</b> <b>PRIMARY SYSTEMS</b>	Contract No. 2007241 Total of Text 47 Pages Appendices 89 Pages
---	---	---

6. IEEE Std. 344-1974 & 1987, "Recommended Practices for Seismic Qualification of Class IE Equipment for Nuclear Power Generating Stations."
7. C-E Analysis Report No. S669-100, Rev. 01, "Q.A. Verification of Time/Data Sinusoidal Vibration Control Code Version 04", issued April 11, 1985.
8. C-E Analysis Report No. S863-113, "Q.A. Verification 3.0 Decade Wave Synthesized SRS Analysis Program, Vibration Control System", issued May 2, 1979.
9. C-E Analysis Report No. SE90-125, Rev. 02, "Q.A. Verification of C-E SRS Analysis Modification", issued April 11, 1985.
10. MISC-PENG-IPQP-007, Rev. 01, "Quality Program Plan for the Control and Calibration of Measuring and Test Equipment".
11. C-E Analysis Report No. 00000-ESE-76D-224, Rev. 01, "Q.A. Verification of Computer Program SRSKHH used for Shock Response Spectrum Analyses", issued November 2, 1993.
12. S-NOME-WTR-0007, Rev. 00, "Test Requirements for the San Onofre MNSA Clamp for Pressurizer Instrument Nozzles and RTD Hot Leg Nozzles".
13. QPM-101, Rev. 01.
14. ABB C-E Drawing E-MNSA-228-004, Rev. 02, "Mechanical Nozzle Seal Assembly Details".
15. ABB C-E Drawing E-MNSA-228-008, Rev. 02, "MNSA Seismic Test Fixtures".
16. MNSA Assembly Procedures, S3-NOME-EP-0124, Rev. 00.
  - 16.1 MNSA - RTD Hot Leg, Section 7.0.
  - 16.2 MNSA - Pressurizer, Bottom Head, Section 6.0.
  - 16.3 MNSA - Pressurizer, Side Nozzle, Section 5.0.
17. Mini-Specification S023-411-57, Rev. 00, "RCS MNSA Assemblies, San Onofre Generating Station, Units 2 and 3".
18. 00000-PENG-037, Rev. 00, "Test Procedure, Seismic Qualification of the San Onofre MNSA Clamps for Pressurizer Instrument Nozzles and RTD Hot Leg Nozzles".
19. IOC PENG-96-501, Assessment of Test Personnel Certificates for 1997.
20. Report CENC-1743, "Addendum to Analytical Report for Southern California Edison San Onofre Unit No. 3 Pressurizer," December 1986.
21. PP-2007241, Rev. 00, Project Plan for MNSA Clamp Analysis and Testing.

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

**TABLE 1**  
EQUIPMENT AND INSTRUMENTATION

INSTRUMENTATION	MANUFACTURER	MODEL NO.	SERIAL NO.	RANGE	ACCURACY	CAL DATE - DUE DATE
Seismic Motion Amplif. Unit	ABB/C-E	---	---	---	N/A	N/A
Hydraulic Shaker	MTS	104.61	412	---	N/A	N/A
Shaker Controller	MTS	406.11	1866	---	N/A	N/A
Shaker Control Unit	MTS	436.11AB	463	---	---	N/A
Digital Vibration Control and Analysis System	Time Data Corp.	P/N 2931-073 TDV25-P	Unit C-E	---	---	Q.A. Verification of Software Used
Control Accelerometers	Unholtz-Dickie	190-PA	492 & 494	1 & 10G	$\pm 5\%$ of Rdg.*	*04/28/97 - 10/28/97 & 04/29/97 - 10/29/97
Signal Conditioners	Unholtz-Dickie	2216X	145 & 146	1 & 10G	$\pm 2\%$ of Rdg.*	04/28/97 - 10/28/97
Response Accelerometers	Unholtz-Dickie	75D21PA	109 & 111	10G - 30G	$\pm 5\%$ of Rdg.*	04/25/97 - 04/25/98
Charge Amplifiers	Unholtz-Dickie	D-22H	2025 & 5482	10G - 30G	$\pm 2\%$ of Rdg.*	04/16/97 - 04/16/98
Tape Recorder	Racal	Store 7DS	6330	10V Input	$\pm 2\%$ of Rdg.	Signal Cal., 05/15/97 - 05/15/98
Digital Multimeter	Fluke	8050A	6168012	2V & 10V	$\pm (0.2\% \text{ of Rdg.})$	12/18/96 - 12/18/97
Personal Computer System	Compaq	486DX-33	ABB 01718	N/A	N/A	N/A
Data Acquisition Board	Data Translation	DT2831-G	S/N 10593	0 - 10V	$<<\pm 1\%$ of Rdg.	05/14/97 - 05/14/98 Signal Cal. **
Torque Wrench	Proto	153668	CL-1031	150 ft-lb	$\pm 1\%$ of Rdg.	05/20/97 - 11/20/97
Torque Wrench	Proto		#25	250 in-lb	$\pm 4\%$ of Rdg.	04/01/97 - 04/01/98
Pressure Gauges	Softrunt	4½"	CL-1041-1043	0 - 5000 psig	½ % of full range	05/15/97 - 11/15/97

\*Overall Measurement Accuracy Better Than 5% of Reading.

\*\*See Appendix B Reference 11.

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

**TABLE 2**

TEST MATRIX, OFF-LINE ANALYSIS AND DATA FILE IDENTIFICATION

PZR Bottom Mounted Instrument Nozzles/NSA, Free Standing

TAPE RUN # NUMBER 80-30	P.C. Acquire	SRS ANALYSIS FILE NAMES FOR				
		D.A. FILE NAME	CHANNEL 0 H-CONTR.	CHANNEL 1 V-CONTR.	CHANNEL 2 RESP. NO.1	CHANNEL 3 RESP. NO.2
EXT. DAT						
45	MN OBUA1	MNOBUA1H	MNOBUA1V			
46	MN OBUA2	MNOBUA2H	MNOBUA2V			
47	MN OBUA3	MNOBUA3H	MNOBUA3V			
48	MN OBUA4	MNOBUA4H	MNOBUA4V			
49	MN OBUA5	MNOBUA5H	MNOBUA5V			
50	MN SS UA	MNSSUAH	MNSSUAV	MNSSUAN	MNSSUAP	
51	MN OBUB1	MNOBUB1H	MNOBUB1V			
52	MN OBUB2	MNOBUB2H	MNOBUB2V			
53	MN OBUB3	MNOBUB3H	MNOBUB3V			
54	MN OBUB4	MNOBUB4H	MNOBUB4V			
55	MN OBUB5	MNOBUB5H	MNOBUB5V			
56	MN SS UB	MNSSUBH	MNSSUBV	MNSSUBN	MNSSUBP	
57	MN OBUC1	MNOBUC1H	MNOBUC1V			
58	MN OBUC2	MNOBUC2H	MNOBUC2V			
59	MN OBUC3	MNOBUC3H	MNOBUC3V			
60	MN OBUC4	MNOBUC4H	MNOBUC4V			
61	MN OBUC5	MNOBUC5H	MNOBUC5V			
62	MN SS UC	MNSSUCH	MNSSUCV	MNSSUCH	MNSSUCP	
63	MN OBUD1	MNOBUD1H	MNOBUD1V			
64	MN OBUD2	MNOBUD2H	MNOBUD2V			
65	MN OBUD3	MNOBUD3H	MNOBUD3V			
66	MN OBUD4	MNOBUD4H	MNOBUD4V			
67	MN OBUD5	MNOBUD5H	MNOBUD5V			
68	MN SS UD	MNSSUDH	MNSSUDV	MNSSUDN	MNSSUDP	

Hot Leg RTD and PZR Side Mounted Nozzles with NSA

TAPE RUN # NUMBER 80-30	P.C. Acquire	FILE NAMES FOR		
		TEST INTENSITY	TEST ORIENTATION	D.A. FILE NAME H-CONTR. V-CONTR.
EXT. DAT				
10	OBE-1	A	MN OBE1	MNOB1H MNOB1V
11	OBE-2	A	MN OBE2	MNOB2H MNOB2V
12	OBE-3	A	MN OBE3	MNOB3H MNOB3V
13	OBE-4	A	MN OBE4	MNOB4H MNOB4V
14	OBE-5	A	MN OBE5	MNOB5H MNOB5V
15	SSE-1	A	MN SSE1	MNSS1H MNSS1V

\* Refer to tape recorder log sheet (Appendix A) for tape I.D. 8030

File Identification Scheme  
where  
XX-Y-ZZ  
XX = HC = Horizontal Control  
XX = VC = Vertical Control

Y = Orientation A, B, C or D


Z = O = OBE Event; Z = S = SSE Event  
Z = Event Number.

**TABLE 3**  
**REQUIRED RESPONSE SPECTRUM LEVELS**  
**AT 1/6th OCTAVE ANALYSIS FREQUENCIES**

San Onofre MNSA Nozzles

FREQUENCY [HERTZ]	OBE [G]	SSE [G]
1.00	1.00	2.00
1.12	1.20	2.40
1.25	1.45	2.92
1.41	1.75	3.50
1.58	2.07	4.14
1.78	2.56	5.12
2.00	3.20	6.40
2.21	3.73	7.46
2.50	4.51	8.02
2.83	5.46	10.92
3.12	6.00	12.00
3.50	6.00	12.00
4.00	6.00	12.00
4.49	6.00	12.00
5.04	6.00	12.00
5.62	6.00	12.00
6.32	6.00	12.00
7.13	6.00	12.00
8.00	6.00	12.00
8.98	6.00	12.00
10.00	6.00	12.00
11.31	6.00	12.00
12.70	6.00	12.00
14.29	6.00	12.00
16.00	6.00	12.00
17.93	6.00	12.00
20.10	6.00	12.00
22.63	5.16	10.32
25.40	4.48	8.96
28.51	3.89	7.78
32.00	3.37	6.74
35.92	2.93	5.86
40.32	2.54	5.08
45.25	2.21	4.42
50.80	1.91	3.82
57.02	1.66	3.32
64.00	1.50	3.00
71.84	1.50	3.00
80.63	1.50	3.00
90.51	1.50	3.00

NOTE:  
OCCASIONAL, UNDERTESTING  
AT ISOLATED FREQUENCIES  
IS PERMISSIBLE ACCORDING TO  
THE IEEE-344 GUIDELINES,  
ESPECIALLY WHEN OCCURRING  
AT LOW (LESS THAN 3 HERTZ)  
FREQUENCIES WHERE NO  
RESONANCE CONDITIONS EXIST.



Note: A less conservative spectra may be used based on the results from the Sine Sweep Test, provided they envelop the Plant Specific Curve(s) of Appendix A.

FIGURE 1: REQUIRED RESPONSE SPECTRA





FIGURE 2: REPRESENTATIVE MNSA CLAMP DETAILS



① BOTTOM PRESSURIZER MHSA SEISMIC TEST ASSEMBLY

Item	Notes
1	BOTTOM PRESSURIZER MHSA BASEFLANGE
2	TOP PLATE
3	UPPER FLANGE (TOP)
4	LOWER FLANGE
5	COMPRESSOR COLLAR
6	SEAL WASHER
7	BOTTOM FLANGE GASKET, SEAL
8	TOP HEAD
9	MHK 5500
10	ANTI-ROTATIONAL WASHER, (2)PC
11	MHK 5000 GASKET
12	ANTI-ROTATIONAL WASHER, (1)PC
13	MHK 5000 GASKET
14	SCREW M6 ANGULAR POSITION
15	BOTTOM FLANGE ASSEMBLY, TUBE, FLANGE
16	UPPER FLANGE ASSEMBLY

FIGURE 3: REPRESENTATIVE TEST FIXTURE AND MOUNTING DETAILS

W-PEN-93  
Rev. 00  
Ref. T.R. No. TS071A

**ABB/COMBUSTION ENGINEERING**

Contract No. 2007241  
Total of Test 47 Pages  
Appendices 89 Pages




FIGURE 4: HYDRAULIC VIBRATION TEST FACILITY




FIGURE 5: HOT LEG RTD AND PZR SIDE MOUNTED NOZZLES WITH MNSAs  
DURING SEISMIC TEST

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages




FIGURE 7: VIEW OF PRESSURE GAUGES AND  
HAND PUMP




FIGURE 6: PZR SIDE MOUNTED NOZZLE  
SEISMIC TEST SET-UP

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages




FIGURE 8: HOT LEG RTD NOZZLE WITH MNSA,  
SEISMIC TEST SET-UP




FIGURE 9: HOT LEG RTD NOZZLE WITH MNSA,  
VERTICAL & HORIZONTAL RESPONSE  
ACCELEROMETER

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages




FIGURE 10: BOTTOM MOUNTED INSTRUMENTED NOZZLE WITH MNSA, FREE STANDING




FIGURE 11: BOTTOM MOUNTED INSTRUMENTED NOZZLE WITH MNSA, SUPPORTED




FIGURE 12: BOTTOM MOUNTED INSTRUMENTED NOZZLE WITH MNSA, RESPONSE ACCELEROMETER MOUNTING BLOCK AT VALVE MASS TOP




FIGURE 13: BOTTOM MOUNTED INSTRUMENTED NOZZLE WITH MNSA, RESPONSE ACCELEROMETER AT NOZZLE TOP AND TOP MNSA PLATE

1 TEST ID: SIM1008  
2 HEADING: SONGS MNSA CLAMPS

SWEEP PARAMETERS:

3 MODE 0=LOG(DEC), 1=LOG(OCT), 0=LIN: 2  
4 START, END FREQ, HZ: 1.000,50.00  
FREQ RANGE, DEC=1.598  
5 SPECIFICATION 1=RATE, 0=DURATION: 1  
RATE, DEC/MIN: .2500  
SWEEP DURATION -- HRS, MIN, SEC: 0,6,47

TEST LENGTH:

6 SPECIFICATION 1=TIME, 0=SWEET CYCLES: 0  
CYCLES: 1.000  
TEST TIME -- HRS, MIN, SEC: 0,6,47

7 START-UP TIME, SEC: 10.00  
8 SHUT-DOWN TIME, SEC: 5.000

REFERENCE SPECTRUM:

9 UNITS 1=METRIC, 0=NON-METRIC: 0

10 SPECTRUM LIMITS:  
DISPLACEMENT, IN(P-P): 2.500  
VELOCITY, IN/SEC: 10.00  
ACCELERATION, G: .2000

11 TYPE, VALUE, FREQ: 2,.1000,1.100  
ALARM LIMIT +DB, -DB: 3.000,-3.000  
ABORT LIMIT +DB, -DB: 10.00,-10.00

12 TYPE, VALUE, FREQ: 3,.2000,2.000  
ALARM LIMIT +DB, -DB: 3.000,-3.000  
ABORT LIMIT +DB, -DB: 10.00,-10.00

13 TYPE, VALUE, FREQ: 2,.2000,50.00  
ALARM LIMIT +DB, -DB: 10.00,-10.00  
ABORT LIMIT +DB, -DB: 40.00,-40.00

14 TEST LEVEL (DB BELOW REF): 0.

15 CONTROL CHANNELS: 1  
PROCESS 3=AUG ABS, 2=FUND, 1=PEAK, 0=RMS: 2

16 LIMIT CHANNELS: 0

17 AUXILIARY CHANNELS: 2,3,4  
PROCESS 3=AUG ABS, 2=FUND, 1=PEAK, 0=RMS: 2  
MAXIMUM EXPECTED G: 1.500

18 ACCEL SENS, MU/G:  
CH 1: 10000.  
CH 2: 10000.  
CH 3: 1000.  
CH 4: 1000.

19 FILTER 1=PROPORTIONAL BW, 0=FIXED BW: 1  
BW, %: 50.00


20 REFERENCE CHANNEL: 1  
21 RESPONSE CHANNEL: 2  
22 MONITOR CHANNEL: 3

23 COMPRESSION SPEED 2=HIGH, 1=NORMAL, 0=LOW: 1  
24 LOOP-CHECK FREQ(HZ), MAX DRIVE(VOLTS): 2.000,.2000


REFERENCE LEVELS:  
MAX DISPLACEMENT, IN(P-P): 1.957  
MAX VELOCITY, IN/SEC: 6.150  
MAX ACCELERATION, G: .2000  
MIN ACCELERATION, G: .1000  
ACCELERATION RANGE, DB: 6.020

CORRECTIONS?

FIGURE 14: DVCS INPUT PARAMETERS FOR SINE SWEEP RESONANCE SURVEYS USING SN21T VERSION 04



RUN 2 SINWRF2  
SONGS MNSA CLAMPS



RUN 2 SINWRF2  
SONGS MNSA CLAMPS

FIGURE 15: TRANSFER FUNCTION PLOTS, PRESSURIZER-TEMPERATURE NOZZLE, TEST ORIENTATION A




FIGURE 16: TRANSFER FUNCTION PLOTS, PRESSURIZER LOWER LEVEL INSTRUMENTATION NOZZLE, TEST ORIENTATION A, FREE STANDING




FIGURE 17: TRANSFER FUNCTION PLOTS, PRESSURIZER LOWER LEVEL INSTRUMENTATION NOZZLE, TEST ORIENTATION D, FREE STANDING




FIGURE 18: TRANSFER FUNCTION PLOTS, PRESSURIZER LOWER LEVEL INSTRUMENTATION NOZZLE, TEST ORIENTATION A, SUPPORTED




FIGURE 19: TRANSFER FUNCTION PLOTS, PRESSURIZER LOWER LEVEL INSTRUMENTATION NOZZLE, TEST ORIENTATION D, SUPPORTED





FIGURE 20: TRANSFER FUNCTION PLOTS, HOT LEG TEMPERATURE RTD NOZZLE, TEST ORIENTATION A

1 HEADING:SONGS MNSA SLE	1 HEADING:SONGS MNSA OBE
2 SENSITIVITY(MU/G):1000.	2 SENSITIVITY(MU/G):1000.
3 SHOCK RESP DEFN 0=ABS ACCEL 1=REL DISPL:0	3 SHOCK RESP DEFN 0=ABS ACCEL 1=REL DISPL:0
4 DAMPING COEFF:.01	4 DAMPING COEFF:.01
5 MAX FREQ:50	5 MAX FREQ:50
6 # OF DECADES 0=2 1=2.3 2=2.6 3=3.3	6 # OF DECADES 0=2 1=2.3 2=2.6 3=3.3
7 WAVE PARAMETERS	7 WAVE PARAMETERS
FREQ AMPL	FREQ AMPL
1 1.	1.
2 1.12	1.12
3 1.25	1.25
4 1.41	1.41
5 1.58	1.58
6 1.77	1.77
7 1.99	1.99
8 2.23	2.23
9 2.51	2.51
10 2.81	2.81
11 3.16	3.16
12 3.56	3.56
13 3.98	3.98
14 4.47	4.47
15 5.01	5.01
16 5.62	5.62
17 6.31	6.31
18 7.01	7.01
19 7.94	7.94
20 8.91	8.91
21 10.	10.
22 11.12	11.12
23 12.63	12.63
24 14.12	14.12
25 15.84	15.84
26 17.78	17.78
27 19.95	19.95
28 22.38	22.38
29 25.11	25.11
30 28.17	28.17
31 31.62	31.62
32 35.48	35.48
33 39.81	39.81
34 44.65	44.65
35 50.1	50.1
8 PEAK WAVELET AMPL(U):10.	8 PEAK WAVELET AMPL(U):10.
9 AUTO MODE LEVEL SEQ 0=FULL	9 AUTO MODE LEVEL SEQ 0=FULL
FIRST:3	FIRST:3
NEXT:2	NEXT:2
NEXT:2	NEXT:2
NEXT:1	NEXT:1
NEXT:1	NEXT:1
10 EXTERNAL TRIGGER MODE 0=NO 1=YES:1	10 EXTERNAL TRIGGER MODE 0=NO 1=YES:1
11 ALARM BAND 1	11 ALARM BAND 1
+DB LIMIT:3.	+DB LIMIT:3.
-DB LIMIT:-3.	-DB LIMIT:-3.
UPPER FREQ, Hz:50.	UPPER FREQ, Hz:50.
CORRECTIONS 0=NO 1=YES:	CORRECTIONS 0=NO 1=YES:

FIGURE 21: DVCS INPUT PARAMETERS FOR OBE AND SSE TEST EVENTS





FIGURE 22: TEST ORIENTATIONS FOR SEISMIC QUALIFICATION TEST

Unfiltered Time History



Low-Pass Filtered Time History ... 100.0 (Hertz)




FIGURE 23: HORIZONTAL CONTROL ACCELEROMETER TIME HISTORY, TEST ORIENTATION A, OBE EVENT NO. 5




FIGURE 24: VERTICAL CONTROL ACCELEROMETER TIME HISTORY, TEST ORIENTATION A, OBE EVENT NO. 5

Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnob5h.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	0.92
1.12	1.15
1.26	1.70
1.41	2.09
1.59	2.40
1.78	3.05
2.00	3.85
2.24	4.52
2.52	5.49
2.83	7.15
3.17	8.08
3.56	8.89
4.00	7.88
4.49	8.08
5.04	8.08
5.66	8.11
6.35	8.45
7.13	10.23
8.00	10.43
8.98	8.81
10.08	8.09
11.31	9.88
12.70	8.83
14.25	8.82
16.00	9.56
17.96	10.48
20.16	10.27
22.63	15.29
25.40	20.69
28.51	14.36
32.00	8.05
35.92	5.04
40.32	3.68
45.25	4.32
50.80	3.53
57.02	4.17
64.00	3.50
71.84	3.80
80.63	3.60
90.51	3.01

## RESPONSE SPECTRUM




FIGURE 25: HORIZONTAL CONTROL ACCELEROMETER TRS &amp; RRS, TEST ORIENTATION A, OBE EVENT NO. 5

Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnob5v.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
(HERTZ) [G]

1.00	1.07
1.12	1.25
1.26	1.83
1.41	2.62
1.59	2.71
1.78	3.20
2.00	3.95
2.24	4.37
2.52	5.30
2.83	6.78
3.17	7.76
3.56	8.13
4.00	7.95
4.49	8.14
5.04	8.34
5.66	7.66
6.35	8.54
7.13	10.41
8.00	9.23
8.98	7.79
10.08	7.95
11.31	9.62
12.70	8.89
14.25	9.56
16.00	9.13
17.96	9.83
20.16	10.33
22.63	14.41
25.40	20.11
28.51	13.70
32.00	9.29
35.92	5.36
40.32	4.38
45.25	4.49
50.80	4.13
57.02	4.16
64.00	4.80
71.84	4.36
80.63	3.81
90.51	3.04





FIGURE 26: VERTICAL CONTROL ACCELEROMETER TRS &amp; RRS, TEST ORIENTATION A, OBE EVENT NO. 5

Unfiltered Time History



Low-Pass Filtered Time History ... 100.0 [Hertz]





FIGURE 27: HORIZONTAL CONTROL ACCELEROMETER TIME HISTORY, TEST ORIENTATION A, SSE EVENT

Unfiltered Time History



Low-Pass Filtered Time History ... 100.0 (Hertz)




FIGURE 28: VERTICAL CONTROL ACCELEROMETER TIME HISTORY, TEST ORIENTATION A, SSE EVENT

Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnss1h.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	2.22
1.12	2.57
1.26	3.93
1.41	4.47
1.59	4.65
1.78	6.06
2.00	7.47
2.24	8.08
2.52	10.93
2.83	12.95
3.17	13.29
3.56	16.50
4.00	13.70
4.49	13.94
5.04	14.62
5.66	15.18
6.35	13.66
7.13	14.73
8.00	17.76
8.98	15.83
10.08	15.41
11.31	15.26
12.70	19.52
14.25	17.00
16.00	16.41
17.96	17.73
20.16	23.65
22.63	31.77
25.40	35.31
28.51	21.23
32.00	14.08
35.92	11.02
40.32	11.82
45.25	8.84
50.80	10.40
57.02	8.47
64.00	7.72
71.84	7.96
80.63	7.01
90.51	7.54

RESPONSE SPECTRUM




FIGURE 29: HORIZONTAL CONTROL ACCELEROMETER TRS & RRS, TEST ORIENTATION A, SSE EVENT

Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnsslv.khh DAMPING 1.00 (%)

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	1.95
1.12	2.56
1.26	3.58
1.41	5.30
1.59	5.06
1.78	6.41
2.00	7.31
2.24	8.02
2.52	10.71
2.83	12.43
3.17	13.47
3.56	17.18
4.00	13.94
4.49	14.55
5.04	13.67
5.66	14.92
6.35	13.74
7.13	15.40
8.00	17.34
8.98	17.00
10.08	14.97
11.31	15.27
12.70	19.96
14.25	15.95
16.00	16.35
17.96	18.07
20.16	21.81
22.63	29.16
25.40	34.29
28.51	20.82
32.00	15.11
35.92	10.72
40.32	10.12
45.25	10.71
50.80	10.10
57.02	8.54
64.00	7.56
71.84	7.39
80.63	6.62
90.51	6.11




FIGURE 30: VERTICAL CONTROL ACCELEROMETER TRS &amp; RRS, TEST ORIENTATION A, SSE EVENT

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

APPENDIX A  
DATA SHEETS AND LOG SHEETS

TEST ID. S-2

## DATA SHEET SINE SHEEP TEST

TEST DESCRIPTION 50455 Measuring ClampsTR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071AABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMSContract No. 2007241  
Total of Text 47 Pages  
Appendices 89 PagesDATE C-12-97ENGINEER J. HARRISTECHNICIAN G. G.

RUN NO.	DIGITAL VIBRATION CONTROL SYSTEM CHANNEL				CHARGE AMPLIFIER				ACCEL.				SENSITIVITY	COMMENTS
	A	B	C	D	A	B	C	D	A	B	C	D		
1	H.C.	V.C.	H.R.	V.R.	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	HOT LEG CLAMP + SCALE
2	H	P	P	P	"	"	"	"	"	"	"	"	"	"
3	V	P	P	P	"	"	"	"	"	"	"	"	"	SIDE PRESS. RD W/CLAMP + SEA ①
4	L	P	H.Q.	H.Q.	"	"	"	"	"	"	"	"	"	RELEAS VALVE RD W/CLAMP, CABLE + VALVE
5	L	P	"	"	"	"	"	"	"	"	"	"	"	"
6	V	P	"	"	"	"	"	"	"	"	"	"	"	Releas Valv w/Valve Supply Rd, Univolt + A
7	P	P	"	"	"	"	"	"	"	"	"	"	"	②
8	P	P	H.A.	V.R.	"	"	"	"	"	"	"	"	"	"
9	P	P	"	"	"	"	"	"	"	"	"	"	"	"

AMPLIFIER NO.	CONTROL	CONTROL	HORIZONTAL	VERTICAL	1	2	3	4	5	6	13	14	15	16	17
FULL SCALE RANGE SETTING	/2	/2													

TR-PENG-033

Rev. 00

Ref. T.R. No. TS071A

## ABB/COMBUSTION ENGINEERING

## PRIMARY SYSTEMS

Contract No. 2007241

Total of Text 47 Pages

Appendices 89 Pages

TAPE DATA LOG SHEETTEST SONG MENDO CLAMPSDATE 6-14-87TECHNICIAN G. E. WilliamsENGINEER R. H. HaslingerLOG SHEET NO. 1HOOKUP SHEET NO. 1/ARECORD SPEED 3 3/4RECORD BAND WB

REEL NO.	RUN NO.	FOOTAGE	ATTENUATOR - AMPLIFIER SETTING							COMMENTS
			1	2	3	4	5	6	7	
59-36	10	236	HF 10	V.C. 10						OBK 1 FOR LAG + SIDE PAPER RFD's
	11	266								OBK 2
	12	277								OBK 3
	13	295								OBK 4
	14	316								OBK 5
	15	328								SSK 1
	16	347								BOTTOM MANSA, ORLEN A OBK 1
	17	358								BOTTOM MANSA, ORLEN A OBK 2
	18	376								BOTTOM MANSA OBK 3 ORLEN A
	19	392								BOTTOM MANSA OBK 4 ORLEN A
	20	409								BOTTOM MANSA OBK 5 ORLEN A
	21	425								BOTTOM MANSA SSK 1 ORLEN A
	22	442								BOTTOM MANSA OBK 1 ORLEN B
	23	460								BOTTOM MANSA OBK 2 ORLEN B
	24	476	9	0						BOTTOM MANSA OBK 3 ORLEN B

TAPE DATA LOG SHEETTEST S-165 MASA CRANEDATE 6-16-97TECHNICIAN G. D. WILLIAMSENGINEER R. H. HASELWATERLOG SHEET NO. 2HOOKUP SHEET NO. N/ARECORD SPEED 3 3/4RECORD BAND W B

REEL NO.	RUN NO.	FOOTAGE	ATTENUATOR - AMPLIFIER SETTING							COMMENTS
			1	2	3	4	5	6	7	
50-30	25	492	145	V.C.						TOPPA MASA OBE 4 ORLEN B
			10V	UV						10V
	26	510	(S)	(S)						BOTTOM MASA OBE 5 ORLEN B
	27	529	(S)	(S)						BOTTOM MASA SSG 1 ORLEN B
	28	545	(S)	(S)						BOTTOM MASA OBE 1 ORLEN C
	29	562	(S)	(S)						BOTTOM MASA OBE 2 ORLEN C
	30	580	(S)	(S)						BOTTOM MASA OBE 3 ORLEN C
	31	598	(S)	(S)						BOTTOM MASA OBE 4 ORLEN C
	32	616	(S)	(S)						BOTTOM MASA OBE 5 ORLEN C
	33	632	(S)	(S)						BOTTOM MASA SSG 1 ORLEN C
	34	648	(S)	(S)						BOTTOM MASA OBE 1 ORLEN D
	35	664	(S)	(S)						BOTTOM MASA OBE 2 ORLEN D
	36	680	(S)	(S)						BOTTOM MASA OBE 3 ORLEN D
	37	696	(S)	(S)						BOTTOM MASA OBE 4 ORLEN D
	38	714	(S)	(S)						BOTTOM MASA OBE 5 ORLEN D
	39	732	(S)	(S)						BOTTOM MASA SSG 1 ORLEN D

DATA SHEET 3  
NOZZLE PRESSURE TEST OBSERVATIONSDate: 6-14-97Observation: 82.6Reviewed By: JH MarshallTest Nozzle: SIDE PRESS. R12

	Nozzle Test Pressure		Comment
	Prior to Event	Following Event	
Orientation A			
OBE1	3150	3150	PRESSURE GAGE IP. CL 1042
OBE2	3125	3125	
OBE3	3100	3100	
OBE4	3160	3150	
OBE5	3150	3150	
SSE1	3200	3200	
Orientation B			
OBE1			
OBE2			
OBE3			
OBE4			
OBE5			
SSE1			Due to Axis Symmetry, Testing limited to one Orientation
Orientation C			
OBE1			
OBE2			
OBE3			
OBE4			
OBE5			
SSE1			
Orientation D			
OBE1			
OBE2			
OBE3			
OBE4			
OBE5			
SSE1			

DATA SHEET 3  
NOZZLE PRESSURE TEST OBSERVATIONSDate: 6-14-97Observation: G.O.W.Reviewed By: K. H. Husler Jr.Test Nozzle: HOT LEG RTD

	Nozzle Test Pressure		Comment
	Prior to Event	Following Event	
Orientation A			
OBE1	3,200	3,200	PRESSURE GAUGE RA CL1+41
OBE2	3,200	3,200	
OBE3	3,175	3,175	
OBE4	3,175	3,175	
OBE5	3,175	3,175	
SSE1	3,200	3,190	
Orientation B			
OBE1			
OBE2			
OBE3			
OBE4			
OBE5			
SSE1			Due to Axis Symmetry
Orientation C			Testing limited to one Orientation
OBE1			
OBE2			
OBE3			
OBE4			
OBE5			
SSE1			
Orientation D			
OBE1			
OBE2			
OBE3			
OBE4			
OBE5			
SSE1			

DATA SHEET 3  
NOZZLE PRESSURE TEST OBSERVATIONSDate: 6-14-97Observation: G.A.U.Reviewed By: J.L. HurlingerTest Nozzle: BOTTOM PLATE RIV  
Instrumentation Nozzle

	Nozzle Test Pressure		Comment
	Prior to Event	Following Event	
Orientation A			
OBE1	3,200	3,200	PRESSURE GAGE CL 10%
OBE2	3,200	3,200	
OBE3	3,200	3,200	
OBE4	3,200	3,200	
OBE5	3,175	3,175	
SSE1	3,175	3,175	
Orientation B			
OBE1	3,225	3,225	
OBE2	3,200	3,200	
OBE3	3,200	3,200	
OBE4	3,175	3,175	
OBE5	3,175	3,175	
SSE1	3,200	3,200	
Orientation C			
OBE1	3,250	3,250	
OBE2	3,200	3,200	
OBE3	3,200	3,200	
OBE4	3,200	3,200	
OBE5	3,200	3,200	
SSE1	3,200	3,200	
Orientation D			
OBE1	3,175	3,175	
OBE2	3,200	3,200	
OBE3	3,200	3,175	
OBE4	3,200	3,200	
OBE5	3,175	3,175	
SSE1	3,175	3,175	

TR-PENG-013  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

DATA SHEET SINE SLEEP TEST

TEST ID. SINMN1

DATE 6-17-97

ENGINEER AH HANUCHA

TECHNICIAN G WILLEMS

RUN NO.	DIGITAL VIBRATION CONTROL SYSTEM CHANNEL				CHARGE AMPLIFIER				ACCEL.	SENSITIVITY			COMMENTS	
	A	B	C	D	1	2	3	4		A	B	C	D	
1	H.C.	V.C.	H.R. MASS	V.R. MASS	4	1/25	1/125	1/125	100°	42.5	76.15	76.3°	"	Bottom mass vertical seal 1/2" unistow mass (D)
2	"	"	H.R. NOZZLE	H.R. PLATE	"	"	"	"	"	"	"	"	"	(D) nozzle plate
3	"	"	H.R. MASS	V.R. MASS	"	"	"	"	"	"	"	"	"	(A) mass
4	"	"	"	"	"	"	"	"	"	"	"	"	"	N.G.
5	"	"	"	"	"	"	"	"	"	"	"	"	"	N.G.
6	"	"	"	"	"	"	"	"	"	"	"	"	"	(A) mass
7	"	"	H.R. NOZZLE	H.R. PLATE	"	"	"	"	"	"	"	"	"	(A) nozzle plate
8	"	"	"	"	"	"	"	"	"	"	"	"	"	
9	"	"	"	"	"	"	"	"	"	"	"	"	"	

AMPLIFIER NO.	CONTROL HORIZONTAL	CONTROL VERTICAL	1	2	3	4	5	6	13	14	15	16	17
FULL SCALE RANGE SETTING	1 <sub>2</sub>	1 <sub>5</sub>								30 <sub>2</sub>	30 <sub>3</sub>		

TAPE DATA LOG SHEETTEST Sengs Bottom mnsaLOG SHEET NO. 1DATE 6-12-97HOOKUP SHEET NO. A1ATECHNICIAN G.V. WilliamsRECORD SPEED 9 ipsENGINEER Karl H. HartwigRECORD BAND WB

REEL NO.	RUN NO.	FOOTAGE	ATTENUATOR - AMPLIFIER SETTING							COMMENTS
			1	2	3	4	5	6	7	
50-30	40	752	H.C.	V.C.						Bottom mnsa ORLEN D
	41	768								OBE 1 NOT SUPPORTED
	42	784								Bottom mnsa NOT SUPPORTED OBE 2 ORLEN D
	43	800								Bottom mnsa NOT SUPPORTED OBE 3 ORLEN D
	44	816								Bottom mnsa NOT SUPPORTED OBE 4 ORLEN D
	45	832								OBE 5 ORLEN D
	46	849								OBE 1 ORLEN A
	47	866								OBE 2 ORLEN A
	48	882								OBE 3 ORLEN A
	49	898								OBE 4 ORLEN A
	50	914								OBE 5 ORLEN A
	51	930								OBE 1 ORLEN B
	52	946								OBE 2 ORLEN B
	53	962								OBE 3 ORLEN B
	54	979	P	V						OBE 4 ORLEN B
										OBE 5 ORLEN B

TAPE DATA LOG SHEET

TEST SONGS B.L.T.D.R. R.H.S.A.  
DATE 6-18-97

LOG SHEET NO. 2

HOOKUP SHEET NO. 4/4

RECORD SPEED 72

RECORD BAND

## DATA SHEET 3

## NOZZLE PRESSURE TEST OBSERVATIONS

Date: 6-18-97Reviewed By: Karl H. HartingerObservation: G. D. WilliamsTest Nozzle: BOTTOM MNSA  
UNSUPPORTED

	Nozzle Test Pressure		Comment
	Prior to Event	Following Event	
Orientation A			
OBE1	3,200	3,200	PRESSURE GAGE CL 1641
OBE2	3,175	3,175	MNSA IS NOT SUPPORTED
OBE3	3,200	3,200	
OBE4	3,200	3,200	
OBE5	3,175	3,175	
SSE1	3,200	3,150	+ NO VISIBLE SIGN OF LEAKAGE?
Orientation B			
OBE1	3,200	3,200	
OBE2	3,175	3,175	
OBE3	3,175	3,175	
OBE4	3,175	3,175	
OBE5	3,175	3,150	* small drop during load (air?)? held pressure after load.
SSE1	3,200	3,175	
Orientation C			
OBE1	3,225	3,200	
OBE2	3,200	3,200	
OBE3	3,200	3,200	
OBE4	3,200	3,200	
OBE5	3,200	3,175	
SSE1	3,200	3,175	
Orientation D			
OBE1	3,200	3,200	
OBE2	3,200	3,200	
OBE3	3,200	3,200	
OBE4	3,200	3,200	
OBE5	3,200	3,200	
SSE1	3,175	3,150	

APPENDIX B

1 VOLT PEAK SIGNAL CALIBRATION CHECK  
OFF-LINE ANALYSIS SYSTEM


Page B2, As recorded by Data Acquisition System for Each of Six (6) Channels,

Page B3, As Registered by the Off-Line Analysis Program SRSKHH for Single Channel


Note:

Calibration Check Consisted of Passing Nominal 100 Hertz Signal (+/- 1 Volt Peak) into PC based Data Acquisition System, Digitizing at Sample Rate of 5000 (each Channel), Display of Portions of Sampled Data by Data Acquisition System, and Finally Display of Portions of Sampled Data by Time History Display Section of Response Spectrum Analysis Code SRSKHH.


Calibration Performed May 14, 1997.



Unfiltered Time History



Low-Pass Filtered Time History ... 1000. Charts 2



TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 200/241  
Total of Text 47 Pages  
Appendices 89 Pages

APPENDIX C  
CALIBRATION RECORDS



### NON-PERMANENT QUALITY RECORD CERTIFICATE OF CALIBRATION

Instrument Type Digital Multimeter  
 Manufacturer Fluke (8050A)  
 Range Multi Accuracy See Mfg Spec.  
 Mfg. Serial No. 6168012  
 C-E ID No. N/A

Calibration Date 12-18-96  
 Calibration Due Date 12-18-97   
 Calibration Document:  
 Procedure \_\_\_\_\_ Rev. \_\_\_\_\_  
 Manufacturer's Specifications TMS-188/1984

#### Test Equipment Used To Perform Calibration:

Test Equipment	Serial or ID No.
<u>Fluke 8050A</u>	<u>CL-2006</u>
<u>Fluke 5100B</u>	<u>16-565</u>

Test Equipment	Serial or ID No.

NIST # 811/254750, 811/254993-95

#### CALIBRATION RESULTS

Standard Value	As Found	As Left	Out of Tol.
<u>Table 4-5 dB/Voltage Test</u>			
Steps	Display		
1	-81	Same	
2	-37.77		
3	-37.76		
4	+2.23		
<u>Table 4-6 Current Test</u>			
Steps	Display		
1	190.14	Same	
2	190.13		
3	18.984		
4	189.80		
5	1859.7		
A/C	18.979		

Standard Value	As Found	As Left	Out of Tol.
<u>Table 4-7 Resistance Test</u>			
Steps	Display		
1	00.01	Same	
2	100.12		
3	.9997		
4	10.001		
5	100.00		
6	1000.0		
7	10.007		
8	1,0000		
9	99.93		

THIS CALIBRATION WAS PERFORMED IN ACCORDANCE WITH PROCEDURE #00000-EES-208-00  
 CALIBRATION HAS BEEN PERFORMED UTILIZING MEASUREMENT DEVICES WHICH HAVE KNOWN RELATIONSHIPS TO NIST STANDARDS WHERE SUCH STANDARDS EXIST. WHERE SUCH STANDARDS DO NOT EXIST, AN APPROVED PROCEDURE WRITTEN IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS HAS BEEN USED AND THE STANDARDS DOCUMENTED.

REMARKS: A \* one year cal. cycle per request

ACCEPTED       REJECTED

CALIBRATED BY: R. L. Brown

Electronics and Electrical Systems

TEMPERATURE 71 °F

HUMIDITY 53 %

Page 1 of 2

Page C-2

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

**ABB/COMBUSTION ENGINEERING**  
**PRIMARY SYSTEMS**

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages



**NON-PERMANENT  
QUALITY RECORD**  
**CERTIFICATE OF CALIBRATION**

Instrument Type Pressure Gauge  
Manufacturer U.S. Gauge  
Range 0-1000 psig Accuracy  $\pm 1\%$   
Mfg. Serial No. N/A  
C.E. ID No. C.L. 1041

Calibration Date 5-15-97  
Calibration Due Date 11-15-97  
Calibration Document:  Procedure Grade E10-91 Rev. B2  
 Manufacturer's Specifications

Test Equipment Used To Perform Calibration:  
Test Equipment MFG DWT Serial or ID No. 11-96H

Test Equipment  Serial or ID No.

MIST # 822/249420

**CALIBRATION RESULTS**

Standard Value	As Found	As Left	Out of Tolerance
0.00	0.00		
1000	1000		
2000	2000		
3000	3000		
4000	3970		
5000	4150		
6000	7000		
7000	1000		
8000	0		
9000			
10000			

Standard Value	As Found	As Left	Out of Tolerance
0.00	0.00		
1000	1000		
2000	2000		
3000	3000		
4000	3970		
5000	4150		
6000	7000		
7000	1000		
8000	0		
9000			
10000			

This calibration was performed in accordance with procedure grade E10-91 Rev. B2. Calibration has been performed utilizing measurement devices which have known relationships to test standards where such standards exist. Where such standards do not exist, an approved procedure written in accordance with the manufacturer's recommendations has been used and the standards documented.

REMARKS: A

ACCEPTED     REJECTED

CALIBRATED BY John Doe

Witnessed and Verified by John Doe

TEMPERATURE 72°F  
HUMIDITY 50%



**NON-PERMANENT  
QUALITY RECORD**  
**CERTIFICATE OF CALIBRATION**

Instrument Type Pressure Gauge  
Manufacturer U.S. Gauge  
Range 0-1000 psig Accuracy  $\pm 1\%$   
Mfg. Serial No. N/A  
C.E. ID No. C.L. 1041

Calibration Date 5-15-97  
Calibration Due Date 11-15-97  
Calibration Document:  Procedure Grade E10-91 Rev. B2  
 Manufacturer's Specifications

Test Equipment Used To Perform Calibration:  
Test Equipment MFG DWT Serial or ID No. 11-96H

Test Equipment  Serial or ID No.

MIST # 822/249420

**CALIBRATION RESULTS**

Standard Value	As Found	As Left	Out of Tolerance
0.00	0.00		
1000	1000		
2000	2000		
3000	3000		
4000	3970		
5000	4150		
6000	7000		
7000	1000		
8000	0		
9000			
10000			

This calibration was performed in accordance with procedure grade E10-91 Rev. B2. Calibration has been performed utilizing measurement devices which have known relationships to test standards where such standards exist. Where such standards do not exist, an approved procedure written in accordance with the manufacturer's recommendations has been used and the standards documented.

REMARKS: A

ACCEPTED     REJECTED

CALIBRATED BY John Doe

Witnessed and Verified by John Doe

TEMPERATURE 72°F  
HUMIDITY 50%



**NON-PERMANENT  
QUALITY RECORD**  
**CERTIFICATE OF CALIBRATION**

Instrument Type Pressure Gauge  
Manufacturer U.S. Gauge  
Range 0-1000 psig Accuracy  $\pm 1\%$   
Mfg. Serial No. N/A  
C.E. ID No. C.L. 1041

Calibration Date 5-15-97  
Calibration Due Date 11-15-97  
Calibration Document:  Procedure Grade E10-91 Rev. B2  
 Manufacturer's Specifications

Test Equipment Used To Perform Calibration:  
Test Equipment MFG DWT Serial or ID No. 11-96H

Test Equipment  Serial or ID No.

MIST # 822/249420

**CALIBRATION RESULTS**

Standard Value	As Found	As Left	Out of Tolerance
0.00	0.00		
1000	1000		
2000	2000		
3000	3000		
4000	4000		
5000	5000		
6000	6000		
7000	7000		
8000	8000		
9000	9000		
10000	10000		

This calibration was performed in accordance with procedure grade E10-91 Rev. B2. Calibration has been performed utilizing measurement devices which have known relationships to test standards where such standards exist. Where such standards do not exist, an approved procedure written in accordance with the manufacturer's recommendations has been used and the standards documented.

REMARKS: A

ACCEPTED     REJECTED

CALIBRATED BY John Doe

Witnessed and Verified by John Doe

TEMPERATURE 72°F  
HUMIDITY 50%

NON-PERMANENT  
QUALITY RECORD  
CERTIFICATE OF CALIBRATION

Instrument Type Signal Conditioner  
 Manufacturer Wohlfritz-Dickis  
 Range Watt Accuracy ±2%  
 Mfg. Serial No. 143  
 C-E ID No. EL-694

Calibration Date 4-28-97  
 Calibration Due Date 10-28-97  
 Calibration Document:  
 I I Procedure \_\_\_\_\_ Rev. \_\_\_\_\_  
 I X Manufacturer's Specification TMS-00Y

## Test Equipment Used To Perform Calibration:

Test Equipment	Serial or ID No.
Fluke	C1-2085
Fluke	C1-2084

Test Equipment	Serial or ID No.
_____	_____
_____	_____

H131 # 521/240585, 251971, 521/242057, 228/245850, 246698

## CALIBRATION RESULTS

Standard Value	As Found	As Left	Out of Tol.
<u>Full Scale Calibration</u>			
Input @ 50 Hz Tap 0 Out			
707 mVrms	7.067 Vrms		
<u>Frequency Response</u>			
50 Hz	7.0704		
100	7.0786		
200	7.0824		
300	7.0874		
500	7.0824		

Standard Value	As Found	As Left	Out of Tol.
<u>Gain</u> <u>Measured</u>			
Input 707 V @ 50 Hz			
Tap 0 Dial Tap 0 Out			
1.00	7.0711		
8.00	5.6543		
6.00	4.2384		
4.00	2.8235		
2.00	1.4147		
<u>Freq Response Tap 0 Dial @ 0.00</u>			
50 Hz	7.0693		
100	7.0784		
200	7.0814		
300	7.0857		
500	7.0814		

THIS CALIBRATION WAS PERFORMED IN ACCORDANCE WITH PROCEDURE #00000-EES-206-00

CALIBRATION HAS BEEN PERFORMED UTILIZING MEASUREMENT DEVICES WHICH HAVE KNOWN RELATIONSHIPS TO NIST STANDARDS WHERE SUCH STANDARDS EXIST. WHERE SUCH STANDARDS DO NOT EXIST, AN APPROVED PROCEDURE WRITTEN IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS HAS BEEN USED AND THE STANDARDS DOCUMENTED.

REMARKS: A

ACCEPTED

REJECTED

TEMPERATURE 70°f  
HUMIDITY 46%

CALIBRATED BY: Chase

Electrical and Mechanical Systems



**NON-PERMANENT  
QUALITY RECORD**

Instrument Type Signal Conditioner  
Manufacturer Whetstone-Dickis  
Range Multi Accuracy  $\pm 2\%$   
Mfg. Serial No. 146  
C-E ID No. EL-695

Calibration Date 4-28-97  
Calibration Due Date 10-28-97  
Calibration Document:  
 Procedure \_\_\_\_\_ Rev. \_\_\_\_\_  
 Manufacturer's Specifications TMS-008

**Test Equipment Used To Perform Calibration:**

<u>Test Equipment</u>	<u>Serial or ID No.</u>
Fluke	CL-2085
Fluke	CL-2084

**Test Equipment** \_\_\_\_\_ **Serial or ID No.** \_\_\_\_\_

N121-#521/240595 251971, 521/242872, 728/245850, 246498

#### CALIBRATION RESULTS

Standard Value	As Found	As Left	Out of Tol.
Fw 11 Seats Calibration			
Input @ 50Hz Tape Out			
70.7 mVrms	7.0699 Vrms		
<hr/>			
Frequency Response			
50 Hz	7.0698		
100	7.0777		
200	7.0814		
300	7.0855		
500	7.0725		

Standard Value	As Found	As Left	Out of Tolerance
<u>Gain Accuracy</u>			
Input 70.7 mV @ 50 Hz			
Tape Dial	tape Out		
10.00	7.0696		
8.00	5.4602		
6.00	4.2453		
4.00	2.8310		
2.00	1.4161		
Frequency Response Tape Dial @ 10.00			
50 Hz	7.0721		
100	7.0801		
200	7.0836		
300	7.0876		
500	7.0747		

THIS CALIBRATION WAS PERFORMED IN ACCORDANCE WITH PROCEDURE #000000-EES-106-00

CALIBRATION HAS BEEN PERFORMED UTILIZING MEASUREMENT DEVICES WHICH HAVE KNOWN RELATIONSHIPS TO NIST STANDARDS WHERE SUCH STANDARDS EXIST. WHERE SUCH STANDARDS DO NOT EXIST, AN APPROVED PROCEDURE WRITTEN IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS HAS BEEN USED AND THE STANDARDS DOCUMENTED

REMARKS: A

I ACCEPTED

I REJECTED

CALIBRATED BY: E. Hayes

Electronics and Electrical Systems

TEMPERATURE 70° F  
HUMIDITY 46%

Page 1 of 1

Page C-5



**NON-PERMANENT  
QUALITY RECORD  
CERTIFICATE OF CALIBRATION**

Instrument Type Signal Card / Accel  
 Manufacturer Hobart-Dickie  
 Range Multi Accuracy +5%  
 Mfg. Serial No. 146 492  
 C-E ID No. EL-695 EL-696

Calibration Date 4-29-97

Calibration Due Date 10-29-97

## Calibration Document:

Procedure \_\_\_\_\_ Rev. \_\_\_\_\_

Manufacturer's Specifications

#### **Test Equipment Used To Perform Calibration:**

Test Equipment	Serial or ID No
Philips	CL-2077
Fluke	CL-2084
Columbia	CL-2083

Test Equipment      Serial or ID No.

---

---

---

1157 524/240585, 251971, 521/642571, 728/245750, 246698, 822/256179

## CALIBRATION RESULTS

THIS CALIBRATION WAS PERFORMED IN ACCORDANCE WITH SECTION 101, PART 100, OF THE

THE CALIBRATION WAS PERFORMED IN ACCORDANCE WITH PROCEDURE #00000-EES-108-00  
CALIBRATION HAS BEEN PERFORMED UTILIZING MEASUREMENT DEVICES WHICH HAVE KNOWN RELATIONSHIPS TO NIST  
STANDARDS WHERE SUCH STANDARDS EXIST. WHERE SUCH STANDARDS DO NOT EXIST, AN APPROVED PROCEDURE WRITTEN  
IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS HAS BEEN USED AND THE STANDARDS DOCUMENTED.

REMARKS: A Chg Sens @ 50 Hz · 100 mV

~~✓~~ ACCEPTED

1185 REJECTED

CALIBRATED SET

Electrical and Electrical Systems

TEMPERATURE 70 °F

HUMIDITY 46%



**NON-PERMANENT  
QUALITY RECORD  
CERTIFICATE OF CALIBRATION**

Instrument Type Spiral Cond./Focel Calibration Date 4-28-97  
Manufacturer Unibattz-Dickir Calibration Due Date 10-28-97  
Range Mult. Accuracy  $\pm 5\%$  Calibration Document:  
Mfg. Serial No. 145 / 494  Procedure \_\_\_\_\_ Rev. \_\_\_\_  
C-E ID No. EL-694 / EL-698  Manufacturer's Specifications

**Test Equipment Used To Perform Calibration:**

<u>Test Equipment</u>	<u>Serial or ID No.</u>	<u>Test Equipment</u>	<u>Serial or ID No.</u>
Philips	CL-2077		
ELNA	CL-2084		
Columbia	CL-2083		
WIZI 45A / 240355 251971 521/472552	228/405850 246638	522/256179	

## CALIBRATION RESULTS

THIS CALIBRATION WAS PERFORMED IN ACCORDANCE WITH PROCEDURE #00000-ESS-108-00  
CALIBRATION HAS BEEN PERFORMED UTILIZING MEASUREMENT DEVICES WHICH HAVE KNOWN RELATIONSHIPS TO NIST  
STANDARDS WHERE SUCH STANDARDS EXIST. WHERE SUCH STANDARDS DO NOT EXIST, AN APPROVED PROCEDURE WRITTEN  
IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS HAS BEEN USED AND THE STANDARDS DOCUMENTED

REMARKS: A Chg. Sins. @ 50 Hz = 98.5 mV / g

I ACCEPTED

L1 REJECTED

CALIBRATED BY:

Electroacoustic Systems

TEMPERATURE 70°f  
HUMIDITY 46%

TR-PENG-033

Rev. 00

Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMSContract No. 2007241  
Total of Text 47 Pages  
Appendices 89 PagesNON-PERMANENT  
QUALITY RECORD  
CERTIFICATE OF CALIBRATION

Instrument Type Charge Amplifier  
 Manufacturer Unholtz-Dickie  
 Range Multi Accuracy  $\pm 2\%$   
 Mfg. Serial No. 2025  
 C-E ID No. EL-942

Calibration Date 4-16-97  
 Calibration Due Date 4-16-97 (9/14/97)  
 Calibration Document:  
 Procedure \_\_\_\_\_ Rev. \_\_\_\_\_  
 Manufacturer's Specifications TMS-008

## Test Equipment Used To Perform Calibration:

Test Equipment	Serial or ID No.
FLUKE 3500	CL-2085
FLUKE 3840A	CL-2084

NIST 514025, 251915N/40577, 228/495850, 246598

Test Equipment	Serial or ID No.

## CALIBRATION RESULTS

Standard Value	As Found	As-Is	Out of Tol.
F-Cal	7.0694		
SINT @	1-10		
Dial	10.00		
Input (1kHz) Meter tape Out			
Range -1			
0.07 mV rms / 100% 7.0825			
Range -10			
0.07 mV / 100% 7.0718			
Range -100			
0.07 mV / 100% 7.1146			
Range -1000			
0.07 Vrms / 100% 7.1366			

Standard Value	As Found	As-Is	Out of Tol.
Range -10			
Input 1kHz Tape Gain Tape Out			
70.7mV 10.00 7.0718			
8.00 5.6525			
6.00 4.2428			
4.00 2.8310			
2.00 1.4161			
Input 70.7mV			
50 Hz 10.00 7.0599			
100			7.0585
200			7.0707
300			7.0711
500			7.0714
1000			7.0714
2000			7.0716

THIS CALIBRATION WAS PERFORMED IN ACCORDANCE WITH PROCEDURE #00000-EE3-108-00

CALIBRATION HAS BEEN PERFORMED UTILIZING MEASUREMENT DEVICES WHICH HAVE KNOWN RELATIONSHIPS TO NIST STANDARDS WHERE SUCH STANDARDS EXIST. WHERE SUCH STANDARDS DO NOT EXIST, AN APPROVED PROCEDURE WRITTEN IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS HAS BEEN USED AND THE STANDARDS DOCUMENTED

REMARKS: A

 ACCEPTED REJECTED

TEMPERATURE 71°f

HUMIDITY 46%

CALIBRATED BY:

Electronics and Electrical Systems

Page 1 of 1



NON-PERMANENT  
QUALITY RECORD  
CERTIFICATE OF CALIBRATION

Instrument Type Charge Amplifier  
Manufacturer Whetstone-Dickis  
Range 0.1V to 1V Accuracy  $\pm 2\%$   
Mfg. Serial No. 5482  
C-E ID No. EL-1844

Calibration Date 4-16-97  
Calibration Due Date 10-16-97  
Calibration Document: 4-16-98 15  
 Procedure Rev.  
 Manufacturer's Specifications MS-008/1974

Test Equipment Used To Perform Calibration:

Test Equipment	Serial or ID No.
Eutek 5330	CL-2085
Eutek 8840A	CL-2084

Test Equipment	Serial or ID No.

NIST 521240585, 251971, 521612577, 22844850, 246698

CALIBRATION RESULTS

Standard Value	As Found	As Left	Out of Tol.
FCal	7.0677		
Sine @	1-10		
Dial @	10.00		
Input (1KHz) Meter tape Out			
Range -1			
2.07 mV rms / 100 $\Omega$	7.0860		
Range -10			
20.7 mV	100 $\Omega$	7.0693	
Range -100			
207 mV	100 $\Omega$	7.0976	
Range -1000			
2.07 V rms	100 $\Omega$	7.0691	

Standard Value	As Found	As Left	Out of Tol.
Range -10			
Input 1K Hz Tape Gain Tape Out			
20.7 mV rms	10.00	7.0691	
8.00	5.6546		
6.00	4.2441		
4.00	2.8341		
2.00	1.4230		
Input 70.7 mV			
50 Hz	10.00	7.0554	
100		7.0647	
200		7.0674	
300		7.0680	
500		7.0686	
1000		7.0691	
2000		7.0693	

THIS CALIBRATION WAS PERFORMED IN ACCORDANCE WITH PROCEDURE #00000-EE5-208-00  
CALIBRATION HAS BEEN PERFORMED UTILIZING MEASUREMENT DEVICES WHICH HAVE KNOWN RELATIONSHIPS TO NIST STANDARDS WHERE SUCH STANDARDS EXIST. WHERE SUCH STANDARDS DO NOT EXIST, AN APPROVED PROCEDURE WRITTEN IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS HAS BEEN USED AND THE STANDARDS DOCUMENTED.

REMARKS: A

ACCEPTED

REJECTED

CALIBRATED BY:

Electronics and Electrical Systems

TEMPERATURE 71 °F  
HUMIDITY 46 %

Page C-9

Page C-9



**NON-PERMANENT  
QUALITY RECORD  
CERTIFICATE OF CALIBRATION**

Instrument Type	<u>Accelerometer</u>	Calibration Date	<u>4-25-97</u>
Manufacturer	<u>Unisoltz-Dickie</u>	Calibration Due Date	<u>4-25-98</u>
Range	<u>N/A</u>	Accuracy	<u>±5%</u>
Mfg. Serial No.	<u>109</u>	Calibration Document:	
C-E ID No.	<u>N/A</u>	<input type="checkbox"/> Procedure	Rev. <u>  </u>
		<input type="checkbox"/> Manufacturer's Specifications	

**Test Equipment Used To Perform Calibration:**

<u>Test Equipment</u>	<u>Serial or ID No.</u>	<u>Test Equipment</u>	<u>Serial or ID No.</u>
Philips	CL-2072	Whitlitz-Dickie	EL-942
Fluke	CL-2084		
Columbia	CL-2083		

## CALIBRATION RESULTS

THIS CALIBRATION WAS PERFORMED IN ACCORDANCE WITH PROCEDURE #00000-EES-208-00  
CALIBRATION HAS BEEN PERFORMED UTILIZING MEASUREMENT DEVICES WHICH HAVE KNOWN RELATIONSHIPS TO  
STANDARDS WHERE SUCH STANDARDS EXIST. WHERE SUCH STANDARDS DO NOT EXIST, AN APPROVED PROCEDURE WRITTEN  
IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS HAS BEEN USED AND THE STANDARDS DOCUMENTED

REMARKS: A Chg SENS = 75.15 pC/g @ 50 Hz

~~X~~ ACCEPTED

REJECTED

EJECTED  
TEMPERATURE 70° f

HUMIDITY 47%

CALIBRATED BY:

Sharing and Dispersal Strategies



**NON-PERMANENT  
QUALITY RECORD**

Instrument Type Accelerometer  
Manufacturer Uhlhertz-Dickis  
Range N/A Accuracy ± 5%  
Mfg. Serial No. 111  
C-E ID No. N/A

Calibration Date 4-25-97  
Calibration Due Date 4-25-98  
Calibration Document:  
 Procedure \_\_\_\_\_ Rev. \_\_\_\_\_  
 Manufacturer's Specifications

#### **Test Equipment Used To Perform Calibration:**

Test Equipment	Serial or ID No.	Test Equipment	Serial or ID No.
Philips	CL-2077	Whitrite Dickie	EL-942
Fluke	CL-2084		
Columbia	CL-2083		

#### CALIBRATION RESULTS

THE CALIBRATION WAS PERFORMED IN ACCORDANCE WITH PROCEDURE #0000-000-000-000  
CALIBRATION HAS BEEN PERFORMED UTILIZING MEASUREMENT DEVICES WHICH HAVE KNOWN RELATIONSHIPS TO NIST  
STANDARDS WHERE SUCH STANDARDS EXIST WHERE SUCH STANDARDS DO NOT EXIST, AN APPROVED PROCEDURE WRITTEN  
IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS HAS BEEN USED AND THE STANDARDS DOCUMENTED

REMARKS: A Chg SENS = 75.80  $\mu$ C/g @ 50 Hz

~~✓~~ ACCEPTED

## I. REJECTED

CALIBRATED BY:

Document ID: 13

TESTED  
TEMPERATURE 70° F

HUMIDITY 47%

**SIGNAL CHECKS, STORE 7 RECORDER, CHANNELS 1-7**

CAL DATE: 05-15-97 DUE DATE: 05-15-98

TECH. G.D.W. ENG. K.H.H.

**1 V ATTEN. RECORD SPEED 7 1/2 - DC INPUT**

INPUT VOLT (all channels)		OUTPUT VOLT				OUTPUT VOLT		
DCV	ATTEN.	CH. 1 DCV	CH. 2 DCV	CH. 3 DCV	CH. 4 DCV	CH. 5 DCV	CH. 6 DCV	CH. 7 DCV
1.000	1.000	0.984	0.989	0.988	1.001	0.995	1.005	1.006
0.800	0.800	0.796	0.800	0.800	0.805	0.795	0.803	0.805
0.600	0.600	0.586	0.588	0.588	0.602	0.585	0.602	0.604
0.400	0.400	0.396	0.399	0.399	0.401	0.395	0.401	0.402
0.200	0.200	0.186	0.197	0.199	0.188	0.194	0.201	0.201
0.000	0.000	-0.005	-0.004	-0.001	-0.003	-0.005	0.001	0.000

**2 V ATTEN. RECORD SPEED 7 1/2 - DC INPUT**

INPUT VOLT (all channels)		OUTPUT VOLT				OUTPUT VOLT		
DCV	ATTEN.	CH. 1 DCV	CH. 2 DCV	CH. 3 DCV	CH. 4 DCV	CH. 5 DCV	CH. 6 DCV	CH. 7 DCV
2.000	1.000	0.989	0.993	0.993	1.002	0.992	0.999	1.000
1.600	0.800	0.794	0.798	0.797	0.803	0.795	0.801	0.803
1.200	0.600	0.586	0.588	0.588	0.602	0.585	0.600	0.601
0.800	0.400	0.394	0.397	0.398	0.401	0.395	0.400	0.401
0.400	0.200	0.195	0.197	0.199	0.200	0.195	0.201	0.202
0.000	0.000	-0.005	-0.003	-0.000	-0.001	-0.004	0.002	0.001

**3 V ATTEN. RECORD SPEED 7 1/2 - DC INPUT**

INPUT VOLT (all channels)		OUTPUT VOLT				OUTPUT VOLT		
DCV	ATTEN.	CH. 1 DCV	CH. 2 DCV	CH. 3 DCV	CH. 4 DCV	CH. 5 DCV	CH. 6 DCV	CH. 7 DCV
5.000	1.000	0.983	0.997	0.995	1.003	0.993	0.998	1.000
4.000	0.800	0.795	0.798	0.798	0.805	0.796	0.801	0.803
3.000	0.600	0.585	0.588	0.588	0.603	0.586	0.601	0.602
2.000	0.400	0.392	0.396	0.399	0.401	0.395	0.399	0.399
1.000	0.200	0.192	0.195	0.197	0.199	0.194	0.199	0.199
0.000	0.000	-0.005	-0.013	-0.000	-0.000	-0.004	0.002	0.001

**10 V ATTEN. RECORD SPEED 7 1/2 - DC INPUT**

INPUT VOLT (all channels)		OUTPUT VOLT				OUTPUT VOLT		
DCV	ATTEN.	CH. 1 DCV	CH. 2 DCV	CH. 3 DCV	CH. 4 DCV	CH. 5 DCV	CH. 6 DCV	CH. 7 DCV
10.000	1.000	0.984	0.987	0.985	1.004	0.994	0.997	1.000
8.000	0.800	0.795	0.798	0.797	0.803	0.796	0.801	0.801
6.000	0.600	0.585	0.588	0.588	0.603	0.585	0.600	0.601
4.000	0.400	0.394	0.397	0.398	0.403	0.395	0.400	0.401
2.000	0.200	0.193	0.195	0.197	0.200	0.195	0.200	0.199
0.000	0.000	-0.005	-0.000	-0.000	-0.000	-0.004	0.002	0.001

SIGNAL CALIBRATION  
EQUIPMENT:

TYPE	MANUFACTURER	MOD	S/N	CAL DATE	DUCE DATE
INPUT VOLT	FLUKE	8050A	6168012	12-18-96	12-18-97
OUTPUT VOLT	FLUKE	8050A	6168012	12-18-96	12-18-97

Range used for Storage and Retrieval of Sea Onofre MNSA Seismic Data.

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

# Quality Plus Inc - *Metrology Services*

ACCEPTED *J. J. Pava*

DATE 4/16/97

**CUSTOMER:**

ABB COMBUSTION ENGINEERING  
1000 PROSPECT HILL RD.  
WINDSOR CT 06095  
P.O.# 44716KP

**DATE:** 04/01/97  
**GAGE TYPE:** TORQUE WRENCH  
**MAKE:** PROTO  
**SER#: #25**  
**DATE DUE:** 04/01/98

THE FOLLOWING TORQUE WRENCH WAS CALIBRATED PER QUALITY PLUS, INC.  
PROCEDURE QP-652 WITH A CONTROL DATE OF 03/31/96. IN ACCORDANCE  
WITH QUALITY PLUS, INC. QUALITY MANUAL, REV.B, 3-31-95. MARTE USED IS  
TSD 6000, S/N 1/P223, CALB. ON 3/22/97. N.L.S.T. TEST# 821/257176-04  
TOLERANCE: +/- 4% IN/LBS/16CPH21 APPLIED.

*Mark Lab 225*

ACTUAL RESULTS

CAL.POINT	IN/LBS	AS FOUND		AFTER ADJUSTMENT	
		CLOCKWISE	COUNTERCLOCKW	CLOCKWISE	COUNTERCLOCKW
50	IN/LBS	49.50	50.20		
100	IN/LBS	98.80	100.20		NO ADJUSTMENTS
150	IN/LBS	148.50	150.00		REQUIRED
200	IN/LBS	197.00	201.20		
250	IN/LBS	246.80	250.40		

INSPECTED BY: *David F. Roy*

GAGE CALIBRATION • FIRST ARTICLE INSPECTION • REPAIRS • GRANITE PLATE RESURFACING • CASTING LAYOUT  
TORQUE CALIBRATION • ON SITE CALIBRATION • PRESSURE GAGE CALIBRATION • CMM CONTRACT INSPECTION  
170 Grove Street • Chicopee MA 01020 • (413) 594-5529 • (413) 594-5596 fax

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages



ACCEPTED *[Signature]*  
DATE 5/20/97

PLYMOUTH INDUSTRIAL PARK  
CORNER OF NAPCO AND CONTAINER DRIVES  
P.O. BOX 46  
TERRYVILLE, CONNECTICUT 06786  
TELEPHONE 203/583-2050

PRECISION  
INSPECTION, Inc.

TORQUE CALIBRATION CERTIFICATE

REPORT NUMBER: 21301-2

PO Number: 45676KP

DATE OF CALIBRATION: 5/20/97

CUSTOMER: ABB Combustion Engineering

**CALIBRATION**

INSTRUMENT: Torque Wrench, 150 ft/lbs.

DUE DATE 11-20-97

S/N: CL-1031 MAKE: Proto 153668

<u>CLOCKWISE</u>	<u>PERCENT OF RANGE</u>				
	20%	40%	60%	80%	100%
INDICATED WRENCH TORQUE:	30'lbs.	60'lbs.	90'lbs.	120'lbs.	150'lbs.
ACTUAL TORQUE:	30'lbs.	60'lbs.	90'lbs.	120'lbs.	149'lbs.

COUNTERCLOCKWISE

INDICATED  
WRENCH TORQUE:

ACTUAL TORQUE:

PROCEDURE: #32

TEMPERATURE /HUMIDITY: 68°/41%

THIS INSTRUMENT WAS CALIBRATED USING MASTER CALIBRATOR

SERIAL NO. 5217

CALIBRATED ON 6/17/96 DUE: 6/17/98

TRACEABLE TO THE NIST THROUGH NIST TEST NO. MMAP 822/LA

*Chris Berlin*  
CALIBRATION TECHNICIAN

Ref. ANSI B107.14

Ref. Federal Spec. GGG-W-686

MIL-W-26497

Calibration conforms to ANSI Z540-1

Estimated level of accuracy is  $\pm 1\%$

APPENDIX D  
OFF-LINE ANALYSIS - RESULTS  
GRAPHS & TABULATIONS

Hot Leg RTD Nozzle and PZR Side Mounted Nozzle

Input Test Response Spectra for 5 OBE Events and 1 SSE Event in one Test Orientation (Axis-Symmetric Specimens)

Pages D2 through D11 Horizontal & Vertical OBE Spectra  
Pages D12 & D13 Horizontal & Vertical SSE Spectra

PZR Bottom Mounted PZR Instrument Nozzle, Supported Configuration

Input Test Response Spectra for 1 OBE and 1 SSE Events in Each of Four Test Orientations

Pages D14 through D17 Orientation A  
Pages D18 through D21 Orientation B  
Pages D22 through D25 Orientation C  
Pages D26 through D29 Orientation D

PZR Bottom Mounted PZR Instrument Nozzle, Free Standing Test Configuration

Input Test Response Spectra for 1 OBE and 1 SSE Events in Each of Four Test Orientations

Pages D30 through D33 Orientation A  
Pages D34 through D37 Orientation B  
Pages D38 through D41 Orientation C  
Pages D42 through D45 Orientation D

Time Histories for 4 SSE Events, for Horizontal Nozzle Top and Horizontal MNSA Top Plate

Pages D46 and D47 Orientation A  
Pages D48 and D49 Orientation B  
Pages D50 and D51 Orientation C  
Pages D52 and D53 Orientation D

Test Response Spectra for 4 SSE Events, for Horizontal Nozzle Top and Horizontal MNSA Top Plate

Pages D54 and D55 Orientation A  
Pages D56 and D57 Orientation B  
Pages D58 and D59 Orientation C  
Pages D60 and D61 Orientation D


Note: Graphs can be identified by File Number in combination with Table 2.

Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnoblh.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
(HERTZ) [G]

1.00	0.95
1.12	1.03
1.26	1.81
1.41	2.15
1.59	2.53
1.78	3.57
2.00	3.69
2.24	4.49
2.52	5.42
2.83	7.13
3.17	7.82
3.56	8.74
4.00	7.77
4.49	8.16
5.04	7.94
5.66	7.98
6.35	8.40
7.13	10.33
8.00	9.60
8.98	8.47
10.08	8.09
11.31	9.31
12.70	8.69
14.25	8.97
16.00	9.05
17.96	11.00
20.16	9.43
22.63	12.74
25.40	18.70
28.51	22.12
32.00	7.89
35.92	5.35
40.32	4.34
45.25	3.92
50.80	3.19
57.02	4.41
64.00	3.13
71.84	3.15
80.63	3.53
90.51	3.06



Analysis Code: SRSKHH Version 1


DATA FILE c:\gl\mnob1v.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	1.09
1.12	1.01
1.26	1.70
1.41	2.16
1.59	2.69
1.78	3.39
2.00	3.86
2.24	4.49
2.52	5.36
2.83	7.10
3.17	7.40
3.56	8.16
4.00	7.63
4.49	8.06
5.04	7.50
5.66	8.18
6.35	7.97
7.13	9.30
8.00	9.59
8.98	8.44
10.08	7.57
11.31	9.03
12.70	8.56
14.25	8.95
16.00	8.99
17.96	11.18
20.16	8.90
22.63	11.26
25.40	18.35
28.51	19.56
32.00	7.34
35.92	5.36
40.32	4.99
45.25	4.07
50.80	4.64
57.02	4.71
64.00	3.32
71.84	3.76
80.63	3.47
90.51	3.46

## RESPONSE SPECTRUM



TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A

ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS


Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnob2h.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	0.96
1.12	1.10
1.26	1.98
1.41	2.23
1.59	2.80
1.78	3.04
2.00	3.95
2.24	4.39
2.52	5.45
2.83	7.47
3.17	7.67
3.56	8.37
4.00	7.88
4.49	8.25
5.04	7.59
5.66	8.02
6.35	8.70
7.13	9.70
8.00	9.58
8.98	8.61
10.08	8.00
11.31	9.76
12.70	8.82
14.25	9.06
16.00	9.29
17.96	10.84
20.16	9.48
22.63	13.25
25.40	19.99
28.51	17.01
32.00	8.09
35.92	4.60
40.32	3.96
45.25	3.58
50.80	3.29
57.02	3.24
64.00	3.05
71.84	3.35
80.63	3.14
90.51	3.59




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnob2v.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	0.94
1.12	1.21
1.26	1.71
1.41	2.11
1.59	2.69
1.78	3.17
2.00	4.04
2.24	4.13
2.52	5.71
2.83	7.19
3.17	7.75
3.56	8.38
4.00	8.36
4.49	7.81
5.04	8.19
5.66	8.01
6.35	8.28
7.13	10.70
8.00	9.37
8.98	9.01
10.08	8.15
11.31	9.72
12.70	8.35
14.25	8.67
16.00	9.28
17.96	10.55
20.16	9.13
22.63	11.99
25.40	20.47
28.51	16.78
32.00	7.17
35.92	4.80
40.32	4.54
45.25	5.28
50.80	4.00
57.02	3.54
64.00	3.34
71.84	3.04
80.63	3.06
90.51	3.06



Analysis Code: SRSKHH Version 1


DATA FILE C:\gl\mnob3h.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	0.91
1.12	1.15
1.26	1.84
1.41	2.27
1.59	2.71
1.78	3.33
2.00	3.97
2.24	4.28
2.52	5.72
2.83	7.50
3.17	8.02
3.56	8.78
4.00	7.99
4.49	8.25
5.04	7.78
5.66	8.06
6.35	8.54
7.13	10.29
8.00	9.60
8.98	8.34
10.08	8.10
11.31	9.83
12.70	8.90
14.25	9.06
16.00	9.51
17.96	10.94
20.16	9.72
22.63	14.46
25.40	20.83
28.51	14.99
32.00	8.01
35.92	4.72
40.32	3.70
45.25	3.73
50.80	3.13
57.02	3.91
64.00	3.46
71.84	3.93
80.63	3.70
90.51	3.21

## RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnob3v.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
(HERTZ) [G]

1.00	0.89
1.12	0.94
1.26	1.76
1.41	2.14
1.59	2.76
1.78	3.34
2.00	3.70
2.24	4.21
2.52	5.46
2.83	7.47
3.17	7.93
3.56	8.33
4.00	7.74
4.49	8.16
5.04	7.81
5.66	7.68
6.35	8.30
7.13	10.11
8.00	9.27
8.98	8.06
10.08	8.21
11.31	9.70
12.70	9.02
14.25	8.76
16.00	8.59
17.96	10.86
20.16	9.83
22.63	13.74
25.40	20.25
28.51	14.22
32.00	7.69
35.92	5.84
40.32	4.54
45.25	3.90
50.80	4.03
57.02	4.79
64.00	3.65
71.84	3.73
80.63	3.65
90.51	2.88

## RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnob4h.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	1.06
1.12	0.98
1.26	1.62
1.41	2.40
1.59	2.76
1.78	3.30
2.00	3.93
2.24	4.40
2.52	5.62
2.83	7.41
3.17	7.68
3.56	8.95
4.00	7.78
4.49	8.16
5.04	7.78
5.66	7.83
6.35	8.25
7.13	9.98
8.00	9.57
8.98	8.92
10.08	8.21
11.31	9.89
12.70	8.91
14.25	9.09
16.00	9.33
17.96	10.77
20.16	10.19
22.63	15.21
25.40	20.03
28.51	14.44
32.00	8.57
35.92	5.18
40.32	4.10
45.25	3.97
50.80	3.77
57.02	3.38
64.00	3.87
71.84	3.89
80.63	3.45
90.51	3.53



Analysis Code: SRSKHM Version 1


DATA FILE c:\gl\mnob4v.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	1.02
1.12	1.26
1.26	1.64
1.41	2.37
1.59	2.52
1.78	3.40
2.00	4.22
2.24	4.46
2.52	5.80
2.83	6.87
3.17	7.45
3.56	8.90
4.00	7.88
4.49	8.15
5.04	7.50
5.66	7.77
6.35	7.98
7.13	9.97
8.00	9.41
8.98	8.84
10.08	7.89
11.31	9.34
12.70	8.51
14.25	8.66
16.00	9.10
17.96	10.16
20.16	9.16
22.63	15.16
25.40	19.99
28.51	13.98
32.00	7.97
35.92	4.82
40.32	5.86
45.25	4.56
50.80	4.55
57.02	3.82
64.00	3.93
71.84	3.78
80.63	3.32
90.51	3.54

RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnob5h.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

FREQUENCY [HERTZ]	ACCELERATION [G]
1.00	0.92
1.12	1.15
1.26	1.70
1.41	2.09
1.59	2.40
1.78	3.05
2.00	3.85
2.24	4.52
2.52	5.49
2.83	7.15
3.17	8.08
3.56	8.89
4.00	7.88
4.49	8.08
5.04	8.08
5.66	8.11
6.35	8.45
7.13	10.23
8.00	10.43
8.98	8.81
10.08	8.09
11.31	9.88
12.70	8.83
14.25	8.82
16.00	9.56
17.96	10.48
20.16	10.27
22.63	15.29
25.40	20.69
28.51	14.36
32.00	8.05
35.92	5.04
40.32	3.68
45.25	4.32
50.80	3.53
57.02	4.17
64.00	3.50
71.84	3.80
80.63	3.60
90.51	3.01




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnob5v.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	1.07
1.12	1.25
1.26	1.83
1.41	2.62
1.59	2.71
1.78	3.20
2.00	3.95
2.24	4.37
2.52	5.30
2.83	6.78
3.17	7.76
3.56	8.13
4.00	7.95
4.49	8.14
5.04	8.34
5.66	7.66
6.35	8.54
7.13	10.41
8.00	9.23
8.98	7.79
10.08	7.95
11.31	9.62
12.70	8.89
14.25	9.56
16.00	9.13
17.96	9.83
20.16	10.33
22.63	14.41
25.40	20.11
28.51	13.70
32.00	9.29
35.92	5.36
40.32	4.38
45.25	4.49
50.80	4.13
57.02	4.16
64.00	4.80
71.84	4.36
80.63	3.81
90.51	3.04

### RESPONSE SPECTRUM



Analysis Code: SRSKHH Version 1


DATA FILE c:\gl\mnss1h.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	2.22
1.12	2.57
1.26	3.93
1.41	4.47
1.59	4.65
1.78	6.06
2.00	7.47
2.24	8.08
2.52	10.93
2.83	12.95
3.17	13.29
3.56	16.50
4.00	13.70
4.49	13.94
5.04	14.62
5.66	15.18
6.35	13.66
7.13	14.73
8.00	17.76
8.98	15.83
10.08	15.41
11.31	15.26
12.70	19.52
14.25	17.00
16.00	16.41
17.96	17.73
20.16	23.65
22.63	31.77
25.40	35.31
28.51	21.23
32.00	14.08
35.92	11.02
40.32	11.82
45.25	8.84
50.80	10.40
57.02	8.47
64.00	7.72
71.84	7.96
80.63	7.01
90.51	7.54

## RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE C:\gl\mnss1v.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]


1.00	1.95
1.12	2.56
1.26	3.58
1.41	5.30
1.59	5.06
1.78	6.41
2.00	7.31
2.24	8.02
2.52	10.71
2.83	12.63
3.17	13.47
3.56	17.18
4.00	13.94
4.49	14.55
5.04	13.67
5.66	14.92
6.35	13.74
7.13	15.40
8.00	17.34
8.98	17.00
10.08	14.97
11.31	15.27
12.70	19.96
14.25	15.95
16.00	16.35
17.96	18.07
20.16	21.81
22.63	29.16
25.40	34.29
28.51	20.82
32.00	15.11
35.92	10.72
40.32	10.12
45.25	10.71
50.80	10.10
57.02	8.54
64.00	7.56
71.84	7.39
80.63	6.62
90.51	6.11



Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnobealh.khh DAMPING 1.00 (%)

FREQUENCY [HERTZ]	ACCELERATION [G]
1.00	0.88
1.12	1.18
1.26	1.89
1.41	2.54
1.59	3.37
1.78	3.30
2.00	3.72
2.24	4.55
2.52	5.73
2.83	7.21
3.17	7.56
3.56	8.65
4.00	7.65
4.49	7.71
5.04	7.61
5.66	7.60
6.35	8.15
7.13	9.89
8.00	9.04
8.98	8.02
10.08	7.59
11.31	9.39
12.70	8.29
14.25	8.60
.00	8.91
.96	10.14
1.16	8.44
22.63	12.56
25.40	16.79
28.51	15.74
32.00	6.65
35.92	4.53
40.32	3.74
45.25	3.35
50.80	2.99
57.02	2.82
64.00	3.43
71.84	3.19
80.63	2.79
90.51	2.90




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mmobealv.khh DAMPING 1.00 (%)

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	0.86
1.12	1.10
1.26	1.70
1.41	2.31
1.59	3.32
1.78	3.49
2.00	3.51
2.24	4.41
2.52	5.52
2.83	7.37
3.17	7.16
3.56	8.33
4.00	7.82
4.49	7.83
5.04	7.46
5.66	7.43
6.35	8.15
7.13	9.52
8.00	8.73
8.98	8.10
10.08	7.22
11.31	8.65
12.70	8.23
14.25	8.29
16.00	8.87
17.96	8.84
20.16	8.02
22.63	12.46
25.40	16.21
28.51	15.54
32.00	6.75
35.92	5.10
40.32	4.60
45.25	4.50
50.80	4.05
57.02	3.91
64.00	3.73
71.84	2.68
80.63	3.25
90.51	3.14




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mn\_ss\_ah.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	1.98
1.12	2.62
1.26	3.46
1.41	4.44
1.59	4.51
1.78	6.25
2.00	7.07
2.24	8.48
2.52	11.40
2.83	12.88
3.17	13.15
3.56	16.17
4.00	14.00
4.49	14.71
5.04	13.94
5.66	13.59
6.35	14.36
7.13	13.51
8.00	17.09
8.98	14.92
10.08	13.88
11.31	13.97
12.70	18.77
14.25	15.83
16.00	16.43
17.96	17.79
20.16	23.87
22.63	28.74
25.40	36.26
28.51	20.62
32.00	14.55
35.92	10.43
40.32	10.38
45.25	8.22
50.80	7.86
57.02	7.45
64.00	7.10
71.84	7.21
80.63	7.12
90.51	7.47


## RESPONSE SPECTRUM



Analysis Code: SRSKHH Version 1

DATA FILE C:\gl\mn\_ss\_av.khh DAMPING 1.00 (%)

FREQUENCY [HERTZ]	ACCELERATION [G]
1.00	2.03
1.12	2.16
1.26	3.80
1.41	4.04
1.59	4.21
1.78	6.66
2.00	7.23
2.24	8.08
2.52	11.05
2.83	17.05
3.17	12.82
3.56	16.23
4.00	13.33
4.49	14.06
5.04	13.24
5.66	14.01
6.35	13.10
7.13	14.53
8.00	16.52
8.98	14.70
10.08	14.29
11.31	13.74
12.70	17.63
14.25	15.19
16.00	15.10
17.96	14.75
20.16	21.03
22.63	28.99
25.40	32.84
28.51	22.96
32.00	13.73
35.92	10.98
40.32	11.34
45.25	11.90
50.80	11.53
57.02	8.89
64.00	7.09
71.84	7.21
80.63	6.57
90.51	7.26




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnobebih.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	0.91
1.12	1.02
1.26	1.77
1.41	2.39
1.59	2.78
1.78	3.34
2.00	3.93
2.24	4.52
2.52	5.72
2.83	6.91
3.17	7.48
3.56	8.27
4.00	7.52
4.49	7.93
5.04	7.67
5.66	7.64
6.35	8.39
7.13	9.87
8.00	9.12
8.98	8.42
10.08	7.54
11.31	9.67
12.70	8.34
14.25	8.67
16.00	8.96
17.96	9.60
20.16	8.87
22.63	14.00
25.40	19.93
28.51	14.17
32.00	7.60
35.92	4.36
40.33	4.24
45.25	3.65
50.80	3.01
57.02	3.42
64.00	3.19
71.84	2.73
80.63	3.11
90.51	3.32




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnobeb1v.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	0.91
1.12	1.13
1.26	2.05
1.41	2.47
1.59	2.66
1.78	3.48
2.00	3.87
2.24	4.21
2.52	5.94
2.83	7.11
3.17	7.65
3.56	7.89
4.00	7.70
4.49	7.44
5.04	7.26
5.66	7.63
6.35	7.97
7.13	9.63
8.00	8.87
8.98	8.23
10.08	7.38
11.31	9.20
12.70	8.23
14.25	8.25
16.00	8.88
17.96	10.40
20.16	9.02
22.63	12.98
25.40	18.75
28.51	12.86
32.00	7.56
35.92	4.49
40.32	3.91
45.25	4.85
50.80	4.24
57.02	3.37
64.00	3.78
71.84	2.98
80.63	3.12
90.51	3.22




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mn\_ss\_bh.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	1.91
1.12	2.68
1.26	3.83
1.41	4.93
1.59	4.54
1.78	6.27
2.00	6.93
2.24	8.22
2.52	10.26
2.83	13.08
3.17	13.38
3.56	16.58
4.00	14.43
4.49	15.57
5.04	14.02
5.66	14.51
6.35	14.66
7.13	14.70
8.00	17.15
8.98	14.87
10.08	14.26
11.31	14.10
12.70	18.94
14.25	16.26
16.00	16.04
17.96	17.17
20.16	22.64
22.63	29.04
25.40	35.93
28.51	19.85
32.00	13.61
35.92	11.06
40.32	10.67
45.25	8.19
50.80	7.95
57.02	7.16
64.00	6.88
71.84	6.28
80.63	6.55
90.51	6.93

## RESPONSE SPECTRUM



Analysis Code: SRSKHH Version 1


DATA FILE c:\gl\mn\_ss\_bv.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	2.03
1.12	2.88
1.26	4.04
1.41	4.87
1.59	4.43
1.78	6.56
2.00	6.74
2.24	8.25
2.52	10.03
2.83	12.52
3.17	12.80
3.56	15.64
4.00	12.95
4.49	14.42
5.04	13.31
5.66	14.42
6.35	13.86
7.13	14.21
8.00	16.99
8.98	14.65
10.08	13.98
11.31	13.95
12.70	18.20
14.25	14.66
16.00	16.17
17.96	15.05
20.16	22.58
22.63	29.60
25.40	32.62
28.51	22.37
32.00	15.86
35.92	12.93
40.32	10.23
45.25	8.87
50.80	13.77
57.02	10.29
64.00	8.82
71.84	8.19
80.63	6.82
90.51	8.23

## RESPONSE SPECTRUM



Analysis Code: SRSKHH Version 1


DATA FILE c:\gl\mnobec1h.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	0.92
1.12	1.06
1.26	2.01
1.41	2.44
1.59	2.36
1.78	3.75
2.00	3.51
2.24	4.51
2.52	5.75
2.83	7.14
3.17	7.49
3.56	8.77
4.00	7.70
4.49	8.09
5.04	7.29
5.66	7.72
6.35	8.31
7.13	9.81
8.00	9.49
8.98	7.90
10.08	7.76
11.31	8.80
12.70	8.40
14.25	8.73
16.00	9.48
17.96	10.23
20.16	8.57
22.63	13.93
25.40	19.04
28.51	16.80
32.00	7.24
35.92	4.37
40.32	3.68
45.25	3.71
50.80	3.33
57.02	3.48
64.00	2.89
71.84	3.05
80.63	3.85
90.51	3.67

## RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnobec1v.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	0.97
1.12	1.18
1.26	1.88
1.41	2.30
1.59	2.48
1.78	2.96
2.00	3.67
2.24	4.22
2.52	5.47
2.83	7.09
3.17	7.36
3.56	8.01
4.00	7.10
4.49	7.39
5.04	7.72
5.66	7.72
6.35	7.91
7.13	9.93
8.00	9.07
8.98	7.74
10.08	7.70
11.31	8.72
12.70	8.36
14.25	8.86
16.00	8.58
17.96	10.16
20.16	9.15
22.63	12.93
25.40	17.42
28.51	14.92
32.00	8.33
35.92	5.41
40.32	5.95
45.25	4.74
50.80	5.15
57.02	5.64
64.00	3.71
71.84	3.33
80.63	3.45
90.51	4.25




Analysis Code: SKSKHH Version 1

DATA FILE c:\gl\mn\_ss\_ch.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	2.17
1.12	2.27
1.26	3.42
1.41	3.93
1.59	4.82
1.78	5.89
2.00	7.13
2.24	7.80
2.52	11.80
2.83	14.05
3.17	13.28
3.56	16.10
4.00	14.52
4.49	13.54
5.04	13.82
5.66	13.20
6.35	13.85
7.13	13.79
9.00	17.13
8.98	14.67
10.08	13.69
11.31	13.90
12.70	18.05
14.25	16.37
16.00	14.86
17.96	17.97
20.16	21.86
22.63	28.65
25.40	34.97
28.51	22.20
32.00	13.34
35.92	11.44
40.32	11.24
45.25	7.77
50.80	8.42
57.02	7.20
64.00	6.87
71.84	6.82
80.63	6.55
90.51	7.63

RESPONSE SPECTRUM




Analysis Code: SRSKHM Version 1

DATA FILE c:\gl\mn\_ss\_cv.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	2.25
1.12	2.43
1.26	3.07
1.41	4.68
1.59	4.60
1.78	6.09
2.00	7.22
2.24	8.53
2.52	11.11
2.83	14.28
3.17	13.29
3.56	15.50
4.00	14.31
4.49	13.21
5.04	13.68
5.66	13.85
6.35	13.57
7.13	14.98
8.00	16.75
8.98	15.50
10.08	14.31
11.31	14.12
12.70	18.23
14.25	16.61
16.00	16.01
17.96	15.02
20.16	23.51
22.63	29.47
25.40	32.12
28.51	19.64
32.00	13.68
35.92	12.60
40.32	12.65
45.25	9.77
50.80	9.78
57.02	10.02
64.00	8.77
71.84	6.87
80.63	8.16
90.51	7.02



Analysis Code: SRSKHH Version 1


DATA FILE c:\gl\mnobedih.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	1.00
1.12	1.12
1.26	2.01
1.41	2.25
1.59	2.77
1.78	3.69
2.00	4.00
2.24	4.30
2.52	5.73
2.83	7.38
3.17	7.67
3.56	8.33
4.00	7.64
4.49	7.82
5.04	7.58
5.66	7.78
6.35	7.81
7.13	9.46
8.00	9.30
8.98	7.77
10.08	7.52
11.31	9.22
12.70	8.47
14.25	8.50
16.00	9.00
17.96	10.09
20.16	8.57
22.63	13.49
25.40	18.05
28.51	18.37
32.00	7.23
35.92	4.91
40.32	4.50
45.25	3.84
50.80	3.14
57.02	3.23
64.00	2.87
71.84	3.01
80.63	3.00
90.51	2.79

## RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnobediv.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
(HERTZ) [G]

1.00	0.81
1.12	0.85
1.26	1.76
1.41	1.75
1.59	2.84
1.78	3.36
2.00	3.90
2.24	4.40
2.52	5.72
2.83	6.72
3.17	7.56
3.56	8.00
4.00	7.37
4.49	7.86
5.04	7.45
5.66	7.46
6.35	7.81
7.13	10.12
8.00	9.43
8.98	7.69
10.08	7.75
11.31	9.23
12.70	8.63
14.25	8.68
16.00	8.51
17.96	10.53
20.16	8.24
22.63	12.72
25.40	17.09
28.51	17.18
32.00	6.24
35.92	4.52
40.32	4.16
45.25	3.67
50.80	3.76
57.02	3.28
64.00	3.13
71.84	3.03
80.63	3.45
90.51	3.47

## RESPONSE SPECTRUM



Analysis Code: SRSKHH Version 1


DATA FILE C:\gl\mn\_ss\_dh.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	2.12
1.12	2.55
1.26	3.65
1.41	5.07
1.59	5.82
1.78	7.14
2.00	6.98
2.24	8.34
2.52	11.63
2.83	13.43
3.17	13.47
3.56	16.34
4.00	14.10
4.49	15.16
5.04	13.80
5.66	14.01
6.35	13.92
7.13	13.86
8.00	16.98
8.98	15.25
10.08	14.59
11.31	14.29
12.70	18.94
14.25	16.05
16.00	15.91
17.96	16.34
20.16	22.69
22.63	28.97
25.40	36.27
28.51	21.13
32.00	14.29
35.92	10.72
40.32	10.35
45.25	8.28
50.80	7.91
57.02	7.15
64.00	7.31
71.84	6.59
80.63	7.23
90.51	5.82

## RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE C:\gl\mn\_ss\_dv.khh DAMPING 1.00 (%)

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	2.68
1.12	2.37
1.26	3.56
1.41	4.04
1.59	5.10
1.78	6.33
2.00	7.09
2.24	8.21
2.52	11.15
2.83	13.80
3.17	13.86
3.56	16.50
4.00	13.71
4.49	14.33
5.04	13.95
5.66	15.17
6.35	13.64
7.13	14.41
8.00	17.18
8.98	15.11
10.08	13.73
11.31	14.25
12.70	17.45
14.25	15.64
16.00	14.47
17.96	17.34
20.16	21.18
22.63	29.08
25.40	32.34
28.51	20.65
32.00	14.09
35.92	11.79
40.32	11.20
45.25	8.20
50.80	11.04
57.02	8.51
64.00	7.35
71.84	6.53
80.63	6.91
90.51	7.28

RESPONSE SPECTRUM




Analysis Code: SRSKIH Version 1

DATA FILE c:\gl\mnobualh.khh DAMPING 1.00 (%)

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	0.95
1.12	1.10
1.26	1.85
1.41	2.17
1.59	2.91
1.78	3.59
2.00	3.92
2.24	4.59
2.52	5.60
2.83	7.14
3.17	7.62
3.56	8.25
4.00	7.34
4.49	7.82
5.04	7.40
5.66	7.66
6.35	7.84
7.13	9.77
8.00	9.32
8.98	7.71
10.08	7.39
11.31	8.88
12.70	8.36
14.25	8.53
16.00	8.90
17.96	10.16
20.16	8.30
22.63	12.44
25.40	18.14
28.51	17.10
32.00	7.75
35.92	4.81
40.32	4.00
45.25	3.74
50.80	3.20
57.02	3.58
64.00	2.95
71.84	3.28
80.63	3.38
90.51	3.18




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnobualv.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	1.05
1.12	1.28
1.26	1.68
1.41	2.40
1.59	2.91
1.80	3.17
2.00	3.58
2.24	4.47
2.52	5.92
2.83	7.49
3.17	7.72
3.56	7.68
4.00	7.40
4.49	7.96
5.04	7.43
5.66	7.68
6.35	7.92
7.13	9.55
8.00	9.23
8.98	7.86
10.08	7.80
11.31	8.55
12.70	8.09
14.25	8.22
16.00	8.80
17.96	9.95
20.16	7.96
22.63	11.65
25.40	17.23
28.51	15.44
32.00	7.75
35.92	4.83
40.32	4.60
45.25	4.28
50.80	4.90
57.02	4.68
64.00	3.33
71.84	3.05
80.63	3.04
90.51	3.02

## RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssuah.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION

[HERTZ]	[G]
1.00	2.21
1.12	2.75
1.26	3.64
1.41	3.86
1.59	4.51
1.78	6.45
2.00	7.82
2.24	8.05
2.52	10.97
2.83	13.19
3.17	13.49
3.56	16.27
4.00	14.07
4.49	13.68
5.04	13.88
5.66	13.92
6.35	13.55
7.13	14.81
8.00	16.50
8.98	14.89
10.08	13.61
11.31	13.62
12.70	15.89
14.25	16.85
16.00	15.18
17.96	17.73
20.16	22.27
22.63	30.75
25.40	39.70
28.51	20.42
32.00	16.46
35.92	12.18
40.32	10.31
45.25	8.42
50.80	8.98
57.02	7.32
64.00	7.77
71.84	7.05
80.63	7.46
90.51	6.17

RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssuav.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	1.91
1.12	2.57
1.26	3.20
1.41	3.96
1.59	4.50
1.78	6.23
2.00	7.98
2.24	8.55
2.52	11.02
2.83	12.05
3.17	13.10
3.56	15.35
4.00	13.66
4.49	14.68
5.04	12.74
5.66	13.91
6.35	13.21
7.13	14.04
8.00	15.65
8.98	13.75
10.08	13.72
11.31	13.51
12.70	15.96
14.25	15.75
16.00	16.46
17.96	17.39
20.16	23.57
22.63	26.83
25.40	36.46
28.51	20.01
32.00	17.29
35.92	14.46
40.32	11.76
45.25	11.12
50.80	12.29
57.02	9.05
64.00	9.33
71.84	7.83
80.63	9.47
90.51	7.35



Analysis Code: SRSKHH Version 1


DATA FILE c:\g1\mnobublh.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	0.88
1.12	1.37
1.26	1.74
1.41	2.27
1.59	2.57
1.78	3.35
2.00	4.17
2.24	4.36
2.52	5.59
2.83	7.07
3.17	7.75
3.56	8.57
4.00	7.57
4.49	7.61
5.04	7.96
5.66	7.44
6.35	7.74
7.13	9.46
8.00	8.84
8.98	7.82
10.08	7.63
11.31	8.70
12.70	8.10
14.25	8.22
16.00	9.26
17.96	10.01
20.16	8.31
22.63	13.12
25.40	18.62
28.51	13.09
32.00	7.70
35.92	4.64
40.32	3.64
45.25	3.44
50.80	2.73
57.02	2.91
64.00	2.91
71.84	3.50
80.63	2.85
90.51	3.13

RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnobubliv.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
(HERTZ) [G]

1.00	1.06
1.12	0.98
1.26	1.98
1.41	2.38
1.59	2.71
1.78	3.53
2.00	3.88
2.24	4.47
2.52	5.43
2.83	6.86
3.17	7.55
3.56	8.69
4.00	7.18
4.49	8.01
5.04	7.56
5.66	7.40
6.35	7.73
7.13	9.56
8.00	8.41
8.98	7.72
10.08	7.20
11.31	8.59
12.70	7.78
14.25	8.68
16.00	8.32
17.96	9.35
20.16	7.83
22.63	12.43
25.40	17.42
28.51	12.27
32.00	6.89
35.92	4.83
40.32	4.74
45.25	4.48
50.80	4.04
57.02	3.98
64.00	3.40
71.84	4.52
80.63	3.64
90.51	3.50




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssubh.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
(HERTZ) [G]

1.00	1.94
1.12	2.97
1.26	3.64
1.41	4.41
1.59	4.63
1.78	6.29
2.00	7.43
2.24	8.36
2.52	10.40
2.83	13.80
3.17	13.12
3.56	16.11
4.00	14.19
4.49	14.21
5.04	13.49
5.66	13.01
6.35	13.50
7.13	13.58
8.00	16.24
8.98	14.55
10.08	13.91
11.31	13.93
12.70	15.64
14.25	15.51
16.00	16.90
17.96	16.69
20.16	23.37
22.63	30.96
25.40	41.32
28.51	22.26
32.00	17.53
35.92	12.20
40.32	11.29
45.25	8.18
50.80	8.23
57.02	7.77
64.00	7.22
71.84	7.77
80.63	7.23
90.51	6.45

## RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssubv.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	2.47
1.12	2.55
1.26	3.29
1.41	4.46
1.59	4.55
1.78	6.09
2.00	7.20
2.24	8.34
2.52	10.26
2.83	13.20
3.17	13.68
3.56	15.91
4.00	14.17
4.49	13.80
5.04	12.83
5.66	13.37
6.35	14.03
7.13	14.27
8.00	15.37
8.98	14.30
10.08	14.29
11.31	13.43
12.70	16.83
14.25	17.00
16.00	15.57
17.96	17.71
20.16	20.48
22.63	27.17
25.44	37.51
28.51	21.43
32.00	17.62
35.92	11.87
40.32	12.29
45.25	9.66
50.80	10.43
57.02	10.19
64.00	9.28
71.84	8.53
80.63	7.10
90.51	7.99



Analysis Code: SRSKHH Version 1


DATA FILE c:\gl\mw\obuc1h.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	0.99
1.12	1.04
1.26	1.76
1.41	2.28
1.59	2.38
1.78	3.56
2.00	4.03
2.24	4.33
2.52	5.97
2.83	6.95
3.17	7.61
3.56	8.19
4.00	7.44
4.49	7.89
5.04	7.84
5.66	7.67
6.35	8.05
7.13	9.54
8.00	9.00
8.98	7.49
10.08	7.22
11.31	8.94
12.70	8.50
14.25	8.31
16.00	8.99
17.96	9.74
20.16	8.56
22.63	13.28
25.40	18.47
28.51	14.94
32.00	6.91
35.92	4.32
40.32	4.48
45.25	3.64
50.80	3.35
57.02	3.34
64.00	2.75
71.84	2.87
80.63	3.14
90.51	3.01

RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnobuc1v.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	0.91
1.12	0.97
1.26	1.83
1.41	2.19
1.59	2.32
1.78	3.40
2.00	4.16
2.24	4.22
2.52	5.82
2.83	7.00
3.17	7.67
3.56	8.04
4.00	7.44
4.49	7.66
5.04	7.36
5.66	7.10
6.35	8.03
7.13	9.16
8.00	8.50
8.98	7.48
10.09	7.21
11.31	8.68
12.70	7.84
14.25	8.39
15.00	9.06
16.96	9.19
20.16	7.81
22.63	12.00
25.40	16.54
28.51	14.36
32.00	6.87
35.92	4.41
40.32	5.95
45.25	5.57
50.80	5.41
57.02	4.53
64.00	4.56
71.84	3.98
80.63	4.00
90.51	3.46




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssuch.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.07	2.22
1.12	2.71
1.26	3.67
1.41	4.12
1.59	5.03
1.78	5.90
2.00	7.65
2.24	7.99
2.52	10.84
2.83	12.32
3.17	13.86
3.56	16.18
4.00	14.77
4.49	14.70
5.04	14.32
5.66	13.84
6.35	13.80
7.13	14.07
8.00	16.61
8.98	14.98
10.08	13.89
11.31	14.08
12.70	15.18
14.25	16.10
16.00	16.01
17.96	18.41
20.16	23.50
22.63	29.43
25.40	39.46
28.51	26.07
32.00	16.86
35.92	12.82
40.32	11.36
45.25	9.28
50.80	8.56
57.02	7.43
64.00	7.77
71.84	6.98
80.63	6.11
90.51	7.41




Analysis Code: SRSKHH Version 1

DATA FILE c:\g1\mnssucv.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	1.85
1.12	2.61
1.26	3.37
1.41	4.32
1.59	5.47
1.78	6.74
2.00	7.50
2.24	7.91
2.52	11.41
2.83	13.00
3.17	13.19
3.56	15.34
4.00	13.13
4.49	13.63
5.04	13.94
5.66	12.97
6.35	14.01
7.13	13.66
8.00	15.04
8.98	14.13
10.08	12.88
11.31	14.36
12.70	14.51
14.25	16.59
16.00	14.80
17.96	17.16
20.16	21.70
22.63	30.48
25.40	39.99
28.51	22.68
32.00	18.03
35.92	15.48
40.32	13.49
45.25	15.44
50.80	12.33
57.02	10.81
64.00	9.39
71.84	8.40
80.63	7.63
90.51	9.38




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnobudlh.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	1.00
1.12	1.20
1.25	1.78
1.41	2.14
1.59	2.50
1.78	3.31
2.00	4.65
2.24	4.43
2.52	5.60
2.83	7.39
3.17	7.76
3.56	8.17
4.00	7.58
4.49	6.01
5.04	7.51
5.66	7.57
6.35	8.17
7.13	9.75
8.00	9.08
8.98	8.02
10.08	7.44
11.31	8.95
12.70	8.24
14.25	8.36
16.00	8.84
17.96	9.75
20.16	8.24
22.63	12.36
25.40	16.78
28.51	14.37
32.00	6.89
35.92	4.36
40.32	3.60
45.25	3.45
50.80	3.29
57.02	3.07
64.00	2.90
71.84	2.78
80.63	2.50
90.51	2.91




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnobud1v.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	1.09
1.12	1.15
1.26	1.72
1.41	2.23
1.59	2.37
1.78	3.36
2.00	3.83
2.24	4.53
2.52	5.53
2.83	7.34
3.17	8.25
3.56	7.82
4.00	7.43
4.49	7.66
5.04	7.42
5.66	7.57
6.35	8.01
7.13	9.61
8.00	9.05
8.98	7.58
10.08	7.45
11.31	8.92
12.70	8.16
14.25	8.12
16.00	8.77
17.95	9.10
20.16	8.77
22.63	11.35
25.40	16.76
28.51	14.12
32.00	6.70
35.92	3.98
40.32	3.76
45.25	3.98
50.80	3.54
57.02	3.92
64.00	3.57
71.84	3.42
80.63	3.27
90.51	3.85




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssudh.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	1.99
1.12	2.22
1.26	3.84
1.41	4.68
1.59	5.30
1.78	6.76
2.00	6.92
2.24	8.25
2.52	10.05
2.83	13.68
3.17	13.14
3.56	16.04
4.00	14.48
4.49	14.01
5.04	13.80
5.66	13.23
6.35	13.51
7.13	14.32
8.00	16.57
8.98	14.87
10.08	14.12
11.31	14.22
12.70	15.55
14.25	15.77
16.00	16.00
17.96	18.19
20.16	22.23
22.63	30.07
25.40	39.32
28.51	23.52
32.00	16.57
35.92	11.44
40.32	10.35
45.25	8.45
50.80	8.91
57.02	7.76
64.00	7.11
71.84	7.32
80.63	6.45
90.51	7.19



Analysis Code: SRSKHH Version 1


DATA FILE C:\gl\mnssudv.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION


[HERTZ] [G]

1.00	1.76
1.12	2.54
1.26	2.90
1.41	4.08
1.59	4.91
1.78	6.58
2.00	6.25
2.24	8.01
2.52	10.62
2.83	12.64
3.17	13.05
3.56	16.28
4.00	13.43
4.49	14.54
5.04	13.01
5.66	14.12
6.35	13.03
7.13	14.42
8.00	15.64
8.98	14.59
10.08	13.19
11.31	14.81
12.70	15.85
14.25	14.42
16.00	14.73
17.96	16.95
20.16	21.32
22.63	28.62
25.40	38.09
28.51	23.12
32.00	16.55
35.92	15.05
40.32	12.81
45.25	8.90
50.80	11.46
57.02	10.64
64.00	8.24
71.84	7.38
80.63	9.01
90.51	7.43


## RESPONSE SPECTRUM



Unfiltered Time History




Low-Pass Filtered Time History ... 100.0 [Hertz]




BOTTOM MOUNTED INSTRUMENT NOZZLE, FREE STANDING, SSE EVENT  
ORIENTATION A, HORIZONTAL

Unfiltered Time History



Low-Pass Filtered Time History ... 100.0 Hertz




BOTTOM MOUNTED INSTRUMENT NOZZLE, FREE STANDING, SSE EVENT  
ORIENTATION A, VERTICAL

TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A


ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

Unfiltered Time History




Low-Pass Filtered Time History ... 100.0 [Hertz]




BOTTOM MOUNTED INSTRUMENT NOZZLE, FREE STANDING, SSE EVENT  
ORIENTATION B, HORIZONTAL

Page D-48

Unfiltered Time History




Low-Pass Filtered Time History ... 100.0 [Hertz]




BOTTOM MOUNTED INSTRUMENT NOZZLE, FREE STANDING, SSE EVENT  
ORIENTATION B, VERTICAL

Unfiltered Time History




Low-Pass Filtered Time History ... 100.0 [Hertz]



BOTTOM MOUNTED INSTRUMENT NOZZLE, FREE STANDING, SSE EVENT  
ORIENTATION C, HORIZONTAL

Unfiltered Time History ...




TR-PENG-033  
Rev. 00  
Ref. T.R. No. TS071A


ABB/COMBUSTION ENGINEERING  
PRIMARY SYSTEMS

Contract No. 2007241  
Total of Text 47 Pages  
Appendices 89 Pages

Unfiltered Time History




Low-Pass Filtered Time History ... 100.0 [Hertz]




BOTTOM MOUNTED INSTRUMENT NOZZLE, FREE STANDING, SSE EVENT  
ORIENTATION D, HORIZONTAL

Unfiltered Time History



Low-Pass Filtered Time History ... 100.0 [Hertz]



BOTTOM MOUNTED INSTRUMENT NOZZLE, FREE STANDING, SSE EVENT  
ORIENTATION D, VERTICAL

Page D-53

Analysis Code: SRSKHH Version 1


DATA FILE c:\g1\mnssuan.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	2.04
1.12	2.60
1.26	3.58
1.41	3.89
1.59	4.44
1.78	6.61
2.00	7.53
2.24	8.29
2.52	10.86
2.83	12.87
3.17	13.27
3.56	15.83
4.00	13.72
4.49	13.38
5.04	13.80
5.66	13.64
6.35	14.36
7.13	14.64
8.00	16.50
8.98	15.94
10.08	16.10
11.31	16.35
12.70	20.13
14.25	21.89
16.00	23.59
17.96	33.61
20.16	52.09
22.63	81.26
25.40	150.68
28.51	197.33
32.00	193.98
35.92	53.01
40.32	35.49
45.25	27.09
50.80	24.12
57.02	23.83
64.00	21.88
71.84	20.55
80.63	19.18
90.51	18.85

REFER TO TABLE 2 FOR  
FILE IDENTIFICATION

## RESPONSE SPECTRUM




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssuap.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
(HERTZ) [G]

1.00	2.26
1.12	2.74
1.26	3.78
1.41	4.32
1.59	4.07
1.78	6.35
2.00	7.75
2.24	7.76
2.52	12.23
2.83	12.02
3.17	13.88
3.56	16.60
4.00	14.86
4.49	13.27
5.04	13.28
5.66	13.90
6.35	14.12
7.13	14.48
8.00	17.16
8.98	15.93
10.08	14.44
11.31	14.30
12.70	18.02
14.25	20.53
16.00	20.12
17.96	25.39
20.16	35.11
22.63	54.35
25.40	82.74
28.51	62.00
32.00	62.75
35.92	204.20
40.32	112.99
45.25	45.11
50.80	32.66
57.02	25.34
64.00	23.86
71.84	19.34
80.60	19.13
90.51	17.69




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssubn.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
(HERTZ) [G]

1.00	2.23
1.12	2.62
1.26	3.66
1.41	4.64
1.59	4.67
1.78	6.50
2.00	7.37
2.24	8.88
2.52	10.33
2.83	13.67
3.17	13.70
3.56	16.32
4.00	14.53
4.49	13.97
5.04	14.19
5.66	14.60
6.35	15.24
7.13	14.53
8.00	17.30
8.98	15.92
10.08	16.37
11.31	16.23
12.70	19.20
14.25	20.12
16.00	22.39
17.96	29.72
20.16	46.94
22.63	78.06
25.40	142.59
28.51	248.86
32.00	80.09
35.92	35.05
40.32	25.33
45.25	21.56
50.80	20.11
57.02	20.11
64.00	17.11
71.84	16.84
80.63	17.92
90.51	15.97

## RESPONSE SPECTRUM




Analysis Code: SRSKHII Version 1

DATA FILE C:\gl\mnssubp.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	2.06
1.12	2.33
1.26	2.90
1.41	3.53
1.59	4.16
1.78	6.06
2.00	7.66
2.24	7.91
2.52	9.86
2.83	12.21
3.17	13.01
3.56	14.93
4.00	13.02
4.49	13.19
5.04	13.62
5.66	12.53
6.35	13.95
7.13	14.17
8.00	15.21
8.98	15.09
10.08	15.08
11.31	14.52
12.70	17.13
14.25	18.34
16.00	19.04
17.96	25.11
20.16	36.21
22.63	51.20
25.40	79.91
28.51	58.75
32.00	58.63
35.92	195.79
40.32	131.23
45.25	47.70
50.80	35.19
57.02	29.74
64.00	25.96
71.84	23.33
80.63	21.91
90.51	20.54




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssuch.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	2.24
1.12	2.40
1.26	3.55
1.41	4.34
1.59	5.13
1.78	6.21
2.00	7.21
2.24	8.21
2.52	10.79
2.83	12.65
3.17	13.13
3.56	15.64
4.00	13.66
4.49	13.88
5.04	13.49
5.66	13.79
6.35	14.01
7.13	14.50
8.00	16.38
8.98	15.17
10.08	15.16
11.31	14.88
12.70	16.13
14.25	18.55
16.00	19.30
17.96	25.62
20.16	37.44
22.63	53.65
25.40	99.20
28.51	113.85
32.00	161.23
35.92	40.08
40.32	21.97
45.25	18.08
50.80	15.58
57.02	13.88
64.00	13.34
71.84	12.49
80.63	11.91
90.51	11.92




Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssucp.khh DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ]	[G]
1.00	2.08
1.12	1.99
1.26	3.28
1.41	3.97
1.59	4.15
1.78	7.01
2.00	7.21
2.24	7.53
2.52	10.74
2.83	12.65
3.17	13.57
3.56	16.07
4.00	14.02
4.49	14.34
5.04	14.14
5.66	14.11
6.35	14.44
7.13	13.89
8.00	15.63
8.98	14.85
10.08	14.14
11.31	15.18
12.70	16.29
14.25	18.98
16.00	19.69
17.96	25.82
20.16	36.63
22.63	56.32
25.40	79.08
28.51	66.33
32.00	69.62
35.92	216.95
40.32	118.53
45.25	45.50
50.80	33.91
57.02	25.55
64.00	22.81
71.84	20.43
80.63	19.30
90.51	19.61



Analysis Code: SRSKHH Version 1


DATA FILE c:\gl\mnssudn.kth DAMPING 1.00 [%]

## FREQUENCY ACCELERATION

[HERTZ] [G]

1.00	2.53
1.12	2.91
1.26	3.78
1.41	4.40
1.59	5.81
1.78	6.48
2.00	7.47
2.24	7.63
2.52	11.51
2.83	13.22
3.17	13.96
3.56	14.73
4.00	14.36
4.49	13.21
5.04	12.96
5.66	13.85
6.35	14.69
7.13	14.05
8.00	16.06
8.98	15.28
10.08	15.09
11.31	15.83
12.70	17.90
14.25	19.40
16.00	22.66
17.96	28.78
20.16	45.09
22.63	73.88
25.40	139.94
28.51	218.58
32.00	96.32
35.92	36.36
40.32	24.76
45.25	22.16
50.80	20.45
57.02	20.85
64.00	19.00
71.84	19.16
80.63	16.15
90.51	17.77

## RESPONSE SPECTRUM



Analysis Code: SRSKHH Version 1

DATA FILE c:\gl\mnssudp.khh DAMPING 1.00 [%]

FREQUENCY ACCELERATION  
[HERTZ] [G]

1.00	2.08
1.12	2.59
1.26	3.13
1.41	4.19
1.59	5.10
1.78	7.41
2.00	9.20
2.24	7.80
2.52	10.27
2.83	12.31
3.17	13.38
3.56	15.37
4.00	13.50
4.49	12.96
5.04	13.28
5.66	13.41
6.35	14.25
7.13	14.26
8.00	16.60
8.98	15.43
10.08	14.69
11.31	15.30
12.70	17.27
14.25	18.15
16.00	20.34
17.96	25.93
20.16	35.69
22.53	53.99
25.40	80.14
28.51	60.92
32.00	60.60
35.92	203.69
40.32	136.17
45.25	49.09
50.80	35.56
57.02	28.71
64.00	26.39
71.84	23.22
80.63	22.14
90.51	21.37

