

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-423

UNIT Millstone Unit No. 3

DATE 2/10/86

COMPLETED BY A. Elms

TELEPHONE (203) 444-5388

MONTH January

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0
2	0
3	0
4	0
5	0
6	0
7	0
8	0
9	0
10	0
11	0
12	0
13	0
14	0
15	0
16	0

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	0
18	0
19	0
20	0
21	0
22	0
23	0
24	0
25	0
26	0
27	0
28	0
29	0
30	0
31	0

IE 24
1/1

OPERATING DATA REPORT

DOCKET NO. 50-423

DATE 2/10/86

COMPLETED BY A. Elms

TELEPHONE (203) 444-5388

OPERATING STATUS

NOTES

1. Unit Name: Millstone Unit 3
2. Reporting Period: January 1986
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1208
5. Design Electrical Rating (Net MWe): 1153
6. Maximum Dependable Capacity (Gross MWe): 0
7. Maximum Dependable Capacity (Net MWe): 0
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: Full Power License Obtained

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: Initial Startup

	<u>This Month</u>	<u>Yr To Date</u>	<u>Cumulative</u>
11. Hours In Reporting Period	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
12. Number of Hours Reactor Was Critical	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
13. Reactor Reserve Shutdown Hour	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
14. Hours Generator On Line	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
15. Unit Reserve Shutdown Hours	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
16. Gross Thermal Energy Generated (MWH)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
17. Gross Electrical Energy Generated (MWH)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
18. Net Electrical Energy Generated (MWH)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
19. Unit Service Factor	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
20. Unit Availability Factor	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
21. Unit Capacity Factor (Using MDC Net)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
22. Unit Capacity Factor (Using DER Net)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
23. Unit Forced Outage Rate	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
(See Attached)

25. If Shut Down at End of Report Period, Estimated Date of Startup: _____
26. Units in Test Status (Prior to Commercial Operation):

	<u>Forecast</u>	<u>Achieved</u>
Initial Criticality	<u>1/23/86</u>	<u>1/23/86</u>
Initial Electricity	<u>2/12/86</u>	<u></u>
Commercial Operation	<u>5/1/86</u>	<u></u>

Operating Data Report

Attachment

24. Scheduled Shutdowns During Startup Testing

February 19, 1986

Reactor Trip from 30% power during Ascension Testing - 24 hour duration.

February 26, 1986

Reactor Trip from 50% power during power Ascension Testing - 8 hour duration.

March 7, 1986

Reactor Trip from 20% power during power Ascension Testing - 24 hour duration.

March 22, 1986

Reactor Trip from 100% power during power Ascension Testing - 8 hour duration.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-423

UNIT Millstone Unit No. 3

DATE 1/10/86

COMPLETED BY A. Elms

TELEPHONE (203) 444-5388

REPORT MONTH January

No.	Date	Type (1)	Duration (Hours)	Reason (2)	Method of Shutting Down Reactor (3)	Licensee Event Report #	System Code	Component Code	Cause & Corrective Action to Prevent Recurrence
N/A	N/A	S	N/A	H	N/A	N/A	N/A	N/A	Initial Plant Startup

1
F: Forced
S: Scheduled

2
Reason:
A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training & License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3
Method:
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continued from previous month
5 - Power Reduction 5 (Duration = 0)
9 - Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensed Event Report (LER) File (NUREG-0161)

Exhibit I - Same Source

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

February 11, 1986
MP-8703

Director, Office of Resource Management
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Reference: Facility Operating License No. NPF-49
Docket No. 50-423

Dear Sir:

This letter is forwarded to provide the report of operating and shutdown experience relating to Millstone Unit 3 Monthly Operating Report 86-2 in accordance with Technical Specifications, Section 6.9.1.5. One additional copy of the report is enclosed.

Yours truly,

NORTHEAST NUCLEAR ENERGY COMPANY

FOR: Wayne D. Romberg
Station Superintendent
Millstone Nuclear Power Station

A handwritten signature in cursive script, appearing to read 'J. Kelley'.

BY: Signature
James J. Kelley
Station Services Superintendent
Millstone Nuclear Power Station

WDR/DM:se

Attachment

cc: Regional Administrator, Office of Inspection and Enforcement, Region I
Director, Office of Inspection and Enforcement, Washington, D.C. (10)
U. S. Nuclear Regulatory Commission, c/o Document Management Branch,
Washington, D. C. 20555

IB24
1/1