

LIMITING CONDITIONS FOR OPERATIONSURVEILLANCE REQUIREMENTS3.7.A Primary Containment (Cont'd.)4.7.A Primary Containment (Cont'd.)3. Pressure Suppression Chamber -  
Reactor Building Vacuum Breakers

- a. Except as specified in 3.7.A.3.b below, two pressure suppression chamber-reactor building vacuum breakers shall be operable at all times when primary containment integrity is required. The setpoint of the differential pressure instrumentation which actuates the pressure suppression chamber-reactor building vacuum breakers shall be 0.5 +/- 0.25 psid.
- b. From and after the date that one of the pressure suppression chamber-reactor building vacuum breakers is made or found to be inoperable for any reason, reactor operation is permissible only during the succeeding seven days unless such vacuum breaker is sooner made operable provided that the repair procedure does not violate primary containment integrity.

4. Drywell-Pressure Suppression  
Chamber Vacuum Breakers

- a. When primary containment is required, all drywell-suppression chamber vacuum breakers shall be operable and positioned in the fully closed position (except during testing) except as specified in 3.7.A.4.b and c below.
- b. Drywell-suppression chamber vacuum breaker(s) may be "not fully seated" as shown by position indication if testing confirms that the bypass area is less than or equivalent to a one-inch diameter hole. Testing shall be initiated within 8 hours of initial detection of a "not fully seated" position

3. Pressure Suppression Chamber -  
Reactor Building Vacuum Breakers

- a. The pressure suppression chamber-reactor building vacuum breaker and associated instrumentation including setpoint shall be checked for proper operation every refueling outage.

4. Drywell-Pressure Suppression  
Chamber Vacuum Breakers

- a. Each drywell-suppression chamber vacuum breaker shall be exercised through an opening-closing cycle once a month.
- b. When it is determined that a vacuum breaker is inoperable for opening at a time when operability is required, all other vacuum breakers shall be exercised immediately and every 15 days thereafter until the inoperable vacuum breaker has been returned to normal service.
- c. Once per operating cycle each vacuum breaker shall be visually inspected

LIMITING CONDITIONS FOR OPERATIONSURVEILLANCE REQUIREMENTS3.7.A Primary Containment (Cont'd)

indication and shall be performed periodically thereafter as follows:

- (1) Once every 15 days (only if "not fully seated" valve(s) are indicated).
- (2) Within 24 hours following vacuum breaker exercising required by 4.7.A.4.a and 4.7.A.4.B. (only if "not fully seated" valve(s) are indicated).

- c. Two drywell-suppression chamber vacuum breakers may be inoperable for opening.
- d. If specifications 3.7.A.4.a, b, or c cannot be met, the situation shall be corrected within 24 hours or the unit shall be placed in a cold shutdown condition in an orderly manner.

4.7.A Primary Containment (Cont'd.)

to insure proper maintenance and operation.

- d. A leak test of the drywell to suppression chamber structure shall be conducted at each refueling outage to assure no bypass larger than or equivalent to a one-inch diameter hole exists between the drywell and suppression chamber.