



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

July 28, 1986

Mr. Paul Koval  
Chief, Operations Section  
Bureau of Water Quality Management  
Pennsylvania Department of Environmental Resources  
90 East Union Street, Second Floor  
Wilkes-Barre, PA 18701-3296

SUSQUEHANNA STEAM ELECTRIC STATION  
DISCHARGE MONITORING REPORT  
NPDES PERMIT NO. PA 0047325/JUNE 1986  
CCN 741326 FILE R9-8A  
PLE- 8526

Dear Mr. Koval:

Enclosed is a copy of the June 1986 Discharge Monitoring Report for Permit No. PA 0047325. The following information details data and/or noncompliances for some of the permitted outfalls:

Outfall 071: Cooling Tower Blowdown

The cooling tower blowdown sample pump was out of service 1-3 June. The pH and free available chlorine samples for these days could not be collected.

Outfall 079: Sewage Treatment Plant

The effluent eight hour composite sample for total suspended solids collected on 27 June was 82 mg/l. This high level was attributed to lack of adequate sludge wasting.

If you have any questions, please call me at (215) 770-7889.

Respectfully yours,

Jerome S. Fields  
Senior Environmental Scientist-Nuclear

JSF/amc

Enclosure

cc: EPA, Region III  
E. Adensam-NRC

8608040089 860728  
PDR ADOCK 05000387  
R PDR

IE25  
1/1