

PDR advanced by per J. Rathje

Date: January 25, 1994

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-III-94-06

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

<u>Facility</u>	<u>Licensee Emergency Classification</u>
Indiana Michigan Power Company	General Emergency
D.C. Cook 2	Site Area Emergency
Bridgeman, Michigan	Alert
	Unusual Event
Docket No. 50-316	X Not Applicable

Subject: SHUTDOWN TO REPAIR STEAM LEAK

On January 21, 1994, the licensee commenced a shutdown of Unit 2 to repair a steam leak that was discovered in the vicinity of Steam Generator No. 1.

The licensee began the shutdown at 5:25 p.m. (EST) from 91 percent power and as of 5:00 a.m. on January 22, 1994, the unit was in Mode 3 (Hot Standby).

A containment entry and inspection identified a leak from a weld at a reducer on the Steam Generator drain line. No other significant deficiencies were discovered during the containment inspection.

The licensee has repaired the leak as of January 25, 1994, and has commenced a plant startup.

The Resident Inspector was notified of the shutdown by the licensee on January 21, 1994, and accompanied the licensee on the containment inspection.

The resident inspectors and Region III (Chicago) will review the licensee's repair activities and root cause analysis.

The State of Michigan will be notified. Information on this preliminary notification has been reviewed with licensee management.

This information is current as of 9:00 a.m. January 25, 1994.

CONTACT:

Jim Isom
616/465-6775

Wayne Kropp
708/829-9633

94 JAN 25 P2:01

DF020/1

9712180316 940125
PDR I&E
PNO-III-94-006 PDR

