



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

July 30, 1986

MEMORANDUM FOR: Victor Stello, Jr.
Executive Director for Operations

FROM: Lando W. Zech, Jr. *Lando W. Zech Jr.*

SUBJECT: STAFF REQUIREMENTS - DISCUSSION/POSSIBLE VOTE
ON FULL POWER OPERATING LICENSE FOR HOPE CREEK,
10:00 A.M., MONDAY, JULY 21, 1986, COMMIS-
SIONERS' CONFERENCE ROOM, D.C. OFFICE (OPEN TO
PUBLIC ATTENDANCE)

The Commission, with all Commissioners agreeing, has approved authorizing the staff to issue a full power operating license to Public Service Electric and Gas Company for the operation of the Hope Creek generating station, subject to the final approval by the NRC staff of items to be completed by the licensee.

(Subsequently, on July 25, 1986 the NRC staff issued the full power license.)

Commissioner Asselstine noted that the SER required the applicant to inspect the inner and outer body surfaces of the feedwater check valves at the first refueling outage and at each time the valves were disassembled for maintenance. This latter requirement was apparently deleted in Supplement No. 2. Commissioner Asselstine with Chairman Zech agreeing requested the staff to detail the reasons for the deletion.

(EDO) (SECY Suspense: 8/15/86)

The Commission urged the applicant and the staff to be mindful of the uniqueness of the solid state logic modules and continue to assess their reliability.

cc: Commissioner Roberts
Commissioner Asselstine
Commissioner Bernthal
Commission Staff Offices
✓ PDR - Advance
✓ DCS - 016 Phillips
SECY

File as is. We have prepared a correction letter to include the entire report.

JUL 30 1986

Dave Wiggint

X 27363

8608050043 860730
PDR 10CFR
PT9.7 PDR

Thanks for bringing to our attention.