


Amendment No. 9  
Attachment D  
Page D-i



UNITED STATES  
ATOMIC ENERGY COMMISSION  
WASHINGTON, D.C. 20545  
DEC 27 1957

IN REPLY REFER TO:  
Docket No. 50-267

Public Service Company of Colorado  
Public Service Company Building  
550 Fifteenth Street  
Denver, Colorado 80202

Attention: Mr. L. R. Patterson  
Senior Vice President  
Electric Department

Gentlemen:

As a result of the ACRS Subcommittee meeting on December 6, 1967, the ACRS has requested the additional information indicated in the enclosure in order to enable completing its review of your proposed Fort St. Vrain Nuclear Generating Station.

Please submit your reply in an original and two copies signed under oath or affirmation together with seventy (70) additional copies.

Sincerely yours,

*Peter A. Morris, Acting*  
Peter A. Morris, Director  
Division of Reactor Licensing

8608050065 860729  
PDR ADDCK 05000267  
P PDR

CC: A. L. Habush  
Gulf General Atomics

Additional Information Required Relative  
to the  
Fort St. Vrain Nuclear Generating Station

December 15, 1967

- D.1. Outline any changes that would be required in the plant design if the tendon ducts were to be filled with a suitable grease in order to inhibit tendon corrosion. How would such a design change influence the surveillance program to assure adequate corrosion control?
- D.2. Evaluate the potential consequences of an accident in which all forced circulation cooling of the core is lost and the PCRV liner is subsequently assumed to fail in such a manner that it offers no resistance to leakage of gas from the PCRV. Assuming no helium buoyancy effect, what off-site doses would result from PCRV internal pressures of 2 and 5 psig?

What is the equilibrium xenon plus krypton STP volume? What would be the pressure rise in the PCRV due to the Xe and Kr released during the core-heat-up accident?

- D.3. Submit the results of a quantitative analysis which determines the permissible number of tendons that may fail before a definite hazard would exist. The failure of both adjacent and parallel tendons as well as adjacent but non-parallel tendons should be considered.
- D.4. Submit preliminary acceptance standards or reasonably definitive criteria for the proof testing of the PCRV in sufficient detail to permit establishing the adequacy of this test program.
- D.5. Expand the analysis submitted of the accident involving the loss of forced circulation gas cooling of the core so as to investigate the long term consequences of such an accident and the procedures for recovering from such an accident.
- D.6. Outline the extent to which either PSC or its agents will perform an independent audit of critical stages of construction and testing.

- D.7. Submit the results of an analysis which investigates the possibility of the PCRV liner failing during a loss-of-cooling accident. The analysis should include consideration of the possibility and consequences of deterioration of the liner during plant lifetime.
- D.8. Assuming the opening of a crack in the PCRV sufficiently large to cause rapid depressurization, is there a possibility that the crack will not close completely so that air ingress becomes a problem?

The information below is submitted in response to Question No. D.3. enclosed in the letter from Peter A. Morris dated December 27, 1967.

D.3. Question: Submit the results of a quantitative analysis which determines the permissible number of tendons which may fail before a definite hazard would exist. The failure of both adjacent and parallel tendons as well as adjacent but nonparallel tendons should be considered.

Answer: A quantitative analysis has been performed to establish the approximate number of tendons which could fail during operation of the reactor before a hazardous condition would exist. The results of this work are presented.

Vertical Tendons. By analyzing the prestress forces on a horizontal section through the vessel, it is shown that at least six adjacent vertical tendons can be lost during vessel operation before the design condition of zero average stress across the wall is violated. This analysis was performed by removing individual adjacent tendons on one side of the cross-section until the centroid of the vertical prestressing shifted sufficiently to produce tension halfway through the wall thickness. This includes the assumption that vertical prestress losses are twice the predicted values.

Even if all vertical prestress forces were lost, the PCRV walls which are very heavily reinforced with continuous high strength bonded reinforcement still tie the two heads together. In order to assess various safety margins, the following information is submitted to show the cavity pressures which the PCRV could resist with only the rebars acting.

$f_s$ [kip/in. <sup>2</sup> ]	$A_s$ [in <sup>2</sup> ]	$A_s f_s$ [kip]	$p = \frac{A_s f_s}{31^2 \times \pi/4} \times \frac{1}{0.144}$ [psig]
$0.9 f_{sy} = 67.5$	1640	110,500	1020
$f_{sy} = 75$	1640	123,000	1135
$f_s = 100$	1640	164,000	* 1515

The amount of reinforcement in the haunch areas and in the wall sections adjacent to the heads is considerably larger than the reinforcement at vessel midheight for which the analysis was performed. Concrete cracks and their effect on liner strains are still small even at 845 psi since the reinforcing steel has not yielded. 75% of the vertical reinforcement

consists of #18S and #11 bars which are spliced by mechanical means to develop the minimum guaranteed tensile strength of the bars. The bars are all anchored within the heads where the concrete will be in compression and the #18S bars have anchor plates attached to their ends.

Circumferential Tendons. The loss of one "complete ring" of circumferential tendons which consists of 3 sets of six tendons each spaced over a wall height of about 5'-0" has been analyzed without taking advantage of load redistribution to adjacent complete rings. The number of tendons that can be lost at any cross-section of the ring is given below in relation to the internal pressure required to produce failure. Of the total of 18 tendons, a minimum number of 12 pass any cross-section. Reinforcing steel is taken into account.

Internal Pressure [psig]	Required No. of Tendons Passing Any 5' Cross-Section	No. of Tendons Allowed to Fail at Any 5' Cross-Section	Safety Factor
1690	9	3	2.0
1475	8	4	1.75
1265	6	6	1.50
1055	5	7	1.25
845	3	9	1.00

The results of this single evaluation indicate that all adjacent circumferential tendons can fail (i.e., all tendons anchored on one face of one pilaster, including head region) without reducing the safety factor against failure at 845 psi below 2.0. Liner strains are still compressive.

Of 236 circumferential tendons, about 30 tendons uniformly distributed could be lost before net tensile stresses would occur across the wall section at 845 psig assuming the predicted prestress losses of about 12% have occurred. On this same basis, of the 84 circumferential tendons in the heads, about 6 from each head could be lost.

Crosshead Tendons. All adjacent crosshead tendons on one face of the vessel represent 33% of the total crosshead prestress, or 16 out of 48 tendons. Loss of these adjacent tendons does not unbalance the remaining prestressing forces that help to counteract the cavity pressure applied to the heads because of the 120 degree orientation of the tendons. The large head depth also allows the unbalanced forces, caused by loss of adjacent tendons, to redistribute and still provide an almost uniform prestress force on the inside face of the vessel head.

The overall effect of the crosshead tendons has been demonstrated by overpressure tests on a 1/13 scale model of the PSC-PCRV bottom head. Test pressures of 2400 psi could not cause failure of the heads. Since the crosshead tendons were tensioned to resist only approximately 600 psi of the internal pressure, the complete loss of all of these tendons would not reduce the head capacity below 1800 psig, which is approximately 2.1 times Reference Pressure. Liner strains are still compressive.

These tests are being continued with various combinations of prestress removed in order to establish failure levels in relation to applied prestress.

The above analyses have not taken credit for the restraint provided by adjacent concrete mass or transverse prestress. It has been shown that the loss of a certain number of tendons in each type of adjacent tendons would not cause a hazard with respect to the reduction in the vessel safety factor or the loss of net compression across a section under operating conditions. The number of adjacent nonparallel tendons that could be lost is at least the same as the number of those determined for each individual group. For example, the lost adjacent vertical tendons and the lost circumferential tendons on one pilaster face or in one complete ring do not depend on each other in the analysis performed; i.e., their contribution to restraint is neglected. It is believed that more refined analyses are not justified in view of the large margin of vessel capacity available even with the loss of the significant number of tendons of each type. A representative number of tendons in Model 2 will be unloaded to confirm the above analysis. Adjacent nonparallel tendons in the region of the crosshead tendon anchorages will be unloaded thereby putting all three types of tendons out of service in one region. One Model 2 tendon is approximately equal to four PSC tendons. (Reference Pressure for Model 2 is 704 psig versus 845 psig for PSC-PCRV.)

The reactor will normally be operated with all of the tendons tensioned, and with the tendon loads in the ranges specified by the design. However, it will be possible at all times to operate with any one tendon detensioned and still comply fully with the design criteria for the PCRV. It is expected that operation with one tendon detensioned will occur at times when tendon load cells are being calibrated, and when a tendon is removed for inspection or replacement of the tendon itself, its anchor hardware, or its corrosion protection.

Reference 1  
to answer to  
specific Question 1

Amendment No. 10  
Attachment D  
Page V.5-84

The information below further supplements the answer given to Question V.5 (Rev. 1), Attachment A, which was contained in Amendment No. 5. Results of the tendon detensioning tests recently completed on Model 2 are given. The information below is also supplemental to the answer to Question D.3, Attachment D, which was contained in Amendment No. 9.

V.5 Question: Submit a summary of the test data and failure mode for Model 2, a similitude study comparing the model and the Fort St. Vrain vessel and predictions of structural performance of the Fort St. Vrain vessel based on the test results from this model.

Supplemental Answer: A series of tests has been made on Model 2 wherein several tendons were fully detensioned and the vessel behavior in the partially detensioned condition was evaluated with internal pressure. These tests were performed to provide experimental confirmation of the approximate analyses used in determining the permissible number of tendons which could fail during operation of the Fort St. Vrain reactor before a hazardous condition would exist. The results of the analyses were given in the answer to Question D.3, Attachment D of Amendment No. 9.

Similar analyses were made on Model 2 to determine the equivalent number and type of tendons that should be detensioned to simulate the Fort St. Vrain PCRV conditions postulated in the answer to Question D.3. Although one Model 2 tendon is approximately equal to four Fort St. Vrain PCRV tendons, the differences in Reference Pressures (705 psig vs 845 psig), effective prestressing forces, and reinforcing steel quantities necessitated a separate analytical evaluation of Model 2. The results of the analyses of Model 2 are summarized as follows:

1. Vertical tendons. Four adjacent vertical tendons out of a total of 36 tendons (11.1% loss) should be fully detensioned to approach zero average stress across the wall at RP = 705 psig.
2. Circumferential tendons. One complete band of circumferential tendons consists of 2 sets of 3 tendons (180° wrap) spaced over a wall height of 18 in. A minimum of 4 out of 6 tendons traverse any 18 in. cross-section. One circumferential tendon should be detensioned to achieve an equivalent 25% loss in one band as postulated for the Fort St. Vrain PCRV.
3. Crosshead tendons. Eight adjacent crosshead tendons on one face of the vessel represent 33% of the total crosshead prestress (8 out of 24 tendons). The four outer crosshead tendons in Model 2 were tensioned to approximately twice the force in the four inner

crosshead tendons. Because of interferences, the inner crosshead tendons are not readily accessible for detensioning. The four outer crosshead tendons could be detensioned and represent a loss of approximately 22% in the crosshead prestressing.

The last test on Model 2 included in the answer to Question V.5, Attachment A, Amendment No. 5 was the overpressure test to 1500 psig (2.13 RP). At the completion of the 1500 psig overpressure test, the vessel was pressurized to its NWP = 585 psig and maintained for a period of time at ambient temperature. When the detensioning tests were initiated, the vessel had been under 585 psig sustained pressure for approximately 5 months.

Detensioning of the tendons was accomplished by rejetting and releasing the residual tendon force. The sequence of detensioning was as follows: 4 crosshead tendons, 1 circumferential tendon, and 4 vertical tendons. The specified tendons detensioned were in a region of the vessel where strain gages in the concrete and the liner were located. The four outer crosshead tendons were located in the bottom head, the circumferential tendon was approximately at the level of the bottom inner crosshead tendon anchor and the four adjacent vertical tendons were located between pilasters in the same face where the crosshead tendons were located. Strain and load measurements were made before and after each tendon was detensioned. Sensor measurements were also taken when the vessel was pressurized to RP = 705 psig, which was done prior to detensioning any tendon and after each group of tendons (i.e., all crosshead tendons) was completely detensioned. After all 9 tendons were fully detensioned, the vessel was subjected to a 48-hr pressure hold test at 705 psig. With the completion of the hold test, the vessel was depressurized and the tendons were retensioned to approximately their residual force prior to detensioning. The 585 psig sustained pressure test at ambient temperature was resumed thereafter.

Data obtained during the detensioning tests have not been fully evaluated. A sampling of concrete and reinforcing steel strains in the vicinity of the detensioned region at various stages of detensioning is given in Table V.5.3. No large strain changes were observed. Detensioning of the 4 vertical tendons caused the major strain increases. Strain reduction was observed in the inner midplane in the circumferential direction (see gages SR 413 and SR 407) after two additional vertical tendons were detensioned, while a strain increase was observed in the outer midplane (see gage SR 823). It appears that bending of the vessel wall is occurring over the region where the vertical prestressing has been drastically reduced by detensioning. Visual examination of the vessel exterior surface during the pressure tests showed no appreciable opening of concrete cracks which had been formed during the previous overpressure tests. Tendon loads monitored by load cells showed little load increases during various stages of detensioning. The major load increase over the residual prestress force was approximately 3600 lb for the circumferential tendons.

near midplane when the vessel was pressurized to 705 psig with all 9 tendons fully detensioned. This compares with a load increase of about 1400 lb at 705 psig pressure prior to detensioning. The residual prestressing force of the circumferential tendons at midplane is approximately 120,000 lb.

During the 48-hr hold test at 705 psig pressure with all 9 tendons fully detensioned, the vessel behavior was stable. Load cells being monitored during the pressure hold test indicated random load changes with a maximum load increase of about 3%.

Table V.5.3  
 SAMPLING OF CONCRETE AND REBAR STRAINS IN THE VICINITY OF  
 DETENSIONED REGION AT VARIOUS STAGES OF DETENSIONING  
**Model 2**

Gage No.	Location	Gage Orient.	Strain Due to 705 psig Pressure At Stages of Detensioning* ( $\mu\text{in/in}$ )				
			1	2	3	4	5
SR 823	Outer Midplane At Thin-wall Sect.	Circumf.	240	243	259	278	284
SR 894	Outer Midplane At Thin-wall Sect.	Vert.	97	91	85	102	124
SR 413	Inner Midplane At Thin-wall Sect.	Circumf.	180	193	219	237	222
SR 895	Adjacent to Circumf. Tendon Detensioned	Vert.	136	124	139	191	252
SR 820	Adjacent to Circumf. Tendon Detensioned	Circumf.	228	230	244	276	296
SR 896	Near Detensioned Crosshead Tendon Anchor Area	Vert.	27	28	21	26	26
SR 407	Inner Midplane At Pilaster Sect.	Circumf.	215	229	237	274	230
SR 873	Outer Midplane At Pilaster Sect.	Vert.	139	144	137	171	218
SR 881	Inner Bottom Haunch Junction at Filaster Sect.	Vert.	167	171	178	203	237
SR 851	Inner Bottom Haunch Junction at Pilaster Sect.	Vert.	161	167	167	205	253

\*Notes: 1. Prior to tendon detensioning  
 2. Four tendons detensioned (outer bottom crosshead tendons)  
 3. Five tendons detensioned (4 crosshead and 1 circumferential tendons)  
 4. Seven tendons detensioned (4 crosshead, 1 circumferential and 2 vertical tendons)  
 5. Nine tendons detensioned (4 crosshead, 1 circumferential and 4 vertical tendons)

Reference 3 to Answer to Specific Question #1  
P-86491 Attachment 3



**Public Service Company of Colorado**

February 14, 1985  
Fort St. Vrain  
Unit No. 1  
P-85053 22

Regional Administrator  
Region IV  
Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Attention: Mr. E. H. Johnson

SUBJECT: FSV - Tendon Requirements  
Based on Safety Consideration

Dear Mr. Johnson:

Enclosed is a copy of GA Technologies' analysis entitled "FSV - Tendon Requirements Based on Safety Consideration." This analysis determines the number of tendons required to prevent a breach of the PCRV liner at various PCRV cavity pressures.

Please be aware that this analysis was contracted and performed well in advance of our January 15, 1985 meeting in Arlington, Texas and has been under final review by PSC. Although this analysis was completed prior to receiving your questions in this area, we believe that it does serve to establish the design margins of the prestressing system.

If you have any questions, please contact Mr. M. H. Holmes at (303) 571-8409.

Very truly yours,

D. W. Warembourg  
D. W. Warembourg  
Manager, Nuclear  
Engineering Division

DWW/MJF/ksc

attachment RAVIAWED BY: Scott Hofstetter 2/4/85

8502280585

## GA Technologies Inc.

## ISSUE SUMMARY

TITLE FSV - TENDON REQUIREMENTS BASED ON SAFETY  
CONSIDERATION       R&D      APPROVAL LEVEL 2  
 DV & S  
 DESIGN

DISCIPLINE	SYSTEM	DOC. TYPE	PROJECT	DOCUMENT NO.	ISSUE NO/LTR.
S	11	CFL	1900	907738	N/C

QUALITY ASSURANCE LEVEL	SAFETY CLASSIFICATION	SEISMIC CATEGORY	ELECTRICAL CLASSIFICATION
I	FSV - 1	FSV - 1	N/A

ISSUE	DATE	PREPARED BY	APPROVAL				ISSUE DESCRIPTION/ CWBS NO.
			ENGINEERING	QA	FUNDING PROJECT	APPLICABLE PROJECT	
N/C	DEC 17 1984	T.T.Lee	J-D.Wistrom <i>D. Pettycord</i>	R.Rosenberg <i>R. Rosenberg</i>			Original Release 2970.205

CONTINUE ON GA FORM 1485-1		NEXT INDENTURED DOCUMENTS	
Text 1 - 11 = 11		P.O. N-5159	

A1 - A20 = 20  
B1 - B80 = 80  
C1 - C2 = 2  
TOTAL 113

REV																										
SH																										
REV																										
SH	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	
REV																										55 56
SH	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
																										27 28

A TECHNOLOGIES I C.

---

TITLE: FSV - TENDON REQUIREMENTS BASED ON SAFETY CONSIDERATION

---

DOCUMENT NO. 907738

ISSUE NO./LTR. N/C

---

TABLE OF CONTENTS

	<u>Page</u>
1. SUMMARY .....	3
2. MATERIAL PROPERTIES .....	3
3. DEFINITION OF NUMBER OF TENDONS .....	4
4. CIRCUMFERENTIAL TENDONS IN PCRV WALL .....	5
5. TENDONS IN PCRV TOP AND BOTTOM HEADS .....	6
6. CONCLUSIONS .....	7
7. REFERENCES .....	7
Appendix A: Number of Circumferential Tendons In the PCRV Wall	A1
Appendix B: Number of PCRV Head Tendons .....	B1
Appendix C: Calculation Review Report .....	C1

LIST OF TABLES

1. Minimum Numbers of Circumferential Tendons In Wall Section .....	9
---	---

LIST OF FIGURES

1. Number of Head Tendons Required in Each Head to Support 1.0 RP ..	10
2. Number of Head Tendons Required in Each Head to Support 1.5 RP ..	11

J A T E C H N O L O G I E S I . C.

---

TITLE: FSV - TENDON REQUIREMENTS BASED ON SAFETY CONSIDERATION

---

DOCUMENT NO. 907738

ISSUE NO./LTR. N/C

---

1. SUMMARY

The minimum numbers of tendons required for safely supporting the core cavity pressure of 845 psig (Reference Pressure, RP) and 1268 psig (1.5 RP) without breaching the liner of the Fort St. Vrain PCRV have been determined for: 1) circumferential tendons in the PCRV wall and 2) crosshead and circumferential tendons in the heads of the PCRV. Hand calculations based on the concept of ultimate load analysis are used. No calculation is performed for the vertical tendons in this study. Per Ref. 1, the PCRV can resist up to 1515 psig cavity pressure with only the rebars acting, i.e., without reliance on any vertical prestress.

The results are given in Table 1 and Figs. 1 and 2. These results indicate that the core cavity pressure of 1.0 RP can be safely resisted with considerably less number of tendons than is actually provided. With 1.5 RP, the number of head tendons required is still less than that actually provided. The difference, however, is small if no vertical tendons exist as assumed in the analysis. Existence of vertical tendons will require less number of head tendons to resist 1.0 and 1.5 RP.

The procedure used in the study is described in the following sections. Detailed calculations are given in the appendices.

2. MATERIAL PROPERTIES

Material properties used in this analysis are (Ref. 1):

Concrete:

Compressive strength  $f'_c = 6000 \text{ psi}$

Liner:

Material = SA 537, Gr. B

Yield strength  $f_{sy} = 60,000 \text{ psi}$  (at 0.2% offset)

Tensile strength  $f'_s = 80,000 \text{ psi}$  (Ref. 2)

Failure strain  $\epsilon' = 18\%$  (Ref. 2)

Modulus of elasticity  $E = 29 \times 10^6 \text{ psi}$

A TECHNOLOGIES I C.

---

TITLE: FSV - TENDON REQUIREMENTS BASED ON SAFETY CONSIDERATION

---

DOCUMENT NO. 907738

ISSUE NO./LTR. N/C

---

Tendon Wires:

Tensile strength  $f'_s = 240,000$  psi

Yield strength  $f_{sy} = 204,000$  psi (at 1% strain)

Failure strain  $\epsilon' = 4\%$

Modulus of elasticity  $E = 27 \times 10^6$  psi

Rebars:

Material = A432

Tensile strength  $f'_s = 90,000$  psi

Yield strength  $f_{sy} = 60,000$  psi

Failure strain  $\epsilon' = 7\%$

Modulus of elasticity  $E = 29 \times 10^6$  psi

### 3. DEFINITION OF NUMBERS OF TENDONS

The Fort St. Vrain PCRV has, in addition to 90 vertical tendons with 169 1/4-in. diameter wires each, 210 circumferential tendons with 152 1/4-in. diameter wires each, 100 circumferential tendons with 169 1/4-in. diameter wires each, and 48 crosshead tendons with 169 1/4-in. diameter wires each.

All 210 152-wire circumferential tendons are in the barrel section. Of the 100 169-wire circumferential tendons, 34 are in the top head (the top 15'-6" section), 34 in the bottom head (the bottom 15'-6" section), and 16 each in the barrel sections adjacent to the top and bottom heads. Each head has 24 cross-head tendons.

All circumferential tendons are 180° tendons rather than full circle tendons (see Fig. E.15-2, Ref. 1). Because of the arrangement of these tendons, of the 18 circumferential (180°) tendons in a typical five-foot high wall section, a minimum of 12 pass any cross section. Hence 18 actual circumferential tendons provide 12 "effective" circumferential tendons. Similarly in the top or bottom head, 34 actual circumferential tendons provide 22 effective circumferential tendons.

The following definitions are used in this report:

J A T E C H N O L O G I E S I C.

TITLE: FSV - TENDON REQUIREMENTS BASED ON SAFETY CONSIDERATION

DOCUMENT NO. 907738

ISSUE NO./LTR. N/C

$N_b$  = Number of effective circumferential tendons in a 5-foot high wall section (12 in existence).

$N_c$  = Number of effective circumferential tendons in the top or bottom head (22 in existence).

$N_x$  = Number of crosshead tendons in the top or bottom head (24 in existence).

It is assumed that there is no broken wire in any tendon and that the required tendons in each group are uniformly distributed.

#### 4. CIRCUMFERENTIAL TENDONS IN PCRV WALL

For the determination of the required number of circumferential tendons in the PCRV wall a typical five-foot high wall section was considered. It is assumed that ultimate conditions are reached at 1.0 RP or 1.5 RP for the purpose of this analysis. The core cavity liner is anchored to the concrete by means of studs welded to the liner and embedded in the concrete. The stud spacings are 7-1/2 in. in both circumferential and axial directions. It is assumed that, at ultimate, radial concrete cracks would develop at stud anchor locations and that resistance to the core cavity pressure is provided by the steel elements acting as multiple structural rings. The steel elements include the liner, and circumferential tendons and rebars at various radial locations. With the liner and rebar cross-sectional areas known, the number of tendons required to provide a total pressure resistance capacity for the core cavity pressure of 1.0 RP or 1.5 RP, and meeting the selected limit criteria can be determined from equilibrium and strain compatibility.

The tendon prestress loss at end of life is assumed to be 13.5% (Ref. 1), and the friction loss is assumed to be 11.5% (Ref. 3) in these calculations.

Two limit criteria are used in this case:

- 1) Liner stress =  $0.9 f_{sy}$ ,  
Tendon stresses  $\leq f'_s$ , and  
Rebar stresses  $\leq f'_s$
- 2) Maximum tendon stress =  $f'_s$ ,  
Liner stress  $< f'_s$ , and  
Rebar stresses  $\leq f'_s$

---

TITLE: FSV - TENDON REQUIREMENTS BASED ON SAFETY CONSIDERATION

---

DOCUMENT NO. 907738

ISSUE NO./LTR. N/C

---

Obviously the first criterion is the more stringent and results in a larger number of tendons being required. The required numbers of circumferential tendons in the PCRV wall for the above two limit conditions are shown in Table 1.

#### 5. TENDONS IN PCRV TOP AND BOTTOM HEADS

The required number of crosshead and circumferential tendons in the PCRV top and bottom heads to safely support 1.0 RP and 1.5 RP without breaching of the liner boundary are determined by ultimate load analysis of the bottom head.

Four quasi-analytical solutions were originally used in assessing the ultimate capacity of the Fort St. Vrain PCRV heads (Ref. 1). These are: 1) bottom head yield line failure analysis, 2) bottom head punching shear failure analysis, 3) bottom head concrete ligament compressive failure analysis, and 4) top head analysis by grid system simulation. In the case of 34 circumferential and 24 crosshead tendons in each head and 90 vertical tendons, the yield line analysis provided the lowest estimate of the ultimate pressure capacity, while the concrete ligament compressive failure analysis provided the highest, about three times as high as the lowest estimate. The top head grid analysis requires use of a computer program.

Based on the above observations it was decided to use the yield line failure analysis method for the ultimate load analysis in the current study, and to check the results using the punching stress failure analysis.

The assumptions and detailed procedure used in the bottom head yield line analysis follow those used in Ref. 1. Based on an assumed number of crosshead tendons the resultant pressure which must be resisted by the bottom head (cavity pressure reduced by the cavity pressure equivalent of crosshead tendons, Ref. 1) is first calculated. By assuming formation of a plastic hinge at the head-to-wall junction (signified by 0.003 in/in maximum concrete strain and/or yielding of liner and majority of rebars in tension), and a yield line pattern (generally radial along concrete ligaments) the unit yield line moment required to prevent this particular yield line mode of failure under the given cavity pressure (1.0 RP or 1.5 RP) can be determined. The number of circumferential tendons required to provide an ultimate moment capacity along the yield line which is larger than the required unit yield line moment is then established. The ultimate moment capacity of the bottom head is defined by the following stress limits (Ref. 1):

A TECHNOLOGIES I.C.

---

TITLE: FSV - TENDON REQUIREMENTS BASED ON SAFETY CONSIDERATION

---

DOCUMENT NO. 907738

ISSUE NO./LTR. N/C

---

Maximum rebar stress  $\leq 0.9 f_{sy}$ ,

Maximum tendon stress  $\leq 0.9 f_{sy}$ , and

Maximum compressive concrete stress  $\leq 0.85 f'_c$

The tendon prestress losses at end of life are assumed to be 12% for both crosshead and circumferential tendons (Ref. 1) and the friction losses are assumed to be 10% and 11.5%, respectively for these two types of tendons (Ref. 3). The yield line failure analysis in the current study is based on the assumption that no vertical tendons exist.

The required number of tendons based on the results of the yield line failure analysis are shown graphically in Figs. 1 and 2.

For the punching shear failure analysis of the bottom head the failure plane is assumed to be the one formed by the concrete ligaments connecting the steam generator penetrations (Ref. 1). Reference 4 provides an equation to estimate the ultimate shearing strength of PCRV heads as a function of span/depth ratio and radial prestress. Based on this equation and the number of head tendons required as determined by the yield line failure analysis, it is found that the punching shear stress is not critical for either the 1.0 RP or the 1.5 RP cases.

## 6. CONCLUSIONS

The required numbers of circumferential tendons in the Fort St. Vrain PCRV wall to safely support the cavity pressure of 1.0 RP and 1.5 RP are given in Table 1. The corresponding required numbers of crosshead and circumferential tendons in either top or bottom head of the PCRV, derived under a conservative assumption of no vertical prestress, are given in Figs. 1 and 2.

From Fig. 2, it appears that under 1.5 RP the permissible reduction in the numbers of crosshead and circumferential tendons in the heads is small if no vertical prestressing tendons exist.

## 7. REFERENCES

1. "Fort St. Vrain Nuclear Generating Station. Updated Final Safety Analysis Report."
2. ASTM, "Specification for Carbon-Manganese-Silicon Steel Plates, Heat Treated for Pressure Vessels. SA-537."

A T E C H N O L O G I E S I C.

TITLE: FSV - TENDON REQUIREMENTS BASED ON SAFETY CONSIDERATION

DOCUMENT NO. 907738

ISSUE NO./LTR. N/C

3. Lee, T. T. and Cheung, K. C., "FSV - PCRV Tendon Evaluation," GA Document 907441/A, April 30, 1984.
4. Garas, F. K. and Trowsdale, D. R., "Overload Behavior and Shear Failure Mechanisms of Model No. 2 of the Bottom Head of the Fort St. Vrain Prestressed Concrete Reactor Vessel," Report 14H/69/1411, Taylor Woodrow Construction, Ltd., September 1969.
5. Bresler, B., "Reinforced Concrete Engineering," Vol. 1 Materials Structural Elements, Safety, John Wiley & Sons, New York, 1974.
6. "PCRV Bottom Head, Reinforcing Plan, Sheet 1," Drawing 3614, B-36/J, Sargent & Lundy, March 1969.
7. "PCRV Bottom Head, Reinforcing Schedule and Details, Sheet 1," Drawing 3614, B-37/E, Sargent & Lundy, October 1969.
8. "PCRV Bottom Head, Reinforcing Plan, Sheet 2," Drawing 3614, B-38/K, Sargent & Lundy, April 1969.
9. "PCRV Bottom Head, Reinforcing Schedule & Details, Sheet 2," Drawing 3614, B-39/E, Sargent & Lundy, December 1968.
10. "PCRV Bottom Head, Reinforcing Schedule & Details, Sheet 3," Drawing 3614, B-40/D, Sargent & Lundy.
11. "PCRV Bottom Half Vertical Section," Drawing 3614, B-35/S, Sargent & Lundy, December 1969.
12. "PCRV Bottom Head, Tendon Tubes Details," Drawings 3614, B-21/E and B-22/D, Sargent & Lundy, October 1969.

NOTE: References 5 through 12 are cited in the appendices.

## J A TECHNOLOGIES I . C.

TITLE: FSV - TENDON REQUIREMENTS BASED ON SAFETY CONSIDERATION

DOCUMENT NO. 907738

ISSUE NO./LTR. N/C

TABLE 1

MINIMUM NUMBERS OF CIRCUMFERENTIAL TENDONS IN WALL SECTION

Criterion	Number of Tendons Required ( $N_b$ ) <sup>(1)</sup>		Percentage of Tendons Required <sup>(2)</sup>	
	1.0 RP <sup>(3)</sup>	1.5 RP	1.0 RP	1.5 RP
Liner Stress = 0.9 $f_{sy}$	5	9	42%	75%
Max. Tendon Stress = $f'_{s}$ <sup>(4)</sup>	3	5	25%	42%

(1) Number of effective tendons required per 5-foot high section. See the text for definition of  $N_b$ .

(2) Percentage of tendons currently provided in any region of the PCRV wall. It is assumed that the required tendons are located uniformly in the region under consideration.

(3) 1.0 RP = 845 psig.

(4) The liner strain is 0.046 in./in. when the maximum tendon stress is  $f'_{s}$ .

TITLE: FSV - TENDON REQUIREMENTS BASED ON SAFETY CONSIDERATION

DOCUMENT NO. 907738

ISSUE NO./LTR. N/C




Figure 1. Number of Head Tendons Required in Each Head to Support 1.0 RP

TITLE: FSV - TENDON REQUIREMENTS BASED ON SAFETY CONSIDERATION

DOCUMENT NO. 907738

ISSUE NO./LTR. N/C




Figure 2. Number of Head Tendons Required in Each Head to Support 1.5 RP

DD 907738/N/C

APPENDIX A

NUMBER OF CIRCUMFERENTIAL TENDONS IN THE PCRV WALL

## TABLE OF CONTENTS - APPENDIX A

	<u>Page</u>
A.1 CASES CONSIDERED .....	A3
A.2 LOCATIONS OF STEEL COMPONENTS .....	A3
A.3 MATERIAL PROPERTIES .....	A5
A.4 ASSUMPTIONS .....	A9
A.5 COMPATIBILITY .....	A11
A.6 CONTRIBUTION TO PRESSURE CAPACITY .....	A12
A.7 CALCULATION OF MINIMUM TENDONS REQUIRED .....	A14
A.8 SUMMARY OF CALCULATED RESULTS .....	A20

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738	N/C	PAGE A 3 OF
PREPARED BY	T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY		DATE		


## A.1 Cases Considered

$$1) \text{ Core cavity pressure} = \text{Reference Pressure} \\ = 1.0 RP = 845 \text{ psig}$$

$$2) \text{ Core cavity pressure} = 1.5 RP = 1268 \text{ psig}$$

## A.2 Location of Steel Components

For a 5'-0" barrel section



$$\begin{array}{c}
 R_{R1} = 191.25'' \quad R_{R3} = 241.31'' \quad R_{R5} = 284.35'' \\
 R_{R2} = 204.07'' \quad R_{R4} = 262.81'' \quad R_{R6} = 291.5'' \\
 \end{array}$$

Fig A-1

(R=f 1. F.SAR F.F E.15-6 )

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907788	N/C	PAGE A 4 OF
PREPARED BY T. T. Lee	DATE 11/19/82	REF. DOCUMENTS.		
CHECKED BY	DATE			

1

2

3

## Rebar Dimensions

4

Table A-1

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

Bar Size	Diam. (in.)	Area (in <sup>2</sup> )
# 8	1.000	0.79
# 9	1.128	1.00
# 11	1.410	—
# 18 S	2.257	—

## Rebar Groups:

Table A-2

Group	R <sub>R</sub> (in.)	Rebars	Number per 5 ft.	Total Area (in <sup>2</sup> )
R1	191.25	*8 @ 7.5"	8	6.32
R2	204.07	3-*9 @ 27"	6	6.00
R3	241.31	*9 @ 10"	6	6.00
R4	262.81	*9 @ 10"	6	6.00
R5	284.31	*9 @ 10"	6	6.00
R6	291.50	*8 @ 10"	6	4.74

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907788	N/C	PAGE A 5 OF
PREPARED BY T. T. Lee	DATE " / 19 / 86		REF. DOCUMENTS:	
CHECKED BY	DATE			

Liner:  $\frac{3}{8}$  in. thick at  $R_L = 186.375$  in.

Tendons: 152 -  $\frac{1}{8}$  in diam wires  $\rightarrow$  Area = 7.463  $\text{in}^2$   
 169 - " " " " "  $\rightarrow$  Area = 8.298

- 3 groups of 6 tendons each (total of 18)

for each 5 ft. section, located at  $R_{T1}$ ,  $R_{T2}$ , &  $R_{T3}$

- Minimum of 12 tendons pass any 5 ft section

### A.3 Material Properties

Rebars A432 (A305-S67, Deformation)

$f_{sy}$  = Minimum guaranteed yield strength

(at 0.5% total extension)

= 60 ksi (FSAR, App. E Section E.1)

$f_s'$  = Minimum guaranteed tensile strength

= 90 ksi (FSAR, Section E.1)

$\epsilon'$  = Minimum guaranteed strain at failure

= 790 in  $\delta$  in (FSAR, Section E.1)

$E$  = Modulus of elasticity =  $29.0 \times 10^3$  ksi  
 FSAR Sec E.10<sup>2</sup>

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738	N/C	PAGE A6 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:		
CHECKED BY	DATE			

Liner: SA 537, Grade B (Quenched & tempered)  
(Ref. 1)

$f_{sy} = 60 \text{ ksi}$  (at 0.2% offset) (FSAR, E.1.  
CFSAR, E.102)

$f'_s = 80 \text{ ksi}$  } (ASTM Spec. SA 537, Ref. 2)  
 $\epsilon' = 18\%$

$E = 290 \times 10^3 \text{ ksi}$  (CFSAR Sec. E.10.3)

Tendons:

Tendon wires:  $f'_s = 240 \text{ ksi}$

$f_{sy} = 204 \text{ ksi}$  at 1% strain

$\epsilon' = 4\%$

See Fig. 4 (From FSAR, Fig. 5.6-1)

$E = 27 \times 10^3 \text{ ksi}$  (Table 5.6-5)  
FSAR


## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. <b>907738</b>	N/C	PAGE A7 OF
PREPARED BY <i>T. T. Lee</i>	DATE <i>11/19/84</i>	REF. DOCUMENTS:		
CHECKED BY	DATE			


1  
2 Stress - Strain Curves:  
3

4 Rebars:



use  $\left\{ \begin{array}{l} f = 90 - (0.07 - \epsilon) \times 461.5, \quad \epsilon \geq 0.00202 \\ f = 290 \times 10^3 \epsilon, \quad \epsilon \leq 0.00202 \end{array} \right.$

Liner:



use  $\left\{ \begin{array}{l} f = 80 - (0.018 - \epsilon) \times 113.7, \quad \epsilon \geq 0.00206 \\ f = 290 \times 10^3 \epsilon, \quad \epsilon \leq 0.00206 \end{array} \right.$




Figure A-4 Typical Stress-Strain Curve of Wire

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE A 9 OF
PREPARED BY	T. T. Lee	DATE	//19/84	REF. DOCUMENTS:	
CHECKED BY		DATE			

A.4 Assumptions

- (1) Based on the discussion on the crack propagation given in FSAR, Section E 8.2.3.1 it is assumed that radial cracks develop at the locations of stud anchors. Hence concrete does not participate in resisting the core cavity pressure. It does transmit the pressure radially
- (2) Each steel component (liner, rebar and tendon) acts as a ring and contributes in resisting the core cavity pressure
- (3) On account of the extensiveness of the concrete crack the bond between rebar and concrete is essentially non-existing and the strain in a given rebar is essentially

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738	N/C	PAGE A 10 OF
PREPARED BY T. T. Lee	DATE 11/19/84		REF. DOCUMENTS:	
CHECKED BY	DATE			

constant (Ref. 5, p 175).

(4) The prestress loss at end of life is  
13.5% (FSAR, Table 5.6-4) The friction loss  
is 11.5% (Ref. 3)

(5) Radial shortening of concrete is negligible  
Hence the radial displacements of all steel  
components are the same

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738	N/C	PAGE A 11 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS.		
CHECKED BY	DATE			

A. 5 Compatibility

Assuming that each steel component displaces radially the same amount, the strains in various components are related as follows:

$$\epsilon_L R_L = \epsilon_{Ri} R_{Ri} = (\Delta \epsilon_{T_i}) R_{T_i}$$

where  $\epsilon$  = strain

$R$  = radial distance from the center of core cavity

$\Delta \epsilon_{T_i}$  = additional tendon strain for Group tendon  
 $=$  total tendon strain - strain due to prestress

The subscripts are:

$L$  = liner

$R$  = a rebar group

$T$  = a tendon group

$i$  = group number

The strain due to prestress  $\cong 0.00476$  in/in (Fig. A-7)  
 based on  $f = 0.7 f'_c \times (1 - 0.125) \times 0.875 = 128.6$  ksi

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738	N/C	PAGE A 12 OF
PREPARED BY T. T. Lee	DATE 11/19/84			REF. DOCUMENTS:
CHECKED BY	DATE			

A.6 Contribution to Pressure Capacity

Let  $f$  = stress (psi)

$A_s$  = total steel area ( $\text{in}^2$ )

$p'$  = pressure capacity if the pressure  
is applied to the steel component  
(psi)

$p$  = contribution to the core cavity  
pressure capacity (psi)

Liner:

$$\frac{p' R_L \cdot 60}{A_{s,L}} = f_L \rightarrow p' = \frac{3/2 \times 60}{186,375 \times 60} f_L = 4024 \times 10^{-3} f_L$$

$$p_L = p'_L = 4024 \times 10^{-3} f_L$$

Rebar Groups:

$$\frac{p'_{Ri} R_{Ri} \cdot 60}{A_{s,Ri}} = f_{Ri} \rightarrow p'_{Ri} = \frac{A_{s,Ri}}{60 \cdot R_{Ri}} f_{Ri}$$

$$p_{Ri} = p'_{Ri} \frac{R_{Ri}}{R_L} = \frac{A_{s,Ri}}{60 R_L} f_{Ri}$$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738	N/C	PAGE A/3 OF
PREPARED BY T. T. Lee	DATE 11/19/86	REF. DOCUMENTS		
CHECKED BY	DATE			

For  $R_1$ :  $P_{R1} = \frac{632}{60 \cdot 186.375} f_{R1} = 0.565 \times 10^{-3} f_{R1}$

For  $R_2 \sim R_5$ :

$$P_{R2} = \frac{600}{632} \cdot 0.565 \times 10^{-3} f_{R2} = 0.536 \times 10^{-3} f_{R2}$$

$$\text{For } R_6: P_{R6} = \frac{474}{632} \cdot 0.565 \times 10^{-3} f_{R6} = 0.424 \times 10^{-3} f_{R6}$$

### Tendon Groups

$$\frac{P'_{Ti} R_{Ti} 60}{A_{s,Ti}} = f_{Ti} \rightarrow P'_{Ti} = \frac{A_{s,Ti}}{60 R_{Ti}} f_{Ti}$$

$$P_{Ti} = P'_{Ti} \frac{R_{Ti}}{R_L} = \frac{A_{s,Ti}}{60 R_L} f_{Ti}$$

$$= \frac{N' \cdot 7.463}{60 \cdot 186.375} f_{Ti} = 0.667 \times 10^{-3} N'_i f_{Ti} \quad (152-\text{wire})$$

$$= \frac{N' \cdot 8.298}{60 \cdot 186.375} f_{Ti} = 0.742 \times 10^{-3} N'_i f_{Ti} \quad (169-\text{wire})$$

where  $N'_i$  = minimum number of tendons passing any 5 ft section

(for each group, maximum is 4)

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738	N/C	PAGE A 1 OF
PREPARED BY	DATE 11/19/84			REF. DOCUMENTS:
CHECKED BY	DATE			

A.7 Calculation of Minimum Tendons Required

- (1) Select a limit criterion in terms of  $\epsilon$ .
- (2) Calculate strains for all steel components using the compatibility relations. Check  $\epsilon \leq \epsilon_c$ .
- (3) Calculate  $f_u$ ,  $f_{Ri}$  and  $f_{Ti}$  (Figs A-2 ~ A-4)
- (4) Calculate  $P_u$ ,  $P_{Ri}$  and  $P_{Ti}$
- (5) Calculate the total pressure capacity to be contributed by tendons:

$$\left( \sum_{i=1}^3 P_{Ti} \right)_{\text{req'd}} = 845 - (P_u + \sum_{i=1}^6 P_{Ri})$$

(or 1268)

- (6) Calculate the total number of tendons required, using the middle row as an average:

$$N_b = \frac{\sum_{i=1}^3 N'_i}{12} = \frac{\left( \sum P_{Ti} \right)_{\text{req'd}}}{0.667 f_{T2}}$$

$f_{T2}$  in kpsi  
(152-wire) (or 0.742) ~ (169-wire tendons)

$$\text{Or } N = \frac{18}{12} \sum_{i=1}^3 N'_i$$

where  $N$  is the actual total number of tendons required to provide  $\sum_{i=1}^3 N'_i$  effective number of tendons in any section

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE A15 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

IRP Case

Table A-3.

Criterion: Liner Stress at 0.9  $f_{sy}$  = 52 ksi

Component	R (in)	$\frac{R_L}{R}$	$\Delta E_{Ti}$	$\epsilon$	f (ksi)	P (psi)
Liner	186.38	1		0.00186	52.0	2173
R1	191.25	0.975		0.00181	52.5	29.7
R2	207.07	0.913		0.00170	29.3	26.4
R3	241.31	0.772		0.00167	21.8	23.6
R4	262.21	0.709		0.00132	38.3	20.5
R5	284.21	0.656		0.00122	35.4	19.0
R6	291.50	0.639		0.00119	34.5	17.6
T1	243.00	0.767	0.00123	0.00619		
T2	254.50	0.705	0.00131	0.00607	Average → 164	109 ear 70.0
T3	286.00	0.652	0.00121	0.00597		

$$\sigma + \epsilon - (P_0 + \sum P_{ext}) = 845 - (351.1) = 493.9 \text{ psi}$$

$$\frac{\sum N_i}{N} = \frac{493.9}{109} = 4.53$$

$$\rightarrow N = 6.80$$

$$\text{For } N = 7 \quad P = 351 + 109 \times 7 \times \frac{2}{3} = 860 \text{ psi}$$

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE A 16 OF
PREPARED BY T T Lee	DATE 11/19/84		
CHECKED BY	DATE	REF. DOCUMENTS:	

1 RP case

2 Table A-4

3 Criteria 2:

4 Tendons at  $R = 223$  in have  $\epsilon = \epsilon'$ 

Component	$R$ (in)	$\frac{R_{T_1}}{R}$	$\Delta\epsilon_{T_2}$	$\epsilon$	$f$ (ksi)	$P$ (psi)
Liner	186.38	1.30		0.0458	647	2605
$R_1$	191.25	1.27		0.0447	783	272
$R_2$	207.07	1.19		0.0419	770	213
$R_3$	241.31	1.01		0.0356	741	397
$R_4$	262.81	0.925		0.0326	727	390
$R_5$	284.31	0.855		0.0301	716	382
$R_6$	291.50	0.854		0.0294	713	302
$T_1$	243.00	1	0.0352	0.04	260	1600 ps
$T_2$	264.50	0.919	0.0324	0.0372	2366	157.8 $\frac{\text{ps}}{\text{in}^2}$
$T_3$	256.00	0.850	0.0300	0.0347	233.6	155.8 ps

$$352 - (P_L + \sum P_{R_i}) = 0.95 - (493) = 352$$

$$\sum N_i = 352 / 157.8 = 2.23$$

$$\rightarrow N = 3.35$$

$$\text{For } N=4 \quad P = 2P_L + 4 \times 157.8 \times \frac{2}{3} = 912 \text{ psi}$$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE A 17 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

1 RP Case Table A-5

2 Criterion 3:

3 Rebars at  $R = 191.25$  in have  $\epsilon = \epsilon'$ 

Component	$R$ (in)	$\frac{R_{Ri}}{R}$	$\Delta \epsilon_{Ti}$	$\epsilon$	$f$ (ksi)	$P$ (psi)
Liner	186.38	1.03		0.072	67.7	272.5
$R_1$	191.25	1		0.07	90.0	50.9
$R_2$	209.07	0.927		0.0656	87.8	47.2
$R_3$	241.31	0.793		0.0555	83.3	29.6
$R_4$	262.81	0.728		0.0509	81.2	23.5
$R_5$	284.21	0.673		0.0471	79.4	22.6
$R_6$	291.50	0.656		0.0459	78.9	22.4
$T_1$	243.00	0.787	0.0551	0.0599		0
$T_2$	267.50	0.723	0.0506	0.0554	$\gamma > 4\%$ $= \epsilon'$	0 <small>each</small> <small>torc</small>
$T_3$	256.00	0.669	0.0468	0.0516	Failed	0

$$345 - (P_s + \sum P_{Ri}) = 345 - (535) = 310$$

$$\sum N_i' = N.A$$

$$\rightarrow N = N.A$$

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE A 18 OF
PREPARED BY T. T. Lee	DATE 11/19/82	REF. DOCUMENTS:	
CHECKED BY	DATE		

Tables A-3 through A-5 are for tendons with 152 wires. For tendons with 169 wires, still for 1 RP, using the data in Tables A-3 and A-4:

Criterion 1.  $f_t = 162 \text{ ksi} \rightarrow \frac{f_t}{N_i} = 121.7 \text{ psi}$

$$\sum N_i' = \frac{493.9}{121.7} = 4.06 \text{ vs } 4.53 \text{ for } 152\text{-wire tendon}$$

Criterion 2.  $f_t = 236.6 \rightarrow \frac{f_t}{N_i} = 175.6 \text{ psi}$

$$\sum N_i' = \frac{352}{175.6} = 2.00 \text{ vs } 2.23 \text{ for } 152\text{-wire tendon}$$

→ Use the same number of tendons  
as in the 152-wire tendon case

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907788 N/C	PAGE A 19 OF
PREPARED BY T. T Lee	DATE 11/19/82	REF. DOCUMENTS:	
CHECKED BY	DATE		

1.5 RP Case

Data in Tables A-3 and A-5 still apply.

The required pressure capacity is 1268 psig instead of 845 psig.

Based on Table A-3.

$$\bar{P}_a + \sum \bar{P}_{R,i} = 351.1 \text{ psig}$$

Tendons must supply  $1268 - 351.1 = 916.9$

$$\sum_{i=1}^3 N_i = \frac{916.9}{109} = 8.41 \rightarrow N = 12.6$$

$$\text{Use } N = 13 \rightarrow P = 351.1 + 109 \times 13 \times \frac{2}{3} = 1295 \text{ psig}$$

Criterion 2: Tendons at R = 243 in. have  $\epsilon = \epsilon'$

$$\sum_{i=1}^3 N_i = \frac{1268 - 293}{157.8} = 4.91 \rightarrow N = 7.37$$

$$\text{Use } N = 8 \rightarrow P = 293 + 8 \times 157.8 \times \frac{2}{3} = 1335 \text{ psig}$$

Criterion 3: Rebars at R = 191.25 in have  $\epsilon = \epsilon'$

Tendon strain > 4%

$$P = 535 \text{ psig}$$

N.G

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE A20 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

A.8 Summary of Calculated Results

Table A-6

Minimum Number of Circumferential Tendons  
Required per 5 ft High Wall Section

Limit Criteria	Required 1.0 RP		Required 1.5 RP		Number currently Provided	
	Actual	Effective	Actual	Effective	Actual	Effect
Liner Stress $= 0.9 f_{sy}$	7	5	13	9	18	12
Max. Tendon strain = $\epsilon'$	4	3	8	5	18	12

DD 907738/N/C

APPENDIX B

NUMBER OF PCRV HEAD TENDONS

## TABLE OF CONTENTS - APPENDIX B

	<u>Page</u>
B.1 YIELD LINE MODE OF FAILURE .....	B3
B.1.1 Basic Assumptions .....	B3
B.1.2 Calculational Procedure .....	B4
B.1.3 Net Head Pressure Load .....	B6
B.1.4 Boundary Force .....	B8
B.1.5 Boundary Moment .....	B9
B.1.6 Unit Yield Line Moment .....	B30
B.1.7 Moment Capacity Along Yield Lines .....	B45
B.1.8 Required Number of Head Tendons .....	B58
B.2 POTENTIAL FAILURE MODE WITH A YIELD LINE AT EDGE OF CORE CAVITY .....	B60
B.3 PUNCHING SHEAR MODE OF FAILURE .....	B78

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 NIC	PAGE B3 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

8.1 Yield Line Mode of Failure

The analysis is performed for the bottom head subjected to 1 RP or 1.5 RP cavity pressure. Calculational steps parallel those used in the FSAR Update, Section E. 11.2.2 (Ref. 1).

8.1.1 Basic Assumptions

See Ref 1, Section. E. 11.2.2

Additional assumptions

- 1) No vertical tendons
- 2) Number of crosshead and circumferential tendons in the heads are to be reduced  
(Original design has 24 crosshead tendons and 32 circumferential tendons.)

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE B-2 OF
PREPARED BY T T Lee	DATE 11/19/82	REF. DOCUMENTS:	
CHECKED BY	DATE		

B. 1.2 Calculational Procedure

- 1) Calculate the net head pressure load.

(Cavity pressure - cavity pressure equivalent of crosshead tendons)

This is done for an assumed  $N_x$  (§B.1.3)

- 2) Calculate the net tensile force (or boundary force) transmitted through the intersection of the PCRV wall and the bottom head (§B.1)




Fig. B-1

- 3) Assuming that a plastic hinge forms at the head-to-wall junction, calculate the boundary moment corresponding to  $F_{L-L}$  (§B.1)

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 85 OF
PREPARED BY	T. T. Lee	DATE	11/19/84	REF. DOCUMENTS:	
CHECKED BY		DATE			

1  
2  
3     4) Assuming a yield pattern for the head,  
5         calculate the unit yield line moment  
6         required to balance the net pressure.  
7  
8

9          $F_{L-L}$  and  $M_{L-L}$ . (§B.1.6)

10  
11  
12     5) Calculate the number of circumferential  
13         (head) tendons required to provide a  
14         unit moment capacity along the yield  
15         equals to or larger than the required  
16         unit yield line moment. (§B.1.7, B.1.8)  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE B6 OF
PREPARED BY T T Lee	DATE 11/19/82	REF. DOCUMENTS:	
CHECKED BY	DATE		

B.1.3 Net Head Pressure Load

The pressure load on the heads is resisted in part by the crosshead tendons. The vertical component of the crosshead tendons is:

$$F_v = (2N_x)(A_t)(f_t) \sin \alpha$$

where:  $N_x$  = Number of crosshead tendons

$A_t$  = X-sectional area of a tendon = 8.35 in.<sup>2</sup>

$f_t$  = tendon stress

$\alpha$  = average inclination of the tendons  
=  $36^\circ 45'$

Allowing  $f_t = 0.7 f_s' (1 - 0.12)(0.9) = 0.554 f_s' = 1$

$$F_v = 2N_x (8.35) (133,000) \sin 36^\circ 45' \\ \text{(Ref. 1, Table 5.6-4) } \frac{\text{loss}}{\text{friction}} \text{ (Ref. 3)}$$

$$= 1,329,000 N_x \text{ lbs}$$

Cavity pressure equivalent of crosshead tendons is assumed constant over the cavity.

$$\frac{p}{N_x} = \frac{F_v}{3.14 \times 186^2} = 12.23 N_x \text{ psig} \quad \text{Cavity} \\ \text{red} = 1.25$$

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 87 OF
PREPARED BY	DATE				
CHECKED BY	DATE			REF. DOCUMENTS:	

1

2

3

4

The net pressure load is:

5

6

$$P = \text{Actual cavity pressure} - 12.23 N_x$$

7

8

9

Table B-1 Net Pressure and Boundary Force

$N_x$	1.0 RP		1.5 RP	
	Net pressure (psi)	$F_{L-L}$ (k/in. of 1m)	Net pressure (psi)	$F_{L-L}$ (k/in. of 1m)
0	845	786	1268	1179
6	772	71.8	1196	111.1
12	698	64.9	1120	1042
18	625	58.1	1046	97.3
24	551	51.3	972	90.4

**CALCULATION SHEET**

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 8 OF
PREPARED BY	DATE				REF. DOCUMENTS:
T. T. Lee	11/19/86				

1

2

3

B 1.4 Boundary Force

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

Since there is no vertical tendon, the net pressure load must be resisted by the vertical rebar, liners and concrete.

The net tensile force per circumferential inch at the head-to-wall junction is:

$$F_{L-4} = \frac{\pi (186)^2 (\text{Net pressure in psi})}{2 \pi (186) (1000)} \quad k/in \text{ of liner}$$

(Core cavity radius)

See Table B-1.

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	REF. DOCUMENTS:
PREPARED BY T T Lee	DATE 11/19/82	907738 N/C	PAGE 89 OF
CHECKED BY	DATE		

B. 1.5 Boundary Moment

Boundary moment at the head-to-wall junction is determined by establishing a strain diagram which is consistent with the plastic hinge condition and which will result in a net cross-section resistance force equals to  $F_{L-L}$ .

A plastic hinge is considered formed when,

$$\text{Max. concrete strain} = 0.003$$

or

Max. steel strain (rebar) =  $0.07 = \epsilon'$   
 liner contribution is neglected in  
 this analysis.

Fig. B-2 shows the location of rebars  
 strain diagram, etc for a case in which  
 the two limits given above occur simultaneously




Figure B-2

## CALCULATION SHEET

## CALCULATIONS FOR


EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE 81 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:		
CHECKED BY	DATE			

1

2

3

A balanced case:




Referring to Fig. 8-2  
and Table B-2:

$$F_{L-L} = 76.6 \text{ k/in. of line}$$

$$M_{L-L} = 1616.06 \text{ k-in./in. line}$$



For  $F_{L-L} < 76.6 \text{ k/in.}$ :



Case 1

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 8/12 OF
PREPARED BY T. T. Lee	DATE 11/19/82	REF. DOCUMENTS:	
CHECKED BY	DATE		

Table E-2

## Wall Moment about Liner Axis L-L

Element	Area <sup>(a)</sup> (in. <sup>2</sup> /in.)	Strain <sup>(b)</sup> (in./in.)	Stress (ksi)	Force (k/in. liner)	Dist. from L-L <sup>(a)</sup> (in.)	Moment ab L-L (k-in.)
A <sub>1</sub>	0.75		~	~	0	~
A <sub>2</sub>	0.27	0.07	90	24.30	40	9720
A <sub>3</sub>	0.29	0.063	82.640	25.126	16.0	402.02
A <sub>4</sub>	0.21	0.040	75.969	15.953	520	86146
A <sub>5</sub>	0.77	0.012	63.331	48.765	99.0	482774
A <sub>6</sub>	0.28	-0.001	-16.412	-6.236	120.0	-74832
A <sub>c</sub>		0.003		-3/306	122.15	-382403


(a) Those for A<sub>2</sub> through A<sub>6</sub>

are from Ref. 1, Table E-1a

$$F_{L-L} = 76.502 \quad M_{L-L} = +161606$$

(b) Based on  $\epsilon = 4.93 \text{ in}$ 

$$\epsilon_c = 0.003$$



**CALCULATION SHEET****CALCULATIONS FOR**

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 8/3 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32


33

34


35

36


For  $F_{L-L} > 76.6 \text{ k/in}$



Case 2



larger  $F_{L-L}$



## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 8 / 14 OF
PREPARED BY T. T. Lee	DATE 1/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

For Case 1,  $F_{L-L} < 766 \text{ k/in}$ :

From the force equilibrium:

$$\sum_{i=2}^5 F_n - F_e - F_c = F_{L-L} = \text{Boundary Force}$$

Note: Liner force not included

Strains:

$$\epsilon_1 = \frac{0.003(120-x)}{x} = \frac{0.372}{x} - 0.003$$

$$\epsilon_2 = \frac{0.003(120-x)}{x} = \frac{0.372}{x} - 0.003$$

$$\epsilon_3 = \frac{0.003(120-16-x)}{x} = \frac{0.003(108-x)}{x} = \frac{0.324}{x} - 0.003$$

$$\epsilon_4 = \frac{0.003(120-50-x)}{x} = \frac{0.003(70-x)}{x} = \frac{0.21}{x} - 0.003$$

$$\epsilon_5 = \frac{0.003(120-99-x)}{x} = \frac{0.003(21-x)}{x} = \frac{0.075}{x} - 0.003$$

$$\epsilon_6 = \frac{0.003(x-4)}{x} = 0.003 - \frac{0.012}{x} \quad (\text{comp})$$

Stress:

Let  $f_i$  be the stress in element  $i$ .

$$f_i = 90 - (0.07 - \epsilon_i) \times 4615 \quad \text{if } \epsilon_i \geq 0.00202 \\ i=2 \sim 6 \quad (\text{Fig A-2})$$

$$f_6 = 29000 \epsilon_6 \quad \text{if } \epsilon_6 \leq 0.00202 \quad (\text{Fig A-3})$$

$$f_c = 0.85 f_c' = 51 \text{ ksi}$$

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 815 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS.	
CHECKED BY	DATE		

Forces:

$$F_i = f_i \times A_i \quad i = 2, \dots, 6$$

$$F_c = f_c \times A_c$$

where  $A_c = (0.75x)(\text{Area width of cone compression zone})$   
 $= (0.75x)(w_c)$

$$\begin{aligned} w_c &= \frac{1}{2}(1.67 + 1.67 - 0.67 - \frac{0.75x}{12.4}) \\ &= 1.67 - 0.00203x \end{aligned}$$

$$\text{else } w_c = 1.66 \quad x \leq 7.39''$$

$$w_c = 1.65 \quad x \leq 12.31''$$

$$w_c = 1.64 \quad x \leq 17.34''$$

$$F_c = 6.35x \quad \text{if } x \leq 7.39''$$

$$= 6.31x \quad \text{if } x \leq 12.31''$$

$$= 6.17x \quad \text{if } x \leq 17.34''$$

Distance from LL for  $A_c$ :

$$12.4 - \frac{0.75x}{2} = 12.4 - 0.375x$$


Calculation of  $M_{Lz}$  using the above formulas and other needed relations are done in tabular form.

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 8/6 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

Case 2: For  $F_{c,L} > 76.6 \text{ k/in}$



$$\epsilon_3 = 0.07 - (\epsilon_c + 0.07) \frac{1^2}{120} = 0.0630 - 0.1 \epsilon_c$$

$$\epsilon_4 = 0.07 - (\epsilon_c + 0.07) \frac{50}{120} = 0.0208 - 0.4167 \epsilon_c$$

$$\epsilon_5 = 0.07 - (\epsilon_c + 0.07) \frac{95}{120} = 0.0126 - 0.7917 \epsilon_c$$

$$\epsilon_6 = 0.07 - (\epsilon_c + 0.07) \frac{116}{120} = 0.0023 - 0.9667 \epsilon_c$$

$$x = \frac{120 \epsilon_c}{0.07 + \epsilon_c}$$

use  $F_c = 6.35x$

$$+ arm = 124 - 0.375x$$

(i.e., assume 0.85  $f_c'$  rect. block)

} For  $\epsilon_c \geq 0.001$

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 8/7 OF
PREPARED BY T T Loo	DATE 11/18/84	REF. DOCUMENTS:			
CHECKED BY	DATE				

To avoid a tedious iteration process, calculation of  $M_{L2}$  for various  $F_{L2}$  given in Table B-1 is done as follows:

- 1) Compute a series of  $F_{L2}$ ,  $M_{L2}$  pairs for selected values of  $\lambda$  or  $\epsilon$ .  
 Use formulas for Case 1 or Case 2, as need  
 (Tables B-2 through B-13)
- 2) Interpolate to obtain  $M_{L2}$  for various  
 $F_{L2}$  of interest  
 (Table B-14)

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 818 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS.	
CHECKED BY	DATE		

Table B-3 Boundary Force and Moment about Liner Axis L-L

Element	Area <sup>(a)</sup> in. <sup>2</sup> /in.)	Strain <sup>(b)</sup> (in./in.)	Stress (ksi)	Force (k/in. liner)	Dist from L-L <sup>(a)</sup> (in.)	Moment ab L-L (k-in.)
A <sub>1</sub>	0.75	0.051	—	—	0	—
A <sub>2</sub>	0.27	0.029	80.389	21.705	70	86.820
A <sub>3</sub>	0.29	0.022	77.981	22.614	16.0	361.832
A <sub>4</sub>	0.21	0.027	70.356	14.775	520	797.859
A <sub>5</sub>	0.77	0.008	61.327	47.222	99.0	4678.972
A <sub>6</sub>	0.28	0.001	-36.565	-13.895	120.0	-1667.374
A <sub>c</sub>		0.003		-43.815	121.413	-5319.687


(a) Those for A<sub>2</sub> through A<sub>6</sub>

are from Ref. 1, Table E.11-1

(b) Based on X = 69 in

$$\varepsilon_c =$$

$$F_{L-L} = 48.61 \quad M_{L-L} = -1065.63$$



## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE B19 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS.	
CHECKED BY	DATE		

Table B-4 Boundary Force and Moment about Liner Axis L-L

Element	Area <sup>(a)</sup> (in <sup>2</sup> /in)	Strain <sup>(b)</sup> (in./in.)	Stress (ksi)	Force (k/in liner)	Dist from L-L <sup>(a)</sup> (in.)	Moment abt L-L (k-in/in)
A <sub>1</sub>	0.75	0.055	—	—	0	—
A <sub>2</sub>	0.27	0.053	72.270	22.213	70	28.251
A <sub>3</sub>	0.29	0.048	79.679	23.105	16.0	369.580
A <sub>4</sub>	0.21	0.030	71.453	15.005	570	810.282
A <sub>5</sub>	0.77	0.009	61.719	47.523	99.0	4708.817
A <sub>6</sub>	0.28	0.001	-32.625	-12.398	120.0	-1487.700
A <sub>c</sub>		0.003		-40.640	121.6	-4981.824


(a) Those for A<sub>2</sub> through A<sub>6</sub>

$$F_{L-L} = 52.85 \quad M_{L-L} = -455.894$$

are from Ref. 1, Table E.1H-1

(b) Based on X = 6.4 in.

$$\epsilon_c =$$



## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE B200F
PREPARED BY T T Lee	DATE 1/19/84	REF. DOCUMENTS.		
CHECKED BY	DATE			

Table B-5 Boundary Force and  
Moment about Liner Axis L-L

Element	Area <sup>(a)</sup> (in <sup>2</sup> /in)	Strain <sup>(b)</sup> (in./in.)	Stress (ksi)	Force (k/in liner) L-L <sup>(a)</sup>	Dist. from L-L <sup>(a)</sup> (in.)	Moment ab L-L (k-in.)
A <sub>1</sub>	0.75	0.060	—	—	0	—
A <sub>2</sub>	0.27	0.058	87.375	22.781	70	91.125
A <sub>3</sub>	0.29	0.052	81.568	23.655	16.0	378.477
A <sub>4</sub>	0.21	0.032	72.681	15.263	570	828.206
A <sub>5</sub>	0.77	0.010	62.157	47.861	99.0	4738.344
A <sub>6</sub>	0.38	0.001	-28.216	-10.722	120.0	-1286.659
A <sub>c</sub>		0.003		-37.592	121.78	-4577.954


(a) Those for A<sub>2</sub> through A<sub>6</sub>

are from Ref. 1, Table E.11-1

(b) Based on x = 592 in

$$\varepsilon_c =$$

$$F_{L-L} = 61.25 \quad M_{L-L} = 167.439$$



## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 807738 N/C PAGE 821 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:
CHECKED BY	DATE	

Table B-6 Boundary Force and Moment about Liner Axis L-L

Element	Area <sup>(a)</sup> (in. <sup>2</sup> /in.)	Strain <sup>(b)</sup> (in./in.)	Stress (ksi)	Force (k/in liner)	Dist from L-L <sup>(a)</sup> (in.)	Moment ab L-L (k-in/in)
A <sub>1</sub>	0.75	0.065	—	—	0	—
A <sub>2</sub>	0.27	0.062	26.52	23.36	20	93.4
A <sub>3</sub>	0.29	0.056	23.50	24.21	16.0	387.4
A <sub>4</sub>	0.21	0.035	73.93	15.63	520	838.4
A <sub>5</sub>	0.77	0.011	62.60	48.20	99.0	4772.3
A <sub>6</sub>	0.38	-0.001	-23.73	-9.02	120.0	-1082.0
A <sub>c</sub>		0.003		-34.92	121.94	-4259.7


(a) Those for A<sub>2</sub> through A<sub>6</sub>

$$F_{L-L} = 6736 \quad M_{L-L} = +7508$$

are from Ref. 1, Table E.11-1

(b) Based on Z = 5.5 in

$$\varepsilon_c = 0.003$$



## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	807738	N/C	PAGE 3.22 OF
PREPARED BY	DATE			REF. DOCUMENTS	
CHECKED BY	DATE				

Table B-7 Boundary Force and Moment about Liner Axis L-L

Element	Area <sup>(a)</sup> (in <sup>2</sup> /in)	Strain <sup>(b)</sup> (in./in.)	Stress (ksi)	Force (k/in liner)	Dist from L-L <sup>(a)</sup> (in.)	Moment ab L-L (k-in)/in
A <sub>1</sub>	0.75		—	—	0	—
A <sub>2</sub>	0.27	0.07	90.0	27.3	70	97.2
A <sub>3</sub>	0.29	0.0627	85.64	25.12	16.0	402.0
A <sub>4</sub>	0.21	0.0296	75.97	15.95	52.0	861.5
A <sub>5</sub>	0.77	0.0123	63.37	48.80	99.0	4830.8
A <sub>6</sub>	0.38	-0.0005	-14.60	-5.55	120.0	-665.7
A <sub>c</sub>		0.0029		-80.29	122.21	-3701.7


(a) Those for A<sub>2</sub> through A<sub>6</sub>

$$F_{L-L} = 78.3 \quad M_{L-L} = 1824.1$$

are from Ref 1, Table E.11.1

(b) Based on I = 477 in<sup>4</sup>

$$\epsilon_c = 0.0029$$



## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 82 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS.	
CHECKED BY	DATE		

Table B-8 Boundary Force and Moment about Liner Axis L-L

Element	Area <sup>(a)</sup> in. <sup>2</sup> /in.)	Strain <sup>(b)</sup> (in./in.)	Stress (ksi)	Force (k/in liner)	Dist from L-L <sup>(a)</sup> (in.)	Moment <sub>L-L</sub> (k-in.)
A <sub>1</sub>	0.75		—	—	0	—
A <sub>2</sub>	0.27	0.07	900	273	70	972
A <sub>3</sub>	0.29	0.0628	8666	25.13	16.0	4021
A <sub>4</sub>	0.21	0.0398	7608	15.98	520	8628
A <sub>5</sub>	0.77	0.0128	63.59	48.97	220	4247.7
A <sub>6</sub>	0.28	0.0001	2.22	0.84	120.0	1013
A <sub>c</sub>		0.0023		-24.24	122.57	-29710


(a) Those for A<sub>2</sub> through A<sub>6</sub>

$$F_{L-L} = 90.98 \quad M_{L-L} = 2340.0$$

are from Ref. 1, Table E.11.1

(b) Based on  $X = 2.82\text{ in}$ 

$$\varepsilon_c = 0.0023$$



## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 807738 N/C	PAGE 8 OF 20
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS	
CHECKED BY	DATE		

Table B-9 Boundary Force and Moment about Liner Axis L-L


Element	Area <sup>(a)</sup> in <sup>2</sup> /in)	Strain <sup>(b)</sup> in/in)	Stress ksi)	Force (k/in liner)	Dist from L-L <sup>(a)</sup> (in.)	Moment a. L-L (k-in)
A <sub>1</sub>	0.75		—	—	0	—
A <sub>2</sub>	0.27	0.07	90.0	24.3	70	97.2
A <sub>3</sub>	0.29	0.0628	86.68	25.14	16.5	902.2
A <sub>4</sub>	0.21	0.0400	76.14	15.99	570	863.4
A <sub>5</sub>	0.77	0.0130	63.70	49.05	22.5	4856.0
A <sub>6</sub>	0.32	0.0004	11.60	4.41	120.0	529.3
A <sub>c</sub>		0.002		-21.17	122.75	-2591.6

(a) Those for A<sub>2</sub> through A<sub>6</sub>  
are from Ref. 1, Table E.11-1

(b) Based on X = 3.33 in

$$\epsilon_c = 0.002$$

$$F_{L-L} = 97.72 \quad M_{L-L} = 9169.2$$



## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738	V/C	PAGE B-5 OF
PREPARED BY T. T. Lee	DATE 11/19/82			REF. DOCUMENTS:
CHECKED BY	DATE			

Table B-10 Boundary Force and Moment about Liner Axis L-L


Element	Area <sup>(a)</sup> (in <sup>2</sup> /in)	Strain <sup>(b)</sup> (in/in)	Stress (ksi)	Force (k/in liner)	Dist from L-L <sup>(a)</sup> (in)	Moment ab L-L (k-in)
A <sub>1</sub>	0.75		—	—	0	—
A <sub>2</sub>	0.27	0.07	90.0	24.3	70	972
A <sub>3</sub>	0.29	0.0628	86.69	25.14	16.0	402.2
A <sub>4</sub>	0.21	0.0601	76.20	16.00	570	864.1
A <sub>5</sub>	0.77	0.0133	63.81	29.14	90	4864.8
A <sub>6</sub>	0.38	0.0007	19.04	7.24	120.0	1027.6
A <sub>7</sub>		0.0017		-1807	1229	-2221.4

(a) Those for A<sub>2</sub> through A<sub>6</sub>  
are from Ref. 1, Table E-111

(b) Based on Z = 2.84 in

$$\varepsilon_z = 0.0017$$

$$F_{L-L} = 103.75 \quad M_{L-L} = 5058.1$$



## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 826 OF
PREPARED BY	T. T. Lee	DATE	" 1/19/84		REF. DOCUMENTS.
CHECKED BY		DATE			

Table B-11 Boundary Force and Moment about Liner Axis L-L

Element	Area <sup>(a)</sup> (in. <sup>2</sup> /in.)	Strain <sup>(b)</sup> (in./in.)	Stress (ksi)	Force (k/in liner)	Dist from L-L <sup>(a)</sup> (in.)	Moment on L-L (k-in.)
A <sub>1</sub>	0.75		—	—	0	—
A <sub>2</sub>	0.27	0.07	90.0	24.3	70	972
A <sub>3</sub>	0.29	0.0629	86.71	25.14	160	4023
A <sub>4</sub>	0.21	0.0403	76.27	16.02	520	8699
A <sub>5</sub>	0.77	0.0136	63.96	29.25	99.0	48755
A <sub>6</sub>	0.32	0.0010	30.26	11.50	120.0	13796
A <sub>c</sub>		0.0013		-13.29	123.18	-17109


(a) Those for A<sub>2</sub> through A<sub>6</sub>

are from Ref. 1, Table E-11.

(b) Based on Z = 2.19 in

$$\epsilon_c = 0.0013$$

$$F_{L-L} = 11232 \quad M_{L-L} = -59026$$



## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 827 OF
PREPARED BY T. T. Lee	DATE 11/19/84		REF. DOCUMENTS.
CHECKED BY	DATE		

Table B-12 Boundary Force and Moment about Liner Axis L-L

Element	Area <sup>(a)</sup> (in. <sup>2</sup> /in.)	Strain <sup>(b)</sup> (in./in.)	Stress (ksi)	Force (k/in liner)	Dist from moment arm L-L <sup>(a)</sup> (in.)	Moment arm L-L (k-in.)
A <sub>1</sub>	0.75		—	—	0	—
A <sub>2</sub>	0.27	0.07	900	24.3	70	972
A <sub>3</sub>	0.29	0.0629	86.723	25.15	16.0	202.4
A <sub>4</sub>	0.21	0.0404	76.34	16.03	520	805.7
A <sub>5</sub>	0.77	0.0138	6407	49.33	22.0	4883.9
A <sub>6</sub>	0.32	0.0013	37.7	14.33	120.0	1719.1
A <sub>c</sub>		0.001		-10.73	123.37	-1323.7


(a) Those for A<sub>2</sub> through A<sub>6</sub>

are from Ref. 1, Table E.11-1

(b) Based on  $X = 1.69 \text{ in}$

$$\varepsilon_c = 0.001$$

$$F_{L-L} = 117.65 \quad M_{L-L} = 6644.6$$



## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 828 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

Table B-13      Boundary Force and  
Moment about Liner Axis L-L

Element	Area <sup>(a)</sup> (in <sup>2</sup> /in)	Strain <sup>(b)</sup> (in/in)	Stress (ksi)	Force (k/in liner)	Dist from L-L <sup>(a)</sup> (in.)	Moment a. L-L (k-in)
A <sub>1</sub>	0.75		—	—	0	—
A <sub>2</sub>	0.27	0.07	90	24.3	70	97.2
A <sub>3</sub>	0.29	0.0630	86.77	25.16	160	202.6
A <sub>4</sub>	0.21	0.0408	76.52	16.07	570	857.8
A <sub>5</sub>	0.77	0.0126	64.43	49.61	220	2911.7
A <sub>6</sub>	0.27	0.0023	58.76	22.33	120.0	2679.3
A <sub>c</sub>						


(a) Those for A<sub>2</sub> through A<sub>6</sub>

are from Ref. 1, Table E.11-1

(b) Based on x = in

$$\varepsilon_c = 0$$

$$F_{L-L} = 137.47 \quad M_{L-L} = 8950.6$$



## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE B29 OF
PREPARED BY	DATE				
CHECKED BY	DATE	REF. DOCUMENTS.			

Table B-14  $M_{L-L}$  values by Interpolation

Calculated (See Tables )		Interpolated	
$F_{L-L}$	$M_{L-L}$	$F_{L-L}$	$M_{L-L}$
28.61	-1065.6	513	-802.8
54.85	-455.9	581	-139.4
61.25	157.4	649	515.9
67.35	750.8	718	1166.6
78.60	1616.1	78.6	1860.0
78.30	1824.1	90.4	3270.7
90.98	3340.0	97.3	4098.8
97.72	2149.2	107.2	5097.0
103.75	5058.1	111.1	5787.0
112.32	5908.6	1179	6673.8
117.65	6644.6		
137.47	8958.6		

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 830 OF
PREPARED BY	T T Lee	DATE	11/19/74	REF. DOCUMENTS:	
CHECKED BY		DATE			

B.1.6 Unit Yield Line Moment

Consider two failure modes as shown in Fig. B-3

For each mode, calculate the unit yield line moment required to maintain equilibrium.

Forces acting on each segment of slab bounded by the yield lines and the boundaries are

- 1) Net cavity pressure
- 2) Boundary forces and moments
- 3) Yield line moment

Equilibrium of these forces are established by computing their moments about Line C-C' (or E-E') shown in Fig. B-4.

The following calculation is performed for the case of 1.0 RP with  $N_y = 0$ . Unit yield moments for other cases are done by proportion from this basic case (Tables B-15 ~ B-18).

T. T. Lee 11/19/84

907738 N/C  
B31




Figure B-3 Arrangement of Lower Head Penetrations and Potential Failure Modes

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 832 OF
PREPARED BY	DATE	11/19/84		REF. DOCUMENTS:	
CHECKED BY	DATE				




Fig. 8-4

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 833 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:			
CHECKED BY	DATE				

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

Yield pattern O-A-B-C (See Fig. 8-3):

Referring to Fig. 8-5, the moment about Line A-A' due to the uniform distributed moment  $m$  is:

$$M_{A-A'} = 2 \int_0^{\theta} mr \cos \theta d\theta = 2mr [\sin \theta]_0^{\theta},$$

$$= 2mr \sin \theta,$$

For this case,  $\theta_1 = 41^\circ 30'$  (Fig. 8-6)

Hence, due to  $M_{L-L}$  (See Table 8-12):

$$\begin{aligned} M_{C-C'} &= M_{H-H'} = 2(1860 \times 1000)(185) \sin 41^\circ 30' \\ &= 0.458 \times 10^9 \text{ lbs-in} \end{aligned}$$

Due to  $F_{L-L}$  over H-H'.

$$\begin{aligned} M_{C-C'} &= 78.6 \times 10^3 \times \frac{2 \times 41.5 \times \pi}{180} \times 185 \times 77.8 \\ &= 1.648 \times 10^9 \text{ lbs-in} \end{aligned}$$

where 77.8 in. is the distance between

the c.g. of  $F_{L-L}$  over H-H' and Line C-C'

(See Fig. 8-4)

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 834 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:			
CHECKED BY	DATE				





Fig. B-5

T.T. Lee 11/19/82

907738 N/C

B35



NOTE: PT. 1 IS CENTROID OF AREA OIF

PT. 2 IS CENTROID OF AREA ADGF

PT. 3 IS CENTROID OF AREA ABHF

$$(y_1)_{C-C'} = 10' 10''$$

Fig. B-6

Potential Failure Mode

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE 836 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:		
CHECKED BY	DATE			

Referring to Fig. 10, and Ref. & P.E. 11-7,

$$\text{Area OAFI} = \frac{1}{2} \pi (186)^2 = 9050 \text{ in}^2$$

$$\text{Centroidal dist. from C-C'} = 10' 10'' = 120$$

$$\text{Area ABHF} = \frac{1}{2} (102 + 42) \times 38 = 2725 \text{ in}^2$$

$$\text{Centroidal dist from C-C'} = 11' = 132 \text{ in}$$

Hence moment about C-C'. due to the cavity pressure on (OABHI)  $\times 2$  is

$$M_{C-C'} = 2 p [(9050 \times 120) + (2725 \times 132)]$$

$$= 3.076 p \times 10^6 \text{ lbs-in}$$

$$= 3.076 \times 845 \times 10^6 = 2.599 \times 10^9 \text{ in}$$

Total moment about C-C' to be resisted by the yield lines O-A-B-C is.

$$M_{C-C'} = (2.599 - 1.648 + 0.458) \times 10^9$$

$$= 1.410 \times 10^9 \text{ lbs-in}$$

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE B37 OF
PREPARED BY	DATE 11/19/84	REF. DOCUMENTS:			
CHECKED BY	DATE				

1

2

3

4

5

6

Let  $m_{B-C}$  be the unit yield line moment for all segments along O-A-B-C

7

8

9

10

11

12

13

The components of total yield line moments for individual segments in the C-C' direction is (See Fig. B-7):

$$2 \left( 17 m_{C-C'} \cdot \frac{9}{17} + 14 m_{B-C} \cdot \frac{13}{14} + 19_2 m_{B-C} \cdot \frac{22}{19_2} \right) \\ = 188 m_{B-C}$$

This balances the  $M_{C-C'}$  totals, hence

$$m_{B-C} = \frac{M_{C-C'} \text{ total}}{188} = \frac{1.410 \times 10^9}{188} = 7.50 \times 10^6 \text{ lb-}$$

T. T. 'ee 11/19/84

907738 N/C B3?




Figure B-7 Projected Length of Yield Line

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 839 OF
PREPARED BY T. T. Lee	DATE 1/19/84	REF. DOCUMENTS.	
CHECKED BY	DATE		

1

2

3

4

Yield pattern O-A-D-E:

5

6

7

Repeating the similar calculation done  
for yield pattern O-A-B-C.

8

9

10

11

Due to  $M_{E-E'}$  over G-G'.

12

13

$$M_{E-E'} = 2(1860 \times 1000) (186) \sin 15^\circ = 0.214 \times 10^9 \text{ lbs-in}$$

14

15

16

Due to  $F_{E-E'}$  over G-G'.

17

18

19

20

$$M_{E-E'} = (78.6 \times 1000) \times \frac{2 \times 18 \times \pi}{180} \times 186 \times 10^3$$

$$= 0.946 \times 10^9 \text{ lbs-in}$$

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

Due to cavity pressure over (O A D G I)  $\times 2$ :

$$M_{E-E'} = 2 P [(9050 \times 168) - (2736 \times 153)]$$

$$= 2.204 P \times 10^6 \text{ lbs-in}$$

$$= 2.204 \times 845 \times 10^6 = 1.862 \times 10^9 \text{ lbs-in}$$

Total to be resisted by the yield lines

O-A-D-E is:

$$M_{E-E'} = (1862 - 0.946 + 0.214) \times 10^9$$

$$= 1.130 \times 10^9 \text{ lbs-in}$$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE 840 OF
PREPARED BY	T. T. Lee	DATE	11/19/84	REF. DOCUMENTS:
CHECKED BY		DATE		

Let  $m_{D-E}$  be the unit yield line moment for all segments along O-A-D-E

The components of total yield line moments for individual segments along the E-E' axis is (Fig. B-7) :

$$\begin{aligned} & 2(9m_{D-E} + m_{D-E} + 72m_{D-E}) \\ & = 164m_{D-E} \end{aligned}$$

This balances the  $M_{E-E'}$  total, hence

$$m_{D-E} = \frac{M_{E-E', \text{total}}}{164} = \frac{1.130 \times 10^9}{164} = 6.89 \times 10^6 \text{ lbs-in/in}$$

The  $m_{S-C}$  of  $7.50 \times 10^6$  lbs-in/in and the  $m_{D-E}$  of  $6.89 \times 10^6$  " computed for the case of  $I_{RP}$  and  $N_x=0$  are used as the basis for proportioning in the following tables.

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	807738	N/C	PAGE 801 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:			
CHECKED BY	DATE				

1

Table B-15

2

Unit Yield Line Moments

3

for Yield Pattern O-A-B-C, 1 RP

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

$N_x$	0	6	12	18	24
$M_{L-L}$	18600	11666	5159	-1394	-8028
$F_{L-L}$	786	718	649	581	513
Resultant Cavity Pressure	245	272	698	625	551
$M_{C-C}^*$	0.458	0.287	0.127	-0.034	-0.198
$M_{C-C}$ Due	-1.648	-1.505	-1.361	-1.218	-1.076
To $(10^9 \text{ lb-in})$ Press.	2.599	2.374	2.127	1.922	1.695
Total $M_{C-C}$	1.410	1.156	0.913	0.670	0.421
$M_{B-C}^*$ $(10^9 \text{ lb-in})$	7.50	6.15	4.86	3.56	2.24

Note: Base  
For Tables Case  
B-15 and 2-17

\* Numbers in these rows are computed  
by proportion from the base case in Table

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE B-12 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

1

2

## Table B-16

3

4

## Unit Yield Line Moments

5

6

for Yield Pattern O-A-D-E, 1 RP

7

8

 $N_x$ 

0

6

12

18

24

9

10

 $M_{L-L}$ 

1860.0

1156.6

515.9

-139.4

-802.8

11

12

 $F_{L-L}$ 

106

718

649

581

513

13

14

Resul. Cavity  
Pressure

845

772

698

625

551

15

16

 $M_{E-E}$ 

\*\*

-0.214

0.134

0059

-0.016

-0.092

17

18

 $F_{L-L}$ 

\*\*

-0.946

-0.864

-0.781

-0.699

-0.617

19

20

21

 $M_{E-E}$ 

\*\*

-0.946

-0.864

-0.781

-0.699

-0.617

22

23

24

 $F_{L-L}$ 

\*\*

1.862

1.701

1.538

1.377

1.214

25

26

27

 $M_{E-E}$ 

\*\*

1.130

0.971

0.816

0.662

0.505

28

29

 $M_{D-E}$ 

\*\*

6.89

592

498

404

303

30

31

32

33

34

35

36

Base Case

Note:

(For Tables B-16 B-18)

\*\* Numbers in these rows are computed by proportion from the case case in Table B-16.

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 843 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

1

2

Table B-17

3

4

Unit Yield Line Moments

5

6

for Yield Pattern o-A-B-C, 15 RP

$N_x$	0	6	12	18	24
$M_{L-L}$	6673.8	5787.0	5099.0	4098.8	3270.7
$F_{L-L}$	117.9	111.1	104.2	97.3	90.4
Resul. Cavity Pressure	1268	1194	1120	1046	972
$M_{C-C}^*$	1.643	1.425	1.256	1.009	0.805
Due to $F_{L-L}^*$	-2272	-2329	-2185	-2040	-1875
to $(10^6 \text{ lb-in})$ Press.	3.900	3.672	3.425	3.217	2.990
Total $M_{C-C}^*$	3.071	2.768	2.516	2.186	1.900
$M_{B-C}^*$ ( $10^6 \text{ lb-in/in}$ )	16.34	14.72	13.38	11.63	10.11

$$M_{B-C} = 11.27$$

$$\text{if } V_x = 19.42 \text{ by integration}$$

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 822 OF
PREPARED BY	T T Lee	DATE	11/19/82	REF. DOCUMENTS:	
CHECKED BY		DATE			

1

Table B-18

2

Unit Yield Line Moments

3

for Yield Pattern O-A-D-E, 15 RP

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

$N_x$	0	6	12	18	24
$M_{L-L}$	6673.8	5787.0	5099.0	4098.8	3270.7
$F_{L-L}$	117.9	111.1	107.2	97.3	90.9
Resul. Cavity Pressure	1268	1197	1120	1046	972
$M_{E-E}^{**}$	0.768	0.666	0.587	0.472	0.376
$F_{L-L}^{**}$	-1419	-1337	-1254	-1171	-1088
Due to $(10^9 lb/in^2)$ Press.	-794	-631	-468	-305	-142
Total $M_{E-E}$	2.143	1.960	1.801	1.606	1.430
$M_{E-E}^{**}$ $(10^6 lb/in/1in)$	13.07	11.95	10.98	9.79	8.72

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 NIC	PAGE 845 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS.		
CHECKED BY	DATE			

E.1.7 Moment Capacity Along Yield Lines

Moment capacity in the hoop direction provided by the circumferential tendons, circumferential rebars and concrete is established for a cross section with unit width along a radial yield line.


Criteria:

- 1) Maximum tendon stress = 0.9  $f_{sy}$  (Ref 1)
- 2) Maximum concrete strain  $\leq 0.003$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 8 46 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:			
CHECKED BY	DATE				

Circumferential Rebars:

For 17" long concrete ligament between O. and A (Fig. 3-7)

$$6 - \# 8 \text{ bars} \rightarrow \frac{6 \times 0.79}{17} = 0.28 \text{ in}^2/\text{in}$$

For 14" long concrete ligament between A and D:

$$6 - \# 8 \text{ bars} \rightarrow 0.28 \text{ in}^2/\text{in}$$

For 142" length between D & E:

$$22 - \# 8 \text{ bars} \rightarrow \frac{22 \times 0.79}{142} = 0.12 \text{ in}^2/\text{in}$$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 347 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

1

2

Rebars: LBH - 30 (2), -31(2), -32(2)

3

(Fig. 8-8) LBH - 33 (1), -34(1), -35(1)

4

LBH - 40 (1), -41(1), -42(1)

5

LBH - 43 (1), -44(2), -45(2)

6

LBH - 56 (2), -57 (2)

7

Each contains three sections, forming a complete circle

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

use  $A_r = 0.12 \text{ in}^2/\text{in}$  in the following calculations

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	307738	N/C	PAGE 8 OF
PREPARED BY T. T Lee	DATE 11/19/84	REF. DOCUMENTS:			
CHECKED BY	DATE				

1

2

3 Effect of Internal Pressure within Penetration:

4

5

6

For concrete compression zone

7

8

9

$$P_c \times x \times \frac{\text{Sum of pen. I.D. over on yield line}}{\text{Total yield line length}}$$

10

11

12

$$= 0.722 P_c x = 0.722 \times 845 x = 610 x$$

13

14

15

where  $P_c$  = cavity pressure.

16

17

 $x$  = height of compression zone

18

19

0.722 is from Ref. I p E 11-10

20

21

22

For tension zone:

23

24

Stress in penetration is

25

26

27

$$\frac{P_c \cdot r}{h} = \frac{845 \times 21}{1} = 17700 \text{ psi.} \\ < f_{sy}$$

28

29

30

31

$$r = \text{radius of penetration} = 21 \text{ in.} \\ h = \text{thickness of penetration} = 1 \text{ in.} \quad \} \text{ (Ref.)}$$

32

33

34

35

36

Hence this effect is applied to compression zone only in the calculation of moment capacity.

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 869 OF
PREPARED BY	T. T. Lee	DATE	11/19/84	REF. DOCUMENTS:	
CHECKED BY		DATE			

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31


32

33

34

35

36

Moment Capacity Per Unit Width Along Yield Line:

M  
C.G. of tendons\*  
Lowest tendon\*\*  
C.G. of rebars\*

(1) Strain due to prestress

(2) Strain at limit

$$\epsilon_r = 0.00186 \quad (f_r = 0.9 f_{st}^2 = 54 \text{ k})$$

\* Ref. 1, Fig. E11-7

\*\* Ref. 5.





Fig. B-7

strain due to moment

Forces due to moment & prestress

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 850 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

1

2

3

Due to prestress:

4

Tendon stress at end of life:

5

6

7

8

9

10

$$0.7 f_s' (1 - 0.12)(0.885) = 0.575 f_s' = 130.8 \text{ ksf}$$

Loss Friction effect

(Ref. 1, Table 5.64), (Ref 3)

11

12

13

14

corresponding strain in tendon is:

$$0.00282 \text{ in/in} \quad (\text{Fig 4})$$

15

16

17

18

Prestress in concrete:

Total tendon force at end of life:

19

20

21

22

$$F_{t,e} = \frac{2}{3} N_c' \times 0.35 \times 130.8 / 294$$

$$= 2.477 N_c' \text{ kip/in width}$$

23

24

Concrete stresses:

$N_c'$  = actual number of circ. head tendons.

25

26

27

28

29

$$\text{Top (or bottom head)} : \frac{2.477 N_c'}{186} - \frac{(2.477 N_c')(118 - \frac{1}{2})}{6}$$

$$= 0.0133 N_c' - 0.0107 N_c' = 0.0026 N_c' \text{ k/in}$$

30

31

32

33

34

35

36

$$\text{Bottom} = 0.0133 N_c' + 0.0107 N_c' = 0.024 N_c' \text{ k/in}$$

Concrete strains:

$$E_c = 5.0 \times 10^6 \text{ psi} \quad (\text{Ref. 1, 5.5.41})$$

$$E_{top} = 0.52 N_c'^{-0.5} \text{ in/in}, \quad E_s = 2.8 N_c \times 10^{-6} \text{ in/in}$$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 85/OF
PREPARED BY	T. T. Lee	DATE	11/19/84	REF. DOCUMENTS:	
CHECKED BY		DATE			

1

2

Concrete strains.

3

4

at rebar location:

5

6

$$\left[ 4.8 - \frac{4.8 - 0.52}{186} \cdot 12 \right] N_c \times 10^{-6} = 4.529 N_c \times 10^{-6}$$

7

8

Due to Moment.

9

10

Limit. Max. rebar stress = 0.9 f<sub>sy</sub> = 54 ksi.

11

12

Rebar strain at limit.

13

14

$$\frac{54}{29000} = 0.00186 \text{ in./in}$$

15

16

Rebar strain due to moment:  $\epsilon_r = 0.00186 + 4.529 N_c$ 

17

18

with  $N_c' = 34$  (Max.) additional  $\epsilon_r$  over 0.001

19

20

is 0.000156 or about 2% of 0.00186.

21

22

23

24

For simplicity and conservatism, assume

25

26

$$\epsilon_r = 0.00186 \text{ in./in}$$

27

28

This gives.

29

30

 $f_r = \text{rebar stress} = 54 \text{ ksi}$ 

31

32

$$F_r = 0.12 \times 54,000 = 6480 \text{ lbs/in}$$

33

34

35

36

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 1352 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

1

2

## Tendons

3

4

$$\Delta \epsilon_t = \frac{118 - x}{172 - x} : 0.00186$$

5

6

$$f_t = 130.8 + \Delta \epsilon_t \cdot 27,000 = 130.8 + \frac{118 - x}{172 - x} \cdot 50,000$$

7

8

$$F_t = \frac{2}{3} N_c' \times 0.35 \times f_t / 294$$

(psi)

9

10

$$= 18.9 f_t N_c' \quad (\text{lbs/in})$$

(in kN)

11

12

## Concrete

13

14

$$\text{Max. strain: } \frac{x}{172 - x} \epsilon_r = \epsilon_c = \frac{x}{172 - x} 0.00186$$

15

16

$$\text{Max. stress: } f_c = E_c \epsilon_c = 5 \times 10^6 \times \frac{x}{172 - x} \times 0.00186$$

17

18

$$= \frac{9300x}{172 - x} \quad (\text{psi})$$

19

20

## Total force in concrete

21

22

$$F_c = \frac{1}{2} x f_c = \frac{2650x^2}{172 - x} \quad (\text{lbs/in})$$

23

24

25

## Effect of pressure inside penetration.

26

27

28

29

$$F_p = 610 x \quad (\text{lbs/in})$$

30

31

32

33

34

35

36

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 853 OF
PREPARED BY	T T Lee	DATE	11/19/84	REF. DOCUMENTS:	
CHECKED BY		DATE			

Equation of equilibrium:

$$F_c + F_p = F_t + F_r$$

$$\frac{4650x^2}{174-x} - 610x = 18.9 N_c \left[ 130.8 + \frac{118-x}{174-x} \cdot 50.28 \right] + 6480$$

$$4650x^2 + 610x(174-x) = 18.9 N_c \cdot 130.8 (-72-x)$$

$$+ 18.9 N_c (118-x) 50.28$$

$$+ 6480 (-74-x)$$

$$(4650 - 610)x^2 + (610 \cdot 174 + 18.9 \cdot 130.8 N_c$$

$$+ 18.9 \cdot 50.28 N_c + 6480) x$$

$$- (18.9 N_c \cdot 130.8 \cdot 174 + 18.9 N_c \cdot 118 \cdot 50.28$$

$$+ 6480 \cdot 174) = 0$$

$$\frac{4040}{a} x^2 + \frac{(112620 + 3422 N_c')}{c} - \frac{(1127.520 + 5422.83 N_c')}{c} = 0$$

$$x = \frac{-b \pm \sqrt{b^2 + 4ac}}{2a}$$

$$\text{Capacity: } M = \frac{2}{3} x F_c + 305x^2 + F_c(118-x) + F_r(174-x)$$

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 852 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS.	
CHECKED BY	DATE		

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

## Table B-19 Moment Capacity

Nc	34	32	30	28
a				
b	-			
c	,			
N. A				
$\bar{x}$ (in.)	46.80	45.52	42.18	42.78
$f_c$ (psi)	3422	3295	3165	3031
$\bar{f}_c$ (psi/in.)	0.0070	74988	69914	64854
$f_t$ (psi)	158.94	159.16	159.39	159.62
$\bar{f}_t$ (psi/in.)	102138	96263	90375	84472
$F_r$ (lbs/in.)	6480	6480	6480	6480
$M$ ( $10^6$ lbs-in) per in.	11.27	10.72	10.17	9.61

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 855 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:			
CHECKED BY	DATE				

Table B-19 Moment Capacity (Continued)

$N_c'$	24	22	20	16
$a$				
$b$				
$c$				
$x$ (in.)	39.78	38.17	36.25	32.73
$f_{c,max}$ (ksi)	27.56	26.13	24.65	21.55
$f_c$ ( ksi )	54823	49877	44942	35261
$f_c$ ( lbs/in.)	16010	16035	16061	161.15
$F_c$ ( lbs/in.)	72622	66674	60710	48731
$F_r$ ( lbs/in.)	6480	6480	6480	6480
$M$ ( $10^6$ lbs-in) per in.	8.49	7.92	7.34	6.17

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 856 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

Table B-19 Moment Capacity (Continued)

Nc	14	12	10	8	6
a					
b					
c					
N, A x (in.)	30.65	28.43	26.00	23.33	20.35
f <sub>c</sub> (psi) c, max	1989	1816	1634	1440	1232
F <sub>c</sub> (lbs/in.)	30495	25819	21239	16798	12533
f <sub>e</sub> (ksi)	161.44	161.74	162.06	162.39	162.75
F <sub>e</sub> (lbs/in.)	42716	36682	30628	24554	18456
F <sub>r</sub> (lbs/in.)	6480	6480	6480	6480	6480
M (10 <sup>6</sup> lbs-in) per in.	557	496	435	373	307

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 857 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

1

2 Effect of pressure inside penetration - a check  
 3

4 If  $F_p = 6/10 x$  is neglected, the equation of  
 5 equilibrium becomes  
 6  
 7

$$F_c = F_t + F_r$$

$$4650 x^2 + (6780 - 3422 N_c') = 1127,520 + 542,282 \\ = 0$$

$$x = \frac{1}{2a} (-b \pm \sqrt{b^2 - 4ac})$$

$$N = \frac{2}{3} x F_c + F_t (118 - x) + F_r (172 - x)$$

$$Check \quad N_c' = 34 \rightarrow x = 52.99$$

$$M = 11.19 \times 10^6$$

If  $F_p$  is included.  $x = 46.80$ ,  $M = 11.27 \times$

$$\frac{11.27 - 11.19}{11.19} = 0.01 \text{ off.}$$

Thus  $F_p$  effect is small.

Also, if  $N_c' = 0 \rightarrow M = 1.095 \times 10^6$  vs  $1.10 \times 10^6$   
 (with  $F_p$ ) (without  $F_p$ )

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738, N/C	PAGE 8 OF 52
PREPARED BY T. T Lee	DATE 11/19/84	REF. DOCUMENTS.	
CHECKED BY	DATE		

1

2

3

B. 1.8 Required Number of Head Tendons

4

5

6

Table B-20

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

$N_x$	1.0 RP			1.5 RP		
	Unit Yield Line Moment Req'd	$N_c'$ Req'd ("")	$N_c$ Req'd ("")	Unit Yield Line Moment Required	$N_c'$ Req'd ("")	$N_c$ Req'd ("")
0	16-in/in			16-in/in		
0	$7.50 \times 10^6$	20.55	13.70	$16.34 \times 10^6$	(2)	-
5	$6.15 \times 10^6$	15.93	10.62	$14.72 \times 10^6$	(2)	-
12	$4.98 \times 10^6$	12.07	8.05	$13.38 \times 10^6$	(2)	-
18	$4.04 \times 10^6$	9.00	6.00	$11.63 \times 10^6$	34 <sup>(3)</sup>	22.6
24	$3.08 \times 10^6$	6.00	4.00	$10.11 \times 10^6$	29.79	19.85
Source	Tables B-15, B-16	Table 19 by interpolation	$N_c' \times \frac{2}{3}$	Tables B-17, B-18	Table 19 by interpolation	$N_c' \times \frac{2}{3}$

(1) Required to provide (See Fig. 1)  
a moment capacity equal to the unit yield line moment

(2) Not possible.

(3) Corresponds to  $N_x = 19.12$ . Max  $N_c'$  is 34.  $N_x = 18$  req'd  $N_c' > 34$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738, N/C	PAGE 859 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:		
CHECKED BY	DATE			

The calculated effective number of circumferential head tendons and the corresponding number of crosshead tendons required are shown graphically in Figs. 1 and 2, main text.

As a further conservatism, the curve for  $N_c = 27$  (Fig. 2) is truncated at  $N_c = 22$  since in each head, the minimum  $N_c$  passing any section is 22, out of 37 actual number of tendons currently provided.

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 360 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

8.2 Potential Failure Mode with YieldLine at Edge of Core Cavity

No.  $N_x$  requirements were determined from consideration of yield patterns O-A-B-H-C and O-A-D-G-E (See Fig. B-3).

Potential yield line failure along the yield pattern O-A-B-H-I and O-A-D-G-I are checked to assure that any of these will not be critical.  
(See Fig. B-3)

Four  $N_x$ ,  $N_c$  combinations representing the extreme conditions in Figs. 1 and 2 are checked. They are

$$N_x = 0, \quad N_c' = 20 \quad (N_c = 13) \quad \} \text{Fig. 1}$$

$$N_x = 24, \quad N_c' = 6 \quad (N_c = 4)$$

$$N_x = 21, \quad N_c' = 33 \quad (N_c = 22)$$

$$N_x = 24, \quad i_1' = 30 \quad (N_c = 20)$$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE B61 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:		
CHECKED BY	DATE			

1  
2      Bottom Rebars for Bottom Head (Ref. 7)  
3

4      Layer #1 : A11 #8, A432  
5

$$6 \quad LBH-1, 2, \dots, 9 = 102$$

$$7 \quad LBH-10, 11, 12, 13, 14 = 72$$

$$\} 18\pi \times (0.79) = 125.3$$

in²

10  
11      Layers #3, 5, 7 : A11 #8, A432  
12

$$13 \quad LBH-10, \dots, 64$$

$$14 \quad LBH-21 \quad 22$$

$$15 \quad 11' - 11" \times 9 \quad 24$$

$$16 \quad 11' - 2" \quad .. \quad 26$$

$$17 \quad 12' - 9" \quad .. \quad 24$$

$$18 \quad 7' - 6" \quad .. \quad 12$$

$$19 \quad 192 \times 10.79) = 151.62 \text{ in}^2$$

20  
21      Total in radial dir = 297.02 in²  
22

23  
24      Or.  $\frac{297.02}{2\pi \cdot 186} = 0.254 \text{ in}^2/\text{in liner}$   
25

26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	807738	N/C	PAGE 362 OF
PREPARED BY T T Lee	DATE 11/19/82	REF. DOCUMENTS.			
CHECKED BY	DATE				

Top Rebars for Bottom HeadDiagonal Bars (Refs. 8. & 10) A431, #11

$$12 \times 16 \times (1.56) \times \cos 19^{\circ} 50' \times \cos 45^{\circ}$$

#11 (plan) (Elevation)

$$= 192 \times 1.56 \times \cos 19^{\circ} 50' \times \cos 45^{\circ}$$

$$= 299.52 \text{ in}^2 \times \cos 19^{\circ} 50' \times \cos 45^{\circ}$$

$(19.83^{\circ})$

$$= 199.23 \text{ in}^2 \text{ total in radial direction}$$

Radial Bars (Refs. 8 and 9) A431, #14s

(Area)

$$\text{UBH-5, 5A, 6, 6A: } 8 \times 2.25 \times \cos 27.5^{\circ} \times \cos 9^{\circ} = 15.77$$

$$\text{UBH-7, 7A, 8, 8A: } 8 \times 2.25 \times \cos 27.5^{\circ} \times \cos 18^{\circ} = 15.18$$

$$\text{UBH-9, 9A, 10, 10A: } 8 \times 2.25 \times \cos 27.5^{\circ} \times \cos 25^{\circ} = 14.47$$

$$\text{UBH-11, 11A, 12, 12A: } 8 \times 2.25 \times \cos 27.5^{\circ} \times \cos 33^{\circ} = 13.39$$

$$\text{UBH-12, 12A, 16, 18A: } 16 \times 2.25 \times \cos 28^{\circ} \times \cos 9^{\circ} = 31.37$$

$$\text{UBH-19, 19A, 20, 20A: } 16 \times 2.25 \times \cos 28^{\circ} \times \cos 18^{\circ} = 30.23$$

$$\text{UBH-21, 21A, 22, 22A: } 16 \times 2.25 \times \cos 28^{\circ} \times \cos 25^{\circ} = 28.81$$

$$\text{UBH-23, 23A, 24, 26A: } 16 \times 2.25 \times \cos 28^{\circ} \times \cos 32^{\circ} = 26.52$$

$$\text{UBH-33, 33A, 34, 34A: } 96 \times 2.25 \times \cos 27.5^{\circ} \times \cos 27.5^{\circ} = 170.1$$

$$\text{T.E.1 in radial dir. = } 346.23$$

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE 263 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:		
CHECKED BY	DATE			

1

2

3

4

5

6

7

8

9

10 Location of Rebars

11 (Refs. 8 and 11)

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31


32

33

34

35

36



## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE 861 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:		
CHECKED BY	DATE			

Radial Prestress due to Crosshead Tendons

Referring to Ref. 10,

Of 24 tendons, 12 are essentially radial at the edge of core cavity, and 12 are inclined about  $30^\circ$  w.r.t the radial direction. Vertically, the largest inclination is  $43^\circ$ . Hence the prestress force is

$$2 \cdot \frac{N_x}{2} (1 + \cos 30^\circ) \cos 43^\circ \times 0.35 \times f_x$$

$$= 2 \times 5.698 f_x N_x \text{ kips} \quad (\text{stress in X-head tendons, } f_x \text{ in ksi})$$

$$\text{or } \frac{2 \times 5.698 f_x N_x}{2 \pi \cdot 186} = 9.75 f_x N_x \text{ lbs/in.} \quad (\text{f}_x \text{ in ksi.})$$

From Ref. 11, the location of crosshead tendons at the edge of core cavity is, about 8 ft from the top of bottom head

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE B65 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS:			
CHECKED BY	DATE				

1

2

3 Moment Capacity Along a Radial Tield Lines  
4

5

6 Same as before (See § B.1.7) except  
7

8 use  $F_t = 18.9 (130.8) N_c = 2472 N_c^*$   
9

10  $F_e + F_p = F_t + F_r$   
11

12  $\frac{4650 x^2}{172-x} + 610 x = 2472 N_c + 6780$   
13

14  $4650 x^2 + 610x(172-x) = (2472 N_c + 6780)(172-x)$   
15

16  $4040 x^2 + (610 \cdot 172 - 2472 N_c - 6780)x$   
17

18  $- 172(2472 N_c + 6780) = 0$   
19

20  $\frac{4040 x^2}{a} + \frac{(112620 - 2472 N_c)x}{b} - \frac{(1127520 + 6780)}{c} = 0$   
21

22  $x = \frac{-b \pm \sqrt{b^2 + 4ac}}{2a}$   
23

24  $M = \frac{2}{3} x F_c + 305x^2 + F_t(118-x) + F_r(172-x)$   
25

26

27

28

29

30

31

32

33

34

35

36

\* The increase in prestress due to further extension of tendons is ignored.

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907788 N/C	PAGE 866 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:	
CHECKED BY	DATE		

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

Table 8-21 Moment Capacity  
Along a Radial Yield Line

N <sub>c</sub>	20	6	33	30
a	4020	6040	4090	7020
b	162060	127182	194196	185780
c	9.730.080	3.708.288	15321.744	14031.360
x (in.)	32.96	18.40	42.07	20.19
f <sub>c, max</sub> (ksi)	2173	1100	2966	2793
F <sub>c</sub> (lbs/in.)	35817	10118	62386	56128
F <sub>t</sub> (ksi)	130.8	130.8	130.8	130.8
F <sub>t</sub> (lbs/in.)	29440	4832	81576	74160
F <sub>r</sub> (lbs/in.)	6480	6280	6480	6780
M (10 <sup>6</sup> lbs-in per in)	6.24	2.71	9.34	8.63

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 8 OF 8
PREPARED BY T. T. Lee	DATE 11/19/86	REF. DOCUMENTS:	
CHECKED BY	DATE		

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31



32

33

34

35

36

Moment Capacity Along a Hoop Yield Line

Strain

due to moment  
(≈ strain at  
limit)

Fig. 8-10

$$\text{Max. rebar strain} = \frac{\epsilon_1}{29000} = 0.00186$$

$$\text{Ave. rebar strain} = \frac{186 - 23 - x}{186 - 7 - x} \cdot 0.00186 = \frac{163 - x}{179 - x} \cdot 0.00186$$

Total rebar force (tensile):

$$F_r = 0.967 \times \frac{163 - x}{179 - x} (0.00186) (29000,000)$$

(Area/in.)

$$= 25190 \times \frac{163 - x}{179 - x} \text{ lbs/in.}$$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE 368 OF
PREPARED BY T. T. Lee	DATE 1/19/82	REF. DOCUMENTS.		
CHECKED BY	DATE			

1

2

3

Total rebar force (compressive):

4

$$Strain: 0.00186 - \frac{x-\delta}{179-x}$$

5

6

$$F_{rc} = 0.00186 \cdot \frac{x-\delta}{179-x} \cdot 29,000,000 \times 0.254 \\ (Area/in.) \\ = 13700 \cdot \frac{x-\delta}{179-x} \quad lbs/in.$$

7

8

9

Crosshead tendons

10

11

12

$$\Delta \epsilon_x = \frac{126-95-x}{179-x} \cdot 0.00186 = 0.00185 \cdot \frac{90-x}{179-x}$$

13

14

15

Stress at end of 1. fe

16

17

18

$$0.7 f'_s (1 - 0.12)(0.9) = 0.554 f'_s = 133 \text{ ksf,} \\ \text{loss friction}$$

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

 $f_x = \text{stress in } X\text{-head tendons}$ 

$$= 133 + \Delta \epsilon_x \cdot 27,000 = 133 + \frac{90-x}{179-x} \cdot 50.28 \quad (100)$$

$$F_x = 9.75 f_x \cdot N_x \quad (\text{lbs/in.}) \\ (\text{in ksf})$$

Concrete:

$$\text{Max. strain - } \epsilon_c = 0.00186 \cdot \frac{x}{179-x}$$

$$f_c(\text{max}) = E_c f_c = 5 \times 10^6 \times 0.00186 \cdot \frac{x}{179-x} = \frac{9300x}{179-x} \quad (P)$$

$$F_c = \frac{1}{2} x f_c = \frac{4650x^2}{179-x}$$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE B6
PREPARED BY	T. T. Lee	DATE	" / 19 / 84	REF. DOCUMENTS:	
CHECKED BY		DATE			

(Ksi)

$$F_t = \frac{2}{3} N_c' (8.35) \cdot f_t / 22.17 \times 12 = 20.9 f_t N_c' : 61$$

↳ Ave. radius of circ. tendon

use  $f_t = 130.8$  ksi (Inc. in  $f_t$  due to  $\Delta E_t$  ignore)

$$F_t = 20.9 \times 130.8 N_c = 2734 N_c$$

Equilibrium:

$$F_r + F_x + F_c = F_c + F_{rc}$$

$$25190 \frac{163-x}{179-x} - 9.75 (133 + \frac{93-x}{179-x} 50.28) N_x$$

$$- 2734 N_c = \frac{4650 x^2}{179-x} - 13700 \frac{x-2}{179-x}$$

$$25190 (163-x) + 9.75 (133) (179-x) N_x + 9.75 (90-x) : 61$$

$$+ 2734 N_c (179-x) = 4650 x^2 - 13700 (x-2)$$

$$4650 x^2 - (13700 + 25190 + 9.75 \times 133 N_x + 9.75 \times 50.28 N_x - 2 : 61$$

$$- (13700 \times 6 + 25190 \times 163 + 9.75 \times 133 \times 179 N_x + 9.75 \times 90 \times 5 : 61$$

$$+ 2734 \times 179 N_c) = 0$$

$$\frac{4650}{a} x^2 + \frac{(38890 - 1787 N_x + 2734 N_c)}{b} x$$

$$- \frac{(4.160,770 + 276,239 N_x + 289.38 N_c)}{c} = 0$$

$$x = \frac{-b \pm \sqrt{b^2 + 4ac}}{2a}$$

$$M = F_r (163-x) + F_x (90-x) + F_t (68-x) + F_c (\frac{2}{3}x) + \frac{2}{n}$$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 870 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:			
CHECKED BY	DATE				

1

2

3

Table B-22 Moment Capacity Along a Hoop Yield Line  
 (At  $R = 186$  in.)

$N_x$	0	24	21	27
$N'_c$	20	6	33	30
$Z$ (in)	45.62	1479	57.13	58.47
$F_r$ (lbs/in)	22168	22187	21828	21826
$f_r$ (ksi)	-	149.94	145.95	146.15
$F_t$ (lbs/in)	0	35085	29883	32200
$\bar{f}_t$ (ksi)	130.8	130.8	130.8	130.8
$F_c$ (lbs/in)	54680	16404	90222	82020
$f_c$ (psi)	3181	3104	4588	4512
$F_e$ (lbs/in)	72556	69507	135631	131894
$\bar{F}_e$ (lbs/in)	4275	4164	6301	6191
$M$ (lbs-in/in)	6.21	6.83	9.68	9.62

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE 871 OF
PREPARED BY	T T Lee	DATE	11/19/84	REF. DOCUMENTS:
CHECKED BY		DATE		

Yield Line Pattern OADSI

Referring to Fig 8-6, the forces acting on the slab section bounded by OADGIG' consist of the effective pressure on the surface vertical force ( $F_{v-e}$ ) along G=G', shearing force along OADG and O'A'D'G', moment along the two radial yield lines (OADG and O'A'D'G'), and moment along the hoop yield line GIG'. For simplicity ignore the shear along OADG, & O'A'D'G'.

From equilibrium, the moment of the effective pressure and  $F_{v-e}$  about any horizontal axis must be balanced by the moments along all yield lines. For convenience, use E-E' as the axis to compute the moment due to pressure and  $F_{v-e}$ .

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE 872 OF
PREPARED BY T. T. Lee	DATE 11/19/84	REF. DOCUMENTS:		
CHECKED BY	DATE			

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

Check 1 RP,  $N_x = 20$   $N_c' = 20$  Case

From Table B-16,

$$(1) M_{E-E'} \text{ due to pressure} = 1.862 \times 10^9 \text{ lb-in}$$

$$(2) " " " F_{L-L} = -0.976 \times 10^9 \text{ lb-in}$$

$$\text{Sum} = 0.916 \times 10^9$$

$$= 916 \times 10^6 \text{ lb-in}$$



Resisting Moment

$$(3) \text{ Along OADG} \times \text{O'A'D'G}' = 2 \times \frac{5.24 \times 10^6}{2} \times (9+1+9) \quad (\text{Table B-21})$$

$$= 237 \times 10^6 \quad (\text{See Fig. B-7})$$

(4) Along GIG'

$$= 2 \times \frac{6.21 \times 10^6}{2} \times 186 \times 5 \text{ in} \quad (\text{Table B-22})$$

$$= 714 \times 10^6 \quad (\text{See Fig. B-7})$$

$$\text{Sum} = 951 \times 10^6 \text{ lb-in}$$

$$> 916 \times 10^6 \text{ lb-in}$$

This yield line failure mode does not contr.

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 873 OF
PREPARED BY	T. T. Lee	DATE	11/19/84	REF. DOCUMENTS:	
CHECKED BY		DATE			

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

Check 1 RP.  $N_x = 24$ ,  $N_c' = 6$  Case

$$M_{E-E'} \text{ due to pressure} = 1.214 \times 10^9$$

$$\text{" " " } F_{x-x} = -0.617 \times 10^9$$

$$\text{Sum} = 0.597 \times 10^9$$

$$= 597 \times 10^6 \text{ lb-in.}$$

Resisting Moment

$$\text{Along OADG + OAD'G'} = 2 \times 2.71 \times 10^6 \times 19 = 103 \times 10^6$$

$$\text{Along GIG'} = 2 \times 683 \times 10^6 \times 186 \times 5.1 \times 18^{\circ}$$

$$= 785 \times 10^6$$

$$\text{Sum} = 588 \times 10^6 \text{ lb-in}$$

$$> 597 \times 10^6 \text{ lb-in}$$

O.K.

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 874 OF
PREPARED BY T. T. Lee	DATE 11/19/82	REF. DOCUMENTS.			
CHECKED BY	DATE				

1

2

3

Check 1.5 RP,  $N_x = 21$ ,  $N_c' = 33$  Case

4

5

From Table B-18,

6

7

$$M_{E-E'} \text{ due to pressure} = 2224 \times 10^9 \text{ (by interpolation)}$$

9

10

$$\text{" " " } F_{L-L} = -1130 \times 10^9 \text{ (by interpolation)}$$

11

12

$$\text{Sum} = 1092 \times 10^9 = 1094 \times 10^6 \text{ lb-in}$$

13

Resisting moment

14

$$\text{Along OADG, O'A'D'G'} = 2 \times 936 \times 10^6 \times 19 = 355 \times 10^6$$

15

16

$$\text{Along GIG' } = 2 \times 9.68 \times 10^6 \times 188 \times \sin 18^\circ = 1113 \times 10^6$$

17

18

$$\text{Sum} = 1468 \times 10^6 > 1094 \times 10^6 \text{ lb-in}$$

19

O.K.

20

21

Check 1.5 RP,  $N_x = 24$ ,  $N_c' = 30$  Case

22

23

$$M_{E-E'} \text{ due to pressure} = 2142 \times 10^9$$

24

25

$$\text{" " " } F_{L-L} = -1088 \times 10^9$$

26

27

$$\text{Sum} = 1054 \times 10^9 = 1052 \times 10^6 \text{ lb-in}$$

28

Resisting moment

29

30

$$\text{along OADG, O'A'D'G'} = 2 \times 863 \times 10^6 \times 19 = 328 \times 10^6$$

31

32

$$\text{along GIG' } = 2 \times 9.62 \times 10^6 \times 188 \times \sin 18^\circ$$

33

34

$$= 1106 \times 10^6$$

35

36

$$\text{Sum} = 1232 \times 10^6 > 1052 \times 10^6 \text{ lb-in}$$

O.K.

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE 875 OF
PREPARED BY T T Lee	DATE 11/19/82	REF. DOCUMENTS:		
CHECKED BY	DATE			

1

2

3

4

Yield Line Pattern OA B H I

5

6

Refer to Fig. B-6

7

8

Check r.o.R.P.  $N_x=0$ ,  $N_c' = 20$  case

9

10

From Table B-15.

11

12

$$M_{c-c'} \text{ due to pressure} = 2599 \times 10^9$$

13

14

$$\underline{\quad \quad \quad F_{L-L} = -1528 \times 10^9}$$

15

16

$$\sum = 0951 \times 10^9$$

17

18

$$= 951 \times 10^6 \text{ lb-in}$$

19

Resisting moment

20

21

$$\text{along OABH, OA'B'H'} = 2 \times 624 \times 10^6 \times (9+13+9) = 327 \times$$

22

23

$$\text{along HIH'} = 2 \times 6.21 \times 10^6 \times 186 \times \sin 41.5^\circ = 153 \times 10^6$$

24

25

$$\sum = 1918 \times 10^6 \text{ lb-in} > 951 \times 10^6$$

26

27

O.K.

28

29

30

31

32

33

34

35

36

## CALCULATION SHEET

CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 876 OF
PREPARED BY	T T Lee	DATE	" / 19 / 84	REF. DOCUMENTS:	
CHECKED BY		DATE			

1

2 Check 1.0 RP,  $N_x = 24$ ,  $N_c' = 6$  Case

4  $M_{c-c}$  due to pressure =  $2.374 \times 10^9$

6 " " "  $F_{x-x}$  =  $-1.505 \times 10^9$

8 Sum =  $0.889 \times 10^9 = 889 \times 10^6$  16-

10 Resisting moment

12 along OA'B'H, OA'B'H' =  $2 \times 7.1 \times 10^6 \times 31 = 16.8 \times 10^6$

14 along HZH' =  $2 \times 6.83 \times 10^6 \times 186 \times \sin 41.5^\circ = 16.84 \times$

16 Sum =  $16.84 \times 10^6 > 889 \times 10^6$  16-

OK

19 Check 1.5 RP,  $N_x = 21$ ,  $N_c' = 33$  Case

21  $M_{c-c}$  due to pressure =  $3.106 \times 10^9$

23 " " "  $F_{x-x}$  =  $-1.968 \times 10^9$

25 Sum =  $1.136 \times 10^9 = 1136 \times 10^6$  16-

27 Resisting moment

29 along OA'B'H, OA'B'H' =  $2 \times 9.34 \times 10^6 \times 31 = 579 \times 10^6$  16-

31 along HZH' =  $2 \times 9.68 \times 10^6 \times 186 \times \sin 41.5^\circ = 2386 \times 10^6$

33 Sum =  $2965 \times 10^6 > 1136 \times 10^6$  16-

OK

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738 N/C	PAGE 877 OF
PREPARED BY	DATE	REF. DOCUMENTS:		
CHECKED BY	DATE			

1

2

Check 1.5 R p     $N_x = 24$ ,  $N_c' = 30$  Case

4

5

$M_{c-cr} \text{ due to pressure} = -1.990 \times 10^9$

6

7

$" " " F_{x-cr} = -1.875 \times 10^9$

8

9

$\text{Sum} = 1.095 \times 10^9 = 1095 \times 10^6$  16-17

10

11

Resisting moment:

12

13

$\text{along OABH, OA'B'H'} = 2 \times 263 \times 10^6 \times 21 = 535 \times 10^6$

14

15

$\text{along HIH'} = 2 \times 962 \times 10^6 \times 186 \times \sin 41.5^\circ = 2371 \times 10^6$

16

17

$\text{Sum} = 2906 \times 10^6 > 1095 \times 10^6$  16-17

OK

18

19

Conclusion (SB. 1.7)

20

21

Yield line failure along OABH or OA'DGI

22

23

will not develop, if  $N_x$ ,  $N_c$  shown in Table B-20

24

25

(or Figs 1 and 2) are used. Hence Table B-20.

26

27

Figs 1 and 2 remain valid

28

29

30

31

32

33

34

35

36

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 57 OF
PREPARED BY	T. T Lee	DATE	/19/84	REF. DOCUMENTS:	
CHECKED BY		DATE			

B. 3      Punching Shear Mode of Failure  
 (Bottom Head)




Fig. B-11

Section susceptible to punching shear failure  
 is the one connecting the S.G. penetrations,

Fig. B-11, ①-①. See Fig. B-3 also.

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO.	907738	N/C	PAGE 877 OF
PREPARED BY	DATE				REF. DOCUMENTS:
CHECKED BY	DATE				

The punching shearing stress is:

$$\frac{p \pi (144)^2}{[2\pi(144) - 12(22)] \cdot 186} = 0.874 p = f_v$$

Ref 4 gives

$$p = \frac{d}{D} (0.874 f_c' + 0.1676 f_t)$$

where  $p$  = ultimate pressure (psi)

$d$  = slab thickness = 186 in

$D$  = pressurized diameter in inches = 277

$f_c'$  = concrete strength = 6000 psi

$f_t$  = prestress (psi)

From this, the shear allowable is:

$$\frac{p \frac{\pi D^2}{4}}{\pi d \cdot d} = \frac{p D}{4d} = f_{v, \text{allowable}}$$

## CALCULATION SHEET

## CALCULATIONS FOR

EQUIP. NO.	PROJ.	CALC. NO. 907738 N/C	PAGE 3 OF
PREPARED BY T T Lee	DATE 11/19/84	REF. DOCUMENTS.	
CHECKED BY	DATE		

$$\begin{aligned}
 f_{v, \text{allowable}} &= \frac{1}{4} (0.842 f_c' + 0.1676 f_t) \\
 &= 0.210 f_c' + 0.0419 f_t \\
 &= 1260 - 0.0419 f_t
 \end{aligned}$$

For  $P = 845 \text{ psi}$  :  $f_t = 732 \text{ psi}$   
 $(1.0 \text{ RP})$

$P = 1258 \text{ psi}$ ,  $f_t = 1108 \text{ psi}$   
 $(1.5 \text{ RP})$

Both are smaller than 1260 psi, the allowable ignoring the constraining effect of the radial prestress

Check Section ②-② (Fig. 8-11) :

$$\begin{aligned}
 \text{Allowable } P &= \frac{186}{2 \times 186} (0.842 f_c' + 0.1676 f_t) \\
 &= 2526 + 0.0838 f_t
 \end{aligned}$$

Actual  $P = 845$  and  $1268 \text{ psi} < 2526 \text{ psi}$

Hence, punching shear is not a problem

DD 907738/N/C

APPENDIX C

CALCULATION REVIEW REPORT

## CALCULATION REVIEW REPORT

TITLE:

FSV - Tendon Requirements Based on Safety Consideration

APPROVAL LEVEL 2QAL LEVEL 2

DISCIPLINE	SYSTEM	DOC. TYPE	PROJECT	DOCUMENT NO.	ISSUE NO/LTR.
S	II	CFL	1900	907738	N/C

INDEPENDENT REVIEWER:

NAME Arnold A. SchwartzORGANIZATION Structural Design and AnalysisREVIEWER SELECTION APPROVAL: BR MGR Tom Ciallo DATE 10.29.84

REVIEW METHOD:

YES	NO	ERROR DETECTED
	✓	
✓		No
	✓	
✓		No
	✓	

REMARKS: (ATTACH LIST OF DOCUMENTS USED IN REVIEW)

*Calculation 907738**FSV - Structural Drugs for PCRV*

CALCULATIONS FOUND TO BE VALID AND CONCLUSIONS TO BE CORRECT:

INDEPENDENT REVIEWER

*Arnold A. Schwartz*

SIGNATURE

11/30/84



## Public Service Company of Colorado

16805 WCR 19 1/2, Platteville, Colorado 80651

January 31, 1985  
Fort St. Vrain  
Unit #1  
P-85039

Final transmitted  
version

Regional Administrator  
Region IV  
U. S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Attn: Mr. E. H. Johnson

SUBJECT: Interim Fort St. Vrain  
Tendon Surveillance  
Program

REFERENCES: PSC Letter,  
D. W. Warembourg to  
E. H. Johnson  
12/14/84 (P-84523)

Dear Mr. Johnson:

In response to the concerns expressed by the NRC we are submitting for your evaluation our plans for implementing an interim tendon surveillance program.

The surveillance program will be based on proposed Technical Specification SR 5.2.2 as submitted in Reference 1 and will include those tendons considered accessible in Reference 1.

PSC plans to implement the surveillance program based on information gathered in our original assessment effort and your expressed concerns for determining the present overall level of corrosion and the current rate of corrosion.

The majority of this program has already been started as a continuing effort following completion of tendon testing we had previously committed to perform. The entire program will be implemented by March 1, 1985 and will be based on an eighteen month cycle, as cited in the submitted SRs.

*8502110687*

Tendon Surveillance Specification SR 5.2.2 includes five (5) sections which PSC plans to treat as follows during this interim period.

1. SAMPLE WIRES INSERTED INTO TENDONS WITH AREAS OF KNOWN CORROSION

No action will be initiated during the interim period. The sample wires currently in the tendons are not necessarily in tendons with areas of known corrosion. The tendons with areas of corrosion are currently being identified and supplies of sample wires are currently being investigated.

2. ATMOSPHERIC SAMPLES OF TENDON TUBES

No action will be initiated during the interim period. Tendon caps have been removed on most tendons for examinations and air, therefore, was introduced into the tubes. The corrosion prevention system has not been finalized as of this date and sampling of the tubes atmosphere would provide no useful information. During the original corrosion determination investigation the atmospheres in 97 tubes were sampled and tested. The results of these tests have been supplied to the NRC.

3. VISUAL EXAMINATION OF ACCESSIBLE TENDONS

During the interim period PSC will perform this section as it was submitted to the NRC. A visual examination of at least 5% of the accessible anchor assemblies for the top crosshead and circumferential tendons shall be performed. A visual examination of at least 33% of the accessible anchor assemblies for the longitudinal and bottom crosshead tendons shall be performed. This will include re-examination of tendons with areas of known corrosion to obtain information on the current rate of corrosion. In addition to the required percentage of tendons, an additional two repeat tendons will be examined to provide for continuous monitoring of corrosion rate.

4. TENDON LIST OFF TEST

During the interim period PSC will perform this section as it was submitted to the NRC. Lift off test of at least 5% of the accessible top crosshead tendons and circumferential tendons shall be performed. Lift off test of at least 15% of the accessible longitudinal tendons and bottom crosshead tendons shall be performed. In addition to the required percentage of tendons, an additional two repeat tendons will be tested to provide for continuous monitoring of corrosion rate.


5. REPORT OF TENDON EXAMINATION RESULTS

At the end of the interim period a report will be prepared covering the testing done during the interim period. This special report will be submitted to the NRC at that time. If specification SR5.2.2 is formally approved prior to the end of the eighteen month interim period, the special report will be prepared indicating the status at that time.

Please be aware that the Specification SR 5.2.2 submitted in Reference 1 was a preliminary Technical Specification submittal, only for the purpose of presenting our rational for a tendon surveillance program.

We trust this provides the requested commitment to begin an interim tendon surveillance program and satisfies your concerns. If there are any further questions concerning the PCRV tendons please contact me or Mr. Chuck Fuller at (303) 785-2223.

Sincerely,



J. W. Gahm  
Manager, Nuclear Production  
Fort St. Vrain Nuclear  
Generating Station

JWG:AR/djc



**Public Service**

**Public Service  
Company of Colorado**

16805 WCR 19 1/2, Platteville, Colorado 80651

June 7, 1985  
Fort St. Vrain  
Unit No. 1  
P-85193 10

P DISTRIBUTION

BORST, T. J.  
BREY, M. L.  
BURCHFIELD, B.  
DENVER DOC. CONT.  
DOLPHIN, M.  
EGGEBROEN, J.  
FULLER, C. H.  
GAHN, J. W.  
GRAMLING, J.  
HOLMES, M. H.  
INDEPENDENT REVIEWER  
JOHNS, J  
JOHNSON, E. H.  
KITZMAM, A.  
LEE, O. R.  
MCBRIDE, L. M.  
MFSC CLERK  
NIEHOFF, M. E.  
NOVACHEK, F.  
PLUMLEE (NRC)  
PORC CLERK  
REESY, J. R.  
SINGLETON, L.  
TECH SERV. CLERK (3)  
U.S.N.R.C.  
WAGNER, P  
WAREMBOURG, D. W.

Regional Administrator  
Region IV  
U. S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Attention: Mr. Eric H. Johnson

Docket No. 50-267

SUBJECT: Fort St. Vrain  
Additional Tendon  
Inspection

- REFERENCES: 1) PSC Letter,  
D. W. Warembourg to  
E. H. Johnson, dated  
5/20/85 (P-85176)
- 2) I&E Information  
Notice 85-10  
(G-85053)
- 3) I&E Information  
Notice 85-10  
Supplement 1 (G-85098)

Dear Mr. Johnson:

As per Reference 1, ten of the bottom longitudinal tendon end caps were removed for inspection. The visual inspection consisted of examining the tendon end caps, prestressing anchor assembly stressing washer, shims, bearing plate and buttonheads for evidence of general corrosion, concavity, water or apparent failures. The inspection showed no evidence of concavity, cracking, water, or general corrosion. No raised buttonheads were found during this inspection. To insure that there was no cracking similar to that at Farley, five of the anchor assemblies were magnetic particle inspected for cracking. The tendons inspected were VM1, VI3, VII1, VM17, VM18, VM22, VI27, VM31, VI34 and VI38. The tendons which were subjected to the examination were VM1, VM17, VM22, VM31 and VI34.

**RECEIVED**

JUN 12 1985

~~6506270277~~

**M. B. DOLPHIN**

Due to bleedout associated with liquid penetrant tests, Public Service Company considers magnetic particle testing to be more sensitive for this application. The magnetic particle tests showed no discontinuities.

During this inspection, no visible evidence of pitting was found in the tendon caps. As per Reference 3, a galvanic cell was established at Farley between their galvanized caps and the stressing washers. The zinc in Farley's prestressing system was essential in the establishment of the galvanic cell, which resulted in stressing washer failure. Since we have no zinc coated components associated with our prestressing system and based on all previous inspections to date, it is Public Service Company of Colorado's conclusion that Fort St. Vrain is not susceptible nor exhibiting evidence of zinc related galvanic cell corrosion.

If you have any further questions, please do not hesitate to contact Mr. M. H. Holmes at (303) 571-8409.

Very truly yours,

*D. W. Warembourg*  
D. W. Warembourg,  
Manager, Nuclear Engineering  
Division

\* Ref. Corrosion Engineering by  
Fontana/Greene, 1978.

DWW/MJF/ksc

Attachments

Reviewed by B. E. Langston



Public Service

2420 W. 26th Avenue, Suite 1000, Denver, CO 80211

Public Service  
Company of Colorado  
P.O. Box 840  
Denver, CO 80201-0840  
(303) 571-7511

March 5, 1985  
Fort St. Vrain  
Unit No. 1  
P-85071

P DISTRIBUTION

BORST, T. J.  
BREY, H. L.  
BURCHFIELD, B.  
DENVER OCC. CONT.  
DOLPHIN, M.  
EGGEBROEN, J.  
FULLER, C. H.  
GAHM, J. A.  
GRAMLING, J.  
HOLMES, M. A.  
INDEPENDENT REVIEWER  
JOHNS, J.  
JOHNSON, E. H.  
KITTMAN, A.  
LEE, O. R.  
MCBRIDE, L. M.  
MILLEN, C. K.  
NFSC CLERK  
NIEMOHN, M. E.  
NOVACHEK, F.  
PLUMLEE (NRC)  
PORC CLERK  
REESY, J. R.  
SINGLETON, L.  
TECH SERV. CLERK (I  
U.S.N.R.C.  
WAGNER, P.  
WAREMBOURG, D. A.

Regional Administrator  
Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive Suite 1000  
Arlington, Texas 76011

Attn: Mr. Eric Johnson

DOCKET NO. 50-267

SUBJECT: Fort St. Vrain Unit No. 1  
Revised Tendon Surveillance  
Program

REFERENCES: 1) P-85039, Gahm to Johnson,  
dated January 31, 1985  
  
2) P-84523, Warembourg to  
Johnson, dated  
December 14, 1984

Dear Mr. Johnson:

As a result of our proposal for a PCRV tendon surveillance program presented at the February 20-22, 1985 site meetings and subsequent telephone conversations, we are transmitting herewith our written description of this program.

The basis for our proposal is as follows:

A. Surveillance Frequency and Tendon Population

Our original interim surveillance program as proposed by P-85039, established an 18 month frequency for the visual inspection and liftoff test programs. While it is felt that this program would provide adequate monitoring of the prestressing system, we recognize that the present data base is not sufficient to define a corrosion rate. Based on present information, the corrosion rate appears to be relatively slow, but we feel it is necessary to develop a more sufficient data base. On this basis we have proposed the accelerated inspection/testing program for

8503220042

the next three (3) year period or until such time that effective corrosion control is established. The program changes the previously proposed 18 month frequency for visual inspection to a six (6) month frequency. The proposed program also establishes a larger control group of tendons to permit a better assessment of corrosion rate.

The liftoff frequency for the new tendon population remains the same as previously proposed; however, a control group has been established to provide a liftoff assessment every six (6) months for tendons in this group.

This substantial increase in the surveillance program together with a very high percentage of tendons that we have already inspected/tested provides the necessary assurance that PCRV prestressing system is capable of performing its design function.

#### B. Engineering Evaluations/Failed Wire Criteria

As indicated in the proposed surveillance program, we will be continuously assessing the PCRV prestressing system from an engineering viewpoint as data is obtained in the surveillance program. We expect the surveillance program to be continuous over the frequency cycle specified.

Within the proposed program, we did specify a mandatory engineering evaluation based on > 15% failed wires for circumferential barrel tendons and > 20% failed wires for all other tendons. It should be noted that the program outlined on February 22, 1985, during the NRC site meetings established a general criteria of > 20% failed wires for all tendons. That original criteria did not recognize the two sub-groups of circumferential tendons, one of which is the 152-wire circumferential barrel tendons. As a result, this surveillance program has established a > 15% failed wire criteria for the circumferential barrel tendons.

Design Criteria DC-11-1 (FSAR, Appendix E) requires the PCRV be designed to resist a cavity pressure of 2.1 RP (1775 psig) for Limit Condition 2 which is the governing case. The allowable stress/strength limits for this condition are:

Longitudinal tendons - Guaranteed ultimate tensile strength provided that strain compatibility is satisfied.

Circumferential tendons in barrel - Same as above.

Top and bottom head tendons (circumferential and crosshead) - 0.9 fsy where fsy is the minimum guaranteed steel yield strength at 1% elongation, and is equal to 204 ksi (FSAR, Fig. 5.6-1).

In this calculation, in order to assure the participation of rebars, the allowable stress for the longitudinal tendons and the circumferential tendons in the barrel section is limited to  $f_{sy}$ .

The PCRV ultimate load analysis (FSAR Section 5.3.3.3 and Appendix E, Section E.10, Figs. E.10-23 through E.10-25) indicates that at a cavity pressure of 1775 psig the stresses in typical tendons are still elastic as given below:

1. Longitudinal tendons: 156 ksi.
2. Circumferential tendons at barrel: 170 ksi.
3. Circumferential tendons at heads: 138 ksi.
4. Crosshead tendons = 139.5 ksi.

These tendon stresses expressed as ratios of the respective allowable stress/strength limits are as follows:

1. Longitudinal tendons:  $156/204 = 0.76$
2. Circumferential tendons at barrel:  $170/204 = 0.83$
3. Circumferential tendons at heads:  $138/(0.9 \times 204) = 0.75$
4. Crosshead tendons:  $139.5/(0.9 \times 204) = 0.76$

It follows that the minimum acceptable tendon steel areas to resist the overpressure condition expressed as ratios of original areas specified in design are as follows:

	Area Required	Permissible Loss	Wire Failure Evaluation Criteria
Longitudinal Tendons	76%	24%	20%
Circumferential Barrel	83%	17%	15%
Circumferential Head	75%	25%	20%
Crosshead, Top or Bottom	76%	24%	20%

Based on the above percentages, we established the  $\geq 15\%$  and  $\geq 20\%$  wire failure criteria as a conservative point for mandatory engineering evaluation. The conservative nature of the criteria is based on the following:

1. Although the above calculations are based on minimum guaranteed yield strengths, they are also based on a hypothetical reactor vessel pressure of 2.1 Reference Pressure (1775 psig). The plant protective system action which monitors reactor pressure, trips the reactor at 107.5% of the normal working pressure of 688 psig. In addition, two redundant safety-relief valves provide overpressure protection with setpoints of 812 psig and 832 psig respectively.
2. The criteria assumes uniform degradation of all tendons. This is obviously not representative of how

corrosion will proceed, and is most certainly ultra conservative based on our inspection findings. The criteria will be utilized to provide a trigger for engineering evaluations on a tendon by tendon basis.

3. The design of the prestressing system (see FSAR Appendix E Section E.14.2.5) permits complete detensioning and removal of a tendon at power operation which represents a 100% loss of wires for that tendon when applied to the prestressing system as a whole. Obviously an evaluation of an individual tendon using the proposed criteria if  $\geq 15\%$  and  $\geq 20\%$  is conservative.
4. The inspection findings to date do not reveal any specific tendency for tendon corrosion on a cluster basis. The corrosion is random in nature and there is no immediate concern for cluster failure of several tendons that would result in localized PCRV concrete tension.

#### C. Overall Conclusion

It is our opinion that the proposed surveillance program will provide adequate monitoring of the PCPV prestressing system to permit assessment of the PCRV integrity on a continuous basis to ensure the health and safety of the public.

Very truly yours,

*Don W. Warembourg*  
Don W. Warembourg  
Manager Nuclear Engineering Division

DWW:pa

Enclosed by: M. H. Holmes

P-3511  
Rev'd to dated June 14  
actual 3-19  
unpublished

Fort St. Vrain  
PCRV Tendon Surveillance Program

CONDITIONS

The following PCRV Tendon Surveillance Program is to be implemented, effective April 22, 1985, for a period of three (3) years or until such time that effective tendon corrosion control is established, whichever occurs first. An ongoing PCRV Tendon Surveillance Program will be established thereafter, subject to NRC review and approval.

DEFINITIONS

For the purpose of this surveillance test, the following definitions are applicable:

**VISUAL INSPECTION:** Removal of the tendon end cap and an in-place visual examination of the anchor assembly to include tendon wire button heads, anchor/bushing assembly, shims and bearing plates.

**LIFTOFF TESTS:** A physical liftoff of the tendon to determine the load being carried by that tendon. Liftoff tests for tendons that have not previously been lifted off would include removal of the shim plates to permit visual examination and as necessary reapplication of grease to the accessible areas of the tendon. Repetitive liftoff tests on the same tendon not in a control group may not include removal of shim plates for visual examination. Liftoff tests for tendons in designated control groups will include removal of shim plates and visual examination.

**NEW TENDONS:** A tendon population selected at random for visual inspection or liftoff testing over the next specified surveillance period. Selection shall be such that the total population of accessible tendons in that group shall be inspected/tested before beginning any repeat inspections/tests.

**CONTROL TENDONS:** A population of tendons in each tendon group that will be selected and will remain constant for each inspection/test surveillance cycle. The criteria for selection of these tendons shall be to select those tendons which represent conditions in which corrosion is most pronounced tempered by ready accessibility. Selection must necessarily be based on inspection data available on or before April 15, 1985.

**TENDON GROUP:** Four tendon population groups defined as

1. Circumferential-----310 ea
2. Top Cross Head----- 24 ea
3. Bottom Cross Head--- 24 ea
4. Longitudinal----- 90 ea

The circumferential tendon group consists of two subgroups consisting of 210 Circumferential Barrel Tendons and 100 Circumferential Head Tendons. In terms of inspection/testing, there will be no attempt to address these subgroups as separate entities in selecting inspection/test population.

**NUMBER OF TENDONS:** The number of tendons to be inspected or tested shall represent a predesignated number of tendons in that group. With the exception of the longitudinal tendon group, all tendons designated for inspection or liftoff testing shall be inspected or lifted off to include both end anchor assemblies if accessible. Longitudinal tendons will be inspected and lifted off only from the top end. (Inaccessible tendons have been designated as such in PSC letter P-84523 dated December 14, 1984).

**ENGINEERING EVALUATION:** A technical evaluation based on visual examinations, liftoff tests, load cells and other pertinent information to determine tendon acceptability and PCRV performance.

**FAILED WIRES:**

Wires within a tendon bundle that have failed as identified by raised button heads in the anchor assembly or as may have been previously identified as failed by visual inspection.

For tendons which are not accessible on both ends, it shall be assumed that 20% of the number of failed wires identified on the accessible end have failed on the inaccessible end in determining the total population of failed wires.

**VISUAL INSPECTION PROGRAM**

Once every six (6) months visual inspection shall be performed for the following tendon population.

Tendon Groups	Total Number of Tendons	Total Number of New Tendons	Total Number of Control Tendons
Circumferential	16	13	3
Top Cross Head	2	1	1
Bottom Cross Head	8	6	2
Longitudinal	30	24	6

**LIFTOFF PROGRAM**

Liftoff tests shall be performed on all "new" tendons once every 18 months and on all control tendons once every six (6) months as follows:

Tendon Group	Total Number of Tendons	Total Number of New Tendons	Total Number of Control Tendons
Circumferential	16	13	3
Top Cross Head	2	1	1
Bottom Cross Head	4	3	1
Longitudinal	15	12	3

**ENGINEERING EVALUATION**

Engineering evaluations will be made on a continuous basis as the tendon inspection/testing program progresses with the intent of ensuring that the prestressing system is performing its design function. Specific engineering evaluations will be mandatory for any circumferential barrel tendon with  $\geq 15\%$  failed wires and for any tendon in any of the remaining tendon groups with  $\geq 20\%$  failed wires.