

JUL 30 1986

In Reply Refer To:
Docket : 50-313
50-368

Arkansas Power & Light Company
ATTN: Mr. Gene Campbell
Vice President, Nuclear
Operations
P. O. Box 551
Little Rock, Arkansas 72203

Gentlemen:

Thank you for your letter of May 14, 1986, in response to IE Bulletin No. 85-03 dated November 15, 1985. As a result of our preliminary review, we find that additional information is needed.

Specifically, we request that you provide us with the following:

- ° Your method to determine the differential pressure (DP) across the valves,
- ° Your method to estimate switch settings,
- ° A detailed step-by-step program to verify the switch settings. Included in this is how will the valves be verified operable if not tested at full operation.

Please provide the supplemental information within 30 days of the date of this letter.

Sincerely,

151

B608050067 B60730
PDR ADOCK 05000313
Q PDR

J. E. Gagliardo, Chief
Reactor Projects Branch

cc:
J. M. Levine, Director
Site Nuclear Operations
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Arkansas Radiation Control Program Director

bcc: (see next page)

RIV:RPB/BN
RPMu111kin/tw
1/15/86

C:RPB/BN
DRHunter
1/15/86

C:RPB
JEGagliardo
7/27/86

110
1E11

Arkansas Power & Light Company

- 2 -

bcc to DMB (IE11)

bcc distrib. by RIV:

*RPB

*R&SPB

*RIV File

*Resident Inspector

*Section Chief (RPB/B)

DRSP

R. D. Martin, RA

M. Murphy

*RSB