

Mr. William T. Cottle
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric
Generating Station
P. O. Box 289
Wadsworth, TX 77483

February 17, 1999

SUBJECT: INSERVICE INSPECTION PROGRAM - RELIEF REQUEST RR-ENG-19,
SOUTH TEXAS PROJECT, UNIT 2 (TAC NO. MA1643)

Dear Mr. Cottle:

By letter dated April 8, 1998, South Texas Project Operating Company (STPNOC) submitted a request for relief from the ASME Code, Section XI requirements, to defer Code repair of a flaw in the Essential Cooling Water System piping at the South Texas Project, Unit 2. The Nuclear Regulatory Commission staff has reviewed the request as discussed in the enclosed Safety Evaluation.

The staff finds that the performance of an immediate Code repair would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety. The staff, therefore, concludes that STPNOC's proposed alternative to the Code requirements are authorized pursuant to 10 CFR 50.55a(a)(3)(ii).

Sincerely,

ORIGINAL SIGNED BY:

John N. Hannon, Director
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No.: 50-499

Enclosure: As stated

cc w/encls: See next page

DISTRIBUTION:

Docket File	PUBLIC	PD4-1 r/f	GHill(2)
EAdensam (EGA1)	JHannon	CHawes	DLange
TAlexion	OGC	ACRS	THarris(TLH3)
TGwynn, RIV	MGamberoni		

Document Name: G:\STPFINAL\STPA1643.REL

OFC	PM/PD4-1	PM/PD4-1	LA/PD4-1	BC/ECGB	OGC	PD/PD4-1
NAME	MGamberoni	TAlexion	CHawes	GBagchi	WYnn	JHannon
DATE	11/24/98	2/3/98	12/3/98	12/7/98	2/4/98	2/17/98
COPY	YES/NO	YES/NO	YES/NO	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY

230003
9902230123 990217
PDR ADOCK 05000499
G PDR

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 17, 1999

Mr. William T. Cottle
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric
Generating Station
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: INSERVICE INSPECTION PROGRAM - RELIEF REQUEST RR-ENG-19,
SOUTH TEXAS PROJECT, UNIT 2 (TAC NO. MA1643)

Dear Mr. Cottle:

By letter dated April 8, 1998, South Texas Project Operating Company (STPNOC) submitted a request for relief from the ASME Code, Section XI requirements, to defer Code repair of a flaw in the Essential Cooling Water System piping at the South Texas Project, Unit 2. The Nuclear Regulatory Commission staff has reviewed the request as discussed in the enclosed Safety Evaluation.

The staff finds that the performance of an immediate Code repair would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety. The staff, therefore, concludes that STPNOC's proposed alternative to the Code requirements are authorized pursuant to 10 CFR 50.55a(a)(3)(ii).

Sincerely,

A handwritten signature in black ink, appearing to read "John N. Hannon", written over a horizontal line.

John N. Hannon, Director
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No.: 50-499

Enclosure: As stated

cc w/encis: See next page

Mr. William T. Cottle
STP Nuclear Operating Company

South Texas, Units 1 & 2

cc:

Mr. Cornelius F. O'Keefe
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77414

Jack R. Newman, Esq.
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

A. Ramirez/C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Mr. T. H. Cloninger
Vice President
Engineering & Technical Services
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

Mr. M. T. Hardt
Mr. W. C. Gunst
City Public Service Board
P. O. Box 1771
San Antonio, TX 78296

Office of the Governor
ATTN: John Howard, Director
Environmental and Natural
Resources Policy
P. O. Box 12428
Austin, TX 78711

Mr. G. E. Vaughn/C. A. Johnson
Central Power and Light Company
P. O. Box 289
Mail Code: N5012
Wadsworth, TX 74483

Jon C. Wood
Matthews & Branscomb
One Alamo Center
106 S. St. Mary's Street, Suite 700
San Antonio, TX 78205-3692

INPO
Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Arthur C. Tate, Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Jim Calloway
Public Utility Commission of Texas
Electric Industry Analysis
P. O. Box 13326
Austin, TX 78711-3326

D. G. Tees/R. L. Balcom
Houston Lighting & Power Co.
P. O. Box 1700
Houston, TX 77251

Judge, Matagorda County
Matagorda County Courthouse
1700 Seventh Street
Bay City, TX 77414