

29 JUL 1986

Docket No. 50-333

Power Authority of the State of New York
James A. FitzPatrick Nuclear Power Plant
ATTN: Mr. Radford J. Converse
Resident Manager
P. O. Box 41
Lycoming, New York 13093

Gentlemen:

Subject: Revised Response to IE Bulletin 85-03

IE Bulletin 85-03, Motor Operated Valve Common Mode Failures During Plant Transients Due To Improper Switch Settings, November 15, 1985, requested a response concerning each licensee's program for selecting, setting and maintaining the switches of the motor-operated valves in the high pressure coolant injection/core spray and emergency feedwater systems.

Your response, letter JAFP-86-0437 dated May 14, 1986, although indicating that a program to accomplish items (b) through (d) of the Bulletin exists, did not supply the program as requested. Accordingly, please submit a revision to your response to IE Bulletin 85-03 which includes a detailed description of your facility's program for selecting, setting and maintaining the switches on the motor operated valves identified in item (a). Additionally, include a synopsis of your program for demonstrating operability of each valve by testing according to item (c), whether or not testing can be accomplished at present.

Please provide your revised response within 30 days of receipt of this letter.

Original Signed By

Richard W. Starostecki, Director
Division of Reactor Projects

cc w/encl:

L. W. Sinclair, President
J. P. Bayne, First Executive Vice President and Chief Operations Officer
A. Klausmann, Vice President - Quality Assurance and Reliability
R. L. Patch, Quality Assurance Superintendent
George M. Wilverding, Chairman, Safety Review Committee
Gerald C. Goldstein, Assistant General Counsel
NRC Licensing Project Manager
Dept. of Public Service, State of New York
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New York

OFFICIAL RECORD COPY

IE BULLETIN - STAIR - 0001.0.0
07/18/86

8608050213 860729
PDR ADDCK 05000333
G PDR

IE 01 110

29 JUL 1986

bcc w/encl:
Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
Section Chief, DRP
Robert J. Bores, DRSS
R. J. Kiessel, IE
E. L. Jordan, Director, I&E
Cliff Anderson
H. KISTER
E WENZINGER

RI:DRP
Stair/rhl

AS
7/18/86

RI:DRP
Linville

7/24/86

RI:DRP
Collins

7/25/86

RI:DRP
Starostecki

7/24/86

OFFICIAL RECORD COPY

IE BULLETIN - STAIR - 0002.0.0
07/18/86