



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

AUG 11 1986

NOTE TO: Tom Novak

FROM: Ihemis Speis

SUBJECT: REVIEW OF THE SEABROOK EPZ SUBMITAL

I have reviewed your proposed memo to H. Denton on the Seabrook review and provided comments in the form of markups to V. Noonan on August 8. It is important to decide what direction NRC is going to take on this issue before a detailed technical review can start. A decision chart set up in the form of three questions is attached for your consideration. I would recommend that you assemble a small group to assess the potential approaches to the review. Four individuals, one from each, PWRL, USRO, IE and OGC, could do the job in about two weeks. Our representative is Len Soffer, please feel free to contact him directly.

A handwritten signature in black ink, appearing to be "Ihemis Speis", with a long horizontal line extending to the right.

Ihemis Speis

cc: H. Denton

8608190179 XA

29 PP.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

AUG 11 1986

NOTE TO: Tom Novak

FROM: Ihemis Speis

SUBJECT: REVIEW OF THE SEABROOK EPZ SUBMITAL

I have reviewed your proposed memo to H. Denton on the Seabrook review and provided comments in the form of markups to V. Noonan on August 8. It is important to decide what direction NRC is going to take on this issue before a detailed technical review can start. A decision chart set up in the form of three questions is attached for your consideration. I would recommend that you assemble a small group to assess the potential approaches to the review. Four individuals, one from each, PWRL, USRO, IE and OGC, could do the job in about two weeks. Our representative is Len Soffer, please feel free to contact him directly.

A handwritten signature in dark ink, appearing to be "Ihemis Speis", with a long horizontal line extending to the right.

Ihemis Speis

cc: H. Denton

8608190179 XA

29 PP

Potential Approaches to the Review of the Seabrook
EPZ Submittal

1. Assuming that all technical information received from Seabrook is correct, can NRC reduce the Seabrook EPZ or evacuation zone below the 10 mile limit under current regulations and established regulatory practice?

If answer is No, go to Q-2.

If answer is Yes:

What information is important for the decision?
What additional information is needed from PSNH?

2. Can NRC use a risk based criteria to justify a reduction in EPZ or evacuation zone for Seabrook without "rulemaking" or granting an exemption?

If answer is No - Seabrook should either join the ongoing rulemaking or go to Q-3.

If answer is Yes:

What information is important for the decision?
What additional information is needed for PSNH?

3. What basis could NRC have for granting an exemption from existing emergency planning requirements for Seabrook?

- a.) Is the Seabrook plant significantly different from other PWRs with large dry containments with respect to Emergency Planning requirements?

If answer is No, go to Q-3b.

If answer is Yes:

What information is important for the decision?
What additional information is needed from PSNH?

- b.) Is there an "immediate need" for Seabrook, that would justify exempting it from current EPZ requirements while the rule change is underway?

If answer is No - give up!

If answer is Yes:

What information is important for the decision?
What additional information is needed from PSNH?

ENCLOSURE 3

References:

1. George S. Thomas to Vincent S. Noonan letter dated July 29, 1986, Seabrook Station Probabilistic Safety Study Update.
2. John DeVincentis to Vincent S. Noonan letter dated July 21, 1986, Seabrook Station Probabilistic Safety Assessment Update.
3. Seismic Fragilities of Structures and Components of the Seabrook Generating Station, Units 1 & 2, prepared by NTS Engineering, Long Beach, CA for Pickard, Lowe and Garrick, Inc. and New Hampshire Yankee Division, Public Service Company of New Hampshire, Seabrook, New Hampshire, June 1986. Technical Report No. 1589.01.
4. Seabrook Station Emergency Planning Sensitivity Study, prepared by Pickard, Lowe and Garrick, Inc., Newport Beach, CA for New Hampshire Yankee Division, Public Service Company of New Hampshire, Seabrook, New Hampshire, April 1986. PLG - 0465.
5. John DeVincentis to George W. Knighton letter dated January 30, 1984, Seabrook Station Probabilistic Safety Assessment Main Report and Summary Report.
6. Seabrook Station Risk Management and Emergency Planning Study, prepared by Pickard, Lowe and Garrick, Inc., Newport Beach, CA for New Hampshire Yankee Division, Public Service Company of New Hampshire, Seabrook, New Hampshire, December 1985. PLG - 0432.
7. Seabrook Station Probabilistic Safety Assessment (Summary Report and 6 volumes), prepared by Pickard, Lowe and Garrick, Inc., Newport Beach, CA for Public Service Company of New Hampshire, Manchester, New Hampshire and Yankee Atomic Electric Company, Framingham, MA, December 1983. PLG - 3000.
8. Seabrook Station Probabilistic Safety Assessment Technical Summary Report, prepared by Pickard, Lowe and Garrick, Newport Beach, CA for Public Service Company of New Hampshire, Manchester, New Hampshire and Yankee Atomic Electric Company, Framingham, MA, June 1984. PLG - 0365.

David Tirrell - Uysaki - AP

• Request for PNH to
NAC will give them top priority-

Top. prelim review in 3 mo
normally take - out of ordinary

Sense of Urgency - no discussion of
holding up licensing

What kind of things

Then utility will determine if they want
to go further

to safe - changes in EP

What other kind of things may be involved
graded response - change current graded response
of EP2

There are so many options - get rid of them
so they don't have to submit

Ricky made progress - November 3 call status

Lillian He Lee
Gweneth - Mary

Tate Allen Spray - Le Ric

Glenn

* John Quinn - VP - NH Yankee.

initial report - lots of work for us to do
possible outcome.

not a simple thing to do

* Andy Archill / Eugene

Samuel indicated - would be the
basis

Luzvix

still in the works - discussed at
staff meeting - Ted Basis

Cy Weiss

Region I. K. Abraham

• Letter from NHY sent to NRC requesting EPZ to be reduced

Only request for reduced EPZ for Current Cliffs

State use police powers to frustrate Federal

2 things - 1) enforce

2) challenge → court → decide

Mass. legislature - created 40 mi EPZ .

- ① Xerox report pages + letter to Abraham + John Lopez
- ② Travel
- ③ Meeting minutes
- ④ Buy ticket

Ron Hernen: 29519

interim - for purpose of telling them where we're at

September 25th afternoon downtown joint on Seabrook

Subcommittee

Ful

Visit

• they'll do what

occupational + prot EP2

→ Kerr

Moeller -

Seabrook unit 1 + 2

Joint Seabrook /

Subs gather + exchange staff status report

PSNH

Occupational + Enr

Prot System, Subs

[Beers] [Oliver-Ala]

Only Subs / Kerr / Moeller

They will specific Seabrook mtg

wrapup

[Michele] 10:00

{ Kerr, Lewis, Moeller, Michelson }

interest of

* • Rich May Jr

{ Air. Settings }
Yorick

Millstone 3

projects - done prior for Oct. For Mtg

> Sano / Okrent <

—
* Bill Derrickson —

* technical basis * reporters

Union leader

Petermark Hkaid

Ch. 9.11

* Does this mean reducing the EPZ
is an option but not requesting this end
may be other options.

60 more days

Technically covered

But interferences - plants not safe

* Brad Pokornal
remains

①

3/14/86

Noonan - intro

communicate info need over next 3 mo. for review
do review in short period of time to get positive
response or questions needed to get there

C. Huggmayer

learn as much as we can about cont. strength
calc. + confirm analysis of key parts of exam
know everything they've done; then focus on key things
* (see agenda)

Design, construction + key elements
then failure modes + specific details
(weak elements)

Site visit for BNL - schedule this today
also tell us what's important - any recommendations

① Design of Containment

Vince - unique features of Seabrook containment?

let's try to make it more unique - show it's
better than average

Rich Tolland/Celwani

Non prototype - (Indian B.M. 2.3) WNP 1 + 4)
general design

(2)

for East Coast Cont. - 52 psi - Design Allowed Load

+ 25 peak ground acc seismic

→ origin for East Coast

not design for average impact but shams to withstand shield building helps distribute the load - PSAR vol. 5

General description: liner, T anchors, reinforced concrete, rebar

Behavior as a shell

ASME Code Design - 62 ksi yield, 72 ksi yield

9/54 ksi

Addition of seismic rebar - enhances strength under pressure.

Custom - considered load of 1.5P? Yes - have to by code

Charlie H - design + constructed to code - yes (1975)

Liner as barrier but not strengthened from code point of view

C.H - Base Stress Design?

no welded rebar configuration in containment except at welds

How does this differ from IN. P.C.?

design acc. P

Seismic peak ground acc.

Comparable material - rebar, equipment - plus welded

Some plate @ apex different

Seabrook bigger diam.

UNP-1 is larger than Seabrook

Don Wesley: looked @ IP - design philosophy seismic rebar vs ^{pressure} rebar
ack or not? seismic gives strong capacity - once you add these 2 - higher
probably a higher % of diag. steel in Seabrook

(3)

- inclined base on outermost layer

- foundation - 9000 velocity rock

bottom of mod = -26

cavity = -82

Cont. is free standing embedded in rock

Encl. + cont. do not show —

Wiley - lack of interaction $\rightarrow$ sq. factor is bounded uplift

Garcia - stress zones in mod can be limiting

lead to - changes in reinforcing pattern

Harnad - with liner capacity goes up - no displacement between

liner + well - is connection between the 2 designed?

- welded T anchors

Garcia - analysis done for severe accident condition

Wiley compatibility of liner + rebar which fails first (liner vs. rebar)

ultimate capacity - severe deformation. liner follows concrete

Ult. Cap in PRA ans. vs design

liner base - there is strength here

how far a T considered - design - 271°

300 - 350° F considered by Tollerud

C.H. may - need to know any key features about design are important - otherwise we can look at drawings

- main rib is continuous / goes around openings rather than terminating / as the bars are taken around

- dome ribs - continued on same angle plain / 4 quadrants

what about anchorages, penetration into concrete

e.g. equip. Patch - stress loads on it?

continuous heavy line welded on top with additional lug weld to continued line from thickness
double lugs weld all around with stiffener
in between

C.H. - how carefully was the look at

Wesley - not controlling - large margin are further controlling
matters

C.H. - used look to look at what you looked at and how you did it

Wesley. publications - looked at vendor design calc.

hatches themselves shown to be very over designed

∴ large margins in the hatches

P capacity were all designed - equip. Patch big

Gordon - go back to purchase spec. to show any difference?

post tensioned¹³ reinforced concrete

based has to be able to withstand imposed
displacements from shell.

No dome slab from trapezoidal steel bars

No crane on the shell. Run smooth transition to dome
Gasket - local loads.

Staggered radial pattern

Relationship to adjacent structures

Penetration assembly details

Refueling bld + fuel transfer canal

Canal + little Run flexible isolation joint
See accident pressure. 4% steam

Adjacent
Building

Cop Hack, Fuel Storage Bldg, Elec. Penetr. Area, Main Steam + Feed pipelns

Ht + Cold Penetrations, any gaps open? No

all major penetrations below grade

elec penetration - welded plates

main steam + feed lines on fixed heads

Vine: ^{circ. water} ~~geyl~~ ^{to relieve press into containment + get it going} ~~splm~~ ^{quite to bypass cond.} taking water from 1 mi ^{1 mi offshore} ~~use this for cold venting system~~ ^{character this}
would cont press be enough to drive it out or would
you need another syst - then add this to emerg. q. sys.

System - most possible would be anything thru fuel pool
John D. looking at this

Scrublook EP2:

Conf Cell - with BNL (Art Tingle + Woodclaw, etc)

Also next week plant models V-sequence

Site Visit

ACRS mtg

PLG c California - Jim Moody

Cora Flemming

c D.C.

Keith Woodclaw

D.C

Sweeney

Framingham

Shengdar Li

BNL

Art Tingle

Purpose of from cell to get - emergency activity going

Art - CRACIT CACLO's done by Woodclaw with PLG

202-296-8633

Q raised c mtg related to coming calc.

Take some time - do some early work;
CRAC or MACCS

• Diff between CRAC II - CRACIT -
MACCS - dosimetry difference

One case was a single puff - early case, airc

Late workplace type calc - easier to verify CRACIT with

single release vs multipuff

Don't make diff. over the puff in the grid if wind changes direction.

∴ MACCS Calc - averaging

②

Check this

- * NPC prefers NACCESS code - but it's not available
clustering to get the source terms (random sampling)
Can control running the uncertainty process -

They have run CRAC 2 + are familiar with the present
Strengths: do they have CRAC II compatible input data
1 hr. Met data for 1 year.

Cell Flaming: testing + auditing CRAC II model
what's been done? test

- 1) benchmark study
- 2) report on where they are the same price (CRAC 2 - no NACCESS)
Roger Blund - "Int Comp Study of K/Arc Conting Models"
EPRI 2 is PLE - Quc ME3

OECD published it

Org. for Economic Coop + Dev. promul

german to verification of CRAC II model

show differences in different codes

Population Table $\rightarrow$ No. Dose to Distance: unicon (0390)

who? Can Strongman to send a copy of Tape + send him a listing
1 yr data - KeithB - confirm with listing that Strongman doing
Altg may be needed - Moody

Are to run tape job - then run audit cell
against this

[Strongman to send CRAC 2 tape which utilizes 1 yr. met data
to BNL. Then BNL to do audit of it using CRAC 2.

Keep in mind: ocean site - so if no people, there can't
be a dose. Alt to discuss if any differences after running.

J. Moody.

(3)

474-9521, no X-tension
2401 (O. Vincenzo)

> Art reviewing inputs &
Schedule - 2/12/68

V-sequence of m. Cal/ give him some guidance

All interesting release categories as multi page

Fleming in the 2nd study, they did V-sequence (5-7W)
with a single p. y. source term - another option

1 5-7W. submerged release (V-sequence)
in PLG-0465, p. 4-8 source term table
Another alternative of single page source term

See by Dept. of Energy for the source term the release
more some they putting into a parameter

• They may want the source term more
sensitive parameters due to the report

✓ 5/1/68, the 4th —————> 617-874-5100 - X 3630

- Tape spec?

• 4/1/68 - 4/11/68, 4/11/68 - 4/11/68
Time of day doesn't make any sense

Name - Arthur Tingle

4/1/68

BNL

Upton N.Y. 11773 4/1/68 - 4/11/68

> 1 week - to read tape & run a dummy calc - the data of source terms

27th mtg - Trevor Patti + Rui mdy
what does he need to see -

capa hrs background for entertain QS
Command mri aspects vs. Plant models (vacations)
Put together an agenda

As PRA needs unfolded
what

external exerts - He should be there

Bring memo to Novak/Lyon

Direct mtg in Cont.

Sept. 8-9 (Mon-Tues)

Tues + Weday cert make it - what does Erowm Rui
available for following week

Finance for ext. Moring - System type person - 12-14
+ Operator (Alice David)

2.00 Conf. Call

1:30

From Morgan
Wash
California
Dike
NAC
BNL

as per model

Offsite
Consig. 110.

* Eastern X 27070

What is the mayor no?

- Tinkle

Art Tinkle 8-666

Art Tinkle V 7755

Miles Kuto R

8-666 → 2626

666-

516-282-7755

666-2630

☼ C Horgan -
☼

August - no used
Sept. maybe ok

How many different types of penetration details do we have
- bidders?

penetrations + how it's closed - how Steve Reid is
- get these drawings → F&A
we want to be sure there's nothing unique

Wesley - what what the review can

- 1) outlines
- 2) most likely to fail
- 3) piping issues - to identify closed support to a penetration

3 Construction of the Card

Anything unusual occur? about line; reinforcing steel
What about NCAs - listed in construction reports

- Coldweld lineup at certain locations > monitoring during
- Potential VCI behind the line Cont. SIF
- + other minor NCAs - damage to rebar (not = lot)

% total hoop rebar - how much damaged?

could be done but not in steel but mat

Wesley - coldweld scatter - ∴ did not state any reduction
majority of failures took place in bars not coldwelded
82% less failures occurred in rebar

2a) Material Certification Reports

data to confirm strength

7 Documented report of review by Tollerel. what is this
he doesn't recall

Vince - can he defend his work in a hearing

C.H. when is it official synopsis of construction of containment

Can't identify anything in nonconformance reports that would
have any effect - Wiley won't effect overall capacity.

(Deabrook to look at allegation files to see if anyone
John D.} disagrees about containment

Wiley did the same U.E.C. Yankee had none
about structural capacity.

Question - our best approach would be to look at allegation files
Deabrook to do this - we may look too.

3) Integrated leak rate test - Henry was 1/2 Howell - Ray has spent
any correction which had to be done?

rate of increase in pressure too low; one valve was open
one closed everything went perfectly.

ILRT was at 100°C

leak chases behind the liner - what did they do with this
they are basically inside cond. not outside

Question - are there double barriers?

every area has a specific boundary for leak chase.

what pressure were these tested to?

4. Ultimate Tensile Variation - UE: C

Tolland: when responded to MR request for info

UE: C did the same as for IP

describe behavior of thing to limit state (shell undergoes large deformations) - essential linear behavior of shell the postulate structural - mechanical interaction failure mode.

shell local phenomena precipitate failures
→ any failure of cont. would be considered

looking at details moving away from bursting mode.

∴ lets see if we can get cont. to a certain level

the failure occurs at some pt beyond. → limit state approach
no PMA approach

① took shell, then looked at linear, then yield strengths, then ultimate cap. very calculated data (margins ok), then looked shell to find what P produces deformation of shell
 $P(\text{depending on } T) \approx 145 \text{ psig}$ (They only took it to 350°)

There is a need to go the hierarchy of structural failure modes
In terms of shell structure interactive behavior/ell
must be explicit - but restrained the way it would apply

Interacting modes.

① displacements in shell

Mechanical Review-

- no failure mode < 150 psig - they wanted to be able to say it's at least as good as this
- 1) Looked at piping penetrations (I was informed) 150 psig - 350°F - no problems
 - 2) Electrical

Stayed within context of design basis for structural Equip hatch, anchor, basement - forces, moments, shears in these locations

Question - for IP shear strength would be the same
IP a little different
We have report

C.H. DeWash has more hoop strength $\therefore$ shear capacity would decrease

Question - did they still run into interference from structure
no - 3" gaps

Ultimate Strength Evaluation - SMA

To Develop Geomir Frag. Cont. Depressurization
Total Variability around central response broken into randomness + uncertainty

Uncertainty - material properties, uncertainty from analytical assumption
identify failure modes associated with overpress. - ones not looked at in design - then identify median internal Press Capac

Breach of conf. liner = failure (SNA)

Base case = design basis accident T'

no basis to know what max. Temp might be
 ∴ Capacity based on design basis pressure distribution
 these capacities could be reduced by

2 types of failure modes

- ① Direct / actual P failure of the structure
- ② Indirect / interaction local fault pipe penetration

Crack based on median material properties

400 psi 28 day strength

Typical aging properties - 6500 psi = median

rebar strength + limited data on line strength

Elongation properties - based on assumed crack propagation

4.7% failure - assumed linear stress between cracks

First looked at structure:

membrane failure

sub failure modes

discontinuity stresses

failure modes of penetrations

looked at general state of yield - 157

Took checked for strength of the liner

Computability between liner strains, rebar strains

what is an average crack spacing

anchors T_s or localized

These make a difference in failure mode

Resulted in average elongation capacity of 4.7%

Can't just take elongation properties of the liner itself
when it's in biaxial state of stress

How much total elongation do you get —

So evaluate what total % of elongation in liner
comes from necking

Effect of necking is something we don't have good data for.

Bottom line of computability:

Highly likely that elong. capability of liner
would exceed the liner $\rightarrow$ rupture of rubber first

What if the liner does fracture first - average hoop strain $< 3\%$

Ultimate P capacity = 216 psig using design basis T

Very unlikely the liner will fail - Controlling failure mode
in hoop direction is cylinder wall

Gets our cues from Wesley on problem jacket revised of
10 degree crack going from 15" to 25".

We need to involve whether it's O.K.

Interaction - both radial and potential vertical

Structure to structure - vertical growth doesn't
effect it but radially leads to punching
shear there and (after 6')

Other place to worry about is in the piping
structure to pipe problem of punching action of
pipe into penetration

Concentrate on interference from radial growth not vertical
 - Can you get these kinds of failures
 What kind of penetrations
 As worse for structure of pipe (you can develop loads)
 They looked to see when are the pipes with the
 structural support open

> Failure to isolate purg. are most dominant in PRA

Question: what happens to an operated valves at hi P.
 are op. valves fail safe?

Vine 1037 Study - when do these valves open to - which ones

Wesley - they did look at fixed head condition
 One thing concerning breach of line / are you going to fail the pipe,

They looked at opening of these pipes - situation is complicated... They have not looked at clogging system but looked at worse cases (bounding conditions)
 Computer input for BNC for PRA from U.E.C

Question: what about Bendra Test Results - not available before

CH - thermal load. how they come up with higher loads in
 accident sequences

Asper from T. Burt Division to talk about PRA aspects
 Consequence analysis - got in touch with Fred if
 any more info needed

Containment has not changed from original PRA

? 2 models are CRAC 2 or NARCS

Chap 2 - 32 radial sectors vs 16 radial sectors

? compatibility of data base - how can they get
 weather + population in compatible format?

> Fred - Source Terms important from multi-AT: release

A. Can't make any runs w/o weather

source term reduction responsibility or dominant effect

Fred - 2 sets of core parameters → need 2 separate runs

Fred Wendland: should be able to get input tapes (in Welsh)

"202-296-8633

5 or 6 other parameters

Norman (John D. Lilly) should be involved in conversation: Keith

ELC to be coordinator of exchange of info

Chap 2 population in FSNR

Gordon - consideration of sheltering within 1 mi - sheltering
 parameters look o.k.

Fred CRAC doesn't calculate dose w/o person - BNL can do this

NRC must determine whether they want to use MACCS or CBM.
 Will have to get back. CBAC would make more sense if
 were comparing to CB%
 Maybe North should put deck on top then have a mtg

In WASH 1400- method 1 + method 2

risk, acute fatality and latent fatality
 median curves changed to mean in 2 cases

Effects of External Events + Seismic Fragility Report
 Equipment Upgraded but not structural
 Fragilities for Subrock keyed to effective PSA

Question - have they looked at protective relays to see if
 they control fragility? - Relay Chatter
 EOs protective relays

Effects of relay chatter not looked at in much detail
 PSA - 1.67g

What are critical elements of PSA driving the results
 - reduction with allowing valves to go closed with loss of air
 -

Identify which fragilities are risk significant


After updating report (fragilities) results of original PSA have not
 changed. But will probably have an effect on latent effects.
 Nothing has increased - but relay chatter was identified

Look at effects of relay chatter when get back

Quantum - what are they going to do with fragility report

- will use it to update PPA next year

lets talk this till Seabrook has made up their mind



Any other significant external events?

Backhouse to go to site - 1st week in Sept. Law about 9/4

- will have to talk to T. Pratt - we may have to have another meeting with him - won't involve as much exchange of ~~data~~ data.

ACAS to go to work to have mtg on 9/25.

also want to go to local community - end of August

V Sequence, Cont. 200, Cont. bypass to be looked at by T. Pratt

Will we do any much calculations.

C. Hagemeyer's Laundry list

- design draws struct + pen
- " specs
- " report
- UE + C utl. capacity analysis
- SMA reports " end of facility
- Capacity Report (Appendix #)
- Piping penetration analysis
- Construction Report
- Drawings showing interfaces between adj. Structures → get this
- Model of the site
- SIT Test
- Material Test Reports
- Structural Analysis Model - UE + C has the best one → detail
- What is relevant in PSAR? - 3.8, 6