

August 7, 1986

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-86-56

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

FACILITY: Virginia Electric & Power Company
North Anna Unit 2
Docket No. 50-339
Mineral, Virginia

Licensee Emergency Classification:
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: OUTAGE IN EXCESS OF 48 HOURS

While operating at full power on August 4 at 11:13 p.m., (EDT) unidentified leakage of 1.31 gpm was noted. Power was reduced to allow containment entry to identify the leakage. Three valves, including a loop stop valve, were observed to be leaking. An Unusual Event was declared at 1:00 a.m., (EDT) August 5 and reactor shutdown was commenced to allow repair of the leakage.

This licensee estimates that the unit will be out of service until August 13.

The NRC received initial notification of the Unusual Event via telephone from the licensee to Headquarter operations officer at 1:09 a.m., (EDT) on August 5, 1986.

Contact: R. Croteau, 242-4299

A. Ignatonis, 242-0341

DISTRIBUTION:

H. Street	MNBB	Phillips	F/W	Willste	MAIL:
Chairman Zech	EDO	NRR	IE	NMSS	ADM:DMB
Comm. Roberts	PA		OIA	RES	DOT: Trans Only
Comm. Asselstine	MPA		AEOD		Applicable State
Comm. Bernthal	ELD				

SECY
ACRS
CA
PDR

Air Rights INPO - 9:09
SP NSAC

Regions: RI - 9:18, RIII - 8:58, RIIV - 9:00, RII - 9:07
Licensee: 9:22
(Reactor Licensees)
Applicable Resident Site 9:16

8608200302 860807
PDR I&E
PNO-II-86-056 PDR

DMB
IEC 1/10