

~~DO NOT~~

~~COPY~~

CONSUMERS POWER COMPANY

PALISADES PLANT

Emergency Preparedness Exercise Manual

PALEX '86

B608210041 B60703
PDR ADOCK 03000255
F PDR

TABLE OF CONTENTS

PART I - GENERAL DESCRIPTION AND OVERVIEW

- 1.0 FOREWORD
- 2.0 SCOPE AND OBJECTIVES
 - 2.1 SCOPE
 - 2.2 OBJECTIVES
- 3.0 EXERCISE INFORMATION
 - 3.1 EXERCISE PARTICIPANTS
 - 3.2 EXERCISE ORGANIZATION
 - 3.3 EMERGENCY RESPONSE FACILITIES
 - 3.4 EXERCISE CONDUCT
 - 3.5 EVALUATION AND CRITIQUE
- ~~4.0 TRAVEL INFORMATION~~
 - ~~4.1 TRANSPORTATION~~
 - ~~4.2 ACCOMMODATIONS~~
- 5.0 REFERENCES/ABBREVIATIONS/DEFINITIONS
 - 5.1 REFERENCES
 - 5.2 LIST OF ABBREVIATIONS
 - 5.3 DEFINITIONS
- 6.0 CONTROLLER INFORMATION
 - 6.1 CONTROLLER ORGANIZATION
 - 6.2 CONTROLLER CONDUCT
 - 6.3 CONTROL ROOM EVALUATION GUIDANCE
 - 6.4 OPERATIONS SUPPORT CENTER EVALUATION GUIDANCE
 - 6.5 EMERGENCY MAINTENANCE TEAM EVALUATION GUIDANCE
 - 6.6 FIRE BRIGADE EVALUATION GUIDANCE
 - 6.7 ONSITE/OFFSITE MONITORING TEAM EVALUATION GUIDANCE
 - 6.8 TECHNICAL SUPPORT CENTER EVALUATION GUIDANCE
 - 6.9 EMERGENCY OPERATIONS FACILITY EVALUATION GUIDANCE
 - 6.10 JOINT PUBLIC INFORMATION CENTER EVALUATION GUIDANCE
- 7.0 EXERCISE SCHEDULE

PART II - SCENARIO

- 8.0 NARRATIVE
- 9.0 SEQUENCE OF EVENTS
- 10.0 MESSAGES AND PLANT DATA
- 11.0 MAINTENANCE

TABLE OF CONTENTS
(Contd)

12.0 CHEM AND RAD-CHEM

13.0 RELEASE BASIS

14.0 MET DATA

15.0 RAD MONITOR DATA

16.0 CFM DATA SHEETS

17.0 PASM DATA

18.0 RGEM SAMPLE DATA

19.0 INGESTION PATHWAY DATA

20.0 ON-SITE MAPS

21.0 OFFSITE MAPS

22.0 OFFSITE TLDS

FIGURES

SECTION 3.0

- FIGURE 3.1 TECHNICAL SUPPORT CENTER (TSC) LAYOUT
- FIGURE 3.2 OPERATIONS SUPPORT CENTER (OSC) LAYOUT
- FIGURE 3.3 EMERGENCY OPERATIONS FACILITY (EOF) LAYOUT
- FIGURE 3.4 JOINT PUBLIC INFORMATION CENTER (JPIC) LAYOUT

SECTION 4.0

- FIGURE 4.1 PALISADES AREA MAP
- FIGURE 4.2 EOF/JPIC MAP

SECTION 6.0

- FIGURE 6.1 CONTROLLER ORGANIZATION

2.0 SCOPE AND OBJECTIVES

2.1 SCOPE

A simulated abnormal radiological incident at the Palisades Plant will escalate to a General Emergency and will involve planned response and recovery actions that include emergency classification, notification of offsite organizations and plant personnel, simulated actions to correct the emergency conditions and initiation of accident assessment and protective actions, as necessary, to cope with the accident. The emergency will then de-escalate, the recovery phase will be initiated and this will terminate the exercise. The exercise will simulate an emergency that results in offsite radiological releases which require response by offsite emergency response organizations.

2.2 OBJECTIVES

The major objective of the exercise is to evaluate the integrated capability and a major portion of the basic elements of the onsite and off-site emergency plans and the emergency response organizations. Specific objectives of the exercise to be demonstrated in various phases are listed below. The "free play" aspect of the exercise will be emphasized where practical. The exercise will demonstrate:

1. Adequacy of the Site Emergency Plan and the Site Emergency Plan Implementing Procedures to ensure compliance with 10 CFR 50.47 and NUREG-0654
2. Activation, staffing and operation of Emergency Response Facilities
3. Effective interface between CP Co Emergency Response Facilities in the assessment and mitigation of an accident, both operationally and radiologically
4. Effective transfer of responsibilities from the Control Room to the Technical Support Center to the Emergency Operations Facility
5. Recognition, classification and trending of emergency conditions
6. Site assembly and accountability of personnel within about 30 minutes
7. Notification of Federal, State, local, Corporate and plant personnel within specified time constraints
8. Coordination with State of Michigan and Nuclear Regulatory Commission emergency response organizations*

* Both the State and NRC will participate on a full-scale basis. The State will supply personnel in the EOF while the NRC will send players to all CPCo Emergency Response Facilities.

9. Access control of Emergency Response Facilities and the plant under emergency conditions
10. Mobilization and capabilities of onsite and offsite radiological monitoring teams
11. Ability to monitor, assess and trend radiological field data.
12. Ability to formulate timely and appropriate protective actions based on Protective Action Guides and postulated event conditions
13. Capability to collect and analyze a post-accident primary coolant sample
14. Ability of CP Co controller organization to effectively control and evaluate exercise performance.

3.0 EXERCISE INFORMATION

3.1 EXERCISE PARTICIPANTS

The participants in the exercise will include the following:

1. Consumers Power Company (CP Co)
 - a. Control Room, TSC, OSC, EOF and JPIC personnel
 - b. Emergency Response Teams
 - (1) Onsite/offsite monitoring
 - (2) Emergency maintenance
 - (3) Security force
 - (4) Post-accident sampling personnel
2. Agencies/Organization (Non-CP Co)
 - a. Federal
Nuclear Regulatory Commission (NRC)
 - b. State of Michigan
Michigan Department of State Police Emergency Services SIBO Division (MSP-ESD) (Lansing, Michigan), which coordinates all State activities.
 - c. Local
Allegan, Berrien and Van Buren Counties
 - d. Indiana and Michigan Electric Company will conduct an independent review of CP Co emergency program.

3.2 EXERCISE ORGANIZATION

The exercise organization for this exercise will consist of the Exercise Coordinator, controllers, players and observers.

The Exercise Coordinator will coordinate exercise preparations including the development of the scenario and controller input messages. He will control all aspects of the conduct of the exercise.

Controllers are Consumers Power (CP Co) or other qualified personnel who may be selected to deliver "exercise messages" to designated players at various times and places during the exercise; inject or deliver additional messages to initiate the appropriate player response and keep the

exercise action moving according to the scenario and exercise objectives; observe and evaluate the exercise at their assigned locations; and submit written recommendations on corrective actions to the Exercise Coordinator prior to the scheduled critique. Controllers judge the effectiveness of selected organizations, personnel, functions and activities in response to the simulated emergency situation. Selection of controllers is based on their expertise and qualifications to evaluate an assigned activity or area. They will evaluate exercise performance on the basis of standards or requirements contained in the SEP, SEP Implementing Procedures and exercise messages. They will take steps, whenever possible, to collect data on the time and motion aspects of the activity observed for postexercise use in designating and implementing system improvements. Section 6.0, Controller Information, provides evaluation guidance. Controllers will be identified by wearing "controller" armbands.

The Players include Palisades, General Office and other CP Co personnel assigned to perform emergency functions, as described in the SEP and SEP Implementing Procedures. Players from offsite organizations include personnel from Allegan, Berrien and Van Buren Counties, the State of Michigan and the Nuclear Regulatory Commission (NRC).

The success of the exercise is largely dependent upon player reaction, player knowledge of the SEP and SEP Implementing Procedures, and an understanding of the exercise objectives. A set of hypothetical initial conditions will be provided to players at the time the exercise begins. Thereafter, most of the elements of the exercise play will be introduced through the use of scenario messages. Players are responsible for initiating actions during the exercise in accordance with SEP Implementing Procedures and other Operating Procedures, as appropriate. Players will advise controllers prior to performing required emergency actions during simulated activities to ensure that credit for actions is given. Players are instructed not to be excessively concerned with the mechanics of the exercise scenario. Additionally, the exercise is a training vehicle for CP Co personnel functioning in a simulated emergency environment. Players may suggest improvements based on their response during the exercise and submit them to the appropriate controller at the conclusion of the exercise. Players will be identified by wearing "player" armbands.

Observers from CP Co and other organizations may be authorized to participate in the exercise. They will be provided with orientation information and appropriate exercise publications. Observer activity will be limited solely to observation. Observers will be identified by wearing "observer" armbands.

3.3 EMERGENCY RESPONSE FACILITIES

During the exercise, several facilities will be activated for the simulated emergency situation to manage, assess and support emergency response.

1. Control Room (CR)

The CR contains instrumentation for monitoring and controlling the plant operating and safety systems. Emergency response measures will be exercised from the CR under the direction of the Site Emergency Director (Shift Engineer, until relieved by the Plant General Manager or designee).

2. Technical Support Center (TSC)

When emergency conditions escalate to an Alert status or higher, coordination for emergency response will shift from the Control Room to the TSC, located inside the Protected Area (see Figure 3.1). The Plant General Manager or his designee relieves the Shift Engineer as Site Emergency Director and directs activities from the TSC. The TSC is the location from which technical management personnel utilize information on plant status provided in the TSC to support actions being performed in the Control Room. The TSC serves as the primary communication source to the NRC, OSC, EOF and offsite agencies, and will perform the functions of the EOF until the EOF is fully activated. The NRC will supply representatives to the TSC.

3. Operational Support Center (OSC)

The OSC provides a location where emergency response teams can be assembled and coordinated during an emergency (see Figure 3.2). The OSC will be activated for emergency conditions classified as an Alert or higher, and may be activated for an Unusual Event at the discretion of the Site Emergency Director.

4. Emergency Operations Facility (EOF)

The EOF, located in the South Haven Conference Center, 9.1 miles from the plant (see Figure 3.4), will be staffed for emergency conditions classified as a Site Area Emergency or General Emergency. The EOF is the command post for coordination of response measures with offsite organizations, assessment of radiological and environmental conditions, determination of recommended protective actions for the public, and management of recovery operations under the direction of the Recovery Manager. The NRC and State of Michigan will send representatives to the EOF.

5. Joint Public Information Center (JPIC)

The JPIC, located at the Lake Michigan Community College (see Figure 3.5), provides coordinated releases of news and information to the news media, general public, CP Co employees and special interest groups. The JPIC is staffed by CP Co, local, State and Federal officials, and will be activated for emergency conditions classified as a Site Area Emergency or General Emergency, or upon declaration of a Disaster by the Governor.

3.4 EXERCISE CONDUCT

The exercise will simulate a radiological incident at the Palisades Plant which will escalate to a General Emergency.

Emergency response actions during the simulated emergency will include: recognition and reclassification of emergency conditions; assessment of onsite/offsite radiological consequences; notification and mobilization of emergency response organizations; implementation of in-plant corrective actions; activation/operation of emergency response facilities and equipment; preparation of reports, messages and record keeping; and recommendation of protective actions. (See Figure 3.10 for Emergency Organization Interfaces.)

The conduct of the exercise will demonstrate the effectiveness of selected organizations, personnel, functions and the SEP and SEP Implementing Procedures. The simulated emergency will then de-escalate. The Recovery Phase will be initiated and demonstrated administratively before the exercise is terminated.

Controllers will be stationed in the CR, OSC, TSC and EOF. Controllers will issue exercise messages and contingency messages, as necessary, to ensure that the exercise objectives are met.

The CR will be the central point for organization of exercise messages and is the key to ensuring that the exercise progresses on schedule (see Figure 3.7). Simulated plant parameters will be provided to the Control Room operators using plant data and status sheets. Since it is required that the emergency escalate to the General Emergency level in order to exercise offsite activities, it may be necessary to postulate low-probability situations. The operators should accept the exercise messages as written. If corrective actions are postulated that would terminate the exercise prematurely, they should be brought to the attention of the Lead Controller, who may elect to negate those actions, so that the exercise will progress as designed.

The TSC will be the coordination point for onsite emergency response activities. TSC personnel will also coordinate offsite emergency response activities until activation of the EOF. TSC and EOF personnel (see Figures 3.8 and 3.9) will be aware that offsite activities are to be exercised and that it may be necessary to postulate low-probability situations to ensure that various aspects of the onsite and offsite emergency response organizations are tested. TSC and EOF personnel will accept exercise messages as written. If corrective actions are postulated that would terminate the exercise prematurely, they should be brought to the attention of the Lead Controller, who may elect to negate those actions so that the exercise will progress as designed.

All players are expected to demonstrate "free play" during the exercise to the extent practical. Notifications of supervisors, Plant Management and offsite agencies should be made in accordance with the SEP

Implementing Procedures. The scenario is designed to activate and test onsite and offsite emergency response capabilities.

3.5 EVALUATION AND CRITIQUE

The exercise will be graded by controllers who are qualified to assess the activity in their assigned locations. Controllers will grade exercise performance on the basis of requirements contained in the SEP and SEP Implementing Procedures. Controllers will prepare evaluations and forward recommendations on corrective actions to the Exercise Coordinator.

After the exercise is completed, the Exercise Coordinator will conduct a postexercise critique, which includes CP Co and NRC representatives. Deficiencies in the SEP, the SEP Implementing Procedures, or facilities and equipment will be identified through the critique process. The deficiencies will be documented by the Exercise Coordinator and corrected by assigned individuals.




FIGURE 3.1

OPERATIONAL SUPPORT CENTER




FIGURE 3.2

PALISADES EOF




FIGURE 3.3




FIGURE 3.4

5.0 REFERENCES/ABBREVIATIONS/DEFINITIONS

5.1 REFERENCES

1. Palisades Site Emergency Plan (SEP) - Consumers Power Company
2. Site Emergency Plan Implementing Procedures
3. State of Michigan Emergency Preparedness Plan
4. Allegan County Emergency Services Plan
5. Berrien County Emergency Operations Plan
6. Van Buren County Emergency Operations Plan
7. 10 CFR Part 5047 and 10 CFR Part 50, Appendix E
8. NUREG-0654 FEMA-REP-1, Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants
9. NUREG-0696, Functional Criteria for Emergency Response Facilities
10. 44 CFR 350.9, Federal Emergency Management Agency Emergency Planning Requirements

5.2 LIST OF ABBREVIATIONS

- CP Co - Consumers Power Company
- CR - Control Room
- DOE - Department of Energy
- EAL - Emergency Action Level
- EMD - Emergency Management Division
- ENS - Emergency Notification System
- EOC - Emergency Operations Center
- EOF - Emergency Operations Facility
- EPA - Environmental Protection Agency
- EPZ - Emergency Planning Zone
- ERF - Emergency Response Facility
- FEMA - Federal Emergency Management Agency

FRRP - Federal Radiological Response Plan
INPO - Institute of Nuclear Power Operations
JPIC - Joint Public Information Center
MEPP - Michigan Emergency Preparedness Plan
MSP-EMD - Michigan Department of State Police - Emergency Management Division
NRC - Nuclear Regulatory Commission
OSC - Operational Support Center
PASH - Post-Accident Sample Monitoring System
PRC - Plant Review Committee
SED - Site Emergency Director
SEP - Site Emergency Plan
TSC - Technical Support Center

5.3 DEFINITIONS

Activated - Status of an Emergency Response Facility following decision to staff it, but prior to being operational.

Alert - Events are in progress or have occurred which involve an actual or potential degradation of the level of safety of the plant.

Assessment Actions - Actions taken during or after an accident to obtain and process information to implement emergency measures.

Control Room (CR) - Onsite location from which the reactor is controlled, and from which initial emergency direction and control is given. The CR is located in the Auxiliary Building.

Controller - Exercise member designated to pass scenario messages to players, resolve scenario discrepancies, supervise and evaluate action of the players.

Emergency Action Levels (EALs) - Specified threshold conditions for initiating emergency measures.

Emergency Operations Center (EOC) - Emergency Response Facility from which government officials exercise direction and control in an emergency.

Emergency Operations Facility (EOF) - Emergency Response Facility from which the offsite emergency support activities are coordinated and overall emergency management provided.

Emergency Planning Zones (EPZs) - Areas in which protective actions may be implemented on the basis of plume or ingestion exposure to protect the public in the event of a nuclear plant accident.

Emergency Response Facility - Any of several onsite and offsite centers which are activated to coordinate emergency actions. These include the Control Room, Technical Support Center, Operational Support Center, Emergency Operations Facility, Joint Public Information Center, and State and local Emergency Operations Centers.

Exclusion Area - The area surrounding the plant in which CP Co has the authority to determine all activities, including exclusion or removal of persons and property from the area during accident conditions.

Exercise - An event which tests the overall functions and capabilities of organizations involved in responding to an emergency situation. An exercise simulates an emergency that results in offsite radiological releases which require response by offsite authorities.

General Emergency - Events are in progress or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity.

Ingestion Exposure Pathway - Area within 50 miles of the Palisades Plant, 30 miles at Big Rock. Planning based on exposure from ingestion of contaminated water or foods, such as milk or fresh vegetables. The time of potential exposure could range in length from hours to months.

Joint Public Information Center (JPIC) - An offsite emergency response facility which is staffed by CP Co, local, State, NRC and FEMA officials. The JPIC provides coordinated releases of news and information to the news media, public, CP Co employees, and special interest groups.

Observer - An individual from Consumers Power, other utilities, local/State/Federal government, and/or other organizations, who is authorized to observe an exercise.

Offsite - All land and water areas outside the owner-controlled area.

On-Scene State Emergency Operations Center (OSEOC) - An offsite emergency response facility which accommodates State personnel who coordinate State and direct local emergency response.

Onsite - All land and water areas within the owner-controlled area, use of which must be authorized by CP Co.

Operational - Status of an Emergency Response Facility following assumption of intended functions and responsibilities.

Operational Support Center (OSC) - An onsite Emergency Response Facility which provides a location where emergency response teams are assembled and coordinated during an emergency. The OSC is located in the machine shop/lunchroom area of the Administration and Services Building.

Owner-Controlled Area - The area around the plant that is owned and the access controlled by CP Co.

Participant - An individual who has part in an exercise as an evaluator, controller, player or observer.

Players - Exercise participants who are assigned to perform functions of the emergency response organization, as described in the SEP and SEP Implementing Procedures.

Plume Exposure Pathway - Planning based on (1) whole body external exposure to gamma radiation from the plume and from deposited material, and (2) inhalation exposure from the passing radioactive plume. The time of potential exposure could range from hours to days.

Protected Area - The fenced area immediately surrounding the Palisades Plant, access to which is controlled in accordance with the Site Security Plan.

Protective Actions - Measures taken to prevent or minimize radiological exposure.

Protective Action Guides (PAGs) - Predetermined limits of projected or actual radiological dose which warrant issuance of protective action recommendations.

Radiological Monitoring Teams - Two-person teams responsible for monitoring radiation levels in the environment.

Site Area Emergency - Events are in progress or have occurred which involve actual or likely major failures of plant functions needed for protection of the public. Any releases of radioactive material are not expected to exceed Protective Action Guide (PAG) exposure levels, except within the site boundary.

Site Emergency Director - Plant Manager or designated alternate who is responsible for all onsite actions during an emergency.

Technical Support Center (TSC) - An onsite Emergency Response Facility outside the Control Room which accommodates personnel who will provide Plant Management and technical support to plant operation personnel during an emergency.

Unusual Event - Events which are in progress or have occurred which indicate a potential degradation of the level of safety of the plant.

6.0 CONTROLLER INFORMATION

6.1 CONTROLLER ORGANIZATION(1)

1. Exercise Coordinator

- a. Approves major deviations from exercise scenario.
- b. Approves exercise termination.
- c. Conducts the preexercise controller briefing.
- d. Conducts the postexercise NRC/CP Co critique.

2. Lead Onsite Controller

- a. Approves deviations from exercise scenario.
- b. Conducts the postexercise CP Co critique.

3. Lead Facility Controller

- a. Conducts postexercise facility critique.
- b. Addresses all scenario-related questions from controllers/players.
- c. Presents facility observation in both CP Co and NRC/CP Co critiques.

4. Controller

- a. Evaluates player performance at assigned location.
- b. Refers player inquiries on scenario/response activities to Lead Facility Controller.
- c. Distributes scenario messages and data sheets to players assigned.
- d. Presents observations orally during facility critique and submits written summary to Lead Facility Controller.

6.2 CONTROLLER CONDUCT

1. Controllers will report to assigned locations prior to exercise activity in assigned area.

(1)An organizational diagram is provided in Figure 6.1.

2. Lead Controllers will test communications between facilities prior to exercise commencement.
3. All controllers will comply with Lead Controller/Exercise Coordinator instructions.
4. Each controller shall be provided a copy of the exercise manual. Each shall be familiar with the general sequence of events and with scenario specifics directly related to area controlled. Each should be familiar with exercise objectives.
5. Controllers shall not prompt players on proper course of action. Players are to exercise judgement in determining appropriate actions and resolving problems.
6. Selected controllers will be assigned to distribute scenario messages and data sheets. No other individuals shall release scenario information to players unless authorized by Facility Lead Controller.
7. Each controller shall:
 - a. Evaluate player performance based on personal expertise and guidelines provided in Sections 6.3-6.10.
 - b. Submit a written summary of observations to the Lead Facility Controller at the conclusion of the exercise.
8. Each Lead Controller shall submit all Controller summaries of observations to the Exercise Coordinator.

6.3 CONTROL ROOM EVALUATION GUIDANCE

1. Activation

- a. Were emergency response teams (if applicable) activated at the appropriate time?
 - (1) Fire brigade
 - (2) Emergency maintenance team
 - (3) Onsite monitoring team
 - (4) Offsite monitoring team
- b. Were emergency OSC and TSC put on standby or activated at the appropriate times?

2. Procedures

- a. Were Control Room staff members familiar with appropriate emergency procedures?
- b. Did the Shift Supervisor (acting as SED) perform or ensure the performance of notifications?
- c. Did the Shift Supervisor (acting as SED) focus on the overall control of emergency response?
- d. Was adequate consideration given to the decision to authorize emergency radiation exposure in excess of normal 10 CFR 20 limits?
- e. Did the Shift Supervisor (acting as SED) adequately supervise and coordinate onsite emergency response activities?
- f. Were plant damage and hazardous conditions adequately assessed?
- g. Were plant personnel kept informed concerning the plant radiological conditions?
- h. Did the Shift Supervisor ensure that the actions of off normal and Emergency Operating Procedures were performed?
- i. Were notifications made in a timely manner?
- j. Was the emergency classified correctly and promptly?
- k. Were dose assessment and projections performed?
- l. Were onsite protective/corrective actions considered/ordered at the appropriate times?
- m. Were radiological assessment and offsite protective action recommendations performed?
- n. Were personnel exposure records maintained?
- o. Was record keeping performing timely and accurately.
- p. Was documentation properly controlled?
- q. Was the transfer of emergency response functions to the TSC performed?
- r. Were emergency fire/medical services (if appropriate) requested at the appropriate time?

- s. Was Security notified of:
 - (1) Emergency classification
 - (2) Support organizations reporting onsite
 - (3) Number of personnel and vehicles reporting onsite
 - (4) Owner-controlled access gate to be used
 - (5) Scene of the emergency
- t. Was emergency classification:
 - (1) Reviewed at frequent intervals.
 - (2) Upgraded at appropriate time.
- u. Were dose assessment personnel familiar with dose assessment methods and procedures?
- v. Was adequate consideration given to personnel safety?
- w. Was emergency information promptly and correctly assessed?

3. Communications

- a. Were communications equipment tested and operable?
- b. Was a sufficient number of communicators available to support communications demand?
- c. Were correct communications procedures and techniques utilized?
- d. Was the information flow between the Control Room staff adequate?
- e. Was the information flow between the emergency response facilities adequate?
- f. Were offsite plant, corporate and government notifications, and information updates performed?
- g. Was appropriate information requested in a timely manner by the Shift Supervisor?

4. Equipment

- a. Were Control Room supplies adequately stocked?

- b. Were Control Room staff members familiar with emergency equipment which they were responsible for operating?

6.4 OPERATIONS SUPPORT CENTER EVALUATION GUIDANCE

1. Activation

- a. Time of arrival for:
 - (1) OSC Director
 - (2) Chemistry Supervisor
 - (3) Rad Pro Supervisor
- b. Time (NA if team not activated at OSC):
 - (1) Emergency maintenance team
 - (2) Onsite monitoring team
 - (3) Offsite monitoring team
- c. Did the OSC Director inform the SED that the OSC was activated?
- d. Were additional support personnel available in the OSC to support the designated emergency response team personnel?

2. Procedures

- a. Were OSC personnel familiar with the OSC activation procedure?
- b. Was an individual assigned to perform radiological surveys in the OSC?
- c. Were communications tested?
- d. Were OSC personnel familiar with their duties and responsibilities?
- e. Was adequate consideration given to personnel exposure control?
- f. Was adequate consideration given to personnel safety?
- g. Was backup assistance requested at the appropriate time?

3. Communications

- a. Was the OSC Director briefed by the SED or a designee?

- b. Were correct communications procedures and techniques utilized?
- c. Was the OSC Director kept informed by the OSC personnel?
- d. Did the OSC Director keep the SED informed?
- e. Did the OSC Director brief the OSC personnel on the emergency conditions?
- f. Was the information flow between the OSC staff adequate?
- g. Was the information flow to other emergency response facilities adequate?

4. Equipment

- a. Was appropriate protective equipment used?
- b. Was the emergency equipment in the OSC in operable condition?
- c. Were special tools available or obtained in a timely manner?

6.5 EMERGENCY MAINTENANCE TEAM EVALUATION GUIDANCE

- 1. At what time was the emergency maintenance team notified?
- 2. How much time elapsed between the time the team was dispatched until the team arrived at the scene?
- 3. At what time were emergency repairs completed?

4. Organization

- a. Did the OSC Supervisor brief Maintenance?
- b. Did the OSC Assistant Supervisor, Maintenance, brief the team members on the information received from the OSC Supervisor?
- c. Were potential causes of the problem identified?
- d. Did planning provide a systematic approach to finding the problem and then correcting it?

5. Equipment and Documentation

- a. Was the necessary equipment for each team member available?
- b. Were reference documents available to team members?
- c. Was the Plant Engineering Technician utilized properly in obtaining necessary reference documentation and information?

d. Were procedures (maintenance, tag out, etc) utilized properly?

6. Radiological Controls

- a. Were team members briefed on potential radiological hazards?
- b. Were quarterly exposure records available and used in determining stay times?
- c. Were necessary surveys taken for access to affected area?

7. Communications

- a. Was the OSC Supervisor kept adequately informed by the OSC Assistant Supervisor, Maintenance?
 - (1) Frequency
 - (2) Information content
- b. Were communications (face to face and radio) adequate?

8. General

- a. Was damage assessment performed quickly and properly?
- b. Did team members periodically check their pocket dosimeters?
- c. Were team members aware of and did they check for potential hazards?
- d. Were repairs conducted quickly and, where applicable, per procedure?
- e. Was equipment tagged out as necessary?

6.6 FIRE BRIGADE EVALUATION GUIDANCE

1. Activation

- a. Was the alarm promptly and accurately sounded?
- b. Was the Fire Brigade promptly notified and dispatched?
- c. Did the Fire Brigade Leader assemble and brief the Brigade?
- d. Was Fire Brigade staffing adequate?
- e. Did Brigade members arrive on scene promptly?
- f. Did personnel arrive properly equipped - ready for duties?

- g. Was Health Physics support adequate?
- h. Was first-aid assistance available, if necessary?

2. Procedures

- a. Did personnel know and carry out proper fire fighting tactics and strategy?
- b. Did Fire Brigade Leader exercise direction and control?
- c. Were fire fighting procedures available and followed?
- d. Was adequate consideration given to personnel safety?
- e. Was offsite fire fighting assistance requested at the appropriate time, if necessary.
- f. Were the efforts of the Fire Brigade and offsite Fire Department adequately coordinated?
- g. Was Security notified that offsite fire fighting assistance was requested?
- h. Were responding offsite Fire Department personnel admitted to the site properly (ie, issued dosimetry and logged in) and in a timely manner?

3. Communications

- a. Was adequate communications equipment available (ie, radios or accessible/operable plant communications equipment)?
- b. Were correct communications procedures and techniques used?
- c. Was the Plant Supervisor/Site Emergency Director kept informed?

4. Equipment

- a. Was appropriate protective equipment used?
- b. Was appropriate fire fighting equipment used?
- c. Was the equipment used during Fire Brigade operations in operable condition?
- d. Were special tools available or obtained in a timely manner, if necessary?

6.7 ONSITE/OFFSITE MONITORING TEAM EVALUATION GUIDANCE

1. Activation

- a. Time team left assembly point.
- b. Time the first survey results were reported.
- c. Was a member designated as the Team Leader?
- d. Did the OSC Director brief the teams?
- e. Did the members arrive at the scene properly equipped?

2. Procedures

- a. Did members use the appropriate procedures?
- b. Did the Team Leader exercise direction and control?
- c. Was adequate consideration given to personnel exposure control?
- d. Were the appropriate radiological surveys/samples performed?
- e. Were survey records and maps accurately maintained?
- f. Were proper radiological control practices used?
- g. Were personnel checked for contamination before they left a controlled area?
- h. Were survey/sample results accurately and promptly reported?
- i. Were survey meters checked?
- j. Were air samples saved and identified correctly?
- k. Was the airflow direction properly indicated on iodine cartridges?
- l. Was personnel dosimetry checked frequently?
- m. Were proper decontamination methods used?

3. Communications

- a. Was adequate communications equipment available?
- b. Was an individual designated as communicator?

- c. Were correct communications procedures and techniques used?
- d. Were information updates frequent enough?

4. Equipment

- a. Were emergency equipment kits available at the scene?
- b. Were emergency equipments kits inventoried?
- c. Were emergency equipment kits completely and adequately stocked?
- d. Were the items in the emergency equipment kits usable/operable?
- e. Was damaged/missing equipment repaired/replaced, as appropriate?
- f. Were missing or deficient items reported to appropriate personnel?

5. For Onsite Teams Only

- a. Were other emergency response team members at the scene apprised of the radiological conditions.
- b. Did team members properly coordinate with other emergency response teams?
- c. Did team members appropriately identify themselves to other emergency response teams?
- d. Was the SED/OSC Director kept informed?

6. For Offsite Teams Only

- a. Time environmental samples were delivered to the EOF.
- b. Was transportation readily available to all activated teams?
- c. Was the EOF kept informed of team operations and survey/sample results?
- d. Were the proper techniques for approaching and tracking the plume utilized?
- e. Were team members proficient in utilizing the Environmental Monitoring Mapping System?
- f. Were TLDs and environmental samples identified properly?

g. Were environmental samples checked for gross contamination?

6.8 TECHNICAL SUPPORT CENTER EVALUATION GUIDANCE

1. Activation

a. Time TSC Staff Arrived

- (1) Site Emergency Director
- (2) Tech Group Leader
- (3) Chem/Health Physics Group Leader
- (4) Communications Group Leader
- (5) Maintenance Support Group Leader
- (6) Administrative Support Group Leader

b. Time TSC Fully Functional

c. Were emergency response teams activated at the appropriate time?

- (1) Fire Brigade
- (2) Emergency maintenance team
- (3) Onsite monitoring team
- (4) Offsite monitoring team

d. Was the EOF put on standby/activated at the appropriate time?

2. Procedures

a. Was the radiation level in the TSC checked?

b. Was the airborne radioactivity level in the TSC checked?

c. Were TSC staff members familiar with appropriate emergency procedures?

d. Did the SED perform or ensure the performance of notifications?

e. Did the SED focus the overall control of emergency response?

f. Was adequate consideration given to the decision to authorize emergency radiation exposure in excess of normal 10 CFR 20 limits?

- g. Did the SED adequately supervise and coordinate TSC activities?
- h. Did the Tech Group Leader adequately assess plant damage and make appropriate and timely recommendations?
- i. Did the HP Group keep the TSC staff informed concerning the radiological environment?
- j. Were radiological assessment and offsite protective action recommendations performed?
- k. Were personnel exposure records maintained?
- l. Was record keeping performed timely and accurately?
- m. Was documentation properly controlled?
- n. Was a contamination control station established in the TSC?
- o. Were TSC status boards maintained?
- p. Was the transfer of TSC functions to other emergency response facilities performed?
- q. Was Security notified of:
 - (1) Emergency classification
 - (2) Supporting organization reporting onsite
 - (3) Number of personnel and vehicles reporting onsite
 - (4) Owner-controlled access gate to be used
 - (5) Scene of the emergency
- r. Was emergency classification:
 - (1) Reviewed at frequent intervals.
 - (2) Upgraded at appropriate time.
- s. Were dose assessment personnel familiar with dose assessment methods and procedures?
- t. Was adequate consideration given to personnel safety?
- u. Were onsite protective/corrective actions considered/ordered at the appropriate times?
- v. Was emergency information promptly and correctly assessed?

3. Communications

- a. Were communications equipment tested and operable?
- b. Was a sufficient number of communicators available to support communications demand?
- c. Were correct communications procedures and techniques utilized?
- d. Was the information flow between the TSC staff adequate?
- e. Was the information flow between the emergency response facilities adequate?
- f. Were offsite plant, corporate and government notifications and information updates performed?

4. Equipment

- a. Were TSC supplies adequately stocked?
- b. Were TSC staff members familiar with TSC equipment which they were responsible for operating?

6.9 EMERGENCY OPERATIONS FACILITY EVALUATION GUIDANCE

1. Activation

- a. Time of Staff Arrival
 - (1) Emergency Officer
 - (2) Director
 - (3) Administrator
 - (4) Secretarial/Clerical Support Team Leader
 - (5) Communications Support Team Leader
 - (6) Reactor Engineering Support Team Leader
 - (7) Health Physics Support Team Leader
 - (8) Plant Support Team Leader
 - (9) Public Affairs Support Team Leader
 - (10) Logistics Support Team Leader
- b. Time fully functional

- c. Was EOF activated at the appropriate time?
- d. Did EOF activate sufficient team members to man the facility?
- e. Was the EOF set up for operation within sixty (60) minutes?

2. Procedures

- a. Were staff members familiar with the appropriate Emergency Plan Implementing Procedures?
- b. Was the transfer of emergency response functions from the TSC to EOF performed adequately?
- c. Did the Emergency Officer assure use of full resources of CP Co and external organizations for the emergency response?
- d. Were Assistance Request Checklists used to request assistance from other organizations when applicable?
- e. Did the EOF Director adequately supervisor and coordinate activities?
- f. Did the Engineering Support Team Leader adequately review all engineering recommendations and calculations made?
- g. Were offsite radiological assessments and protective action recommendations performed?
- h. Did the Health Physics Support Team Leader keep the Director apprised of the radiological consequences and assessments during the emergency?
- i. Were emergency support services requested at the appropriate time?
- j. Was record keeping performed timely and accurately?
- k. Was documentation properly controlled?
- l. Were status boards maintained current?
- m. Was the emergency classification:
 - (1) Reviewed at frequent intervals.
 - (2) Upgraded at the appropriate time.
 - (3) Downgraded at the appropriate time.
- n. Were dose assessment personnel familiar with dose assessment methods and procedures and the available data?

- o. Was adequate consideration given to personnel safety?
- p. Was emergency information promptly and correctly assessed?

3. Communications

- a. Was communications equipment tested and operable?
- b. Was a sufficient number of communicators available to support the communications demand?
- c. Were correct communications procedures and techniques utilized?
- d. Was the information flow between EOF staff adequate?
- e. Was the information flow between emergency response facilities adequate?
- f. Were offsite corporate, government, and industry notifications and information updates performed?
- g. Was appropriate information requested by EOF personnel in a timely manner?
- h. Was the information exchange with the Site Emergency Director adequate?

4. Equipment

- a. Was equipment tested to be operational, as applicable.
- b. Were staff members familiar with the equipment which they were responsible for operating?
- c. Were EOF supplies adequately stocked?

6.10 JOINT PUBLIC INFORMATION CENTER EVALUATION GUIDANCE

1. Activation

- a. Time JPIC Director arrived
- b. Time communications manned
- c. Time JPIC fully functional
- d. Was the JPIC activated at the appropriate time?

2. Procedures

- a. Were JPIC staff members familiar with JPIC Operating Guidelines and Procedures?
- b. Did the JPIC Director maintain overall control of information released to the media (public) through the JPIC?
- c. Was the dissemination of information to the media adequate?
- d. Was rumor control in the JPIC adequate?
- e. Did the JPIC Director ensure smooth operation of the JPIC-EOF communications link and that the media services were properly handled?
- f. Were news releases prepared?
- g. Were news releases approved prior to release?
- h. Was the media briefing schedule adequate?
- i. Was security enforced properly at the JPIC?
- j. Was record keeping performed?
- k. Was documentation properly controlled?
- l. Were JPIC status boards maintained?

3. Communications

- a. Was communications equipment tested and operable?
- b. Was a sufficient number of communicators available to support communications demand?
- c. Were correct communications procedures and techniques utilized?

4. Equipment

- a. Were JPIC supplies adequately stocked?
- b. Was JPIC equipment tested to be operational, as applicable?
- c. Were JPIC staff members familiar with the equipment which they were responsible for operating?
- d. Was sufficient space and equipment provided for local, State, and Federal government officials and local media?

6.11 PASM EVALUATION GUIDANCE

1. O.S.C. Supervisor

- A. Were arrangement made for habitability surveys (PASM Room, Hot Lab, Hallways, etc.)?

- B. Were arrangement for special dosimetry (TLD's for wrists, ring TLD, etc.) made?

- C. Did the O.S.C. Supervisor have I&C jumper CV-1910 and CV-1911?

- D. Was Jackson Lab called into do the chloride analysis on the PASM sample?

- E. Were the technician kept informed and given directions?

- F. Were communication maintained between the O.S.C. Chemistry Supervisor and the technician?

2. Pre-sampling and Analysis Preparation

- A. Was the proper dress worn (Anti-C, gloves, fish skin, etc.)?

- B. Was dosimetry placed properly (wrists, finger, chest, etc.)?

- C. Did the technician know where to get SCBA, how to use it, and was technician SCBA training up-to-date?

- D. Did the Health Physics technician have the proper instrument (air sampler, survey meter, etc.)?

- E. Were all instrument calibration date checked, were they functional checked?

- F. Did the Health Physics technician given direction on dress requirements and radiation condition in the sampling and analysis area?

3. At the PASM Panel


- A. Was the proper pre-sampling preparation followed?
- B. Were purges and flushes times followed? Were proper flows used?
- C. Were valve lineup done properly?
- D. Were all recording taken (temperature pressure, time, etc.)?
- E. Were the proper samples obtained?
- F. Did the equipment function properly (PASM panel, lab instruments)?
- G. Were the technician aware of dose rate and stay times? Did they read their dosimeters?
- H. Did they undress properly? Did they frisk upon leaving?
- I. Did the technician keep the O.S.C. Supervisor informed?

- J. Was ALARA followed?
- K. Was there to much simulation?
- L. Did the Health Physics technician calculate dose rate and stay times?
- M. Did the Health Physics technician take radiation reading of samples and panel during sample collection?
- N. Did the Health Physics technician identify boundary?

4. A. Was the proper shielding used?
- B. Was ALARA used?
- C. Was there a sample storage area?
- D. Were samples disposed of properly?
- E. Did analysis compared to NSSS?
- F. Was proper dress used?
- G. Was the three hours sampling and analysis time met?
- H. Were samples labeled (date, time, etc.)?
- I. Was the proper data recorded (sample results, functional check, etc.)?

- J. Did the technician read their dosimeters?
- K. Did Health Physics technician calculate dose rate and stay times?
- L. Were general area survey up dated? Were air samples taken?
- M. Were the technician given direction by the O.S.C. Chemistry Supervisor?

PALEX 86
CONTROLLER
ORGANIZATION



NOTE: Lead controllers evaluate direction and control.

*Lead On-site Controller

FIGURE 6.1

7.0 EXERCISE SCHEDULE

August 18, 1986

1400 NRC entrance meeting attended by CP Co lead facility controllers
and scenario writers

August 19, 1986

0815 Initial conditions provided to players

8045 First exercise message

1400-1600 Exercise ends; CP Co facility critiques immediately follow.

August 20, 1986

0900 CP Co lead controller critique

1300 CP Co formal critique/NRC exit comments

8.0 NARRATIVE

The plant is at full power, 98-100%, at the middle of core life. Bus 13 and 14 are cross-tied in preparation for resetting the "taps" on station power transformer 13. Bus 77 and 78 are also cross-tied as the supply breaker to transformer 13 also feeds transformer 77. Boric Acid pump P-56A will not run due to solidified boric acid. Spray pump P-54A has been disassembled following a seal failure. HPSI motor-operated valve MO-3007 is out of service and blocked open. Service water pump P-7A basket strainer is clogged with debris and marine life causing intermittent HI-DP alarm.

It is partly cloudy and cool. Forecasts call for a clearing trend with a 40% chance of showers in the morning.

At 0845, primary coolant pump P-50B shears, stopping the impeller. In the subsequent reactor trip, Control Rod 34 fails to insert. It remains fully withdrawn and fuel damage occurs. The primary coolant pump failure was chosen to provide a single initiation which could fail two fission product barriers.

Following the turbine trip, both diesel generators start. One trips immediately on overcurrent.

A loose section of Bus 1C enclosure cabinet is jarred by cycling breakers during fast transfer and falls against the bus bars causing both phase-to-phase and phase-to-ground faults. The following equipment is lost: Auxiliary feedwater pump P-8A, LPSI pump P-67B, Service Water Pump P-7B, HPSI pump P-66B, Containment Spray Pumps P-52A and C, Station Power Transformers 11, 13 and 19, and the Meteorological Tower.

The primary coolant pump failure was chosen to provide a single initiation which could fail two fission product barriers.

The failure of Bus 1C removes any possibility of operating the train of Emergency Core Cooling Systems powered by that bus, irrespective of diesel generator operability or availability of offsite power. Lost are the two additional spray pumps, the effective containment air cooler, and the operable boric acid pump. Thus, containment pressure will increase with even a moderate primary coolant system leak and no method of boration is available from the control room.

The Site Emergency Director (SED) may immediately elect to declare an Unusual Event based on the existence of plant conditions which warrant increased awareness of plant staff or due to an abnormal trip.

At 0855, the failed fuel monitor responds to fuel damage. The SED may elect to classify the situation as an Alert based on "coolant pump seizure leading to fuel failure." He may elect to wait for confirmation via sample analysis.

At 0915, the upper seal on P-50B fails, leaking 60 gpm to containment. The situation warrants Alert declaration according to procedure. It is, however, possible that the SED may elect to escalate to Site Area Emergency based on loss of two fission product barriers.

The Alert (or higher) declaration brings personnel accountability and activation of the Technical Support Center (TSC) and Operational Support Center.

NARRATIVE

The Site Emergency Director may elect to activate the Emergency Operations Facility (EOF) at the Alert Classification.

Following completion of accountability, the Lead Security Controller, in conjunction with the Lead Onsite Controller, will initiate a security plan activation sequence. A bomb threat is received with bomb location and detonation time provided. The bomb will explode and result in damage to the warehouse. No personnel will be injured. The warehouse is outside the protected area. The bomb is not a threat to plant operation. No change in emergency classification is warranted by procedure.

At 1045, P-50B seal fails completely, resulting in a LOCA of 1000 gpm. If not already classified, a Site Area Emergency should be declared based on LOCA greater than charging pump capacity. As containment pressure increases rapidly, stack monitor readings climb accordingly. A release begins through faulty purge valves to the stack. Noting this, the SED may opt to declare a General Emergency. He may, however, elect to wait for confirmation by monitoring teams prior to declaration of General Emergency.

At 1050, Primary Coolant System pressure is dropping rapidly. The Safety Injection System actuates, resulting in E Bus opening and subsequent loss of Fire System Jockey pump and Fire Pump 9A, Pressurizer Heater Transformer 15, the meteorological tower, half of the lights and all wall outlets in the TSC. The computer used for dose calculations in the TSC is rendered inoperable. Based on anticipated operator actions, full TSC power should be restored in about five minutes.

Palisades personnel reporting to the EOF will be allowed access upon arrival. General Office Response Team (GORT) will be allowed entry sixty minutes after the decision to activate the EOF. Remaining General Office personnel will be granted access thirty minutes after arrival of the GORT.

There are three foreseen methods of terminating the release: 1) repair of spray pump P-54A, 2) repair of Bus 1C, 3) plugging of release path through purge line. In any case, the earliest permissible repair is at 1400. Items (1) and (2) employ spray pumps to condense steam, reduce pressure, and thereby halt the release. Item (3) requires physical plugging of the line. Reentry and recovery will be demonstrated administratively through development of a recovery plan.

The exercise, or portions thereof, will be terminated by the Exercise Coordinator in conjunction with Lead Controllers and State and Federal officials.

9.0 SEQUENCE OF EVENTS

<u>Drill Time</u>	<u>Clock Time</u>	<u>Event</u>
-0:30	0815	Initial Conditions - Normal Full Power Bus 13 and 14 cross-tied, Bus 77 and 78 cross-tied. Spray Pump A and Boric Acid Pump A out of service. Light NW breeze; 58°F Containment Air Temp 135°F
0:00	0845	Loss of Flow Reactor Trip P-50B shaft parted, Rod #34 stuck out Bus 1C lost - phase-to-phase fault P-50B lower and middle seals damaged Possible Unusual Event - Miscellaneous Category, SED Opinion
+0:10	0855	Failed Fuel Monitor Off Scale High First indication of fuel damage Possible Alert* - Coolant pump trip and failed fuel indication
+0:30	0915	P-50B Upper Seal Fails LOCA - 60 gpm to containment Alert conditions, 60 gpm LOCA. Possible Site Area Emergency** on loss of 2 of 3 fission product barriers.
+0:35	0920	Containment Humidity and Rad Levels Increase
+0:40	0925	Containment Hi Radiation/Containment Isolation
+0:50	0930	Containment Sump Hi Level Alarm
Variable	Variable	Bomb Threat & Ignition in Warehouse Will occur after Accountability at discretion of Lead Security Controller and Lead Onsite Controller

+2:00 1045 P-50B Vapor Seal Fails

SIS, CHP (no spray pumps)
LOCA - 1000 gpm to containment
Containment pressure increases
Stack monitor readings increase

Site Area Emergency condition, LOCA. General Emergency may be declared at SED discretion, must be declared when monitoring teams confirm magnitude of release.

+5:15 1400 Recovery (3 possible methods)

Bus 1C repair
Spray pump A repair
Plug release path

+5:30 1415 Release terminated

by +7:15 by 1600 Exercise terminated at discretion of Exercise Coordinator.

-
- * TSC is staffed at Alert Classification, EOF may be activated at discretion of SED.
- ** EOF is activated at Site Area Emergency declaration.

Scenario No: PALEX-86

Time = 0815

Message No: 1

T = -30

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Initial Conditions Sheet and Data Sheets

Message: Announce the following over the Plant's Public Address System:

"Attention all personnel. The annual emergency exercise will commence shortly. All announcements related to the exercise will be preceded and followed by the statement, 'This is a Drill.' Only drill participants are to respond to drill announcements."

For Controller Use Only

Controller Notes: See Controller Sheet for Initial Conditions

Action Expected: Operators should familiarize themselves with the simulated conditions as indicated on the data sheets.

PALISADES SEP EVALUATED EXERCISE

INITIAL CONDITIONS

1. The plant is at full power, 98% to 100% power, at middle of core life. (5.8 GWD/MTU)
2. The following operating conditions exist:
 - a. Bus 13 and Bus 14 are cross-tied in preparation for resetting the "taps" on station power transformer 13. Work has not started.
 1. 2400 Volt breaker 152-110, the supply to transformers 13 and 77, is racked out and red tagged.
 2. 480 Volt breaker 52-1302, the supply to Bus 13 from transformer 13, is racked out and red tagged.
 - b. Bus 77 and Bus 78 are cross-tied since the supply breaker to transformer 13 also feeds transformer 77.
 1. 480 Volt breaker 52-7701, the supply to Bus 77 from transformer 77, is racked out and red tagged.
 - c. Boric Acid Pump P-56A will not run.
 1. It is thought to be bound-up with solidified boric acid.
 2. Its breaker is open and caution tagged. Work order written, but not yet processed.
 3. It was declared "INOPERABLE" yesterday at 0103 hours.
 - d. Spray Pump P-54A is out of service.
 1. The pump is disassembled following a seal failure.
 2. The manufacturer's representative is due in tomorrow.
 3. She is bring an improved design seal with her.
 4. The pump was declared inoperable two days ago at 1317 hours.
 - e. HPSI MOV MO-3007 is out of service and blocked open.
 - f. The "SERVICE WATER PUMP P-7A BASKET STRAINER HI dP" alarm has been intermittent since last evening.
 1. A maintenance order has been written for cleaning the strainer.
 2. P-7B strainer was cleaned last week. It was partially plugged with debris and marine life.
 - (a) A DR has been written and is being resolved.
 - (b) The marine life may have been Asiatic Clams.

PALISADES SEP EVALUATED EXERCISE

INITIAL CONDITIONS (CONTINUED)

3. The following equipment is in service:
 - a. Service Water Pumps P-7A and B
 1. P-7C is in standby
 - b. CCW Pumps P-52A and B
 1. P-52C is in standby
 - c. Battery Chargers #1 and #2
 - d. Main Exhaust Fan V-6A
 - e. Switchyard Station Power Transformers #1 and #2

4. The meteorological conditions are as follows:
 - a. It is partly cloudy and cool with forecasts for a general clearing trend throughout the morning, but a 40% chance of rain. The Met Tower indicates the following (10 meters):
 1. Wind speed: 9.7 mph
 2. Wind direction: 320°
 3. Stability: C (based on dt)
 4. Ambient Temperature: 58°F

5. Primary and secondary chemistry is stable at the following conditions:
 - a. Primary System Chemistry
 1. ph: 6.7
 2. Boron: 500 ppm
 3. Dissolved O₂: less than .02 ppm
 4. H₂: 24.8 cc/Kg
 5. Total Beta Gamma activity: 1.58 uCi/ml
 6. Iodine Dose Equivalent: 2.5E-2 uci/mi
 7. Total PCS gas activity: 4.33 uCi/ml

 - b. Secondary System Chemistry
 1. Primary to secondary leak rate: .001 gpm
 2. Offgas Xe133: 2.95E-6 uci/ml
 3. Condenser Air in Leakage: 5.0 cfm
 4. A and B S/G Gross Gama activity: less than 5.6 E-6 uci/ml

 - c. For additional information, see data sheets in the Chemistry section.

LIMITING CONDITIONS FOR OPERATION

MESSAGE: 1

TIME= 0815

T= -30

SCENARIO PALEX 86

COMPONENT	INITIATED		FINISH BY		APPLICABLE TECH SPEC	COMMENTS
	DATE	TIME	DATE	TIME		
P-56A (Boric Acid Pump)	8/18/86	0103	----	----	3.2.3	No LCO as long as P-56B operable
P-54A (Cont Spray Pump)	8/17/86	1317	8/24/86	1317	3.4.1	
MO-3007 (HPSI Train 1)	1/1/86	0000	-----	-----	3.3	No LCO as long as valve blocked open

Message: 1

Time: 0815

T: -30 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A Run P-7B P-7C
CCW Pumps Run P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 O CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 O CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp 175 °F
Charging Line Temp 400 °F
Letdown Line Temp 230 °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 22 psi
(10) VCT Level 72 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow 36 GPM
(26) Charging Flow 40 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 2010 psia
(8) Pzr Level (R) LRC-0101A 57 %
LRC-0101B 57 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A P55B P55C
(6) PCPs Run P50A Run P50B Run P50C Run P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 562 °F
Loop 2 (TR-0121) 562 °F
(25) Reactor Power Level
NI-1 - cps NI-3 100 % NI-7 100 %
NI-2 - cps NI-4 100 % NI-8 100 %
NI-5 100 % NI-9 100 %
NI-6 100 % NI-10 100 %

C-01

MFP Suction Press 370 psig
MFP A Dsch Press 940 psig
MFP B Dsch Press 940 psig
AFW Pump 8C Amperes amps
AFW Pump 8C Disch Press psig
AFW Pump 8A Amperes amps
AFW Pump 8B Steam Press psig
AFW Pumps 8A & 8B Disch Press psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B P8C
Heater Drain Pumps Run P10A Run P10B
Condensate Pumps Run P2A Run P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 800
Net MW 760
(28) Control Rod Position
GP1 132 GP2 132 GP3 132 GP4 132
GP 5(P) 132 GP 6(A) 132 GP 7(B) 132
Stuck Rods Yes X No #
(4) Core Exit Temp 590 °F

C-13

CST Level (T-2) 80 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 0.3 psig
 (16) S/G A Compartment Temp 130 °F
 S/G A Compartment Humidity 0 %
 (16) S/G B Compartment Temp 135 °F
 S/G B Compartment Humidity 0 %
 (16) Dome Temp 140 °F
 (11) SIRWT Level 99 %
 (15) WR Containment Press (R) 15.0 psia
 (14) Containment Sump Level 0 %
 (14) Containment Water Level (R) 0 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS Yes X No

Panel K-13

(20) Containment High Pressure
 Yes X No
 (20) Containment High Radiation
 Yes X No

C-12

Conc. Boric Acid Tank Levels
 T53A 98 %
 T53B 98 %
 Reactor Vessel DP 48 psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 620 amps B 630 amps
 C 625 amps D 620 amps
 (6) PCS Flow 75 %
 (3) T_H Loop 1 587 °F
 Loop 2 587 °F
 (2) T_C Loop 1 537 °F
 Loop 2 537 °F
 T_C WR(R) Loop 1 535 °F
 Loop 2 535 °F
 (5) Subcooling 49 °F 600 psig
 (7) PCS WR Press (R) 2010 psia
 (7) PCS NR Press (R) - psia
 (20) S/G A Level WR 70 %
 (30) S/G A Level (R) 70 %
 (30) S/G A Press 700 psia
 S/G A Steam Flow (R) 5.6 X10⁶PPH
 S/G A Feed Flow (R) 5.6 X10⁶PPH
 (30) S/G B Level WR 70 %
 (30) S/G B Level (R) 70 %
 (30) S/G B Press 700 psia
 S/G B Steam Flow (R) 5.6 X10⁶PPH
 S/G B Feed Flow (R) 5.6 X10⁶PPH

C-11

(31) AFW Flow to SGA
 From P8A&B 0 gpm From P8C 0 gpm
 (31) AFW Flow to SGB
 From P8A&B 0 gpm From P8C 0 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 1 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2
 (32) IC Buss Volts 2400 Amps OK
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 .02 R/Hr RIA 1806 .02 R/Hr
 RIA 1807 0.2 R/Hr RIA 1808 0.1 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 1.01 R/Hr RIA 2322 1.01 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R - %
 AI 2401 L - %
 (30) Main Steam Gamma
 S/G A RIA 2324 40 cpm
 S/G B RIA 2323 30 cpm

Equipment Status:

1. Significant Equipment Outages (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or Outages

CONTROL ROOM ALARMS

MESSAGE: 1

TIME: 0815

T= -30

SCENARIO: PALEX 86

C-13 PANEL



K-11

K-13

K-11#32 "Service Water Pump
P-7A Basket Str
HI DP"

C-12 PANEL



K-07

K-09

C-11 PANEL



K-01

K-03

K-05

INITIAL CONDITIONS INFORMATION

FOR CONTROLLER USE ONLY

The following information will be supplied to the players at the players' request:

1. Containment Temperatures one week ago:

Reactor Cavity:	125
Dome:	128
S/G A Compt:	120
S/G B Compt:	122

2. Outside air temperatures for the past week have been relatively constant.

Scenario No: PALEX-86

Time = 0845

Message No: 2

T = 0

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets and Alarm Sheets

Message:

For Controller Use Only

Controller Notes: See 0845 Controller Notes sheet.

Action Expected: See 0845 Summary of Expected Action sheet.

0845 CONTROLLER NOTESI. CONTROL ROOM CONTROLLER NOTES

1. Loss of flow trip all four channels (due to P-50B shaft failure)
 - a. Flow instrument readings imply no flow in Loop 1B
 - 1) FI 0102A-D: approx 55
 - 2) PDI 01122AA-AD: approx 39
 - 3) PDI 0112BA-BD: approx 6
 - 4) PDI 0122CA-CD: approx 54
 - 5) PDI 0122DA-DD: approx 55

a) Readings 2 - 5 Controller supplied on request.
 - b. Primary Coolant Pump P-50B ammeter reads lower than others.
 - 1) P-50A: 635A
 - 2) P-50B: 165A
 - 3) P-50C: 630A
 - 4) P-50D: 625A
 - c. P-50B seal conditioning are abnormal
 - 1) Leak off flow is 3 gmp
 - 2) Middle seal inlet pressure is 2K psi
 - 3) Upper seal inlet pressure is oscillating 800-1600 psi
 - 4) Vapor seal inlet pressure is 100 psi
 - 5) Temperature indications are normal
 - 6) Items 2 - 5 are Controller supplied on request.
 - d. The following control room alarms come in:
 - 1) PCP VIBRATION ALERT
 - 2) PCP VIBRATION DANGER
 - 3) PCP P-50B SEAL PRESSURE OFF NORMAL
 - 4) PCP P-50B SEAL HX HI TEMP LEAKAGE HI FLOW
 - e. The P-50B vibration monitor reads full scale at 30 mils.
 - 1) Item e is Controller supplied on request.
2. Control Rod 34 fails to insert.
 - a. All other rods insert normally.
 - b. Primary and secondary rod position show Rod 34 fully withdrawn.
 - c. Neither rod rundown circuit nor operator actions (if taken) cause insertion.
 - d. The following alarms occur:
 - 1) ROD POSITION 4" DEVIATION
 - 2) ROD POSITION 8" DEVIATION

0845 CONTROLLER NOTES (CONTINUED)II. CONTROL ROOM CONTROLLER AND BUS 1C CONTROLLER NOTES:

1. Turbine and generator trip
 - a. Normal trips
 - b. Both diesel generators start
 - c. Diesel Generator 1-1 trips immediately
 - 1) The Diesel Generator breaker 152-107 has tripped on overcurrent.
 2. Lockout relay 187-107 picks up on an overcurrent trip and must be reset before engine will start or breaker will reclose.
 - a) To reset relay 187-107 either the control room or local hand switch for breaker 152-107 must be put to TRIP.
 3. Controller is at Bus 1C to inform operator that there are targets showing on two phases of the time-overcurrent relay.
 4. The following control room alarms are on:
 - a) D/G BREAKER 152-107 TRIP
 - b) D/G 1-1 START SIGNAL BLOCKED
 - c) D/G 1-1 and 1-2 OVERLOAD
2. Bus 1C is lost
 - a. A loose section of the bus enclosure cabinet is jarred by the cycling of the 152-105 and 152-106 breakers during fast transfer and falls against the bus bars. This causes both phase-to-phase and phase-to-ground faults.
 - b. Startup power breaker 152-106 has tripped.
 - 1) Two phases show flags on the time-overcurrent relays.
 - 2) Controller at Bus 1C to inform operator of indications.
 - 3) Breaker will close if tried from control room, but will trip again.
 - c. The following major equipment is lost with Bus 1C
 - 1) AFW P-8A
 - 2) LPSI P-67B
 - 3) Service Water P-7B
 - 4) HPSI P-66B
 - 5) CCW P-52A and C
 - 6) Spray P-54B and C
 - 7) Station Power Transformer 11
 - a) Bus 11 (can be X-tied to Bus 12)
 - 1) Chg P-55C
 - 2) Instrument Air Comp C-2A and C
 - 3) Main Exh Fan V-6B
 - 4) Cont Recirc Fan V-4A

0845 CONTROLLER NOTES (CONTINUED)

- c. One boric pump is powered from Bus 1C, the other was made inoperable in the initial conditions; both boric acid gravity valves are powered from Bus 1C.
- 1) Failure of a control rod to insert on a scram requires emergency boration. No method of boration is available from the control room.
 - 2) An operator will have to be sent to open the gravity feed valves by hand.
 - 3) This pump failure may provide an additional maintenance project.

0845 CONTROLLER NOTES (CONTINUED)

8. Station Power Transformer 19
 - a) MCC 1
 - 1) Battery Chargers #1 and #4
 - 2) HPSI MOVs 3007, 3009, 3011, and 3013
 - 3) LPSI MOVs 3008 and 3010
 - 4) Boric Acid Pump P-56B
 - a) P-56A is inoperative, see Initial Conditions
 - 5) Boric Acid Gravity Feed Valves MO 2169 and 2170
 - 6) VCT outlet valve MO-2087
 - 7) Emergency Bearing Oil Pump P-27
 - 8) Emergency Air Side Backup P-24
 - 9) Normal supply to Y-01
 - a) Y-01 auto transfers to MCC 3, fed from Bus 13, which has been tied to Bus 14. See Initial Conditions.
 - b) Control room HVAC, one train
9. Switchyard Transformer #2 and 240V Bus #2
 - a) Meteorological Tower lost
 - b) Can cross-connect to Bus #1 at Switchyard.
10. Station Power Transformer 13
 - a) Electrically isolated and tagged, See Initial Conditions.

III. GENERAL INFORMATION

1. The PCP shaft failure event was chosen to provide a single initiator which could, by only slightly stretching the facts, fail two of the three boundaries to fission product release.
2. The failure of Bus 1C due to a phase-to-phase fault removes any possibility of operating the train of ECCS powered by that bus (regardless of diesel generator operability or off-site power availability).
 - a. Two containment spray pumps are powered from Bus 1C, the third was made inoperable in the initial conditions.
 - 1) The inoperable spray pump provides a mechanical maintenance project.
 - b. One containment air cooler is powered from Bus 1C. It may be recovered with Bus 11. The running coolers are assumed to be ineffective due to fouling by Asiatic Clams.
 - 1) Evidenced by high containment temperature and service water basket strainer note in initial data.
 - 2) With neither sprays nor air coolers, containment pressure will increase with even a moderate PCS leak.
 - a) A leak through faulty purge valve is assumed.
 - 3) Repair of the inoperable spray pump or repair of Bus 1C, allowing use of the other spray pumps, will provide a method to quickly reduce containment pressure.

0845 SUMMARY OF EXPECTED ACTIONS

1. Normal Post Trip actions
2. Trip P-50B
 - a. Vibration reading alone requires trip
3. Attempt to insert Rod #34
 - a. Manual trip
 - 1) Two places
 - b. Rod drop switches
 - c. Manual insertion
 - d. Open RPS breakers 42-1 and 42-2 in Cable Spreading Room
4. Investigate loss of Bus 1C
 - a. Controller stationed at Bus 1C with information
 - b. Some possible actions (1, 2 and 3 are futile)
 - 1) Try to reclose startup power breaker 152-106
 - a) Breaker would not close unless the "ITC switch" has been placed to CUT OUT, AND the generator trip relay 386-C has been reset.
 - b) If closed, prior to repairing bus fault, the breaker would immediately trip on overcurrent.
 - 2) Try to use Diesel Generator 1-1.
 - a) Engine would not start until relay 187-107 is reset.
 - b) Breaker would immediately trip on overcurrent.
 - 3) Backfeed Bus 1C through main transformers.
 - a) Generator disconnect links must be opened which would take a minimum of three hours.
 - b) If station power breaker 152-105 is closed, it would immediately trip on overcurrent. (Unless bus has been repaired).
 - 4) Inspect and repair bus work
 - a) After repair of fault, any of the above 3 methods will restore power to the bus and allow use of two spray pumps.
 - b) Earliest permissible repair 1410 hours.
5. Send operator to open Boric Acid Gravity Feed valves.
 - a. Stuck rod on trip requires emergency boration.
 - b. Both Boric Acid pumps disabled.
 - c. Power to gravity valves lost with Bus 1C.

0845 SUMMARY OF EXPECTED ACTIONS (CONTINUED)

6. Cross tie Bus 11 to Bus 12
 - a. Regain vital loads
 - 1) Chg P-55C
 - 2) Instrument Air Comp C-2A and C
 - 3) Exh Fan V-6B
 - 4) Containment Fan V-4A
 - b. Regain "Left" half of TSC lighting.
7. Send operator to switchyard to cross tie 240V Bus 2 to Bus 1
 - a. Regain Meteorological Tower
8. Switch from battery charger #1 to #3.

C-13

C-12

C-04

CST Level (T-2) 80 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 0.3 psig
 (16) S/G A Compartment Temp 130 °F
 S/G A Compartment Humidity 0 %
 (16) S/G B Compartment Temp 135 °F
 S/G B Compartment Humidity 0 %
 (16) Dome Temp 140 °F
 (11) SIRWT Level 99 %
 (15) WR Containment Press (R) 15.0 psia
 (14) Containment Sump Level 0 %
 (14) Containment Water Level (R) 0 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS Yes X No

PCP Current
 A 635 amps B 165 amps
 C 630 amps D 625 amps
 (6) PCS Flow 55 %
 (3) T_H Loop 1 ↓ 558 °F
 Loop 2 ↓ 558 °F
 (2) T_C Loop 1 ↓ 538 °F
 Loop 2 ↓ 538 °F
 T_C WR(R) Loop 1 ↓ 535 °F
 Loop 2 ↓ 535 °F
 (5) Subcooling 70 °F
 (7) PCS WR Press (R) 1900 psia
 (7) PCS NR Press (R) psia
 (30) S/G A Level WR ↓ 25 %
 (30) S/G A Level (R) ↓ 25 %
 (30) S/G A Press 900 psia
 S/G A Steam Flow (R) X10⁶PPH
 S/G A Feed Flow (R) X10⁶PPH
 (30) S/G B Level WR ↓ 25 %
 (30) S/G B Level (R) ↓ 25 %
 (30) S/G B Press 900 psia
 S/G B Steam Flow (R) X10⁶PPH
 S/G B Feed Flow (R) X10⁶PPH

(32) D/G 1-1 Trip D/G 1-2 Run
 (32) 1C Buss Volts 0 Amps 0
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 .02 R/Hr RIA 1806 .02 R/Hr
 RIA 1807 0.2 R/Hr RIA 1808 0.1 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 1.01 R/Hr RIA 2322 1.01 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R %
 AI 2401 L %
 (30) Main Steam Gamma
 S/G A RIA 2324 40 cpm
 S/G B RIA 2323 30 cpm

Panel K-13

(20) Containment High Pressure
 Yes X No
 (20) Containment High Radiation
 Yes X No

C-12

C-11

Conc. Boric Acid Tank Levels
 T53A 99 %
 T53B 99 %
 Reactor Vessel DP 40 psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

(31) AFW Flow to SGA
 From P8A&B gpm From P8C 150 gpm
 (31) AFW Flow to SGB
 From P8A&B gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 3 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

Equipment Status:
 1. Significant Equipment Outages
 (Inoperable Equipment)
 2. Surveillance Due or in Progress
 3. Abnormal Electrical Lineups or
 Outages

Message: 2

Time: 0845

T: 0 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp 175 °F
Charging Line Temp 400 °F
Letdown Line Temp 230 °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 22 psi
(10) VCT Level 71 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 93 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) ↓1900 psia
(8) Pzr Level (R) LRC-0101A ↓40 %
LRC-0101B ↓40 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B P55C
(6) PCPs Run P50A Run P50B Run P50C Run P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 548 °F ↓
Loop 2 (TR-0121) 548 °F ↓
(25) Reactor Power Level
NI-1 - cps NI-3 10 % NI-7 10 %
NI-2 - cps NI-4 10 % NI-8 10 %
NI-5 10 % NI-9 10 %
NI-6 10 % NI-10 10 %
All ↓

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps Run P10A Run P10B
Condensate Pumps Run P2A Run P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 132 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34

(4) Core Exit Temp 560 °F

CONTROL ROOM ALARMS

MESSAGE: 2

TIME: 0845

T= 0

SCENARIO: PALEX 86

C-13 PANEL



K-11

K-13

C-12 PANEL



K-07

K-09

K-07 #53 & 54 - "Pzr Press Off-Norm
Hi-Lo"
K-07 #61 - "Pzr Level Hi-Lo"
K-09 #11 - "Rod 4 Inch Deviation"
K-09 #12 - "Rod 8 Inch Deviation"
K-09 #13 - "PCP Vibration Alert"
K-09 #14 - "PCP Vibration Danger"
K-09 #18 - "Auto Rod Withdrawal
Prohibit"
K-09 #23,24,29,30,35,36,41 & 42 -
"Rod PPDIL/PDIL Alarms"
K-09 #48 - "Dropped Rod"
K-09 #50 - "P-50B Seal Press Off Normal"
K-09 #56 - "P-50B Seal HX Hi Temp/
Leakage Hi Flow"
K-09 #62 - "E-50A Low Level"
K-09 #64 - "E-50B Low Level"
K-09 #68 - "#1 Rx Reg Gross Deviation"
K-09 #69 - "#2 Rx Reg Gross Deviation"
K-09 #72 - "Reactor Trip"

C-11 PANEL



K-01

K-03

K-05

K-01 #1 - "Turbine Trip"
K-01 #12 - "Relatch Turbine and Vacuum"
K-03 #1 - "Generator Trip"
K-03 #7 - "Generator ACB Trip"
K-03 #33 - "SWYD 125VDC/240VAC Trouble"
K-05 #3 - "Bus 1C BRK 152-105 Trip"
K-05 #6 - "SWYD BRK 152-108 Trip"
K-05 #9 - "Bus 1C BKR 152-106 Trip"
K-05 #15 - "Bus 1C/1D Undervoltage"
K-05 #18 - "Bus 1C/1D/1E Ground"
K-05 #22 - "Bus Fail to Transfer"
K-05 #41 - "Battery Charger Power Off"
K-05 #49 - "D/G KBR 152-107 Trip"
K-05 #51 - "D/G 1-1 Trouble"
K-05 #52 - "D/G 1-1 Start Signal
Blocked"
K-05 #53 - "D/G's 1-1/1-2 Overload"

CONTROL ROOM ALARMS

MESSAGE: 2

TIME: 0845

T= 0

SCENARIO: PALEX 86

C-06 PANEL



A	B	C	D
RACK	RACK	RACK	RACK

Rack A

#3 - "Low Flow Channel Trip"
#7 - "Low Flow Channel
Pretrip"

Rack C

#7 - "Dropped Rod"

C-106 PANEL



K-33

C-126 PANEL



K-35

C-11A PANEL



K-02

Scenario No: PALEX-86

Time = 0845

Message No: 2a

T = 0

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Operators and/or Maintenance Repair Team

Simulated Plant Conditions: Unable to operate Bus 1C

Message: Start-up power breaker 152-106 and diesel generator breaker 152-107 have tripped.

Two phases show flags on the time-overcurrent relays.

For Controller Use Only

Controller Notes: A loose section of the bus enclosure cabinet was jarred by the cycling of the 152-105 and 152-106 breakers during fast transfer and falls against the bus bars. This causes both phase-to-phase and phase-to-ground faults.

Action Expected: Investigate loss of Bus 1C.
Some possible actions (1, 2 and 3 are futile).

1. Try to reclose start-up power breaker 152-106.
 - a. Breaker would not close unless the "ITC switch" has been placed to CUT OUT, AND the generator trip relay 386-C has been reset.
 - b. If closed, prior to repairing bus fault, the breaker would immediately trip on overcurrent.
2. Try to use Diesel Generator 1-1.
 - a. Engine would not start until relay 187-107 is reset.
 - b. Breaker would immediately trip on overcurrent.
3. Backfeed Bus 1C through main transformers.
 - a. Generator disconnect links must be opened which would take a minimum of three hours.
 - b. If station power breaker 152-105 is closed, it would immediately trip on overcurrent (unless bus has been repaired).
4. Inspect and repair bus work.
 - a. After repair of fault, any of the above three methods will restore power to the bus and allow use of two spray pumps.

Earliest permissible repair, 1410 hours.

Scenario No: PALEX-86

Time = 0845

Message No: 2b

T = 0

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Maintenance Teams

Simulated Plant Conditions: Spray pump P-54A out of service

Message: As required by Controller either verbal or written

For Controller Use Only:

Controller Notes: Spray Pump P-54A is out of service.

1. The pump is disassembled following a seal failure.
2. The manufacturer's representative is due in tomorrow.
3. She is bringing an improved design seal with her.
4. The pump was declared inoperable two days ago at 1317 hours.

Action Expected:

1. Locate a spare seal using appropriate methods a spare seal from the Stockroom-simulate transporting to Safeguards Room.
2. Locate appropriate tools to effect repair (may already be at jobsite).
3. Simulate repair.
4. Cannot be repaired before 1410.

Parts Needs:

1. Seal stock No 37-44059

Scenario No: PALEX-86

Time = 0845

Message No: 2c

T = 0

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Maintenance Teams

Simulated Plant Conditions: Service water basket strainer P-7A high D/P.

Message: As required by Controller either verbal or written.

For Controller Use Only:

Controller Notes: The "SERVICE WATER PUMP P-7A BASKET STRAINER HI dP" alarm has been intermittent since last evening.

1. A maintenance order has been written for cleaning the strainer.
2. P-7B strainer was cleaned last week. It was partially plugged with debris and marine life.
 - a. A DR has been written and is being resolved.
 - b. The marine life may have been Asiatic Clams.

Action Expected:

1. If the Technical Support Center wants this work performed the maintenance teams shall perform all necessary steps to setup for basket strainer cleaning, ie, valving clearance, tools in area, etc.
2. Simulate the actual work of disassembly of strainer and valving.
3. This work will take two hours to complete.
4. Will require taking pump out of service resulting in less water to containment air coolers.

Scenario No: PALEX-86

Time = 0845

Message No: 2d

T = 0

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Maintenance Teams

Simulated Plant Conditions: Boric Acid Pump P-56A will not run

Message: As required by Controller either verbal or written

For Controller Use Only:

Controller Notes: Boric Acid Pump P-56A will not run.

1. It is thought to be bound up with solidified boric acid.
2. Its breaker is open and caution tagged. Work order written, but not yet processed.
3. It was declared "INOPERABLE" yesterday at 0103 hours.

- Action Expected:
1. Inspect and troubleshoot pump. (This may require Anti 'C's) depending on requirement for BA Room.
 2. Pump will have to be torn apart. (Simulate at site.)
 3. Involve Electrical and/or I&C to remove heat trace and instruments.
 4. Find spare pump (motor good, pump bad) using all appropriate methods.
 5. This pump will take eight hours to rebuild.

Scenario No: PALEX-86

Time = 0845

Message No: 2e

T = 0

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Maintenance Team

Simulated Plant Conditions: Control Rod No 34 stuck full out.

Message: As required by Controller either verbal or written.

For Controller Use Only:

Controller Notes: Control Rod No 34 fails to insert.

1. All other rods insert normally.
2. Primary and secondary rod position show Rod No 34 fully withdrawn.
3. Neither rod rundown circuit nor operator actions (if taken) cause insertion.
4. The following alarms occur:
 - a. ROD POSITION 4" DEVIATION
 - b. ROD POSITION 8" DEVIATION

Action Expected:

1. All attempts to insert this rod by maintenance teams fail.
2. This rod will be stuck for the duration of the scenario.
3. Possible action that may be demonstrated (simulate) to remove all power/or drive rod in from C-15 Panel.

Attempt to insert Rod No 34

- a. Manual trip
 - (1) Two places
- b. Rod drop switches
- c. Manual insertion
- d. Open RPS breakers 42-1 and 42-2 in Cable Spreading Room

Scenario No: PALEX-86

Time = 0855

Message No: 3

T = +10 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets and Alarm Sheet

Message:

For Controller Use Only

Controller Notes: Failed Fuel Monitor Responds to Fuel Damage

- A. Both gross Gamma and single channel go off scale high.
- B. NSSS sample panel area, high radiation.
- C. Letdown path and charging pump areas, high radiation.

Action Expected: A. Per fuel cladding failure procedure ONP 11.

- B. Possibly declare Alert prior to receipt of sample analysis results.

Message: 3

Time: 0855

T: 10 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps P-51A P-51B

Containment Cooler Recirc Fans

Run V1A Run V2A Run V3A V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp 175 °F
Charging Line Temp 400 °F
Letdown Line Temp 230 °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 18 psi
(10) VCT Level 48 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 93 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 1800 psia
(8) Pzr Level (R) LRC-0101A 36 %
LRC-0101B 36 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B P55C
(6) PCPs Run P50A P50B Run P50C Run P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{av} (R) Loop 1 (TR-0111) 532 °F
Loop 2 (TR-0121) 532 °F

(25) Reactor Power Level
NI-1 - cps NI-3 10⁻² % NI-7 - %
NI-2 - cps NI-4 10⁻² % NI-8 - %
NI-5 - % NI-9 - %
NI-6 - % NI-10 - %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Nct MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 132 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 535 °F

C-13

CST Level (T-2) 79 %

Instrument Air Press 105 psig

(15) Containment Building Press 0.3 psig

(16) S/G A Compartment Temp 130 °F

S/G A Compartment Humidity 0 %

(16) S/G B Compartment Temp 135 °F

S/G B Compartment Humidity 0 %

(16) Dome Temp 140 °F

(11) SIRWT Level 99 %

(15) WR Containment Press (R) 15.0 psia

(14) Containment Sump Level 0 %

(14) Containment Water Level (R) 0 %

(22) SI Tank Level (%) A 48 B 48 C 48 D 48

SI Tank Press (psig) A 210 B 210 C 210 D 210

(21) SIAS Yes X No

Panel K-13

(20) Containment High Pressure Yes X No

(20) Containment High Radiation Yes X No

C-12

Conc. Boric Acid Tank Levels

T53A 97 %

T53B 97 %

Reactor Vessel DP 40 psid

(12) PORV Discharge Temp 115 °F

(13) Pzr Safety Valve Dsch Temp

RV-1039 115 °F

RV-1040 115 °F

RV-1041 115 °F

C-12

PCP Current

A 635 amps B 0 amps

C 630 amps D 625 amps

(6) PCS Flow 55 %

(3) T_H Loop 1 532 °F

Loop 2 532 °F

(2) T_C Loop 1 532 °F

Loop 2 532 °F

T_C WR(R) Loop 1 530 °F

Loop 2 530 °F

(5) Subcooling 89 °F 900 psig

(7) PCS WR Press (R) 1800 psia

(7) PCS NR Press (R) psia

(30) S/G A Level WR 25 %

(30) S/G A Level (R) 25 %

(30) S/G A Press 900 psia

S/G A Steam Flow (R) X10⁶PPH

S/G A Feed Flow (R) X10⁶PPH

(30) S/G B Level WR 25 %

(30) S/G B Level (R) 25 %

(30) S/G B Press 900 psia

S/G B Steam Flow (R) X10⁶PPH

S/G B Feed Flow (R) X10⁶PPH

C-11

(31) AFW Flow to SGA

From P8A&B 0 gpm From P8C 150 gpm

(31) AFW Flow to SGB

From P8A&B 0 gpm From P8C 150 gpm

Condenser Vacuum (R) 27 in hg.

PCP A Leak-off Flow (R) 1 GPM

PCP B Leak-off Flow (R) 3 GPM

PCP C Leak-off Flow (R) 1 GPM

PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run

(32) 1C Buss Volts 0 Amps 0

(32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors

RIA 1805 .02 R/Hr RIA 1806 .02 R/Hr

RIA 1807 2.7 R/Hr RIA 1808 2.7 R/Hr

(17) High Range Containment Monitors

RIA 2321 1.01 R/Hr RIA 2322 1.01 R/Hr

(19) Containment H₂ Concentration

AI 2401 R %

AI 2401 L %

(30) Main Steam Gamma

S/G A RIA 2324 40 cpm

S/G B RIA 2323 30 cpm

Equipment Status:

1. Significant Equipment Outages (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or Outages

CONTROL ROOM ALARMS

MESSAGE: 3 TIME: 0855 T= +10 min SCENARIO: PALEX 86

C-13 PANEL



K-11

K-13

C-12 PANEL



K-07

K-09

K-07 #71 - "VCT Rad Monitor Hi
Radiation"

C-11 PANEL



K-01

K-03

K-05

Scenario No: PALEX-86

Time = 0900

Message No: 4 (Contingency Message)

T = 15 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions:

Message: A Reactor Operator has called and requested that Exhaust Fan V-6B and Charging Pump P-55C be returned to service immediately.

For Controller Use Only

Controller Notes: Submit this message only if action has not been initiated to cross tie Buses 11 and 12 which restores the following equipment:

- A. P-55C (Charging Pump)
- B. C-2A and C-2C (Instrument Air Compressors)
- C. V-6B (Main Exhaust Fan)
- D. V-4A (Containment Vent Fan)

Action Expected: Cross tie Buses 11 and 12.

Scenario No: PALEX-86

Time = 0905

Message No: 5

T = +20 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 5

Time: 0905

T: 20 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp 175 °F
Charging Line Temp 400 °F
Letdown Line Temp 230 °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 18 psi
(10) VCT Level 50 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow (Diverting) 40 GPM
(26) Charging Flow 93 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) ↑ 1900 psia
(8) Pzr Level (R) LRC-0101A 42 %
LRC-0101B 42 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B P55C
(6) PCPs Run P50A P50B Run P50C Run P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 532 °F
Loop 2 (TR-0121) 532 °F
(25) Reactor Power Level
NI-1 10⁴ cps NI-3 10⁻⁵ % NI-7 %
NI-2 10⁴ cps NI-4 10⁻⁵ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 132 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34

(4) Core Exit Temp 535 °F

C-13

CST Level (T-2) 78 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 0.3 psig
 (16) S/G A Compartment Temp 130 °F
 S/G A Compartment Humidity 0 %
 (16) S/G B Compartment Temp 135 °F
 S/G B Compartment Humidity 0 %
 (16) Dome Temp 140 °F
 (11) SIRWT Level 99 %
 (15) WR Containment Press (R) 15.0 psia
 (14) Containment Sump Level 0 %
 (14) Containment Water Level (R) 0 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) STIAS Yes X No

Panel K-13

(20) Containment High Pressure
 Yes X No
 (20) Containment High Radiation
 Yes X No

C-12

Conc. Boric Acid Tank Levels
 T53A 90 %
 T53B 90 %
 Reactor Vessel DP 40 psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 635 amps B 0 amps
 C 630 amps D 625 amps
 (6) PCS Flow 55 %
 (3) T_H Loop 1 532 °F
 Loop 2 532 °F
 (2) T_C Loop 1 532 °F
 Loop 2 532 °F
 T_C WR(R) Loop 1 530 °F
 Loop 2 530 °F
 (5) Subcooling 96 °F
 Loop 2 1000 psig
 (7) PCS WR Press (R) ↑1900 psia
 (7) PCS NR Press (R) ↑1900 psia
 (30) S/G A Level WR 26 %
 (30) S/G A Level (R) 26 %
 (30) S/G A Press 900 psia
 S/G A Steam Flow (R) - X10⁶PPH
 S/G A Feed Flow (R) - X10⁶PPH
 (30) S/G B Level WR 26 %
 (30) S/G B Level (R) 26 %
 (30) S/G B Press 900 psia
 S/G B Steam Flow (R) - X10⁶PPH
 S/G B Feed Flow (R) - X10⁶PPH

C-11

(31) AFW Flow to SGA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SCB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 3 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run
 (32) 1C Buss Volts 0 Amps 0
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 .02 R/Hr RIA 1806 .02 R/Hr
 RIA 1807 3.8 R/Hr RIA 1808 3.3 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 1.01 R/Hr RIA 2322 1.01 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R - %
 AI 2401 L - %
 (30) Main Steam Gamma
 S/G A RIA 2324 40 cpm
 S/G B RIA 2323 30 cpm

Equipment Status:

1. Significant Equipment Outages
 (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or Outages

Scenario No: PALEX-86

Time = 0915

Message No: 6

T = +30 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

1. P-50B upper seal fails, vapor seal is leaking to containment (60 gpm).
2. P-50B seal inlet pressures go to PCS pressure.
3. P-50B lower seal temperature is off scale high.
4. Primary Coolant drain tank level and temperature will start to increase slowly.
5. Pressurizer level is decreasing at approximately 1% every 6 minutes (assumes P-55A & B running, 40 gpm letdown, 60 gpm leak)

Action Expected:

- A. Per "Primary Coolant Leak" Procedure ONP 23.1
- B. Possible declaration of Site Area Emergency (SED opinion)

Message: 6

Time: 0915

T: 30 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp 175 °F
Charging Line Temp 400 °F
Letdown Line Temp 230 °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 18 psi
(10) VCT Level 52 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow (Diverting) 40 GPM
(26) Charging Flow 93 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 2010 psia
(8) Pzr Level (R) LRC-0101A 42 %
LRC-0101B 42 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B P55C
(6) PCPs Run P50A P50B Run P50C Run P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 532 °F
Loop 2 (TR-0121) 532 °F
(25) Reactor Power Level

NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 132 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 535 °F

C-13

CST Level (T-2) 77 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 0.3 psig
 (16) S/G A Compartment Temp 130 °F
 S/G A Compartment Humidity 0 %
 (16) S/G B Compartment Temp 135 °F
 S/G B Compartment Humidity 0 %
 (16) Dome Temp 140 °F
 (11) SIRWT Level 99 %
 (15) WR Containment Press (R) 15.0 psia
 (14) Containment Sump Level 0 %
 (14) Containment Water Level (R) 0 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS Yes X No

Panel K-13

(20) Containment High Pressure
 Yes X No
 (20) Containment High Radiation
 Yes X No

C-12

Conc. Boric Acid Tank Levels
 T53A 82 %
 T53B 82 %
 Reactor Vessel DP 40 psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 635 amps B 0 amps
 C 630 amps D 625 amps
 (6) PCS Flow 55 %
 (3) T_H Loop 1 532 °F
 Loop 2 532 °F
 (2) T_C Loop 1 532 °F
 Loop 2 532 °F
 T_C WR(R) Loop 1 530 °F
 Loop 2 530 °F
 (5) Subcooling 104 °F 1110 psig
 (7) PCS WR Press (R) 2010 psia
 (7) PCS NR Press (R) psia
 (30) S/G A Level WR 26 %
 (30) S/G A Level (R) 26 %
 (30) S/G A Press 900 psia
 S/G A Steam Flow (R) - X10⁶PPH
 S/G A Feed Flow (R) - X10⁶PPH
 (30) S/G B Level WR 26 %
 (30) S/G B Level (R) 26 %
 (30) S/G B Press 900 psia
 S/G B Steam Flow (R) - X10⁶PPH
 S/G B Feed Flow (R) - X10⁶PPH

C-11

(31) AFW Flow to SCA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SCB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 0 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run
 (32) 1C Buss Volts 0 Amps 0
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 .02 R/Hr RIA 1806 .02 R/Hr
 RIA 1807 4.3 R/Hr RIA 1808 3.8 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 1.01 R/Hr RIA 2322 1.01 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R - %
 AI 2401 L - %
 (30) Main Steam Gamma
 S/G A RIA 2324 40 cpm
 S/G B RIA 2323 30 cpm

Equipment Status:

1. Significant Equipment Outages
 (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or
 Outages

Scenario No: PALEX-86

Time = 0920

Message No: 7

T = +35 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

- Controller Notes:
- a. With letdown isolated, pZR level will increase at approximately $\frac{1}{2}\%$ per minute (assumes charging flow at approximately 93 gpm, leak from P-50B seal at approximately 60 gpm).
 - b. With letdown in service, pZR level will decrease approximately 1% every 6 minutes (same assumptions as (a) above plus 40 gpm letdown).

Action Expected: Per ONP 23.1.

Message: 7

Time: 0920

T: 35 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans

Run V1A Run V2A Run V3A Run V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp 175 °F
Charging Line Temp 400 °F
Letdown Line Temp 230 °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 19 psi
(10) VCT Level 53 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 93 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 2010 psia
(8) Pzr Level (R) LRC-0101A 43 %
LRC-0101B 43 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B P55C
(6) PCPs Run P50A P50B Run P50C Run P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 532 °F
Loop 2 (TR-0121) 532 °F

(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 132 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 535 °F

C-13

CST Level (T-2) 76 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 0.4 psig
 (16) S/G A Compartment Temp 132 °F
 S/G A Compartment Humidity 10 %
 (16) S/G B Compartment Temp 135 °F
 S/G B Compartment Humidity 0 %
 (16) Dome Temp 140 °F
 (11) SIRWT Level 99 %
 (15) WR Containment Press (R) 15.1 psia
 (14) Containment Sump Level 1 %
 (14) Containment Water Level (R) 0 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS Yes No X

Panel K-13

(20) Containment High Pressure
 Yes X No
 (20) Containment High Radiation
 Yes X No

C-12

Conc. Boric Acid Tank Levels
 T53A 79 %
 T53B 79 %
 Reactor Vessel DP 40 psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 635 amps B 0 amps
 C 630 amps D 625 amps
 (6) PCS Flow 55 %
 (3) T_H Loop 1 532 °F
 Loop 2 532 °F
 (2) T_C Loop 1 532 °F
 Loop 2 532 °F
 T_C WR(R) Loop 1 530 °F
 Loop 2 530 °F
 (5) Subcooling 104 °F
 (7) PCS WR Press (R) 2010 psia
 (7) PCS NR Press (R) - psia
 (30) S/G A Level WR 27 %
 (30) S/G A Level (R) 27 %
 (30) S/G A Press 900 psia
 S/G A Steam Flow (R) - X10⁶PPH
 S/G A Feed Flow (R) - X10⁶PPH
 (30) S/G B Level WR 27 %
 (30) S/G B Level (R) 27 %
 (30) S/G B Press 900 psia
 S/G B Steam Flow (R) - X10⁶PPH
 S/G B Feed Flow (R) - X10⁶PPH

C-11

(31) AFW Flow to SGA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SCB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 0 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run
 (32) 1C Buss Volts 0 Amps 0
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 .02 R/Hr RIA 1806 .02 R/Hr
 RIA 1807 4.5 R/Hr RIA 1808 4 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 1.01 R/Hr RIA 2322 1.01 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R - %
 AI 2401 L - %
 (30) Main Steam Gamma
 S/G A RIA 2324 40 cpm
 S/G B RIA 2323 30 cpm

Equipment Status:

1. Significant Equipment Outages (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or Outages

Scenario No: PALEX-86

Time = 0925

Message No: 8

T = +40 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets and Alarm Sheet

Message:

For Controller Use Only

Controller Notes: a. Sample line valves CV-1910 and CV-1911 will be closed by CHR signal. Will not be able to sample PCS until appropriate jumpers are placed per EI-7.1.

b. Letwodn also isolated on CHR signal.

Action Expected: Verify CHR isolation.

Message: 8

Time: 0925

T: 40 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans

Run V1A Run V2A Run V3A Run V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 150 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 19 psi
(10) VCT Level 53 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 93 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 2010 psia
(8) Pzr Level (R) LRC-0101A 45 %
LRC-0101B 45 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B P55C
(6) PCPs Run P50A P50B Run P50C Run P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 532 °F
Loop 2 (TR-0121) 532 °F

(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 132 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 535 °F

C-13

CST Level (T-2) 76 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 0.5 psig
 (16) S/G A Compartment Temp 136 °F
 S/G A Compartment Humidity 20 %
 (16) S/G B Compartment Temp 136 °F
 S/G B Compartment Humidity 5 %
 (16) Dome Temp 141 °F
 (11) SIRWT Level 99 %
 (15) WR Containment Press (R) 15.2 psia
 (14) Containment Sump Level 2 %
 (14) Containment Water Level (R) 0 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS Yes X No

Panel K-13

(20) Containment High Pressure
 Yes X No
 (20) Containment High Radiation
 X Yes No

C-12

Conc. Boric Acid Tank Levels
 T53A 71 %
 T53B 71 %
 Reactor Vessel DP 40 psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 535 amps B 0 amps
 C 630 amps D 625 amps
 (6) PCS Flow 55 %
 (3) T_H Loop 1 532 °F
 Loop 2 532 °F
 (2) T_C Loop 1 532 °F
 Loop 2 532 °F
 T_C WR(R) Loop 1 530 °F
 Loop 2 530 °F
 (5) Subcooling 104 °F
 (7) PCS WR Press (R) 2010 psia
 (7) PCS NR Press (R) psia
 (30) S/G A Level WR 27 %
 (30) S/G A Level (R) 27 %
 (30) S/G A Press 900 psia
 S/G A Steam Flow (R) X10⁶PPH
 S/G A Feed Flow (R) X10⁶PPH
 (30) S/G B Level WR 27 %
 (30) S/G B Level (R) 27 %
 (30) S/G B Press 900 psia
 S/G B Steam Flow (R) X10⁶PPH
 S/G B Feed Flow (R) X10⁶PPH

C-11

(31) AFW Flow to SCA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SCB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 0 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run
 (32) 1C Buss Volts 0 Amps 0
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 0.1 R/Hr RIA 1806 0.2 R/Hr
 RIA 1807 5 R/Hr RIA 1808 4.8 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 1.2 R/Hr RIA 2322 1.8 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R %
 AI 2401 L %
 (30) Main Steam Gamma
 S/G A RIA 2324 40 cpm
 S/G B RIA 2323 30 cpm

Equipment Status:

1. Significant Equipment Outages
(Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or Outages

CONTROL ROOM ALARMS

MESSAGE: 8 TIME: 0925 T= +40 min SCENARIO: PALEX 86

C-13 PANEL



K-11

K-13

K-11 #26 - "CIS Initiated"

K-13 #63 - "Containment Hi Radiation"

C-12 PANEL



K-07

K-09

C-11 PANEL




K-01

K-03

K-05

CONTROL ROOM ALARMS

MESSAGE: 9 TIME: 0930 T= +45 min SCENARIO: PALEX 86



Scenario No: PALEX-86

Time = 0930

Message No: 9

T = 45 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets and Alarm Sheet

Message:

For Controller Use Only

Controller Notes: Operators should be reducing PCS pressure (via normal pwr spray) in attempt to reduce leak rate out of P-50B seal. (Operators should block SIAS while pressure is being reduced).

Action Expected: The SED should classify an Alert based on 60 gpm LOCA.

Message: 9

Time: 0930

T: 45 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 150 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 19 psi
(10) VCT Level 54 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 93 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 1980 psia
(8) Pzr Level (R) LRC-0101A 47 %
LRC-0101B 47 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B P55C
(6) PCPs Run P50A P50B Run P50C Run P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 532 °F
Loop 2 (TR-0121) 532 °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 132 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 535 °F

C-13

CST Level (T-2) 75 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 0.6 psig
 (16) S/G A Compartment Temp 140 °F
 S/G A Compartment Humidity 30 %
 (16) S/G B Compartment Temp 137 °F
 S/G B Compartment Humidity 10 %
 (16) Dome Temp 142 °F
 (11) SIRWT Level 99 %
 (15) WR Containment Press (R) 15.3 psia
 (14) Containment Sump Level 4 %
 (14) Containment Water Level (R) 0 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS Yes X No

Panel K-13

(20) Containment High Pressure
 Yes X No
 (20) Containment High Radiation
 X Yes No

C-12

Conc. Boric Acid Tank Levels
 T53A 68 %
 T53B 68 %
 Reactor Vessel DP 40 psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 635 amps B 0 amps
 C 630 amps D 625 amps
 (6) PCS Flow 55 %
 (3) T_H Loop 1 532 °F
 Loop 2 532 °F
 (2) T_C Loop 1 532 °F
 Loop 2 532 °F
 T_C WR(R) Loop 1 530 °F
 Loop 2 530 °F
 (5) Subcooling 102 °F 1080 psig
 (7) PCS WR Press (R) 1980 psia
 (7) PCS NR Press (R) - psia
 (30) S/G A Level WR 28 %
 (30) S/G A Level (R) 28 %
 (30) S/G A Press 900 psia
 S/G A Steam Flow (R) - X10⁶PPH
 S/G A Feed Flow (R) - X10⁶PPH
 (30) S/G B Level WR 28 %
 (30) S/G B Level (R) 28 %
 (30) S/G B Press 900 psia
 S/G B Steam Flow (R) - X10⁶PPH
 S/G B Feed Flow (R) - X10⁶PPH

C-11

(31) AFW Flow to SGA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SGB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 0 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run
 (32) 1C Buss Volts 0 Amps 0
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 .15 R/Hr RIA 1806 .35 R/Hr
 RIA 1807 5.5 R/Hr RIA 1808 5 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 1.5 R/Hr RIA 2322 2.0 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R - %
 AI 2401 L - %
 (30) Main Steam Gamma
 S/G A RIA 2324 40 cpm
 S/G B RIA 2323 30 cpm

Equipment Status:

1. Significant Equipment Outages (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or Outages

THREAT REPORT GUIDE

INSTRUCTIONS: BE CALM. BE COURTEOUS. LISTEN, DO NOT INTERRUPT THE CALLER.
SIGNAL A SECOND PERSON TO LISTEN TO THE CONVERSATION, IF POSSIBLE.

Date 8/19/86 Time _____

Exact Words of Person Placing Call: There is a pipe bomb in the warehouse
set to go off in 15 minutes. I don't want anyone to get hurt except the
power company. I couldn't get one into the plant or else I would have
planted it there. (Then hung up)

SAMPLE QUESTIONS TO ASK:

Bomb Threats

1. When is the bomb going to explode? 15 minutes
2. Where is the bomb right now? Warehouse
3. What kind of a bomb is it? Pipe
4. What does it look like? _____
5. Why did you place the bomb? _____
6. How much explosive in the bomb? _____

Hostage/Kidnap/Extortion

1. Where is the person now? _____
2. When will he be released? _____
3. Who do you represent? _____
4. Where can you be contacted? _____
5. What do you want? _____

Scenario No: PALEX-86

Time = 0930

Message No: 10A

T = 45 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Property Protection Supervisor or Designate

Simulated Plant Conditions: Simulated call from switchboard/simulated device

Message: See attached

For Controller Use Only

Controller Notes: To be initiated by lead security controller in conjunction with lead onsite controller.

Action Expected:

- Procedures in SCP-1 should be followed.
- Building should be evacuated.
- Actions as determined by the PPS for owner controlled area bomb threat.

Threats of Attacks

1. What objective do you hope to gain? _____
 2. What is the size of the attack force? _____
 3. How do you plan to attack? _____
 4. What group do you represent? _____
 5. When will the attack take place? _____
-

TRY TO DETERMINE THE FOLLOWING (CIRCLE AS APPROPRIATE):

Caller's Identity: Male Female Adult Juvenile Age 30-40 Years

Voice: Loud Soft High Pitch Deep Raspy Pleasant

Intoxicated Other _____

Accent: Local Not Local Foreign Region

Speech: Fast Slow Distinct Distorted Stutter Nasal

Slurred Lisp

Language: Excellent Good Fair Poor Foul Other

Manner: Calm Angry Rational Irrational Coherent

Incoherent Deliberate Emotional Righteous Laughing

Intoxicated

Background Noises: Office Machines Factory Machines Bedlam Trains

Animals Music Quiet Voices Mixed

Airplanes Street Traffic Party Atmosphere

Scenario No: PALEX-86

Time = 0930

Message No: 10b

T = 45 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Site Emergency Director/Property Protection Supervisor

Simulated Plant Conditions:

Message: Do not perform a second accountability.

For Controller Use Only:

Controller Notes: This message will be issued only in the event that accountability is being ordered due to the bomb sequence.

Action Expected:

Scenario No: PALEX-86

Time = 0945

Message No: 10C

T = 1 hr

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Officers on Scene

Simulated Plant Conditions: Simulated explosion

Message: Device has exploded. Extensive damage to the west side of the warehouse.

- There is no fire
- There are no suspects

For Controller Use Only

Controller Notes: Security phase terminated upon discretion of lead security controller in conjunction with lead onsite controller.

Action Expected: Actions in SCP-8 should be followed.
Action as determined by the PPS for owner controlled area explosion.

Scenario No: PALEX-86

Time = 0945

Message No: 11

T = 1 hr

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 11

Time: 0945

T: 1 hr.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp - °F
Charging Line Temp 150 °F
Letdown Line Temp - °F
SDCS from PCS (R) - °F
SDCS to PCS (R) - °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 19 psi
(10) VCT Level 55 %
 PCP Control Bleedoff Press 80 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 93 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 1550 psia
(8) Pzr Level (R) LRC-0101A ↑ 55 %
 LRC-0101B ↑ 55 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
 Charging Pumps Run P55A Run P55B P55C
(6) PCPs Run P50A P50B Run P50C Run P50D
 Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 532 °F
 Loop 2 (TR-0121) 532 °F
(25) Reactor Power Level
 NI-1 10 cps NI-3 10⁻⁸ % NI-7 - %
 NI-2 10 cps NI-4 10⁻⁸ % NI-8 - %
 NI-5 - % NI-9 - %
 NI-6 - % NI-10 - %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
 GP1 0 GP2 0 GP3 132 GP4 0
 GP 5(P) 132 GP 6(A) 0 GP 7(B) 0
 Stuck Rods X Yes - No # 34
(4) Core Exit Temp 535 °F

C-13

CST Level (T-2)	<u>74</u> %
Instrument Air Press	<u>105</u> psig
(15) Containment Building Press	<u>0.7</u> psig
(16) S/G A Compartment Temp	<u>142</u> °F
S/G A Compartment Humidity	<u>50</u> %
(16) S/G B Compartment Temp	<u>139</u> °F
S/G B Compartment Humidity	<u>20</u> %
(16) Dome Temp	<u>145</u> °F
(11) SIRWT Level	<u>99</u> %
(15) WR Containment Press (R)	<u>15.4</u> psia
(14) Containment Sump Level	<u>7</u> %
(14) Containment Water Level (R)	<u>0</u> %
(22) SI Tank Level (%) A <u>48</u> B <u>48</u> C <u>48</u> D <u>48</u>	
SI Tank Press (psig) A <u>210</u> B <u>210</u> C <u>210</u> D <u>210</u>	
(21) SIAS ___ Yes <u>X</u> No	

Panel K-13

(20) Containment High Pressure	<u>___</u> Yes <u>X</u> No
(20) Containment High Radiation	<u>X</u> Yes <u>___</u> No

C-12

Conc. Boric Acid Tank Levels	
T53A	<u>57</u> %
T53B	<u>57</u> %
Reactor Vessel DP	<u>40</u> psid
(12) PORV Discharge Temp	<u>115</u> °F
(13) Pzr Safety Valve Dsch Temp	
RV-1039	<u>115</u> °F
RV-1040	<u>115</u> °F
RV-1041	<u>115</u> °F

C-12

PCP Current	
A <u>635</u> amps B <u>0</u> amps	
C <u>630</u> amps D <u>625</u> amps	
(6) PCS Flow	<u>55</u> %
(3) T _H Loop 1	<u>532</u> °F
Loop 2	<u>532</u> °F
(2) T _C Loop 1	<u>532</u> °F
Loop 2	<u>532</u> °F
T _C WR(R) Loop 1	<u>530</u> °F
Loop 2	<u>530</u> °F
(5) Subcooling <u>67</u> °F	<u>650</u> psig
(7) PCS WR Press (R)	<u>1550</u> psia
(7) PCS NR Press (R)	<u>___</u> psia
(30) S/G A Level WR	<u>28</u> %
(30) S/G A Level (R)	<u>28</u> %
(30) S/G A Press	<u>900</u> psia
S/G A Steam Flow (R)	<u>___</u> X10 ⁶ PPH
S/G A Feed Flow (R)	<u>___</u> X10 ⁶ PPH
(30) S/G B Level WR	<u>28</u> %
(30) S/G B Level (R)	<u>28</u> %
(30) S/G B Press	<u>900</u> psia
S/G B Steam Flow (R)	<u>___</u> X10 ⁶ PPH
S/G B Feed Flow (R)	<u>___</u> X10 ⁶ PPH

C-11

(31) AFW Flow to SGA	
From P8A&B <u>0</u> gpm From P8C <u>150</u> gpm	
(31) AFW Flow to SGB	
From P8A&B <u>0</u> gpm From P8C <u>150</u> gpm	
Condenser Vacuum (R)	<u>27</u> in hg.
PCP A Leak-off Flow (R)	<u>1</u> GPM
PCP B Leak-off Flow (R)	<u>0</u> GPM
PCP C Leak-off Flow (R)	<u>1</u> GPM
PCP D Leak-off Flow (R)	<u>1</u> GPM

C-04

(32) D/G 1-1 ___ D/G 1-2 <u>Run</u>	
(32) 1C Buss Volts <u>0</u> Aaps <u>0</u>	
(32) 1D Buss Volts <u>2400</u> Amps <u>OK</u>	

C-11 Back C-11A

(17) Containment Area Monitors	
RIA 1805 <u>.27</u> R/Hr RIA 1806 <u>.55</u> R/Hr	
RIA 1807 <u>7.5</u> R/Hr RIA 1808 <u>6.5</u> R/Hr	
(17) High Range Containment Monitors	
RIA 2321 <u>10</u> R/Hr RIA 2322 <u>16</u> R/Hr	
(19) Containment H ₂ Concentration	
AI 2401 R <u>___</u> %	
AI 2401 L <u>___</u> %	
(30) Main Steam Gamma	
S/G A RIA 2324 <u>40</u> cpm	
S/G B RIA 2323 <u>30</u> cpm	

Equipment Status:

- Significant Equipment Outages (Inoperable Equipment)
 - Surveillance Due or in Progress
 - Abnormal Electrical Lineups or Outages
-
-
-
-
-
-
-
-
-
-

Scenario No: PALEX-86

Time = 1000

Message No: 12

T = 1 hr 15 min
(or sooner if requested)

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Health Physics Team Leader

Simulated Plant Conditions: Power has been lost to the Met Tower.

Message:

For Controller Use Only

Controller Notes: Submit this message only if action has not been initiated to cross tie the 240V switchyard buses. The Health Physics Team should check into the lack of met data prior to issuance of this message. The message may be issued prior to 1000, if clarification is requested by the HP Team.

Action Expected:

Scenario No: PALEX-86

Time = 1000

Message No: 13

T = 1 hr 15 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets and Alarm Sheet

Message:

For Controller Use Only

Controller Notes: Operators stabilize PCS pressure at 1200 psia and await sufficient boron injection prior to commencing cooldown.

Action Expected:

Message: 13

Time: 1000

T: 1 hr., 15 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 O CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 O CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 150 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 19 psi
(10) VCT Level 56 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 93 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 1200 psia
(8) Pzr Level (R) LRC-0101A 63 %
LRC-0101B 63 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A P55B P55C
(6) PCPs Run P50A P50B Run P50C Run P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 532 °F
Loop 2 (TR-0121) 532 °F

(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 132 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 535 °F

C-13

CST Level (T-2) 72 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 0.8 psig
 (16) S/G A Compartment Temp 149 °F
 S/G A Compartment Humidity 65 %
 (16) S/G B Compartment Temp 140 °F
 S/G B Compartment Humidity 29 %
 (16) Dome Temp 150 °F
 (11) SIRT Level 99 %
 (15) WR Containment Press (R) 15.5 psia
 (14) Containment Sump Level 10 %
 (14) Containment Water Level (R) 0 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS Yes No X

Panel K-13

(20) Containment High Pressure
 Yes X No
 (20) Containment High Radiation
X Yes No

C-12

Conc. Boric Acid Tank Levels
 T53A 46 %
 T53B 46 %
 Reactor Vessel DP 40 psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 635 amps B 0 amps
 C 630 amps D 625 amps
 (6) PCS Flow 55 %
 (3) T_H Loop 1 532 °F
 Loop 2 532 °F
 (2) T_C Loop 1 532 °F
 Loop 2 532 °F
 T_C WR(R) Loop 1 530 °F
 Loop 2 530 °F
 (5) Subcooling 35 °F
 (7) PCS WR Press (R) 1200 psia
 (7) PCS NR Press (R) psia
 (30) S/G A Level WR 29 %
 (30) S/G A Level (R) 29 %
 (30) S/G A Press 900 psia
 S/G A Steam Flow (R) X10⁶PPH
 S/G A Feed Flow (R) X10⁶PPH
 (30) S/G B Level WR 29 %
 (30) S/G B Level (R) 29 %
 (30) S/G B Press 900 psia
 S/G B Steam Flow (R) X10⁶PPH
 S/G B Feed Flow (R) X10⁶PPH

C-11

(31) AFW Flow to SGA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SGB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 0 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/C 1-2 Run
 (32) 1C Buss Volts 0 Amps 0
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A


(17) Containment Area Monitors
 RIA 1805 2 R/Hr RIA 1806 4.1 R/Hr
 RIA 1807 9 R/Hr RIA 1808 8 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 20 R/Hr RIA 2322 25 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R %
 AI 2401 L %
 (30) Main Steam Gamma
 S/G A RIA 2324 40 cpm
 S/G B RIA 2323 30 cpm

Equipment Status:

1. Significant Equipment Outages (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or Outages

CONTROL ROOM ALARMS

MESSAGE: 13 TIME: 1000 T= 1 hr 15 min SCENARIO: PALEX 86



Scenario No: PALEX-86

Time = 1015

Message No: 14

T = 1 hr 30 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes: Operators should commence orderly cooldown after verification (by sample or calculation) that sufficient boron has been injected to PCS.

Action Expected:

Message: 14

Time: 1015

T: 1 hr., 30 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp - °F
Charging Line Temp 100 °F
Letdown Line Temp - °F
SDCS from PCS (R) - °F
SDCS to PCS (R) - °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 19 psi
(10) VCT Level 57 %
 PCP Control Bleedoff Press' 80 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 53 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 1200 psia
(8) Pzr Level (R) LRC-0101A 61 %
 LRC-0101B 61 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
 Charging Pumps Run P55A P55B P55C
(6) PCPs Run P50A P50B Run P50C P50D
 Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 532 °F
 Loop 2 (TR-0121) 532 °F
(25) Reactor Power Level

NI-1 10 cps NI-3 10⁻⁸ % NI-7 - %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 - %
 NI-5 - % NI-9 - %
 NI-6 - % NI-10 - %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0

(28) Control Rod Position
 GP1 0 GP2 0 GP3 132 GP4 0
 GP 5(P) 132 GP 6(A) 0 GP 7(B) 0
 Stuck Rods X Yes No # 34

(4) Core Exit Temp 535 °F

Scenario No: PALEX-86

Time = 1030

Message No: 15

T = 1 hr 45 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 15

Time: 1030

T: 1 hr., 45 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
Run V1B Run V2B Run V3B Run V4B

C-03

(23) HPSI Pumps P-66A P-66B
(24) LPSI Pumps P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 O CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 O CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 20 psi
(10) VCT Level 58 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 53 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 1200 psia
(8) Pzr Level (R) LRC-0101A 59 %
LRC-0101B 59 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A P55B P55C
(6) PCs Run P50A P50B Run P50C P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 530 °F
Loop 2 (TR-0121) 530 °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 533 °F

Scenario No: PALEX-86

Time = 1045

Message No: 16

T = 2 hr

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes: LOCA (approximately 1000 gpm) has started due to P-50B
seal complete failure.

Action Expected: Per EOP 8.1 (LOCA Procedure)

Message: 16

Time: 1045

T: 2 hr., 5 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans

Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIB, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 20 psi
(10) VCT Level 59 %
PCP Control Bleedoff Press 80 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 93 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) ↓ 1100 psia
(8) Pzr Level (R) LRC-0101A ↓ 47 %
LRC-0101B ↓ 47 %
(12) PORV PRV-1042B C 1043B C
(12) block MO-1042A C 1043A C
Charging Pump Run P55A Run P55B P55C
(6) PCPs Run P50A P50B Run P50C P50D
Pzr Htr Amps L.C. 15 130 L.C. 16 130
(1) PCS T_{ave} (R) Loop 1 (TR-0111) 515 °F
Loop 2 (TR-0121) 515 °F

(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Sta. Lumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 518 °F

C-13

CST Level (T-2) 69 %
 Instrument Air Press 105 psig
 (15) Containment Building Press ↑ 1.5 psig
 (16) S/G A Compartment Temp ↑ 160 °F
 S/G A Compartment Humidity 100 %
 (16) S/G B Compartment Temp 148 °F
 S/G B Compartment Humidity 50 %
 (16) Dome Temp 162 °F
 (11) SIRMT Level 98 %
 (15) WR Containment Press (R) ↑ 16.2 psia
 (14) Containment Sump Level ↑ 20 %
 (14) Containment Water Level (R) 0 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS ___ Yes X No

Panel K-13

(20) Containment High Pressure
 ___ Yes X No
 (20) Containment High Radiation
X Yes ___ No

C-12

Conc. Boric Acid Tank Levels
 T53A 46 %
 T53B 46 %
 Reactor Vessel DP 35 psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 640 amps B 0 amps
 C 640 amps D 0 amps
 (6) PCS Flow 50 %
 (3) T_H Loop 1 515 °F
 Loop 2 515 °F
 (2) T_C Loop 1 515 °F
 Loop 2 515 °F
 T_C WR(R) Loop 1 515 °F
 Loop 2 515 °F
 (5) Subcooling - °F
 (7) PCS WR Press (R) ↓ 1100 psia
 (7) PCS NR Press (R) - psia
 (30) S/G A Level WR 32 %
 (30) S/G A Level (R) 32 %
 (30) S/G A Press 885 psia
 S/G A Steam Flow (R) - X10⁶PPH
 S/G A Feed Flow (R) - X10⁶PPH
 (30) S/G B Level WR 32 %
 (30) S/G B Level (R) 32 %
 (30) S/G B Press 885 psia
 S/G B Steam Flow (R) - X10⁶PPH
 S/G B Feed Flow (R) - X10⁶PPH

C-11

(31) AFW Flow to SGA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SGB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 0 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 ___ D/G 1-2 Run
 (32) 1C Buss Volts 0 Amps 0
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 100 R/Hr RIA 1806 200 R/Hr
 RIA 1807 300 R/Hr RIA 1808 300 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 1000 R/Hr RIA 2322 1000 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R - %
 AI 2401 L - %
 (30) Main Steam Gamma
 S/G A RIA 2324 100 cpm
 S/G B RIA 2323 150 cpm

Equipment Status:

1. Significant Equipment Outages
 (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or
 Outages

Scenario No: PALEX-86

Time = 1045

Message No: 16a

T = 2 hr

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Maintenance Team

Simulated Plant Conditions: Purge Valve Failure

Message: Verbal or written as required by Controller

For Controller Use Only:

- Controller Notes:
1. Purge Valves CV-1807 and CV-1808 have experienced an internal failure of their elastomer seats.
 2. There are no external signs of damage or failure.
 3. There are no normal maintenance procedures which will stop the leak.
 4. The dose rates on contact with the purge line is 20-30 R/hr and 8-10 R/hr at 18 inches. The leaky valves cannot be identified by differing radiation levels due to the proximity of the two lines. These radiation levels will severely impede any work efforts.
 5. None of the repair efforts may be successful until 14:15.

- Action Expected:
1. Inspect outside of purge lines, valves, etc, for damage.
 2. Determine damage is internal and that the valves cannot be repaired externally.
 3. Possible repairs:
 - a. Inject a suitable plugging material into the leak rate test tap between the two leaking valves.
 - b. Remove the valves and blind flange the pipe end. (This is very unlikely due to dose rates and the resulting airborne that would be released).

Scenario No: PALEX-86

Time = 1050

Message No: 17

T = 2 hr 5 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: All TSC Players

Simulated Plant Conditions:

Message: "You have lost one-half of TSC lighting and all wall receptacles. Turn all computers off until instructed that power has been restored."

For Controller Use Only

Controller Notes: Regaining bus 1E will restore power to TSC lighting and receptacles. Control Room Controller will advise when power is restored.

Action Expected:

Scenario No: PALEX-86

Time = 1050

Message No: 18

T = 2 hr 5 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets and Alarm Sheet

Message "CRDM Matrix on C-12 panel is dark (ie, no lights are lit)"

For Controller Use Only

Controller Notes: A. See 1050 Controller Notes Sheet.
B. Operators should have manually initiated SIAS upon detecting LOCA conditions.
C. Data sheets reflect loss of instrumentation on loss of Y-01 (due to loss of Bus 1E on SIAS).

Action Expected: A. Per EOP 8.1.
B. Definite Site Area Emergency, possible declaration of General Emergency (SED opinion).

1050 CONTROLLER NOTES

1. PSC pressure continues to drop rapidly.
 - a. Safety Injection Actuation Signal:
 - b. E-Bus trips
 - 1) Normal action on SIS actuation.
 - 2) Generator trip relay 386-C (on back of C-04) must be reset before E-Bus breaker 152-303 will reclose.
 - 3) The following significant loads are lost until E-Bus re-energized.
 - a) Fire System Jockey Pump and Fire Pump P-9A
 - 1) Diesel Fire Pump starts
 - b) Pressurizer Heater Transformer 15
 - c) Switchyard 240V Bus 1
 - 1) Bus 2 (possibly X-tied to Bus 1) supplies the Meteorological Tower
 - d) Instrument AC Bus Y-01
 - 1) This bus is being supplied by its alternate feed from MCC-3, which is fed from load center 13, which is X-tied to load center 14, which is fed from the 1E Bus.
 - 2) Normal Y-01 feed is (indirectly) from Bus 1C.
 - 3) A list of Y-01 loads can be found on electrical drawing E-29.
 - e) "Right" half of TSC lights and all TSC receptacles.
3. Containment pressure increases rapidly.
 - a) Temperature and rad data up also
 - b) CHP occurs at 4 psi
 - 1) No spray pumps available
 - c) Fan coolers ineffective
 - 1) Low service water flow due to cooler coils plugging with Asiatic Clams.
4. Stack Monitor readings increase with containment pressure.
 - a) Release is through faulty purge valves to stack.

Message: 18

Time: 1050

T: 2 hr., 5 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp Fail Low °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp (No Green Light) 120 °F
(10) VCT Press Fail Low psi
(10) VCT Level Fail Low %
PCP Control Bleedoff Press 65 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow Fail Low GPM
(9) Quench Tank Temp Fail Low °F
(9) Quench Tank Press Fail Low psig
(9) Quench Tank Level Fail Low %
(7) Pzr Press (R) ↓ 890 psia
(8) Pzr Level (R) LRC-0101A ↓ 5 %
LRC-0101B ↓ 5 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B Run P55C
(6) PCPs Run P50A P50B Run P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 513 °F


CONTROL ROOM ALARMS

MESSAGE: 18

TIME: 1050

T= 2 hr 5 min

SCENARIO: PALEX 86



CONTROL ROOM ALARMS

MESSAGE: 18

TIME: 1050

T= 2 hr 5 min

SCENARIO: PALEX 86

C-06 PANEL



A	B	C	D
RACK	RACK	RACK	RACK

C-106 PANEL



K-33

C-126 PANEL



K-35

C-11A PANEL



K-02

- #1 "Cont Gamma RIA-2321 High"
- #2 "Cont Gamma RIA-2322 High"
- #5 "Main Steam E-50B
RIA-2323 High"
- #6 "Main Steam E-50A
RIA-2324 High"
- #13 "Cont Gamma RIA-2321 Alert"
- #14 "Cont Gamma RIA-2322 Alert"
- #17 "Main Steam E-50B
RIA-2323 Alert"
- #18 "Main Steam E-50A
RIA-2324 Alert"
- #7 "Stack Eff Rad C-169 High"
- #19 "Stack Eff Rad C-169 Alert"

Scenario No: PALEX-86

Time = 1100

Message No: 19

T = 2 hr 15 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets and Alarm Sheet

Message:

For Controller Use Only

Controller Notes: Bus 1E is assumed to have been restored thereby restoring
Y-01 (Instrument AC Bus)

Action Expected:

Message: 19

Time: 1100

T: 2 hr., 15 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans

Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 20 psi
(10) VCT Level 61 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 133 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 800 psia
(8) Pzr Level (R) LRC-0101A 0 %
LRC-0101B 0 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B Run P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 513 °F

CONTROL ROOM ALARMS

MESSAGE: 19 TIME: 1100 T= 2 hr 15 min SCENARIO: PALEX 86

C-13 PANEL



K-11

K-13

K-13 #55 "SIRW Tank T-58 Hi-Lo Level"

K-13 #56 "SIRW Tank T-58 Hi-Lo Level"

C-12 PANEL



K-07

K-09

C-11 PANEL



K-01

K-03

K-05

Scenario No: PALEX-86

Time = 1115

Message No: 20

T = 2 hr 30 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 20

Time: 1115

T: 2 hr., 30 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 21 psi
(10) VCT Level 62 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 133 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 750 psia
(8) Pzr Level (R) IRC-0101A 0 %
LRC-0101B 0 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B Run P55C
(6) PCFs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps PSA P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 513 °F

C-13

CST Level (T-2) 67 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 5(P.H.) psig
 (16) S/G A Compartment Temp 194 °F
 S/G A Compartment Humidity 100 %
 (16) S/G B Compartment Temp 172 °F
 S/G B Compartment Humidity 100 %
 (16) Dome Temp 175 °F
 (11) SIRWT Level 94 %
 (15) WR Containment Press (R) 20.2 psia
 (14) Containment Sump Level 55 %
 (14) Containment Water Level (R) 590.5 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS X Yes No

Panel K-13

(20) Containment High Pressure
 X Yes No
 (20) Containment High Radiation
 X Yes No

C-12

Conc. Boric Acid Tank Levels
 T53A 46 %
 T53B 46 %
 Reactor Vessel DP psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 0 amps B 0 amps
 C 0 amps D 0 amps
 (6) PCS Flow %
 (3) T_H Loop 1 °F
 Loop 2 °F
 (2) T_C Loop 1 °F
 Loop 2 °F
 T_C WR(R) Loop 1 510 °F
 Loop 2 510 °F
 (5) Subcooling °F
 (7) PCS WR Press (R) 750 psia
 (7) PCS NR Press (R) psia
 (30) S/G A Level WR 34 %
 (30) S/G A Level (R) 34 %
 (30) S/G A Press 740 psia
 S/G A Steam Flow (R) X10⁶PPH
 S/G A Feed Flow (R) X10⁶PPH
 (30) S/G B Level WR 34 %
 (30) S/G B Level (R) 34 %
 (30) S/G B Press 740 psia
 S/G B Steam Flow (R) X10⁶PPH
 S/G B Feed Flow (R) X10⁶PPH

C-11

(31) AFW Flow to SGA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SGB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 0 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run
 (32) IC Buss Volts 0 Amps 0
 (32) ID Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 460 R/Hr RIA 1806 820 R/Hr
 RIA 1807 660 R/Hr RIA 1808 660 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 4400 R/Hr RIA 2322 4400 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R %
 AI 2401 L %
 (30) Main Steam Gamma
 S/G A RIA 2324 800 cpm
 S/G B RIA 2323 700 cpm

Equipment Status:

1. Significant Equipment Outages (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or Outages

Scenario No: PALEX-86

Time = 1130

Message No: 21

T = 2 hr 45 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 21

Time: 1130

T: 2 hr., 45 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 21 psi
(10) VCT Level 64 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 133 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 700 psia
(8) Pzr Level (R) LRC-0101A 0 %
LRC-0101B 0 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B Run P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F

(25) Reactor Power Level

NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position

GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34

(4) Core Exit Temp 513 °F

Scenario No: PALEX-86

Time = 1145

Message No: 22

T = 3 hr

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes: Operators should recommence cooldown of PCS per EOP 8.1.

Action Expected:

Message: 22

Time: 1145

T: 3 hr.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 21 psi
(10) VCT Level 65 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 133 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 675 psia
(8) Pzr Level (R) LRC-0101A 0 %
LRC-0101B 0 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B Run P55C
(6) PCFs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Closed
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 513 °F

Scenario No: PALEX-86

Time = 1200

Message No: 23

T = 3 hr 15 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 23

Time: 1200

T: 3 hr., 15 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 O CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 O CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 21 psi
(10) VCT Level 67 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 133 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 650 psia
(8) Pzr Level (R) LRC-0101A 0 %
LRC-0101B 0 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B Run P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) - °F
Loop 2 (TR-0121) - °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position

GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34

(4) Core Exit Temp 515 °F

Scenario No: PALEX-86

Time = 1215

Message No: 24

T = 3 hr 30 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 24

Time: 1215

T: 3 hr., 30 min.

Scenario: PALEX 1986

C-08

C-02

C-01

SW Pumps Run P-7A P-7B Run P-7C
 CCW Pumps P-52A Run P-52B P-52C
 FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
 (24) LPSI Pumps Run P-67A P-67B
 (18) Containment Spray Pumps
 P-54A P-54B P-54C
 (27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
 (27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
 Charging Line Temp 100 °F
 Letdown Line Temp °F
 SDCS from PCS (R) °F
 SDCS to PCS (R) °F

(10) VCT Temp 120 °F
 (10) VCT Press 21 psi
 (10) VCT Level 68 %
 PCP Control Bleedoff Press 40 psig
 (26) Letdown Flow 0 GPM
 (26) Charging Flow 133 GPM
 (9) Quench Tank Temp 115 °F
 (9) Quench Tank Press 0.5 psig
 (9) Quench Tank Level 75 %
 (7) Pzr Press (R) 625 psia
 (8) Pzr Level (R) LRC-0101A 0 %
 LRC-0101B 0 %
 (12) PORV PRV-1042B C 1043B C
 (12) Block MO-1042A C 1043A C
 Charging Pumps Run P55A Run P55B Run P55C
 (6) PCPs P50A P50B P50C P50D
 Pzr Htr Amps L.C. 15 0 L.C. 16 0
 (1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
 Loop 2 (TR-0121) °F

(25) Reactor Power Level
 NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
 NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
 NI-5 % NI-9 %
 NI-6 % NI-10 %

MFP Suction Press - psig
 MFP A Dsch Press - psig
 MFP B Dsch Press - psig
 AFW Pump 8C Amperes 85 amps
 AFW Pump 8C Disch Press 1600 psig
 AFW Pump 8A Amperes - amps
 AFW Pump 8B Steam Press - psig
 AFW Pumps 8A & 8B Disch Press - psig
 Moisture Sep Dr Tank 64 %
 Condenser Hotwell Level 65 %
 Condenser Vacuum 27 in hg.
 Gland Seal Cond Vacuum 18 in hg.
 Atm. Stm. Dumps Open
 AFW Feed Pumps P8A P8B Run P8C
 Heater Drain Pumps P10A P10B
 Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
 Net MW 0
 (28) Control Rod Position
 GP1 0 GP2 0 GP3 132 GP4 0
 GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
 Stuck Rods X Yes No # 34
 (4) Core Exit Temp 505 °F

Scenario No: PALEX-86

Time = 1230

Message No: 25

T = 3 hr 45 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes: Pressurizer starts to refill since injection flow has overcome leak flow.

Action Expected:

Message: 25

Time: 1230

T: 3 hr., 45 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans

Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 O CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 O CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 21 psi
(10) VCT Level 70 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 133 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 600 psia
(8) Pzr Level (R) LRC-0101A ↑ 1 %
LRC-0101B ↑ 1 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B Run P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 485 °F

C-13

CST Level (T-2) 62 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 5(P.H.) psig
 (16) S/G A Compartment Temp 225 °F
 S/G A Compartment Humidity 100 %
 (16) S/G B Compartment Temp 200 °F
 S/G B Compartment Humidity 100 %
 (16) Dome Temp 209 °F
 (11) SIRWT Level 84 %
 (15) WR Containment Press (R) 23.1 psia
 (14) Containment Sump Level 60 %
 (14) Containment Water Level (R) 591 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS X Yes No

Panel K-13

(20) Containment High Pressure
X Yes No
 (20) Containment High Radiation
X Yes No

C-12

Conc. Boric Acid Tank Levels
 T53A 46 %
 T53B 46 %
 Reactor Vessel DP - psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 0 amps B 0 amps
 C 0 amps D 0 amps
 (6) PCS Flow - %
 (3) T_H Loop 1 - °F
 Loop 2 - °F
 (2) T_C Loop 1 - °F
 Loop 2 - °F
 T_C WR(R) Loop 1 450 °F
 Loop 2 450 °F
 (5) Subcooling - °F
 (7) PCS WR Press (R) 600 psia
 (7) PCS NR Press (R) - psia
 (30) S/G A Level WR 39 %
 (30) S/G A Level (R) 39 %
 (30) S/G A Press 422 psia
 S/G A Steam Flow (R) - X10⁶PPH
 S/G A Feed Flow (R) - X10⁶PPH
 (30) S/G B Level WR 39 %
 (30) S/G B Level (R) 39 %
 (30) S/G B Press 422 psia
 S/G B Steam Flow (R) - X10⁶PPH
 S/G B Feed Flow (R) - X10⁶PPH

C-11

(31) AFW Flow to SGA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SGB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 0 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run
 (32) 1C Buss Volts 0 Amps 0
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 530 R/Hr RIA 1806 880 R/Hr
 RIA 1807 760 R/Hr RIA 1808 760 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 4400 R/Hr RIA 2322 4400 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R - %
 AI 2401 L - %
 (30) Main Steam Gamma
 S/G A RIA 2324 700 cpm
 S/G B RIA 2323 600 cpm

Equipment Status:

1. Significant Equipment Outages (Inoperable Equipment)
 2. Surveillance Due or in Progress
 3. Abnormal Electrical Lineups or Outages
-
-
-
-
-
-
-
-
-
-

Scenario No: PALEX-86

Time = 1245

Message No: 26

T = 4 hr

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: Size Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 26

Time: 1245

T: 4 hr.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 22 psi
(10) VCT Level 71 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 133 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 580 psia
(8) Pzr Level (R) LRC-0101A 30 %
LR-0101B 30 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B Run P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 465 °F

C-13

CST Level (T-2)	<u>61</u> %
Instrument Air Press	<u>105</u> psig
(15) Containment Building Press	<u>5(P.H.)</u> psig
(16) S/G A Compartment Temp	<u>230</u> °F
S/G A Compartment Humidity	<u>100</u> %
(16) S/G B Compartment Temp	<u>205</u> °F
S/G B Compartment Humidity	<u>100</u> %
(16) Dome Temp	<u>214</u> °F
(11) SIRWT Level	<u>82</u> %
(15) WR Containment Press (R)	<u>23.7</u> psia
(14) Containment Sump Level	<u>61</u> %
(14) Containment Water Level (R)	<u>591.1</u> %
(22) SI Tank Level (%) A <u>48</u> B <u>48</u> C <u>48</u> D <u>48</u>	
SI Tank Press (psig) A <u>210</u> B <u>210</u> C <u>210</u> D <u>210</u>	
(21) SIAS <u>X</u> Yes <u> </u> No	

Panel K-13

(20) Containment High Pressure
 Yes No

(20) Containment High Radiation
 Yes No

C-12

Conc. Boric Acid Tank Levels	
T53A	<u>46</u> %
T53B	<u>46</u> %
Reactor Vessel DP	<u>-</u> psid
(12) PORV Discharge Temp	<u>115</u> °F
(13) Pzr Safety Valve Dsch Temp	
RV-1039	<u>115</u> °F
RV-1040	<u>115</u> °F
RV-1041	<u>115</u> °F

C-12

PCF Current	
A	<u>0</u> amps
B	<u>0</u> amps
C	<u>0</u> amps
D	<u>0</u> amps
(6) PCS Flow	<u>-</u> %
(3) T _H Loop 1	<u>-</u> °F
Loop 2	<u>-</u> °F
(2) T _C Loop 1	<u>-</u> °F
Loop 2	<u>-</u> °F
T _C WR(R) Loop 1	<u>430</u> °F
Loop 2	<u>430</u> °F
(5) Subcooling <u>-</u> °F	<u>-</u> psig
(7) PCS WR Press (R)	<u>580</u> psia
(7) PCS NR Press (R)	<u>-</u> psia
(30) S/G A Level WR	<u>40</u> %
(30) S/G A Level (R)	<u>40</u> %
(30) S/G A Press	<u>343</u> psia
S/G A Steam Flow (R)	<u>-</u> X10 ⁶ PPH
S/G A Feed Flow (R)	<u>-</u> X10 ⁶ PPH
(30) S/G B Level WR	<u>40</u> %
(30) S/G B Level (R)	<u>40</u> %
(30) S/G B Press	<u>343</u> psia
S/G B Steam Flow (R)	<u>-</u> X10 ⁶ PPH
S/G B Feed Flow (R)	<u>-</u> X10 ⁶ PPH

C-11

(31) AFW Flow to SGA	
From P8A&B	<u>0</u> gpm
From P8C	<u>150</u> gpm
(31) AFW Flow to SGB	
From P8A&B	<u>0</u> gpm
From P8C	<u>150</u> gpm
Condenser Vacuum (R)	<u>27</u> in hg.
PCP A Leak-off Flow (R)	<u>1</u> GPM
PCP B Leak-off Flow (R)	<u>0</u> GPM
PCP C Leak-off Flow (R)	<u>1</u> GPM
PCP D Leak-off Flow (R)	<u>1</u> GPM

C-04

(32) D/G 1-1	<u> </u>	D/G 1-2	<u>Run</u>
(32) 1C Buss Volts	<u>0</u>	Amps	<u>0</u>
(32) 1D Buss Volts	<u>2400</u>	Amps	<u>OK</u>

C-11 Back C-11A

(17) Containment Area Monitors					
RIA 1805	<u>555</u>	R/Hr	RIA 1806	<u>915</u>	R/Hr
RIA 1807	<u>785</u>	R/Hr	RIA 1808	<u>785</u>	R/Hr
(17) High Range Containment Monitors					
RIA 2321	<u>4800</u>	R/Hr	RIA 2322	<u>4800</u>	R/Hr
(19) Containment H ₂ Concentration					
AI 2401 R				<u>-</u>	%
AI 2401 L				<u>-</u>	%
(30) Main Steam Gamma					
S/G A RIA 2324				<u>850</u>	cpm
S/G B RIA 2323				<u>750</u>	cpm

Equipment Status:

1. Significant Equipment Outages (Inoperable Equipment)
 2. Surveillance Due or in Progress
 3. Abnormal Electrical Lineups or Outages
-
-
-
-
-
-
-
-
-
-
-

Scenario No: PALEX-86

Time = 1300

Message No: 27

T = 4 hr 15 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 27

Time: 1300

T: 4 hr., 15 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 22 psi
(10) VCT Level 73 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 133 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 560 psia
(8) Pzr Level (R) LRC-0101A ↑ 60 %
LRC-0101B ↑ 60 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B Run P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)
Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 445 °F

Scenario No: PALEX-86

Time = 1315

Message No: 28

T = 4 hr 30 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes: Operators should start to secure charging pumps as
pressurizer level approaches 100%.

Action Expected:

Message: 28

Time: 1315

T: 4 hr., 30 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 O CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 O CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 22 psi
(10) VCT Level 74 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 133 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 540 psia
(8) Pzr Level (R) LRC-0101A 90 %
LRC-0101B 90 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A Run P55B Run P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 425 °F

Scenario No: PALEX-86

Time = 1330

Message No: 29

T = 4 hr 45 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 29

Time: 1330

T: 4 hr., 45 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 O CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 O CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 23 psi
(10) VCT Level 76 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 43 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 520 psia
(8) Pzr Level (R) LRC-0101A 100 %
LRC-0101B 100 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps Run P55A P55B P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F

(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34

(4) Core Exit Temp 410 °F

Scenario No: PALEX-86

Time = 1345

Message No: 30

T = 5 hr

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 30

Time: 1345

T: 5 hr.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans

Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
 P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 O CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 O CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 23 psi
(10) VCT Level 77 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 0 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 500 psia
(8) Pzr Level (R) LRC-0101A 100 %
LRC-0101B 100 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps P55A P55B P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
 NI-5 % NI-9 %
 NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps PSA P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position

GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34

(4) Core Exit Temp 395 °F

Scenario No: PALEX-86

Time = 1400

Message No: 31

T = 5 hr 15 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes: A. Three Foreseen Methods for Accident Recovery

1. Repair of Spray Pump P-54A
 - a. 1400 earliest permissible repair
2. Bus 1C repair
 - a. 1410 earliest permissible repair
 - 1) Relay 386-C must be reset for breaker 152-106 to reclose.
 - 2) ITC switch must be placed in cutout for breaker to reclose.
3. Plug Release Path (purge line)
 - a. 1415 earliest permissible repair.

Action Expected:

Message: 31

Time: 1400

T: 5 hr., 15 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
Run P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp - °F
Charging Line Temp 100 °F
Letdown Line Temp - °F
SDCS from PCS (R) - °F
SDCS to PCS (R) - °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 23 psi
(10) VCT Level 79 %
 PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 0 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 480 psia
(8) Pzr Level (R) LRC-0101A 100 %
 LRC-0101B 100 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
 Charging Pumps P55A P55B P55C
(6) PCs P50A P50B P50C P50D
 Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) - °F
 Loop 2 (TR-0121) - °F
(25) Reactor Power Level
 NI-1 10 cps NI-3 10⁻⁸ % NI-7 - %
 NI-2 10 cps NI-4 10⁻⁸ % NI-8 - %
 NI-5 - % NI-9 - %
 NI-6 - % NI-10 - %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position
 GP1 0 GP2 0 GP3 132 GP4 0
 GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
 Stuck Rods X Yes No # 34
(4) Core Exit Temp 380 °F

Scenario No: PALEX-86

Time = 1415

Message No: 32

T = 5 hr 30 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 32

Time: 1415

T: 5 hr., 30 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
Run P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp - °F
Charging Line Temp 100 °F
Letdown Line Temp - °F
SDCS from PCS (R) - °F
SDCS to PCS (R) - °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 23 psi
(10) VCT Level 80 %
 PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 0 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 460 psia
(8) Pzr Level (R) LRC-0101A 100 %
 LRC-0101B 100 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
 Charging Pumps P55A P55B P55C
(6) PCs P50A P50B P50C P50D
 Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) - °F
 Loop 2 (TR-0121) - °F
(25) Reactor Power Level
 NI-1 10 cps NI-3 10⁻⁸ % NI-7 - %
 NI-2 10 cps NI-4 10⁻⁸ % NI-8 - %
 NI-5 - % NI-9 - %
 NI-6 - % NI-10 - %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position
 GP1 0 GP2 0 GP3 132 GP4 0
 GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
 Stuck Rods X Yes No # 34
(4) Core Exit Temp 365 °F

C-13

CST Level (T-2) 55 %
Instrument Air Press 105 psig
(15) Containment Building Press 2.9 psig
(16) S/G A Compartment Temp 235 °F
S/G A Compartment Humidity 100 %
(16) S/G B Compartment Temp 225 °F
S/G B Compartment Humidity 100 %
(16) Dome Temp 235 °F
(11) SIRWT Level 63 %
(15) WR Containment Press (R) 17.6 psia
(14) Containment Sump Level 6.8 %
(14) Containment Water Level (R) 591.8 %
(22) SI Tank Level (%) A 48 B 48 C 48 D 48
SI Tank Press (psig) A 210 B 210 C 210 D 210
(21) SIAS X Yes No

Panel K-13

(20) Containment High Pressure X Yes No
(20) Containment High Radiation X Yes No

C-12

Conc. Boric Acid Tank Levels
T53A 46 %
T53B 46 %
Reactor Vessel DP - psid
(12) PORV Discharge Temp 115 °F
(13) Pzr Safety Valve Dsch Temp
RV-1039 115 °F
RV-1040 115 °F
RV-1041 115 °F

C-12

PCT Current
A 0 amps B 0 amps
C 0 amps D 0 amps
(6) PCS Flow - %
(3) T_H Loop 1 - °F
Loop 2 - °F
(2) T_C Loop 1 - °F
Loop 2 - °F
T_C WR(R) Loop 1 330 °F
Loop 2 330 °F
(5) Subcooling - °F
(7) PCS WR Press (R) 460 psia
(7) PCS NR Press (R) 460 psia
(30) S/G A Level WR 46 %
(30) S/G A Level (R) 46 %
(30) S/G A Press 103 psia
S/G A Steam Flow (R) - X10⁶PPH
S/G A Feed Flow (R) - X10⁶PPH
(30) S/G B Level WR 46 %
(30) S/G B Level (R) 46 %
(30) S/G B Press 103 psia
S/G B Steam Flow (R) - X10⁶PPH
S/G B Feed Flow (R) - X10⁶PPH

C-11

(31) AFW Flow to SGA
From P8A&B 0 gpm From P8C 150 gpm
(31) AFW Flow to SGB
From P8A&B 0 gpm From P8C 150 gpm
Condenser Vacuum (R) 27 in hg.
PCP A Leak-off Flow (R) 1 GPM
PCP B Leak-off Flow (R) 0 GPM
PCP C Leak-off Flow (R) 1 GPM
PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run
(32) 1C Buss Volts Amps
(32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
RIA 1805 500 R/Hr RIA 1806 800 R/Hr
RIA 1807 700 R/Hr RIA 1808 700 R/Hr
(17) High Range Containment Monitors
RIA 2321 5000 R/Hr RIA 2322 5000 R/Hr
(19) Containment H₂ Concentration
AI 2401 R - %
AI 2401 L - %
(30) Main Steam Gamma
S/G A RIA 2324 400 cpm
S/G B RIA 2323 300 cpm

Equipment Status:

1. Significant Equipment Outages (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or Outages

Scenario No: PALEX-86

Time = 1430

Message No: 33

T = 5 hr 45 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 33

Time: 1430

T: 5 hr., 45 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans
Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
Run P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 23 psi
(10) VCT Level 82 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 0 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 440 psia
(8) Pzr Level (R) LRC-0101A 100 %
LRC-0101B 100 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps P55A P55B P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
NI-5 % NI-9 %
NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34

(4) Core Exit Temp 360 °F

C-13

CST Level (T-2) 54 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 0.3 psig
 (16) S/G A Compartment Temp 230 °F
 S/G A Compartment Humidity 100 %
 (16) S/G B Compartment Temp 220 °F
 S/G B Compartment Humidity 100 %
 (16) Dome Temp 230 °F
 (11) SIRWT Level 55 %
 (15) WR Containment Press (R) 15.0 psia
 (14) Containment Sump Level 70 %
 (14) Containment Water Level (R) 592 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS X Yes No

Panel K-13

(20) Containment High Pressure
 Yes X No
 (20) Containment High Radiation
 X Yes No

C-12

Conc. Boric Acid Tank Levels
 T53A 46 %
 T53B 46 %
 Reactor Vessel DP psid
 (12) PORV Discharge Temp 115 °F
 (15) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 0 amps B 0 amps
 C 0 amps D 0 amps
 (6) PCS Flow %
 (3) T_H Loop 1 °F
 Loop 2 °F
 (2) T_C Loop 1 °F
 Loop 2 °F
 T_C WR(R) Loop 1 325 °F
 Loop 2 325 °F
 (5) Subcooling °F
 (7) PCS WR Press (R) 440 psia
 (7) PCS NR Press (R) 440 psia
 (30) S/G A Level WR 47 %
 (30) S/G A Level (R) 47 %
 (30) S/G A Press 90 psia
 S/G A Steam Flow (R) X10⁶PPH
 S/G A Feed Flow (R) X10⁶PPH
 (30) S/G B Level WR 47 %
 (30) S/G B Level (R) 47 %
 (30) S/G B Press 90 psia
 S/G B Steam Flow (R) X10⁶PPH
 S/G B Feed Flow (R) X10⁶PPH

C-11

(31) AFW Flow to SGA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SGB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 0 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run
 (32) IC Buss Volts Amps
 (32) ID Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 500 R/Hr RIA 1806 800 R/Hr
 RIA 1807 700 R/Hr RIA 1808 700 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 5000 R/Hr RIA 2322 5000 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R %
 AI 2401 L %
 (30) Main Steam Gamma
 S/G A RIA 2324 100 cpm
 S/G B RIA 2323 100 cpm

Equipment Status:

1. Significant Equipment Outages (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or Outages

Scenario No: PALEX-86

Time = 1445

Message No: 34

T = 6 hrs

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 34

Time: 1445

T: 6 hr.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans

Run VIA Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
Run P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
0 CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
0 CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 24 psi
(10) VCT Level 83 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 0 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 420 psia
(8) Pzr Level (R) LRC-0101A 100 %
LRC-0101B 100 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps P55A P55B P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
 NI-5 % NI-9 %
 NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0

(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 355 °F

Scenario No: PALEX-86

Time = 1500

Message No: 35

T = 6 hrs 15 min

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Control Room Operators

Simulated Plant Conditions: See Data Sheets

Message:

For Controller Use Only

Controller Notes:

Action Expected:

Message: 35

Time: 1500

T: 6 hr., 15 min.

Scenario: PALEX 1986

C-08

SW Pumps Run P-7A P-7B Run P-7C
CCW Pumps P-52A Run P-52B P-52C
FPC Pumps Run P-51A P-51B

Containment Cooler Recirc Fans

Run V1A Run V2A Run V3A Run V4A
 V1B V2B V3B V4B

C-03

(23) HPSI Pumps Run P-66A P-66B
(24) LPSI Pumps Run P-67A P-67B
(18) Containment Spray Pumps
Run P-54A P-54B P-54C
(27) HPSIA, LPSIA, Spray A Suction
 () CV-3057 (SIRWT) C CV-3029 (Sump)
(27) HPSIB, LPSIB, Spray B Suction
 () CV-3031 (SIRWT) C CV-3030 (Sump)

C-02

Intermediate Press Letdown Temp °F
Charging Line Temp 100 °F
Letdown Line Temp °F
SDCS from PCS (R) °F
SDCS to PCS (R) °F

C-02

(10) VCT Temp 120 °F
(10) VCT Press 24 psi
(10) VCT Level 85 %
PCP Control Bleedoff Press 40 psig
(26) Letdown Flow 0 GPM
(26) Charging Flow 0 GPM
(9) Quench Tank Temp 115 °F
(9) Quench Tank Press 0.5 psig
(9) Quench Tank Level 75 %
(7) Pzr Press (R) 400 psia
(8) Pzr Level (R) LRC-0101A 100 %
LRC-0101B 100 %
(12) PORV PRV-1042B C 1043B C
(12) Block MO-1042A C 1043A C
Charging Pumps P55A P55B P55C
(6) PCPs P50A P50B P50C P50D
Pzr Htr Amps L.C. 15 0 L.C. 16 0
(1) PCS T_{ave} (R) Loop 1 (TR-0111) °F
Loop 2 (TR-0121) °F
(25) Reactor Power Level
NI-1 10 cps NI-3 10⁻⁸ % NI-7 %
NI-2 10 cps NI-4 10⁻⁸ % NI-8 %
 NI-5 % NI-9 %
 NI-6 % NI-10 %

C-01

MFP Suction Press - psig
MFP A Dsch Press - psig
MFP B Dsch Press - psig
AFW Pump 8C Amperes 85 amps
AFW Pump 8C Disch Press 1600 psig
AFW Pump 8A Amperes - amps
AFW Pump 8B Steam Press - psig
AFW Pumps 8A & 8B Disch Press - psig
Moisture Sep Dr Tank 64 %
Condenser Hotwell Level 65 %
Condenser Vacuum 27 in hg.
Gland Seal Cond Vacuum 18 in hg.
Atm. Stm. Dumps Open
AFW Feed Pumps P8A P8B Run P8C
Heater Drain Pumps P10A P10B
Condensate Pumps Run P2A P2B

PIP

(Demand Log + Constant, Rod, or Flux/Temp)

Gross MW 0
Net MW 0
(28) Control Rod Position
GP1 0 GP2 0 GP3 132 GP4 0
GP 5(P) 0 GP 6(A) 0 GP 7(B) 0
Stuck Rods X Yes No # 34
(4) Core Exit Temp 350 °F

C-13

CST Level (T-2) 52 %
 Instrument Air Press 105 psig
 (15) Containment Building Press 0.3 psig
 (16) S/G A Compartment Temp 220 °F
 S/G A Compartment Humidity 100 %
 (16) S/G B Compartment Temp 210 °F
 S/G B Compartment Humidity 100 %
 (16) Dome Temp 220 °F
 (11) SIRWT Level 39 %
 (15) WR Containment Press (R) 15.0 psia
 (14) Containment Sump Level 74 %
 (14) Containment Water Level (R) 592.4 %
 (22) SI Tank Level (%) A 48 B 48 C 48 D 48
 SI Tank Press (psig) A 210 B 210 C 210 D 210
 (21) SIAS X Yes No

Panel K-13

(20) Containment High Pressure
 Yes X No
 (20) Containment High Radiation
X Yes No

C-12

Conc. Boric Acid Tank Levels

T53A 46 %
 T53B 46 %
 Reactor Vessel DP - psid
 (12) PORV Discharge Temp 115 °F
 (13) Pzr Safety Valve Dsch Temp
 RV-1039 115 °F
 RV-1040 115 °F
 RV-1041 115 °F

C-12

PCP Current
 A 0 amps B 0 amps
 C 0 amps D 0 amps
 (6) PCS Flow - %
 (3) T_H Loop 1 - °F
 Loop 2 - °F
 (2) T_C Loop 1 - °F
 Loop 2 - °F
 T_C WR(R) Loop 1 315 °F
 Loop 2 315 °F
 (5) Subcooling - °F
 (7) PCS WR Press (R) 400 psia
 (7) PCS NR Press (R) 400 psia
 (30) S/G A Level WR 49 %
 (30) S/G A Level (R) 49 %
 (30) S/G A Press 75 psia
 S/G A Steam Flow (R) - X10⁶PPH
 S/G A Feed Flow (R) - X10⁶PPH
 (30) S/G B Level WR 49 %
 (30) S/G B Level (R) 49 %
 (30) S/G B Press 75 psia
 S/G B Steam Flow (R) - X10⁶PPH
 S/G E Feed Flow (R) - X10⁶PPH

C-11

(31) AFW Flow to SGA
 From P8A&B 0 gpm From P8C 150 gpm
 (31) AFW Flow to SGB
 From P8A&B 0 gpm From P8C 150 gpm
 Condenser Vacuum (R) 27 in hg.
 PCP A Leak-off Flow (R) 1 GPM
 PCP B Leak-off Flow (R) 0 GPM
 PCP C Leak-off Flow (R) 1 GPM
 PCP D Leak-off Flow (R) 1 GPM

C-04

(32) D/G 1-1 D/G 1-2 Run
 (32) 1C Buss Volts Amps
 (32) 1D Buss Volts 2400 Amps OK

C-11 Back C-11A

(17) Containment Area Monitors
 RIA 1805 500 R/Hr RIA 1806 800 R/Hr
 RIA 1807 700 R/Hr RIA 1808 700 R/Hr
 (17) High Range Containment Monitors
 RIA 2321 5000 R/Hr RIA 2322 5000 R/Hr
 (19) Containment H₂ Concentration
 AI 2401 R - %
 AI 2401 L - %
 (30) Main Steam Gamma
 S/G A RIA 2324 100 cpm
 S/G B RIA 2323 100 cpm

Equipment Status:

1. Significant Equipment Outages
 (Inoperable Equipment)
2. Surveillance Due or in Progress
3. Abnormal Electrical Lineups or
 Outages

Scenario No: PALEX-86

Time =

Message No: 36

T =

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE MESSAGE FORM

Message for: Site Emergency Director

Simulated Plant Conditions:

Message: Announce the following over the plant public address system:

"Attention all personnel. The annual emergency exercise has been terminated as of _____. All drill participants may resume normal work activities."

For Controller Use Only

Controller Notes: Issue this message upon termination of the exercise.

Action Expected:

11.0 MAINTENANCE

Expected maintenance actions are detailed in Messages 2a, 2b, 2c, 2d, 2e and 16a. Messages will be issued as deemed necessary by the Maintenance Controller. Times listed on messages indicate the earliest time of issuance. Message content and form will be determined by the Controller at the time of issuance based on exercise actions and conditions.

PALISADES NUCLEAR PLANT
EMERGENCY PREPAREDNESS EXERCISE INFORMATION

CHEMISTRY AND RADIO-CHEMISTRY DATA

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE INFORMATION

Initial Chemistry Condition

The Plant is at full power, primary and secondary chemistry are stable. The last sampling of the PCS was at 0805 on August 18, 1986. (See attached Data Sheets) The last sampling of the Secondary System was at 0030 on August 19, 1986. (See attached Data Sheet) While setting up the NSSS panel for routine chemistry sampling, a chemistry technician notices a abnormally high radiation level when opening PCS sample point SX-1023. The chemistry technician then closes the sample point and at 0900 on August 19, 1986 calls the control room to report a high radiation level of 200 mr/hr at the NSSS panel.

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE INFORMATION

PASM Data for FALEX '86

1.0 pH

- 1.1 pH is a function of ppm boron if there is no LiOH in the sample, LiOH and boron concentration will depend on what water is added to the PCS during the accident. (SIRW, SI Bottles, BAST, etc.)
- 1.2 If accident progress to the point where LPSI pumps are drawing suction from containment sump and containment spray has been activated pH of PCS will be approximately 8.00 due to hydrazine and NaOH in containment spray.
- 1.3 pH should be determined by the Chemistry Controller based on accident condition and operator action. Table 1.1 and 1.2 maybe used as aid to determining pH.

2.0 Boron

- 2.1 Boron should be determined by the control room Controller based on operator action and boronmeter readings. PASM boron analysis is to be used as verification of those readings.
- 2.2 Chemistry Controller should converse with control room Controller to determine boron ppm value for reporting during exercise.

3.0 Chlorides

- 3.1 Chloride analysis is to be done within four days of the accident. Data will not be available during the course of the drill.
- 3.2 OSC Supervisor shall request Trail Street Lab to bring their Ion Chromatograph to the Plant within four days to do chloride analysis.

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE INFORMATION

4.0 Dissolved oxygen

- 4.1 Dissolved oxygen is not required until 30 days after accident if dissolved hydrogen and chloride data are available.
- 4.2 Oxygen is not mandatory unless chloride exceeds 0.15 ppm. A measurement of dissolved hydrogen residual of greater than 10 cc/kg is acceptable verification for up to 30 days.
- 4.3 Therefore dissolved oxygen data will not be available during the course of the drill.

5.0 Dissolved Hydrogen

- 5.1 Dissolved hydrogen in PCS during the accident will be 18 cc/kg a reduction from normal due to H₂ escaping from 1,000 gpm leak.
- 5.2 Percent hydrogen in containment air will be higher than normal due to H₂ production from the reaction of steam with galvanizing and paint. Also, H₂ will be increased as a result of the 1,000 gpm leak. Percent oxygen in containment air will be normal.

6.0 Radionuclide Concentration for Gross Activity and Gamma Spectrum

- 6.1 See Table for Containment Atmosphere
- 6.2 See Table for Sump Liquid Activity
- 6.3 See Table for Primary Coolant Liquid
- 6.4 See Table for A & B S/G Liquid Activity

7.0 Dose Rate and Radiation Levels

- 7.1 Dose rate and radiation levels around the PASM Panel, NSSS Panel, Hot Lab, and hallways are listed in the inplant radiation data section.
- 7.2 Areas monitors readings are listed in the area monitors section.

PALISADES NUCLEAR PLANT

EMERGENCY PREPAREDNESS EXERCISE INFORMATION

Table 1.1

Variation of pH with Lithium and Boron Concentrations

B, ppm \ Li, ppm

	0	0.2	0.4	0.6	0.8	1.0	1.2	1.4	1.6	1.8	2.0	2.2	2.4
0	7.0	9.46	9.76	9.94	10.06	10.16	10.24	10.30	10.36	10.41	10.46	10.50	10.54
50	5.78	7.03	7.34	7.51	7.64	7.74	7.82	7.89	7.95	8.01	8.06	8.10	8.14
100	5.63	6.73	7.03	7.20	7.33	7.43	7.51	7.58	7.64	7.69	7.74	7.78	7.82
150	5.54	6.54	6.84	7.02	7.14	7.24	7.32	7.39	7.45	7.50	7.55	7.59	7.63
200	5.47	6.41	6.70	6.88	7.00	7.10	7.18	7.25	7.31	7.36	7.41	7.45	7.49
250	5.41	6.30	6.59	6.77	6.89	6.99	7.07	7.14	7.20	7.25	7.30	7.34	7.38
300	5.37	6.20	6.50	6.67	6.80	6.90	6.97	7.04	7.10	7.15	7.20	7.24	7.28
350	5.32	6.12	6.41	6.59	6.71	6.81	6.89	6.96	7.02	7.07	7.11	7.16	7.19
400	5.28	6.04	6.33	6.51	6.63	6.73	6.80	6.88	6.94	6.99	7.04	7.08	7.12
450	5.25	5.97	6.26	6.44	6.56	6.66	6.74	6.81	6.86	6.92	6.96	7.0	7.04
500	5.21	5.91	6.20	6.37	6.49	6.59	6.67	6.74	6.80	6.85	6.89	6.94	6.97
550	5.18	5.85	6.13	6.31	6.43	6.53	6.64	6.67	6.73	6.78	6.83	6.87	6.91
600	5.15	5.79	6.07	6.24	6.37	6.46	6.54	6.61	6.67	6.72	6.77	6.81	6.85
650	5.12	5.73	6.01	6.18	6.31	6.41	6.49	6.55	6.61	6.66	6.71	6.75	6.79
700	5.09	5.68	5.96	6.13	6.25	6.35	6.43	6.50	6.55	6.61	6.65	6.69	6.73
750	5.07	5.63	5.90	6.07	6.20	6.29	6.37	6.44	6.50	6.55	6.60	6.64	6.68
800	5.04	5.58	5.85	6.02	6.14	6.24	6.32	6.39	6.45	6.50	6.54	6.59	6.62
850	5.01	5.53	5.80	5.97	6.09	6.19	6.27	6.34	6.39	6.45	6.49	6.53	6.57
900	4.99	5.48	5.75	5.92	6.04	6.14	6.22	6.29	6.34	6.40	6.44	6.48	6.52
950	4.96	5.44	5.70	5.87	5.99	6.09	6.17	6.24	6.30	6.35	6.39	6.43	6.47
1000	4.94	5.40	5.66	5.83	5.95	6.04	6.12	6.19	6.25	6.30	6.35	6.39	6.43

- NOTE: 1. Numbers contained in above table are approximation for exercise purposes only.
 2. If boron concentration are above 1,000 ppm use Table 1.2.

PALISADES NUCLEAR PLANT
EMERGENCY PREPAREDNESS EXERCISE INFORMATION

Table 1.2

Variation of pH with Boron Concentration

ppm Boron	pH	LiOH ppm
1000	5.0	<.02
1100	5.0	<.02
1200	4.9	<.02
1300	4.9	<.02
1400	4.8	<.02
1500	4.8	<.02
1600	4.7	<.02
1700	4.7	<.02
1800	4.6	<.02
1900	4.6	<.02
2000	4.5	<.02

NOTE: 1. Numbers contained in above Table are approximation for exercise purposes only.

PCS CHEMISTRY ANALYSIS (Power Operations)		Week of <u>3-18-86</u> to <u>3-24-86</u>		Proc No. CH 15 Attachment 3 Revision 1 Page 1 of 1			
Date		<u>3-18-86</u>					
Day		Monday	Tuesday	Wednesday	Thursday	Friday	Saturday
Time		<u>0805</u>					
Reactor Power	%	<u>97.0</u>					
PCS Pressure	Psig	<u>2009</u>					
PCS T avg	°F	<u>560.8</u>					
Boronmeter	PPM	<u>260</u>					
Parameter	Limit						
Sample Temp °C	D/NR	<u>26</u>					
pH	D/NR	<u>6.7</u>					
Conductivity μ mho/cm	D/NR	<u>20.0</u>					
Boron (ppm)	D/2	<u>500</u>					
Chloride (ppm)	<0.12 4/3	<u><.02</u>					
Dissolved O ₂ (ppm)	<0.1 4/3	<u><.02</u>					
Fluoride (ppm)	<0.1 1/M						
Lithium (ppm)	0.1 < Li < 2.0 D/NR	<u>1.50</u>					
Sodium (ppm)	D/NR	<u>.185</u>					
Suspended Solids (ppm)	<0.5 1/NR	<u>—</u>					
PCS Gas Expansion (in ml)		<u>17.7</u>					
% Hydrogen Gas		<u>93.6</u>					
% Nitrogen Gas		<u>5.0</u>					
Hydrogen cc/kg		<u>24.80</u>					
Nitrogen cc/kg		<u>1.33</u>					
Total Gas cc/kg		<u>26.5</u>					
Analysis by		<u>JEF</u>					
Senior Technician Review		<u>TCA</u>					
Lab Supervisor Review		<u>Smith</u>					
Remarks							

PCS GAS ACTIVITY

Week of 8-18-86 to 8-24-86
 Approved [Signature] 5-14-85

Proc No. CH 1.5
 Attachment 6
 Revision 1
 Page 1 of 2

Sample PT SX 023

Day	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
Date	3/18/86						
Time	0850						
Total Gas ^{cc} /kg	26.5						
Volume Counted	.10						
Isotope $\mu\text{Ci/cc}$							
Ar41	2.9E-1						
Kr85M	2.4E-1						
Kr87	3.0E-1						
Kr88	3.5E-1						
Xe131M	NONE DET.						
Xe133	2.2						
Xe133M	5.7E-2						
Xe135	8.9E-1						
Xe135M	NONE DET.						
Total Isotope $\mu\text{Ci/cc}$							
Note 3	4.33						
Delta Volume (A-B) (cc)	17.7						
PCS Gas Xe133 ($\mu\text{Ci/cc}$)	2.19						
PCS Liquid Xe133 ($\mu\text{Ci/mL}$)	1.11E-1						
PCS Total X ¹³³ ($\mu\text{Ci/kg}$) Note 1	1.35E-2						
Off Gas Xe133 (microcuries/cc)	2.95E-6						
Condenser Air in Leakage (Cfm)	5.0						
Primary to Secondary Leak (Gpm) Note 2	.0010						
Analysis by	JEF						
Senior Technician Review	TCA						
Lab Supervisor Review	C Smith						

Note

- 1 Determine the total microcuries/kg of any isotope or sums of isotopes by summing gaseous and liquid activity components of samples gathered from the same sample stream with the following formula:

Specific isotope activity (μ Ci/kg) =

$$\frac{\text{PCS gas activity } \times (A - B - C_w) + \text{PCS liquid activity } (1000 \text{ mL} + C_w)}{\left[1.0 + \frac{C_w}{1000} \right] \text{ kg}}$$

$(\mu\text{Ci/cc})$ (cc) $(\mu\text{Ci/mL})$

Where C_w is the compressibility of water from Procedure CH 4.26.

Where A and B are burette levels from Procedure CH 4.26.

- 2 Determine primary to secondary leak rate:

$$\text{Leak rate (gpm)} = \frac{\text{off gas Xe}^{133} \times \text{condenser air} \times 7.48\text{E3} \left(\frac{\text{cc-gal}}{\text{Cuft-kg}} \right)}{\text{leakage (cfm)} \times \text{Specific isotope activity Xe}^{133} \left(\frac{\mu\text{Ci}}{\text{kg}} \right)}$$

$(\mu\text{Ci/cc})$ (μCi)

Leak rate limit is 0.3 gpm by Technical Specifications.

- 3 The total isotope μ Ci/cc value is not directly representative of the specific activity of the primary coolant system.

WEEKLY RADIOCHEMISTRY

Week of 8-18-86 to 8-24-86

Proc No. CH 1.5
Attachment 7
Revision 1
Page 1 of 2

Approved *[Signature]* 5-14-85

System	SIRW	Fuel Pool	CCW	T-90	T-91	'A' BAST	'B' BAST	RBAT
Tank Level	96%			41%	23%	100%	98%	90%
Day	Mon.	Mon.	Mon.	Mon.	Mon.	Tue.	Mon.	Mon.
Date	8-18-86	8-19-86	8-19-86	8-18-86	8-18-86	8-18-86	8-18-86	8-18-86
Time	0855	1020	0840	0835	0835	0200	2325	1630
Sample Temp °C	25	26	27	27	25	28	28	28
pH	6.1	4.6	9.0	6.9	5.7	3.3	3.3	3.5
Conductivity	48.5	9.7	1350	0.87	<3.0	97	97.5	90.5
Boron, Note 1	1864	1982		5.0	7.0	13,670	12,400	12,200
Chloride	<.02	<.02		<.02	<.02	<.02	<.02	<.02
Fluoride	<.05	<.05		<.05	<.05	<.05	<.05	<.05
Lithium	.012	.005				.014	.014	.014
Chromate			633					
Sodium	9.28	<.005	.053	<.0007	.009	.096	.032	.028
Activity Analysis								
Gross Gamma								
Gross c/m	70,501	66,927	730	313	205	4817	23,185	18,127
Bkg c/m	194	194	194	194	194	186	186	186
mi	4	4	4	4	4	4	4	4
Inst Eff	.2387	.2387	.2387	.2387	.2387	.2387	.2387	.2387
microcuries/ml	3.3E-2	3.1E-2	1.7E-5	5.6E-5	7.9E-6	2.2E-3	1.1E-2	8.5E-3
Gross Beta								
Gross c/m	8264	7063	82	153	79	—	—	—
Bkg c/m	43	43	43	43	43	—	—	—
Vol ml	1	1	10	10	10	—	—	—
Inst Eff	.356	.356	.356	.356	.356	—	—	—
microcuries/ml	1.0E-2	8.9E-3	4.9E-6	1.4E-5	4.6E-6	—	—	—
Tritium								
Net cpm	34719	45866		23264	17410	—	—	—
Vol ml	1	1		1	1	—	—	—
Inst Eff	.3374	.3374		.3374	.3374	—	—	—
µ Ci/ml	4.6E-2	6.1E-2		3.1E-2	2.3E-2	—	—	—

Remarks

Analysis by JEF

Sr Tech Review TCA

Laboratory Supvr Review C. Smith

Note

1	Fuel Pool Boron	1720 ppm minimum
	SIRW Tank Boron	1720 ppm to 2000 ppm

PLANT SECONDARY
CHEMISTRY ANALYSIS,
POWER OPERATIONS

Date 8/17/86 Time 0030

Approved by Stanley Baker 5-14-85

Proc No. CH 1.5
Attachment 10
Revision 1
Page 1 of 1


	Rx Power	A S/G	B S/G	CPD	Feed Train	HDP	A Tower	B Tower	CST	T104	
	97.6 %										
	Blowdown	18K pph	18K pph	NR	NR	NR ↑	20K gpm	9K gpm	NR ↑	56 gpm	
	Sample Temp °C	24	24	26	24		25	25			
	pH	9.10 8.4	9.07 7.15	9.25 9.25	9.23 9.20		7.60 7.70	8.58 8.50			
	Specific Conductivity μmhos/cm	- 4.0	- 3.6	5.3	0.05	- 5.5	360 340	350 340		.03	
All results as noted	Cation Conductivity μmhos/cm	- .60	- .66	- .38	- .48	NR	NR	NR	NR	NR	
	Chloride mg/l						NR	NR			
	Morpholine mg/l						NR	NR			
	Ammonia mg/l						NR	NR			
	Hydrazine mg/l	.015	.013	.030	.015		NR	NR			
	Dissolved Oxygen mg/l			.010 .010	<.005 .006		NR	NR	NR	NR	
	Alkalinity mg/l	NR	NR	NR	NR	NR	81	140	NR	NR	
	Langelier's Index	NR	NR	NR	NR	NR	+ .13	(+ .135)	NR	NR	
	SiO ₂ mg/l										
	SO ₄ mg/l										
	PO ₄ mg/l			NR	NR	NR	NR	NR	NR	NR	
	Fluoride mg/l			NR	NR	NR	NR	NR	NR	NR	
	Sodium ppb	3.5	4.2	-	.28						Blank
	Calcium ppb						52	48			
	Magnesium ppb			<.05							
Copper ppb											
Iron ppb						↓			↓		
Gross Gamma Activity	Gross cpm	190	192								
	Bkg cpm	193	193								
	Inst Eff	.2397	.2327								
	Vol ml	4	4								
	Gross Activity μCi/ml	<5.6E-6	<5.6E-6								
	Iodine Dose Equivalent μCi/gm	-	-								

Not Sampled

Not Sampled

B/C acid pump out of service.

Remarks



Analysis by DCC

Sr Tech Review JKK

Lab Supervisor Review S.J. Jones

FALEX-86 RELEASE RATES

<u>TIME</u>	<u>NOBLE GAS (CI/SEC)</u>	<u>IODINE (DE 1-131) (CI/SEC)</u>
10:30	0	0.00000
10:45	99	0.00080
11:00	163	0.00163
11:15	147	0.00197
11:30	139	0.00188
11:45	137	0.00184
12:00	146	0.00210
12:15	158	0.00203
12:30	181	0.00195
12:45	206	0.00190
13:00	228	0.00183
13:15	254	0.00180
13:30	255	0.00177
13:45	251	0.00149
14:00	20	0.00000
14:15	0	0.00000

No particulates (other than noble gas daughters) are released

RELEASE ISOTOPICS

Nuclide	1045	1100	1200	1400
I-131	1.25E-01	1.37E-01	1.70E-01	2.27E-01
I-132	1.81E-01	1.78E-01	1.67E-01	1.23E-01
I-133	2.08E-01	2.22E-01	2.72E-01	3.40E-01
I-134	2.71E-01	2.37E-01	1.36E-01	3.60E-02
I-135	2.15E-01	2.26E-01	2.54E-01	2.75E-01
Total	1.00E+00	1.00E+00	1.00E+00	1.00E+00

13.2

RELEASE ISOTOPICS

Nuclide	1045	1100	1200	1400
Kr-83m	1.31E-02	1.61E-02	1.47E-02	7.81E-03
Kr-85m	2.83E-02	3.63E-02	4.15E-02	3.41E-02
Kr-85	1.31E-03	1.75E-03	2.32E-03	2.60E-03
Kr-87	5.05E-02	5.97E-02	4.46E-02	1.69E-02
Kr-88	7.60E-02	9.19E-02	9.81E-02	6.71E-02
Kr-89	8.98E-02	4.41E-03	1.25E-08	0.00E+00
Xe-131m	7.60E-02	1.01E-01	1.34E-01	1.53E-01
Xe-133m	8.29E-02	1.15E-01	1.47E-01	1.63E-01
Xe-133	2.49E-01	3.26E-01	4.37E-01	4.87E-01
Xe-135m	7.60E-02	5.05E-02	4.91E-03	0.00E+00
Xe-135	4.29E-02	5.51E-02	6.69E-02	6.80E-02
Xe-137	2.07E-02	1.79E-02	4.46E-07	0.00E+00
Xe-138	1.94E-01	1.24E-01	8.92E-03	0.00E+00
Total	1.00E+00	1.00E+00	1.00E+00	1.00E+00

METEOROLOGICAL DATA

At 0845, electric power to the met tower is lost. Met tower function can be regained if the appropriate electrical crosstie is made in the switchyard. Until that crosstie is made, no met tower data will be available. It is estimated that this should take 30 minutes; therefore, 3 intervals of data are not supplied. The data from 0930 on should not be given out until the met tower power is regained.

At 1045, when the 1E bus is shed by the DBA sequencer, the met tower will again be lost. The 1E bus should be recovered in approximately five minutes, at which time the met tower will be available again. Therefore, only one 15-minute interval of data is lost.

Results of WSI forecasts requested prior to 1000:

+ - MOSPAL

Interpolated MOS for PAL (4219N, 8619W) using ORD, SBN and GRR:

Date/GMT	19/06	19/12	19/18	20/00	20/06	20/12	20/18	21/00
Date/EST	19/01	19/07	19/13	19/19	20/01	20/07	20/13	20/19
Wind-mpH	3210	0107	0110	3408	3005	2705	2008	1805
Clds-.1	2	10	10	8	6	2	1	1
Hgt-ft	7200	800	800	1500	2000	> 7500	> 7500	> 7500
PAS	E	D	C	D	E	E	E	E

+ LOGOUT

Results of WSI forecasts requested after 1000:

+ - MOSPAL

Interpolated MOS for PAL (4219N, 8619N) using ORD, SBN, GRR:

Date/GMT	19/12	19/18	20/00	20/06	20/12	20/18	21/00	21/06
Date/EST	19/07	19/13	19/19	20/01	20/07	20/13	20/19	21/01
Wind-MPH	0207	0210	0020	3415	3010	2710	2705	2703
Clds-.1	10	10	10	8	6	2	2	1
Hgt-ft	500	500	500	2000	5000	7000	> 7500	> 7500
PAS	D	C	C	C	D	D	D	E

+ LOGOUT

Results of hourly meteorological data at Benton Harbor:

<u>Station Name</u>	<u>Time</u>	<u>Wind</u>	<u>PS</u>
Benton Harbor, Michigan	0800	NW12	C
	0900	NNW10	C
	1000	N10	C
	1100	NNE08	D
	1200	NNE07	E
	1300	NNE06	E
	1400	NNE05	E
	1500	NNE05	D

Results of hourly meteorological data at Muskegon:

<u>Station Name</u>	<u>Time</u>	<u>Wind</u>	<u>PS</u>
Muskegon, Michigan	0800	NNW15	C
	0900	NNW12	C
	1000	N10	C
	1100	NNE10	D
	1200	NNE12	C
	1300	NNE08	D
	1400	NNE08	E
	1500	NNE07	E

14.4

PALEX-86
Meteorological Tower Data

08/19/86 Parameter Units	0800	15-Minute Averages								
		Temp C	Stab PASQ	DT C	WS10 MPH	WD10 Deg	SIG1 Deg	WS60 MPH	WD60 Deg	SIG6 Deg
08/19/86 Status 00	0800	18.1	C DT	-0.79 0	10.10 0	321. 0	13.8 0	13.10 0	323. 0	15.1 0
08/19/86 Status 00	0815	18.3	C DT	-0.77 0	9.70 0	320. 0	14.2 0	12.60 0	321. 0	15.2 0
08/19/86 Status 00	0830	18.4	C DT	-0.75 0	9.10 0	325. 0	13.0 0	11.80 0	328. 0	13.4 0
08/19/86 Status 00	0845	NA	NA	NA	NA	NA	NA	NA	NA	NA
08/19/86 Status 00	0900	NA	NA	NA	NA	NA	NA	NA	NA	NA
08/19/86 Status 00	0915	NA	NA	NA	NA	NA	NA	NA	NA	NA
08/19/86 Status 00	0930	19.3	D DT	-0.73 0	7.80 0	346. 0	11.8 0	10.10 0	350. 0	12.1 0
08/19/86 Status 00	0945	19.5	D DT	-0.71 0	7.60 0	351. 0	12.2 0	9.90 0	354. 0	12.1 0
08/19/86 Status 00	1000	19.7	C DT	-0.76 0	8.90 0	358. 0	14.2 0	11.60 0	0 0	15.3 0
08/19/86 Status 00	1015	19.9	D DT	-0.64 0	7.60 0	2. 0	10.1 0	9.90 0	5. 0	12.0 0
08/19/86 Status 00	1030	20.1	D DT	-0.50 0	7.10 0	7. 0	11.2 0	9.20 0	10. 0	11.8 0
08/19/86 Status 00	1045	NA	NA	NA	NA	NA	NA	NA	NA	NA
08/19/86 Status 00	1100	20.4	D DT	-0.30 0	7.80 0	15. 0	8.2 0	10.10 0	17. 0	9.3 0
08/19/86 Status 00	1115	20.8	E DT	-0.24 0	6.50 0	17. 0	7.0 0	8.40 0	19. 0	7.1 0
08/19/86 Status 00	1130	21.2	D DT	-0.30 0	7.20 0	18. 0	8.3 0	9.40 0	20. 0	9.6 0

08/19/86 Parameter Units	1145	15-Minute Averages								
		Temp C	Stab PASQ	DT C	WS10 MPH	WD10 Deg	SIG1 Deg	WS60 MPH	WD60 Deg	SIG6 Deg
08/19/86 Status 00	1145	21.6	D DT	-0.28 0	6.80 0	20. 0	10.7 0	8.80 0	21. 0	9.3 0
08/19/86 Status 00	1200	22.1	E DT	-0.22 0	5.80 0	21. 0	5.6 0	7.50 0	21. 0	6.3 0
08/19/86 Status 00	1215	22.7	E DT	-0.20 0	5.60 0	19. 0	7.2 0	7.30 0	20. 0	6.5 0
08/19/86 Status 00	1230	23.4	E DT	-0.20 0	5.60 0	20. 0	6.7 0	7.40 0	21. 0	6.5 0
08/19/86 Status 00	1245	24.2	D DT	-0.26 0	6.50 0	22. 0	8.9 0	8.40 0	23. 0	10.6 0
08/19/86 Status 00	1300	25.1	D DT	-0.28 0	6.20 0	20. 0	9.3 0	8.10 0	21. 0	8.6 0
08/19/86 Status 00	1315	25.8	D DT	-0.27 0	5.80 0	18. 0	7.7 0	7.50 0	20. 0	8.3 0
08/19/86 Status 00	1330	26.6	E DT	-0.23 0	5.00 0	19. 0	6.6 0	6.50 0	21. 0	6.8 0
08/19/86 Status 00	1345	26.7	E DT	-0.20 0	5.20 0	16. 0	6.3 0	6.80 0	18. 0	7.1 0
08/19/86 Status 00	1400	26.6	E DT	-0.21 0	5.40 0	18. 0	6.3 0	7.00 0	20. 0	7.0 0
08/19/86 Status 00	1415	25.9	D DT	-0.26 0	5.90 0	20. 0	7.8 0	7.70 0	18. 0	8.3 0
08/19/86 Status 00	1430	25.7	D DT	-0.28 0	5.70 0	19. 0	9.4 0	7.40 0	20. 0	10.7 0
08/19/86 Status 00	1445	25.7	D DT	-0.25 0	5.50 0	17. 0	10.5 0	7.10 0	19. 0	9.6 0
08/19/86 Status 00	1500	25.3	E DT	-0.23 0	5.10 0	18. 0	5.3 0	6.60 0	19. 0	6.6 0
08/19/86 Status 00	1515	25.1	D DT	-0.26 0	5.40 0	16. 0	8.4 0	7.00 0	17. 0	9.3 0
08/19/86 Status 00	1530	24.8	E DT	-0.23 0	5.10 0	18. 0	6.1 0	6.60 0	18. 0	5.7 0

08/19/86 Parameter Units	1545	15-Minute Averages								
		Temp C	Stab PASQ	DT C	WS10 MPH	WD10 Deg	SIG1 Deg	WS60 MPH	WD60 Deg	SIG6 Deg
08/19/86 Status 00	1545	24.6	E DT	-0.20 0	5.10 0	17. 0	7.1 0	6.60 0	19. 0	6.8 0
08/19/86 Status 00	1600	24.3	E DT	-0.22 0	8.00 0	16. 0	6.9 0	10.40 0	18. 0	5.8 0
08/19/86 Status 00	1615	24.1	D DT	-0.26 0	9.00 0	15. 0	8.6 0	11.70 0	17. 0	8.8 0
08/19/86 Status 00	1630	23.5	D DT	-0.70 0	10.00 0	12. 0	9.3 0	13.00 0	14. 0	10.4 0
08/19/86 Status 00	1645	22.9	C DT	-0.80 0	12.00 0	10. 0	13.1 0	15.60 0	12. 0	14.8 0
08/19/86 Status 00	1700	22.3	C DT	-0.84 0	15.00 0	10. 0	14.2 0	19.50 0	12. 0	15.7 0
08/19/86 Status 00	1715	22.1	B DT	-0.87 0	20.00 0	10. 0	18.3 0	26.00 0	13. 0	19.7 0
08/19/86 Status 00	1730	22.0	B DT	-0.92 0	20.00 0	10. 0	19.2 0	27.00 0	11. 0	21.3 0
08/19/86 Status 00	1745	19.9	B DT	-0.94 0	20.00 0	10. 0	19.5 0	25.00 0	12. 0	18.7 0
08/19/86 Status 00	1800	19.9	B DT	-0.91 0	20.00 0	10. 0	21.3 0	26.50 0	10. 0	19.2 0

AREA RAD MONITORS
(Panel 1)

<u>Monitor</u>	<u>Alarm Time</u>	<u>Reset/Clear Time</u>
2300	1050	NA
2301	0830	NA
2302	0840	NA
2303	1050	NA
2304	NA	NA
2305	1100	NA
2306	0850	NA
2307	1100	NA
2308	1100	NA
2309	1100	NA
2310	1100	NA
2311	1050	NA
2312	1100	NA
2313	1100	NA
2314	0930	NA
2315	0930	NA
1805	1020	NA
1806	1020	NA
1807	0925	NA
1808	0925	NA

PROCESS RAD MONITORS
(Panel 2)

<u>Monitor</u>	<u>Alarm Time</u>	<u>Reset/Clear Time</u>
0833	NA	NA
0707	NA	NA
0915	NA	NA
1323	NA	NA
1049	NA	NA

15.2

PROCESS RAD MONITORS
(Panel 3)

<u>Monitor</u>	<u>Alarm</u>	<u>Reset/Clear</u>
2318	NA	NA
2319	NA	NA
1809	0830	Will reset if scale changed to x4.
1810	1050	Will reset if scale changed to x4.
1811	NA	NA
1817	0930	NA
1113	NA	NA
0631	NA	NA
2320	1050	Will reset if scale changed to x4.

AREA AND PROCESS RAD MONITORS
(Panel 4)


<u>Monitor</u>	<u>Alarm Time</u>	<u>Reset/Clear</u>
5211	NA	NA
8265	NA	NA
8266	NA	NA
8267	NA	NA
8268	NA	NA
8269	NA	NA
8270	NA	NA
8271	NA	NA
8272	NA	NA

AREA AND PROCESS RAD MONITORS
(Panel 5)



<u>Monitor</u>	<u>Alarm Time</u>	<u>Reset/Clear</u>
5701	1050	NA
5702	NA	NA
5703	NA	NA
5704	NA	NA
5705	NA	NA
5706	NA	NA
5707	NA	NA
5708	NA	NA
5709	NA	NA
5710	0950	NA
5711	NA	NA
5712	NA	NA

AREA AND PROCESS RAD MONITORS
(Panel 6)


<u>Monitor</u>	<u>Alarm Time</u>	<u>Reset/Clear</u>
2325	NA	NA
2326	1050	1415
2327	1050	1415
2323	1050	NA
2324	1050	NA
2321	1050	NA
2322	1050	NA



PALISADES CONTROL ROOM



③ ② ①



0202A READ OUT ON C40 PANEL IN
0202B AUX BUILDING 590' ELEV

15.7

15.9
 ALL MONITOR RESPONSES IN MR/HR EXCEPT 1805-1808 WHICH ARE F/HR

CONSUMERS POWER COMPANY SYSTEM DOCUMENTATION

TIME	2300	2701	2802	2303	2804	2305	2306	2307	2308	2309	2310	2311	2312	2313	2314	2315	1805	1806	1807	1808
1000	50	50	200	50	2.0	20	30,000	100	50	50	20	2000	60	15	850,000	850,000	850	750	780	
1100	40	40	100	10	10	50	50	50	50	20	1000	50	15	800,000	800,000	510	800	700	700	
1200	80	80			10	10	10	10	10	20	20	10	1.0			500				
1300	20	20			1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0								
1400	10	10																		
1500																				
1600																				
1700																				
1800																				

TITLE: ALL MONITOR RESPONSES IN MR/HR EXCEPT 1805-1808 WHICH ARE F/HR
 AUTHORITY: PANEL 1
 COMPLETED: 2314
 REVISED: 1805
 SYSTEM: 1806
 TYPE: 1807
 SERIAL PAGE: 1808
 OF:

1530

CONSUMERS POWER COMPANY SYSTEM DOCUMENTATION

TITLE ALL MONITOR RESPONSES IN CPM

AUTHOR(S) PAGE 2

COMPLETED


REVISION

SYSTEM

TYPE

SERIAL PAGE

OF



15.12


CONSUMERS POWER COMPANY SYSTEM DOCUMENTATION

TIME	2318	2319	1809	1810	1811	1817	1118	0631	2520	COMPLETED	REVISED	SYSTEM	TYPE	SERIAL	DATE
0800	005	005	550	300	500	10,000	2,000	400	3000						
10															
0830															
40															
50															
0900															
10															
20															
0930															
40															
50															
1000															
10															
20															
1030															
40															
50															
1100															
10															
20															
1130															
40															
50															
1200															
10															
20															
1230															
40															
50															
1300															
10															
20															
1330															
40															
50															
1400															

FILE: ALL MONITOR RESPONSES IN CPM


AUTHORITY: P-486L 3

OF



15.16

CONSUMERS POWER COMPANY SYSTEM DOCUMENTATION



15.7
 ALL MONITOR READINGS IN MR/HR EXCEPT S711 AND S712 WHICH ARE CPM

CONSUMERS POWER COMPANY SYSTEM DOCUMENTATION

TITLE	CHEAT	TIME	S701	S702	S703	S704	S705	S706	S707	S708	S709	S710	S711	S712	AUTHORITY	COMPLETED	REVISED	SYSTEM	TYPE	SERIAL PAGE	OF
1000		30		10.0	0.2	1.0	0.1	1.0	10.000	1.0	0.1	10.000	800	400	PANEL 5						
11				10.0	0.2	1.0	0.1	1.0	2.000	1.0	0.1	10.000	800	400							
20				10.0	0.2	1.0	0.1	1.0	1.000	1.0	0.1	10.000	800	400							
1430				10.0	0.2	1.0	0.1	1.0	500	1.0	0.1	10.000	800	400							
40				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
50				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
1500				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
20				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
1530				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
40				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
50				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
1600				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
10				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
20				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
1630				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
40				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
50				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
1700				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
10				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
20				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
1730				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
40				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
50				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							
1800				10.0	0.2	1.0	0.1	1.0		1.0	0.1	10.000	800	400							

15.8

CONSUMERS POWER COMPANY SYSTEM DOCUMENTATION

2321/2322 WHICH ARE R/HR

TITLE ALL MONITOR RESPONSES IN CPM EXCEPT 2327 WHICH IS MR/HR										AUTHOR(S) Panel 6	COMPLETED	REVISED	SYSTEM	TYPE	SERIAL	PAGE
CHART	CPM	CPM	MR/HR	CPM	CPM	R/HR	R/HR	C/sec	C/sec							
TIME	2325	2326	2327	2323	2324	2321	2322	2326	2327							
0800	400	100	0.4	30	40	1.01	1.01	4.0-5	4.0-5							
10																
20																
0830																
40																
50																
0900																
10																
20																
0930	400	150	0.4	30	40	1.5	2.0	6.0-5	4.0-5							
40		200				5.0	8.0	8.0-5	7.0-5							
50						15	20									
1000						20	25									
10						24	28									
20						28	32									
1030						30	35									
40						50	70									
50	2000	OSH	100	300	400	3500	3500	OSH								
1100			200	400	500	5400	5400		90							
10			200	600	700	4700	4700		90							
20			200	800	900	4200	4200		90							
1130			150	700	800	4000	4000		85							
40			150	600	700	3900	3900		85							
50			150	500	600	3900	3900		85							
1200			150	500	600	3900	3900		85							
10			150	500	600	4000	4000		85							
20			150	500	600	4200	4200		85							
1230			200	600	700	4400	4400		90							
40			200	700	800	4700	4700		90							
50			200	800	900	5000	5000		90							
1300			200	800	900	5300	5300		90							
10			200	900	1000	5300	5300		90							
20			200	900	1000	5400	5400		90							
1330			200	900	1000	5400	5400		90							
40			200	900	1000	5300	5300		90							
50			200	900	1000	5200	5200		90							
1400			200	800	900	5100	5100		90							

CFM DATA

The monitor responses on the CFM data sheets denoted by asterisks are dependent on the decade selected on the monitor itself in the control room. Presented values assume that the decade selection is such that the monitor reads out in the first significant figure (ie, 0.100, not 0.010). If it becomes obvious to a controller that monitor decade selection by a player is not being adequately considered, the monitor responses can be changed appropriately.

DATE 1/17/86

TIME 0800

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
0.5000 CPM

SERVICE WATER 0833
4.000+2 CPM

RAD WASTE DISCHG 1049
1.000+5 CPM

STM GEN BLOWDOWN 0707
3.000+3 CPM


*MIXING BASIN 1323
0.5000 CPM

*FAILED FUEL 0202A
0.5500 CPM

MAIN STEAM A 2324
4.000+1 CPM

MAIN STEAM B 2323
3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR
MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 2.000 -2 R/HR
RIA-1806 2.000 -2 R/HR
RIA-1807 2.000 -1 R/HR
RIA-1808 1.000 -1 R/HR
HI RANGE L 1.010 +0 R/HR
HI RANGE R 1.010 +0 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
T-60E L 35%

RIA2326 1.000 +2 CPM
RIA2327 4.000 -1 mR/hr

BACKUP STACK
RIA-2318 ???? CPM
*RIA-2319 ???? CPM

CONTROL ROOM RAD MON 1.000 -1 MR/HR

COND OFF GAS 4.000 +2 CPM

*RAD WASTE PLENUM 0.2000 CPM

*EESG RAD 0.3000 CPM

*WESG RAD 0.5000 CPM

RAD WASTE VENT 5.500+2 CPM

SFP NORTH 5709 1.000 +0 MR/HR

SFP SOUTH 2313 1.000 +0 MR/HR

DATE 3/17/86

TIME 0810

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
0.5000 CPM

SERVICE WATER 0833
4.000 ± 2 CPM

RAD WASTE DISCHG 1049
1.000 ± 5 CPM

STM GEN BLOWDOWN 0707
3.000 ± 3 CPM

*MIXING BASIN 1323
0.5000 CPM

*FAILED FUEL 0202A
0.5500 CPM

MAIN STEAM A 2324
4.000 ± 1 CPM

MAIN STEAM B 2323
3.000 ± 1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 **????** MR/HR

MON 2 **????** MR/HR

CONTAINMENT ISOLATION

RIA-1805 **2.000 - 2** R/HR

RIA-1806 **2.000 - 2** R/HR

RIA-1807 **2.000 - 1** R/HR

RIA-1808 **1.000 - 1** R/HR

HI RANGE L **1.010 ± 0** R/HR

HI RANGE R **1.010 ± 0** R/HR

DIRTY WASTE DRAIN TANKS

T-60W L **35%**

T-60E L **35%**

RIA2326 **1.000 ± 2** CPM

RIA2327 **4.000 - 1** mR/hr

BACKUP STACK RIA-2318 **????** CPM

*RIA-2319 **????** CPM

CONTROL ROOM RAD MON **1.000 - 1** MR/HR

COND OFF GAS **4.000 ± 2** CPM

*RAD WASTE PLENUM **0.2000** CPM

*EESG RAD **0.3000** CPM

*WESG RAD **0.5000** CPM

RAD WASTE VENT **5.500 ± 2** CPM

SFP NORTH 5709 **1.000 ± 0** MR/HR

SFP SOUTH 2313 **1.000 ± 0** MR/HR

DATE 8/17/86
 TIME 0820

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM


STM GEN BLOWDOWN 0707
 3.000+3 CPM

*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 0.5500 CPM

MAIN STEAM A 2324
 4.000+1 CPM

MAIN STEAM B 2323
 3.000+1 CPM



FUEL HANDLING AREAS

MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 2.000-2 R/HR
 RIA-1806 2.000-2 R/HR
 RIA-1807 2.000-1 R/HR
 RIA-1808 1.000-1 R/HR
 HI RANGE L 1.010+0 R/HR
 HI RANGE R 1.010+0 R/HR


DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%

RIA2326 1.000+2 CPM
 RIA2327 4.000-1 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 1.000-1 MR/HR



SFP NORTH 5709 1.000+0 MR/HR
 SFP SOUTH 2313 1.000+0 MR/HR

*DECADE DEPENDENT ON CR SWITCH POSITION



DAY 8/17/86
 TIME 0830

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000 +2 CPM

RAD WASTE DISCHG 1049
 1.000 +5 CPM

STM GEN BLOWDOWN 0707
 3.000 +3 CPM

*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 0.5500 CPM

MAIN STEAM A 2324
 4.000 +1 CPM

MAIN STEAM B 2323
 3.000 +1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 2.000 -2 R/HR
 RIA-1806 2.000 -2 R/HR
 RIA-1807 2.000 -1 R/HR
 RIA-1808 1.000 -1 R/HR
 HI RANGE L 1.010 +0 R/HR
 HI RANGE R 1.010 +0 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%

RIA2326 1.000 +2 CPM
 RIA2327 4.000 -1 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD MON
 1.000 -1 MR/HR

COND OFF GAS
 4.000 +2 CPM

*RAD WASTE PLENUM
 0.2000 CPM

*EESG RAD
 0.3000 CPM

*WESG RAD
 0.5000 CPM

RAD WASTE VENT
 5.500 +2 CPM

SFP NORTH 5709
 1.000 +0 MR/HR

SFP SOUTH 2313
 1.000 +0 MR/HR

DATE 9/17/86
 TIME 0840

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000 + 2 CPM

RAD WASTE DISCHG 1049
 1.000 + 5 CPM

STM GEN BLOWDOWN 0707
 3.000 + 3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 0.5500 CPM

MAIN STEAM A 2324
 4.000 + 1 CPM

MAIN STEAM B 2323
 3.000 + 1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 2.000 - 2 R/HR
 RIA-806 2.000 - 2 R/HR
 RIA-807 2.000 - 1 R/HR
 RIA-1808 1.000 - 1 R/HR
 HI RANGE L 1.010 + 0 R/HR
 HI RANGE R 1.010 + 0 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 1.000 + 2 CPM
 RIA2327 4.000 - 1 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 1.000 - 1 MR/HR

COND OFF GAS
 4.000 + 2 CPM
 *RAD WASTE PLENUM
 0.2000 CPM
 *EESG RAD
 0.3000 CPM
 *WESG RAD
 0.5000 CPM
 RAD WASTE VENT
 5.500 + 2 CPM

SFP NORTH
 5709 1.000 + 0 MR/HR
 SFP SOUTH
 2313 1.000 + 0 MR/HR

DATE 8/17/86
 TIME 0850

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000 + 2 CPM

RAD WASTE DISCHG 1049
 1.000 + 5 CPM

STM GEN BLOWDOWN 0707
 3.000 + 3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.000 CPM

MAIN STEAM A 2324
 4.000 + 1 CPM

MAIN STEAM B 2323
 3.000 + 1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION




RIA2326 1.000 + 2 CPM
 RIA2327 4.000 - 1 mR/hr

BACKUP STACK
 RIA-2318 2.???

*RIA-2319 2.???

CONTROL ROOM RAD
 MON 1.000 - 1 MR/HR



SFP NORTH 5709 1.000 + 0 MR/HR

SFP SOUTH 233 1.000 + 0 MR/HR

DATE 3/17/86
 TIME 0900

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 3.000+3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 4.000+1 CPM

MAIN STEAM B 2323
 3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ??? MR/HR
 MON 2 ??? MR/HR

CONTAINMENT ISOLATION

RIA-1805 2.000 -2 R/HR
 RIA-1806 2.000 -2 R/HR
 RIA-1807 3.500 +0 R/HR
 RIA-1808 3.000 +0 R/HR
 HI RANGE L 1.010 +0 R/HR
 HI RANGE R 1.010 +0 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 1.000+2 CPM
 RIA2327 4.000 -1 MR/HR

BACKUP STACK RIA-2318 ??? CPM

*RIA-2319 ??? CPM

CONTROL ROOM RAD MON 1.000 -1 MR/HR

COND OFF GAS 5.000+2 CPM

*RAD WASTE PLENUM 0.2000 CPM

*EESG RAD 0.6000 CPM

*WESG RAD 1.0000 CPM

RAD WASTE VENT 1.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.000+0 MR/HR

DATE 8/17/86

TIME 0910

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
0.5000 CPM

SERVICE WATER 0833
4.000+2 CPM

RAD WASTE DISCHG 1049
1.000+5 CPM

STM GEN BLOWDOWN 0707
3.000+3 CPM


*MIXING BASIN 1323
0.5000 CPM

*FAILED FUEL 0202A
1.0000 CPM

MAIN STEAM A 2324
4.000+1 CPM

MAIN STEAM B 2323
3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 2.000-2 R/HR
RIA-1806 2.000-2 R/HR
RIA-1807 4.000+0 R/HR
RIA-1808 3.500+0 R/HR
HI RANGE L 1.010+0 R/HR
HI RANGE R 1.010+0 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
T-60E L 35%



RIA2326 1.000+2 CPM
RIA2327 4.000-1 mR/hr

BACKUP STACK
RIA-2318 ???? CPM
*RIA-2319 ???? CPM

CONTROL ROOM RAD
MON 1.000-1 MR/HR

COND OFF GAS
5.000+2 CPM
*RAD WASTE PLENUM
0.2000 CPM
*EESG RAD
0.6000 CPM
*WESG RAD
1.0000 CPM
RAD WASTE VENT
1.000+3 CPM

SFP NORTH
5709 1.000+0 MR/HR
SFP SOUTH
2313 1.000+0 MR/HR

DAT 3/17/86
 TIME 0920

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 3.000+3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 4.000+1 CPM

MAIN STEAM B 2323
 3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 2.000-2 R/HR
 RIA-1806 2.000-2 R/HR
 RIA-1807 4.500+0 R/HR
 RIA-1808 4.000+0 R/HR
 HI RANGE L 1.010+0 R/HR
 HI RANGE R 1.010+0 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 1.000+2 CPM
 RIA2327 4.000-1 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 1.000-1 MR/HR

COND OFF GAS
 5.000+2 CPM

*RAD WASTE PLENUM
 0.2000 CPM

*EESG RAD
 0.6000 CPM

*WESG RAD
 1.0000 CPM

RAD WASTE VENT
 1.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.00+0 MR/HR

DAT 1/17/86

TIME 0930

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
0.5000 CPM

SERVICE WATER 0833
4.000+2 CPM

RAD WASTE DISCHG 1049
1.000+5 CPM

STM GEN BLOWDOWN 0707
3.000+3 CPM


*MIXING BASIN 1323
0.5000 CPM

*FAILED FUEL 0202A
1.0000 CPM

MAIN STEAM A 2324
4.000+1 CPM

MAIN STEAM B 2323
3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 1.500 -1 R/HR
RIA-1806 3.500 -1 R/HR
RIA-1807 5.500 +0 R/HR
RIA-1808 5.000 +0 R/HR
HI RANGE L 1.500 +0 R/HR
HI RANGE R 2.000 +0 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
T-60E L 35%



RIA2326 1.500+2 CPM
RIA2327 4.000-1 mR/hr

BACKUP STACK
RIA-2318 ???? CPM
*RIA-2319 ???? CPM

CONTROL ROOM RAD
MON 1.000-1 MR/HR

COND OFF GAS 5.000+2 CPM
*RAD WASTE PLENUM 0.2000 CPM
*EESG RAD 0.6000 CPM
*WESG RAD 1.0000 CPM
RAD WASTE VENT 1.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR
SFP SOUTH 2313 1.000+0 MR/HR

DATE 8/17/86
 TIME 0940

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 3.000+3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 4.000+1 CPM

MAIN STEAM B 2323
 3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ??? MR/HR
 MON 2 ??? MR/HR

CONTAINMENT ISOLATION

RIA-1805 2.500-1 R/HR
 RIA-1806 5.000-1 R/HR
 RIA-1807 7.000+0 R/HR
 RIA-1808 6.000+0 R/HR
 HI RANGE L 5.000+0 R/HR
 HI RANGE R 8.000+0 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 2.000+0 CPM
 RIA2327 4.000-1 mR/hr

BACKUP STACK RIA-2318 ??? CPM

*RIA-2319 ??? CPM

CONTROL ROOM RAD MON 1.000-1 MR/HR

COND OFF GAS 5.000+2 CPM

*RAD WASTE PLENUM 0.2000 CPM

*EESG RAD 0.6000 CPM

*WESG RAD 1.0000 CPM

RAD WASTE VENT 1.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.000+0 MR/HR

DAT 9/17/86

TIME 0950

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
0.5000 CPM

SERVICE WATER 0833
4.000 + 2 CPM

RAD WASTE DISCHG 1049
1.000 + 5 CPM

STM GEN BLOWDOWN 0707
3.000 + 3 CPM


*MIXING BASIN 1323
0.5000 CPM

*FAILED FUEL 0202A
1.0000 CPM

MAIN STEAM A 2324
4.000 + 1 CPM

MAIN STEAM B 2323
3.000 + 1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 3.000 - 1 R/HR
RIA-1806 6.000 - 1 R/HR
RIA-1807 8.000 + 0 R/HR
RIA-1808 7.000 + 0 R/HR
HI RANGE L 1.500 + 1 R/HR
HI RANGE R 2.000 + 1 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
T-60E L 35%



RIA2326 2.000 + 2 CPM
RIA2327 4.000 - 1 mR/hr

BACKUP STACK
RIA-2318 ???? CPM
*RIA-2319 ???? CPM

CONTROL ROOM RAD
MON 1.000 - 1 MR/HR

COND OFF GAS
5.000 + 2 CPM
*RAD WASTE PLENUM
0.2000 CPM
*EESG RAD
0.6000 CPM
*WESG RAD
1.0000 CPM
RAD WASTE VENT
1.000 + 3 CPM

SFP NORTH 5709 1.000 + 0 MR/HR
SFP SOUTH 2313 1.000 + 0 MR/HR

DAT 8/17/86
 TIME 1000

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 3.000+3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 4.000+1 CPM

MAIN STEAM B 2323
 3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 2.000+0 R/HR
 RIA-1806 4.100+0 R/HR
 RIA-1807 9.000+0 R/HR
 RIA-1808 8.000+0 R/HR
 HI RANGE L 2.000+1 R/HR
 HI RANGE R 2.500+1 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 2.000+2 CPM
 RIA2327 4.000-1 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD MON
 MR/HR

COND OFF GAS 5.000+2 CPM
 *RAD WASTE PLENUM 0.2000 CPM
 *EESG RAD 0.6000 CPM
 *WESG RAD 1.0000 CPM
 RAD WASTE VENT 1.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR
 SFP SOUTH 2313 1.000+0 MR/HR

DATE 8/17/86
 TIME 1010

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 3.000+3 CPM

*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 4.000+1 CPM

MAIN STEAM B 2323
 3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 4.000 + 0 R/HR
 RIA-1806 5.000 + 0 R/HR
 RIA-1807 1.000 + 1 R/HR
 RIA-1808 9.000 + 1 R/HR
 HI RANGE L 2.400 + 1 R/HR
 HI RANGE R 2.800 + 1 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%

RIA2326 2.000 + 2 CPM
 RIA2327 9.000 - 1 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON MR/HR

COND OFF GAS
 5.000 + 2 CPM

*RAD WASTE PLENUM
 0.2000 CPM

*EESG RAD
 0.6000 CPM

*WESG RAD
 1.0000 CPM

RAD WASTE VENT
 1.000 + 3 CPM

SFP NORTH 5709
 1.000 + 0 MR/HR

SFP SOUTH 2313
 1.000 + 0 MR/HR

DATE 8/17/86
 TIME 1020

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 3.000+3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 4.000+1 CPM

MAIN STEAM B 2323
 3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 7.000+0 R/HR
 RIA-1806 6.000+0 R/HR
 RIA-1807 1.200+1 R/HR
 RIA-1808 1.000+1 R/HR
 HI RANGE L 2.800+1 R/HR
 HI RANGE R 3.200+1 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2325 2.000+2 CPM
 RIA2327 4.000-1 mR/hr

BACKUP STACK RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD MON: MR/HR

COND OFF GAS 5.000+2 CPM

*RAD WASTE PLENUM 0.2000 CPM

*EESG RAD 0.6000 CPM

*WESG RAD 1.0000 CPM

RAD WASTE VENT 1.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.000+0 MR/HR

DATE 8/17/86
 TIME 1030

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 3.000+3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 4.000+1 CPM

MAIN STEAM B 2323
 3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 7.000 + 0 R/HR
 RIA-1806 6.000 + 0 R/HR
 RIA-1807 1.200 + 1 R/HR
 RIA-1808 1.000 + 1 R/HR
 HI RANGE L 3.000 + 1 R/HR
 HI RANGE R 3.500 + 1 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 2.000+2 CPM
 RIA2327 4.000-1 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD MON
 MR/HR

COND OFF GAS
 5.000+2 CPM

*RAD WASTE PLENUM
 0.2000 CPM

*EESG RAD
 0.6000 CPM

*WESG RAD
 1.0000 CPM

RAD WASTE VENT
 1.000+3 CPM

SFP NORTH 5709
 1.000+0 MR/HR

SFP SOUTH 2313
 1.000+0 MR/HR

DAT 9/17/86

TIME 1040

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
0.5000 CPM

SERVICE WATER 0833
4.000+2 CPM

RAD WASTE DISCHG 1049
1.000+5 CPM

STM GEN BLOWDOWN 0707
3.000+3 CPM


*MIXING BASIN 1323
0.5000 CPM

*FAILED FUEL 0202A
1.0000 CPM

MAIN STEAM A 2324
4.000+1 CPM

MAIN STEAM B 2323
3.000+1 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR
MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 7.000+0 R/HR
RIA-1806 6.000+0 R/HR
RIA-1807 1.200+1 R/HR
RIA-1808 1.000+1 R/HR
HI RANGE L 5.000+1 R/HR
HI RANGE R 7.000+1 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
T-60E L 35%

RIA2326 2.000+2 CPM
RIA2327 4.000-1 mR/hr

BACKUP STACK
RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
MON MR/HR

COND OFF GAS
5.000+2 CPM

*RAD WASTE PLENUM
0.2000 CPM

*EESG RAD
0.6000 CPM

*WESG RAD
1.0000 CPM

RAD WASTE VENT
1.000+3 CPM

SFP NORTH
5709 1.000+0 MR/HR

SFP SOUTH
2313 1.000+0 MR/HR

DATE 8/17/86
 TIME 1050

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.7000 CPM

SERVICE WATER 0833
 8.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 5.000+3 CPM


*MIXING BASIN 1323
 1.0000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 4.000+2 CPM

MAIN STEAM B 2323
 3.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 3.500+2 R/HR
 RIA-1806 6.000+2 R/HR
 RIA-1807 5.000+2 R/HR
 RIA-1808 5.000+2 R/HR
 HI RANGE L 3.500+3 R/HR
 HI RANGE R 3.500+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 ???? CPM
 RIA2327 1.000+2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 2.000+1 MR/HR

COND OFF GAS 2.500+3 CPM
 *RAD WASTE PLENUM 0.4000 CPM
 *EESG RAD 0.1500 CPM
 *WESG RAD 0.2000 CPM
 RAD WASTE VENT 2.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR
 SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1100

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.7000 CPM

SERVICE WATER 0833
 8.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 5.000+3 CPM


*MIXING BASIN 1323
 1.0000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 5.000+2 CPM

MAIN STEAM B 2323
 4.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.400 + 2 R/HR
 RIA-1806 9.000 + 2 R/HR
 RIA-1807 7.700 + 2 R/HR
 RIA-1808 7.700 + 2 R/HR
 HI RANGE L 5.400 + 3 R/HR
 HI RANGE R 5.400 + 3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 ???? CPM
 RIA2327 2.000 + 2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 2.000 + 1 MR/HR

COND OFF GAS
 2.500 + 3 CPM

*RAD WASTE PLENUM
 0.4000 CPM

*EESG RAD
 0.1500 CPM

*WESG RAD
 0.2000 CPM

RAD WASTE VENT
 2.000 + 3 CPM

SFP NORTH
 5709 1.000 + 0 MR/HR

SFP SOUTH
 2313 1.500 + 1 MR/HR

DATE 8/17/86
 TIME 1110

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.7000 CPM

SERVICE WATER 0833
 8.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 5.000+3 CPM


*MIXING BASIN 1323
 1.0000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 7.000+2 CPM

MAIN STEAM B 2323
 6.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 4.900+2 R/HR
 RIA-1806 7.900+2 R/HR
 RIA-1807 7.000+2 R/HR
 RIA-1808 7.000+2 R/HR
 HI RANGE L 4.700+3 R/HR
 HI RANGE R 4.700+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 ???? CPM
 RIA2327 1.700+2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD MON
 2.000+1 MR/HR

COND OFF GAS
 2.500+3 CPM

*RAD WASTE PLENUM
 0.4000 CPM

*EESG RAD
 0.1500 CPM

*WESG RAD
 0.2000 CPM

RAD WASTE VENT
 2.000+3 CPM

SFP NORTH 5709
 1.000+0 MR/HR

SFP SOUTH 2313
 1.500+1 MR/HR

DATE 8/17/86
 TIME 1120

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.7000 CPM

SERVICE WATER 0833
 8.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 5.000+3 CPM


*MIXING BASIN 1323
 1.0000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 9.000+2 CPM

MAIN STEAM B 2323
 8.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 4.400+2 R/HR
 RIA-1806 8.800+2 R/HR
 RIA-1807 6.300+2 R/HR
 RIA-1808 6.300+2 R/HR
 HI RANGE L 4.200+3 R/HR
 HI RANGE R 4.200+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 ???? CPM
 RIA2327 1.850+2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 2.000+1 MR/HR

COND OFF GAS 2.500+3 CPM
 *RAD WASTE PLENUM 0.4000 CPM
 *EESG RAD 0.1500 CPM
 *WESG RAD 0.2000 CPM
 RAD WASTE VENT 2.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86

TIME 1130

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
0.7000 CPM

SERVICE WATER 0833
8.000+2 CPM

RAD WASTE DISCHG 1049
1.000+5 CPM

STM GEN BLOWDOWN 0707
5.000+3 CPM


*MIXING BASIN 1323
1.0000 CPM

*FAILED FUEL 0202A
1.0000 CPM

MAIN STEAM A 2324
8.000+2 CPM

MAIN STEAM B 2323
7.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 4.000+2 R/HR
RIA-1806 6.600+2 R/HR
RIA-1807 5.700+2 R/HR
RIA-1808 5.700+2 R/HR
HI RANGE L 4.000+3 R/HR
HI RANGE R 4.000+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
T-60E L 35%



RIA2326 ???? CPM
RIA2327 1.600+2 mR/hr

BACKUP STACK
RIA-2318 ???? CPM
*RIA-2319 ???? CPM

CONTROL ROOM RAD MON
2.000+1 MR/HR

COND OFF GAS 2.500+3 CPM
*RAD WASTE PLENUM 0.4000 CPM
*EESG RAD 0.1500 CPM
*WESG RAD 0.2000 CPM
RAD WASTE VENT 2.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR
SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1140

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.7000 CPM

SERVICE WATER 0833
 8.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 5.000+3 CPM


*MIXING BASIN 1323
 1.0000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 7.000+2 CPM

MAIN STEAM B 2323
 6.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 4.000+2 R/HR
 RIA-1806 6.500+2 R/HR
 RIA-1807 5.700+2 R/HR
 RIA-1808 5.600+2 R/HR
 HI RANGE L 3.900+3 R/HR
 HI RANGE R 3.900+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 ???? CPM
 RIA2327 1.550+2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 2.000+1 MR/HR

COND OFF GAS
 2.500+3 CPM

*RAD WASTE PLENUM
 0.4000 CPM

*EESG RAD
 0.1500 CPM

*WESG RAD
 0.2000 CPM

RAD WASTE VENT
 2.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR
 SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86

TIME 1150

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM


MAIN STEAM A 2324

6.000+2 CPM

MAIN STEAM B 2323

5.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 4.000+2 R/HR

RIA-1806 6.500+2 R/HR

RIA-1807 5.600+2 R/HR

RIA-1808 5.600+2 R/HR


HI RANGE L 3.900+3 R/HR

HI RANGE R 3.900+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%



RIA2326 ???? CPM

RIA2327 1.550+2 mR/hr

BACKUP STACK
RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
MON 2.000+1 MR/HR

COND OFF GAS
2.500+3 CPM

*RAD WASTE PLENUM
0.4000 CPM

*EESG RAD
0.1500 CPM

*WESG RAD
0.2000 CPM

RAD WASTE VENT
2.000+3 CPM

SFP NORTH
5709 1.000+0 MR/HR

SFP SOUTH
2313 1.500+1 MR/HR

DATE 1/17/86
 TIME 1200

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM


MAIN STEAM A 2324

6.000+2 CPM

MAIN STEAM B 2323

5.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 3.900+2 R/HR

RIA-1806 6.500+2 R/HR

RIA-1807 5.600+2 R/HR

RIA-1808 5.600+2 R/HR


HI RANGE L 3.900+3 R/HR

HI RANGE R 3.900+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%



RIA2326 ???? CPM

RIA2327 1.580+2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 2.000+1 MR/HR

COND OFF GAS
 2.500+3 CPM

*RAD WASTE PLENUM
 0.4000 CPM

*EESG RAD
 0.1500 CPM

*WESG RAD
 0.2000 CPM

RAD WASTE VENT
 2.000+3 CPM

SFP NORTH
 5709 1.000+0 MR/HR

SFP SOUTH
 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1210

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.7000 CPM

SERVICE WATER 0833
 8.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 5.000+3 CPM



*MIXING BASIN 1323
 1.0000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 6.000+2 CPM

MAIN STEAM B 2323
 5.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



DATE 8/17/86

TIME 1220

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM


MAIN STEAM A 2324

6.000+2 CPM

MAIN STEAM B 2323

5.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 4.800+2 R/HR

RIA-1806 8.000+2 R/HR

RIA-1807 7.000+2 R/HR

RIA-1808 7.100+2 R/HR


HI RANGE L 4.200+3 R/HR

HI RANGE R 4.200+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%



RIA2326 ???? CPM

RIA2327 1.720+2 mR/hr

BACKUP STACK RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD MON 2.000+1 MR/HR

COND OFF GAS 2.500+3 CPM

*RAD WASTE PLENUM 0.4000 CPM

*EESG RAD 0.1500 CPM

*WESG RAD 0.2000 CPM

RAD WASTE VENT 2.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86

TIME 1230

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM


MAIN STEAM A 2324

7.000+2 CPM

MAIN STEAM B 2323

6.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.300+2 R/HR

RIA-1806 8.800+2 R/HR

RIA-1807 7.600+2 R/HR

RIA-1808 7.600+2 R/HR


HI RANGE L 4.400+3 R/HR

HI RANGE R 4.400+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%



RIA2326 ???? CPM

RIA2327 1.800+2 mR/hr

BACKUP STACK
RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
MON 2.000+1 MR/HR

COND OFF GAS
2.500+3 CPM

*RAD WASTE PLENUM
0.4000 CPM

*EESG RAD
0.1500 CPM

*WESG RAD
0.2000 CPM

RAD WASTE VENT
2.000+3 CPM

SFP NORTH
5709 1.000+0 MR/HR

SFP SOUTH
2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1240

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DRAIN 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM

MAIN STEAM A 2324

8.000+2 CPM

MAIN STEAM B 2323

7.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.600+2 R/HR

RIA-1806 9.200+2 R/HR

RIA-1807 7.900+2 R/HR

RIA-1808 7.900+2 R/HR


HI RANGE L 4.700+3 R/HR

HI RANGE R 4.700+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%



RIA2326 ???? CPM

RIA2327 1.500+2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 2.000+1 MR/HR

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1250

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.7000 CPM

SERVICE WATER 0833
 8.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 5.000+3 CPM


*MIXING BASIN 1323
 1.0000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 9.000+2 CPM

MAIN STEAM B 2323
 8.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ??? MR/HR
 MON 2 ??? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.500 +2 R/HR
 RIA-1806 9.100 +2 R/HR
 RIA-1807 7.800 +2 R/HR
 RIA-1808 7.800 +2 R/HR
 HI RANGE L 5.000 +3 R/HR
 HI RANGE R 5.000 +3 R/HR


DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%

RIA2326 ??? CPM
 RIA2327 2.050 +2mR/hr

BACKUP STACK
 RIA-2318 ??? CPM
 *RIA-2319 ??? CPM

CONTROL ROOM RAD MON
 2.000 +1 MR/HR



COND OFF GAS 2.500 +3 CPM
 *RAD WASTE PLENUM 0.4000 CPM
 *EESG RAD 0.1500 CPM
 *WESG RAD 0.2000 CPM
 RAD WASTE VENT 2.000 +3 CPM

SFP NORTH 5709 1.000 +0 MR/HR

SFP SOUTH 2313 1.500 +1 MR/HR

DATE 8/17/86
 TIME 1300

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM

MAIN STEAM A 2324

9.000+2 CPM

MAIN STEAM B 2323

8.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.400+2 R/HR

RIA-1806 9.000+2 R/HR

RIA-1807 7.700+2 R/HR

RIA-1808 7.700+2 R/HR


HI RANGE L 5.300+3 R/HR

HI RANGE R 5.300+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%



RIA2326 ???? CPM

RIA2327 2.150+2 mR/hr

BACKUP STACK RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD MON 2.000+1 MR/HR

COND OFF GAS 2.500+3 CPM

*RAD WASTE PLENUM 0.4000 CPM

*EESG RAD 0.1500 CPM

*WESG RAD 0.2000 CPM

RAD WASTE VENT 2.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1310

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM


MAIN STEAM A 2324

1.000+3 CPM

MAIN STEAM B 2323

9.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.400+2 R/HR
 RIA-1806 9.000+2 R/HR
 RIA-1807 7.700+2 R/HR
 RIA-1808 7.700+2 R/HR
 HI RANGE L 5.300+3 R/HR
 HI RANGE R 5.300+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 ???? CPM
 RIA2327 2.220+2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON: 2.000+1 MR/HR

COND OFF GAS 2.500+3 CPM
 *RAD WASTE PLENUM 0.4000 CPM
 *EESG RAD 0.1500 CPM
 *WESG RAD 0.2000 CPM
 RAD WASTE VENT 2.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR
 SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1320

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM

MAIN STEAM A 2324

1.000+3 CPM

MAIN STEAM B 2323

9.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.400+2 R/HR

RIA-1806 9.000+2 R/HR

RIA-1807 7.700+2 R/HR

RIA-1808 7.700+2 R/HR


HI RANGE L 5.400+3 R/HR

HI RANGE R 5.400+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%



SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 500+1 MR/HR

DATE 8/17/86
 TIME 1330

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM


MAIN STEAM A 2324

1.000+3 CPM

MAIN STEAM B 2323

9.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.400+2 R/HR

RIA-1806 9.000+2 R/HR

RIA-1807 7.700+2 R/HR

RIA-1808 7.700+2 R/HR


HI RANGE L 5.400+3 R/HR

HI RANGE R 5.400+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%



RIA2326 ???? CPM

RIA2327 2.250+2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 2.000+1 MR/HR

COND OFF GAS
 2.500+3 CPM

*RAD WASTE PLENUM
 0.4000 CPM

*EESG RAD
 0.1500 CPM

*WESG RAD
 0.2000 CPM

RAD WASTE VENT
 2.000+3 CPM

SFP NORTH
 5709 1.000+0 MR/HR

SFP SOUTH
 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1340

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM


MAIN STEAM A 2324

1.000+3 CPM

MAIN STEAM B 2323

9.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.400+2 R/HR

RIA-1806 9.000+2 R/HR

RIA-1807 7.700+2 R/HR

RIA-1808 7.700+2 R/HR


HI RANGE L 5.300+3 R/HR

HI RANGE R 5.300+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%



RIA2326 ???? CPM

RIA2327 2.200+2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 2.000+1 MR/HR

COND OFF GAS
 2.500+3 CPM

*RAD WASTE PLENUM
 0.4000 CPM

*EESG RAD
 0.1500 CPM

*WESG RAD
 0.2000 CPM

RAD WASTE VENT
 2.000+3 CPM

SFP NORTH
 5709 1.000+0 MR/HR

SFP SOUTH
 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1350

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.7000 CPM

SERVICE WATER 0833
 8.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 5.000+3 CPM


*MIXING BASIN 1323
 1.0000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 1.000+3 CPM

MAIN STEAM B 2323
 9.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.400+2 R/HR
 RIA-1806 9.000+2 R/HR
 RIA-1807 7.700+2 R/HR
 RIA-1808 7.700+2 R/HR
 HI RANGE L 5.200+3 R/HR
 HI RANGE R 5.200+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 ???? CPM
 RIA2327 2.080+2 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 2.000+1 MR/HR

COND OFF GAS 2.500+3 CPM
 *RAD WASTE PLENUM 0.4000 CPM
 *EESG RAD 0.1500 CPM
 *WESG RAD 0.2000 CPM
 RAD WASTE VENT 2.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR
 SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86

TIME 1400

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.7000 CPM

SERVICE WATER 0833

8.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

5.000+3 CPM

*MIXING BASIN 1323

1.0000 CPM

*FAILED FUEL 0202A

1.0000 CPM

MAIN STEAM A 2324

9.000+2 CPM

MAIN STEAM B 2323

8.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.100+2 R/HR

RIA-1806 8.500+2 R/HR

RIA-1807 7.300+2 R/HR

RIA-1808 7.300+2 R/HR

HI RANGE L 5.100+3 R/HR

HI RANGE R 5.100+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%

RIA2326 ???? CPM

RIA2327 1.800+2 mR/hr

BACKUP STACK RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD MON 2.000+1 MR/HR

COND OFF GAS 2.500+3 CPM

*RAD WASTE PLENUM 0.4000 CPM

*EESG RAD 0.1500 CPM

*WESG RAD 0.2000 CPM

RAD WASTE VENT 2.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1410

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.7000 CPM

SERVICE WATER 0833
 8.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 5.000+3 CPM


*MIXING BASIN 1323
 1.0000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 5.000+2 CPM

MAIN STEAM B 2323
 6.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.000+2 R/HR
 RIA-1806 8.000+2 R/HR
 RIA-1807 7.000+2 R/HR
 RIA-1808 7.000+2 R/HR
 HI RANGE L 5.000+3 R/HR
 HI RANGE R 5.000+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 ???? CPM
 RIA2327 2.000+1 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 1.000+1 MR/HR

COND OFF GAS 2.000+3 CPM
 *RAD WASTE PLENUM 0.000 CPM
 *EESG RAD 0.8000 CPM
 *WESG RAD 0.1000 CPM
 RAD WASTE VENT 1.000+3 CPM

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.500+1 MR/HR

DAT 8/17/86
 TIME 1420

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 3.000+3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.000+0 CPM

MAIN STEAM A 2324
 1.000+2 CPM

MAIN STEAM B 2323
 1.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.000+2 R/HR
 RIA-1806 8.000+2 R/HR
 RIA-1807 7.000+2 R/HR
 RIA-1808 7.000+2 R/HR
 HI RANGE L 5.000+3 R/HR
 HI RANGE R 5.000+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%



RIA2326 1.000+6 CPM
 RIA2327 1.000+0 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 1.000+0 MR/HR

COND OFF GAS 1.000+3 CPM
 *RAD WASTE PLENUM 0.2000 CPM
 *EESG RAD 0.3000 CPM
 *WESG RAD 0.5000 CPM
 RAD WASTE VENT 6.000+2 CPM

SFP NORTH 5709 1.000+0 MR/HR
 SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1430

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.5000 CPM

SERVICE WATER 0833

4.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

3.000+3 CPM

*MIXING BASIN 1323

0.5000 CPM

*FAILED FUEL 0202A

1.0000 CPM


MAIN STEAM A 2324

1.000+2 CPM

MAIN STEAM B 2323

1.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.000+2 R/HR

RIA-1806 8.000+2 R/HR

RIA-1807 7.000+2 R/HR

RIA-1808 7.000+2 R/HR

HI RANGE L 5.000+3 R/HR

HI RANGE R 5.000+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%

RIA2326 1.000+3 CPM

RIA2327 1.000+0 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 1.000+1 MR/HR

COND OFF GAS
 5.000+2 CPM

*RAD WASTE PLENUM
 0.2000 CPM

*EESG RAD
 0.3000 CPM

*WESG RAD
 0.5000 CPM

RAD WASTE VENT
 6.000+2 CPM

SFP NORTH
 5709 1.000+0 MR/HR

SFP SOUTH
 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1440

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 3.000+3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 1.000+2 CPM

MAIN STEAM B 2323
 1.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.000+2 R/HR
 RIA-1806 8.000+2 R/HR
 RIA-1807 7.000+2 R/HR
 RIA-1808 7.000+2 R/HR
 HI RANGE L 5.000+3 R/HR
 HI RANGE R 5.000+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%
 T-60E L 35%

RIA2326 5.000+2 CPM
 RIA2327 1.000+0 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 1.000+1 MR/HR

COND OFF GAS
 5.000+2 CPM

*RAD WASTE PLENUM
 0.2000 CPM

*EESG RAD
 0.3000 CPM

*WESG RAD
 0.5000 CPM

RAD WASTE VENT
 6.000+2 CPM

SFP NORTH 5709 1.000+0 MR/HR
 SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86
 TIME 1450

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915
 0.5000 CPM

SERVICE WATER 0833
 4.000+2 CPM

RAD WASTE DISCHG 1049
 1.000+5 CPM

STM GEN BLOWDOWN 0707
 3.000+3 CPM


*MIXING BASIN 1323
 0.5000 CPM

*FAILED FUEL 0202A
 1.0000 CPM

MAIN STEAM A 2324
 1.000+2 CPM

MAIN STEAM B 2323
 1.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS


MON 1 ???? MR/HR
 MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.000+2 R/HR
 RIA-1806 8.000+2 R/HR
 RIA-1807 7.000+2 R/HR
 RIA-1808 7.000+2 R/HR
 HI RANGE L 5.000+3 R/HR
 HI RANGE R 5.000+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60 L 35%
 T-60E L 35%



RIA2326 5.000+2 CPM
 RIA2327 1.000+0 mR/hr

BACKUP STACK
 RIA-2318 ???? CPM
 *RIA-2319 ???? CPM

CONTROL ROOM RAD
 MON 1.000+1 MR/HR

COND OFF GAS 5.000+2 CPM
 *RAD WASTE PLENUM 0.2000 CPM
 *EESG RAD 0.3000 CPM
 *WESG RAD 0.5000 CPM
 RAD WASTE VENT 6.000+2 CPM

SFP NORTH 5709 1.000+0 MR/HR
 SFP SOUTH 2313 1.500+1 MR/HR

DATE 8/17/86

TIME 1500

RADIOLOGICAL

LIQUID RADIATION MONITORS

*COMPONENT COOLING WATER 0915

0.5000 CPM

SERVICE WATER 0833

4.000+2 CPM

RAD WASTE DISCHG 1049

1.000+5 CPM

STM GEN BLOWDOWN 0707

3.000+3 CPM

*MIXING BASIN 1323

0.5000 CPM

*FAILED FUEL 0202A

1.0000 CPM

MAIN STEAM A 2324

1.000+2 CPM

MAIN STEAM B 2323

1.000+2 CPM

*DECADE DEPENDENT ON CR SWITCH POSITION



FUEL HANDLING AREAS

MON 1 ???? MR/HR

MON 2 ???? MR/HR

CONTAINMENT ISOLATION

RIA-1805 5.000+2 R/HR

RIA-1806 8.000+2 R/HR

RIA-1807 7.000+2 R/HR

RIA-1808 7.000+2 R/HR

HI RANGE L 5.000+3 R/HR

HI RANGE R 5.000+3 R/HR

DIRTY WASTE DRAIN TANKS

T-60W L 35%

T-60E L 35%

RIA2326 5.000+2 CPM

RIA2327 1.000+0 mR/hr

BACKUP STACK RIA-2318 ???? CPM

*RIA-2319 ???? CPM

CONTROL ROOM RAD MON 1.000+1 MR/HR

COND OFF GAS

5.000+2 CPM

*RAD WASTE PLENUM 0.2000 CPM

*EESG RAD 0.3000 CPM

*WESG RAD 0.5000 CPM

RAD WASTE VENT 6.000+2 CPM

SFP NORTH 5709 1.000+0 MR/HR

SFP SOUTH 2313 1.500+1 MR/HR

To get dose rate in mR/hr from PASM samples:

CONT ATM

$$\text{Total Conc } (\mu\text{Ci/gm}) \times 0.23 \frac{\text{mR-cm}^3}{\mu\text{Ci-hr}} = \text{Dose Rate}$$

PCS/LPSI/SUMP - UNDILUTED LIQUID

$$\text{Total Conc } (\mu\text{Ci/gm}) \times 40 \frac{\text{mR-gm}}{\mu\text{Ci-hr}} = \text{Dose Rate}$$

PCS/LPSI/SUMP - DILUTED LIQUID

$$\text{Total Conc } (\mu\text{Ci/gm}) \times 0.05 \frac{\text{mR-gm}}{\mu\text{Ci-hr}} = \text{Dose Rate}$$

PCS/LPSI/SUMP - DILUTED OFF GAS

$$\text{Total Conc } (\mu\text{Ci/gm}) \times 0.005 \frac{\text{mR-gm}}{\mu\text{Ci-hr}} = \text{Dose Rate}$$

All dose rates are at 1 inch.

Contact on the shielded transfer cask is ~ 1/1000 that of the sample.

PASM PANEL DOSE RATES

When the panel is in use, the contact dose rates at the front of the panel will rise to ~ 5,000 mR/hr and ~ 500 mR/hr at 3 feet. After the panel is flushed, the dose rates can be reduced to 100 mR/hr and 10 mR/hr, respectively. (Back of the PASM panel is essentially the same as the front.)

Containment Atmosphere Concentration: Senario Time

microcuries per cubic centimeter (UNDILUTED)

Nuclide	0800	0815	0845	0900	1000	1045	1100	1200	1300
Kr-83m	2.00E-10	2.00E-10	1.90E-03	1.90E-02	1.90E-01	1.90E+00	3.50E+00	3.30E+00	3.70E+00
Kr-85m	3.00E-10	3.00E-10	4.10E-03	4.10E-02	4.10E-01	4.10E+00	7.90E+00	9.30E+00	1.30E+01
Kr-85	5.00E-11	5.00E-11	1.90E-04	1.90E-03	1.90E-02	1.90E-01	3.80E-01	5.20E-01	8.50E-01
Kr-87	6.70E-09	6.70E-09	7.30E-03	7.30E-02	7.30E-01	7.30E+00	1.30E+01	1.00E+01	9.50E+00
Kr-88	5.40E-09	5.40E-09	1.10E-02	1.10E-01	1.10E+00	1.10E+01	2.00E+01	2.20E+01	2.80E+01
Kr-89	7.80E-09	7.80E-09	1.30E-02	1.30E-01	1.30E+00	1.30E+01	9.60E-01	2.80E-06	9.60E-12
Xe-131m	1.60E-10	1.60E-10	1.10E-02	1.10E-01	1.10E+00	1.10E+01	7.20E+01	3.00E+01	5.00E+01
Xe-133m	3.90E-10	3.90E-10	1.20E-02	1.20E-01	1.20E+00	1.20E+01	2.50E+01	3.30E+01	5.40E+01
Xe-133	8.90E-09	8.90E-09	3.60E-02	3.60E-01	3.60E+00	3.60E+01	7.10E+01	9.80E+01	1.60E+02
Xe-135m	1.10E-09	1.10E-09	1.10E-02	1.10E-01	1.10E+00	1.10E+01	1.10E+01	1.10E+00	1.50E-01
Xe-135	4.30E-10	4.30E-10	6.20E-03	6.20E-02	6.20E-01	6.20E+00	1.20E+01	1.50E+01	2.40E+01
Xe-137	8.40E-10	8.40E-10	3.00E-03	3.00E-02	3.00E-01	3.00E+00	3.90E+00	1.00E-04	3.20E-09
Xe-138	9.10E-10	9.10E-10	2.80E-02	2.80E-01	2.80E+00	2.80E+01	2.70E+01	2.00E+00	1.70E-01
Total	3.32E-08	3.32E-08	1.45E-01	1.45E+00	1.45E+01	1.45E+02	2.18E+02	2.24E+02	3.43E+02
I-131	2.00E-12	2.00E-12	1.80E-07	1.80E-06	1.80E-05	1.80E-03	1.96E-03	2.37E-03	2.09E-03
I-132	4.00E-11	4.00E-11	2.60E-07	2.60E-06	2.60E-05	1.48E-03	2.54E-03	2.32E-03	1.52E-03
I-133	8.00E-11	8.00E-11	3.00E-07	3.00E-06	3.00E-05	1.71E-03	3.18E-03	3.78E-03	3.23E-03
I-134	2.10E-11	2.10E-11	3.90E-07	3.90E-06	3.90E-05	2.22E-03	3.39E-03	1.89E-03	7.22E-04
I-135	6.00E-11	6.00E-11	3.10E-07	3.10E-06	3.10E-05	1.77E-03	3.23E-03	3.53E-03	2.81E-03
Total	2.03E-10	2.03E-10	1.44E-06	1.44E-05	1.44E-04	8.21E-03	1.43E-02	1.39E-02	1.04E-02

Primary Coolant Liquid Activity: Scenario Time

microcuries per gram (UNDILUTED)

Nuclide	0800	0815	0845	0900	1000	1045	1100	1200	1300
1-130	0.00E+00	0.00E+00	2.10E+01	2.07E+01	1.96E+01	1.88E+01	1.85E+01	1.75E+01	1.66E+01
1-131	6.80E-02	6.80E-02	3.00E+04	3.00E+04	2.99E+04	2.98E+04	2.98E+04	2.97E+04	2.95E+04
1-132	2.20E-01	2.20E-01	4.33E+04	4.02E+04	2.98E+04	2.38E+04	2.21E+04	1.63E+04	1.21E+04
1-133	2.10E-01	2.10E-01	5.00E+04	4.96E+04	4.79E+04	4.68E+04	4.64E+04	4.48E+04	4.33E+04
1-134	3.30E-01	3.30E-01	6.50E+04	5.35E+04	2.45E+04	1.37E+04	1.12E+04	5.15E+03	2.36E+03
1-135	3.00E-01	3.00E-01	5.17E+04	5.03E+04	4.51E+04	4.16E+04	4.05E+04	3.64E+04	3.26E+04
1-136	0.00E+00	0.00E+00	2.50E+04	1.61E+01	2.74E-12	7.27E-22	4.67E-25	7.96E-38	1.36E-50
Total	1.13E+00	1.13E+00	2.65E+05	2.24E+05	1.77E+05	1.56E+05	1.50E+05	1.32E+05	1.20E+05
Cs-134m	1.13E-07	1.13E-07	1.00E+03	9.42E+02	7.41E+02	6.19E+02	5.83E+02	4.58E+02	3.61E+02
Cs-134	2.40E-07	2.40E-07	3.10E+03	3.10E+03	3.10E+03	3.10E+03	3.10E+03	3.10E+03	3.10E+03
Cs-137	3.80E-07	3.80E-07	7.50E+03	7.50E+03	7.50E+03	7.50E+03	7.50E+03	7.50E+03	7.50E+03
Cs-138	3.30E-01	3.30E-01	1.20E+05	5.18E+05	1.38E+05	5.14E+04	3.69E+04	9.87E+03	2.64E+03
Cs-139	0.00E+00	0.00E+00	9.60E+04	4.01E+04	1.95E+04	1.14E+04	9.50E+03	4.62E+03	2.25E+03
Rb-88	2.00E+00	2.00E+00	1.70E+03	1.04E+04	1.00E+03	1.74E+02	9.67E+01	9.31E+00	8.97E-01
Rb-89	3.70E+00	3.70E+00	2.30E+03	8.20E+03	5.51E+02	7.27E+01	3.70E+01	2.49E+00	1.67E-01
Rb-90	0.00E+00	0.00E+00	4.10E+03	3.84E-10	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Ba-140	3.80E-08	3.80E-08	3.80E-08	3.80E-08	3.80E-08	3.80E-08	3.80E-08	3.80E-08	3.80E-08
Ru-103	7.90E-08	7.90E-08	7.90E-08	7.90E-08	7.90E-08	7.90E-08	7.90E-08	7.90E-08	7.90E-08
Te-132	7.60E-08	7.60E-08	7.60E-08	7.60E-08	7.60E-08	7.60E-08	7.60E-08	7.60E-08	7.60E-08
Mn-54	2.60E-05	2.60E-05	2.60E-05	2.60E-05	2.60E-05	2.60E-05	2.60E-05	2.60E-05	2.60E-05
Mn-56	3.10E-02	3.10E-02	3.10E-02	3.10E-02	3.10E-02	3.10E-02	3.10E-02	3.10E-02	3.10E-02
Cr-51	1.60E-02	1.60E-02	1.60E-02	1.60E-02	1.60E-02	1.60E-02	1.60E-02	1.60E-02	1.60E-02
Co-58	4.10E-03	4.10E-03	4.10E-03	4.10E-03	4.10E-03	4.10E-03	4.10E-03	4.10E-03	4.10E-03
Co-60	5.40E-05	5.40E-05	5.40E-05	5.40E-05	5.40E-05	5.40E-05	5.40E-05	5.40E-05	5.40E-05
Total	6.09E+00	6.09E+00	2.36E+05	5.88E+05	1.71E+05	7.42E+04	5.78E+04	2.56E+04	1.58E+04

Primary Coolant Liquid Activity: Scenario Time

microcuries per gram (UNDILUTED)

Nuclide	0800	0815	0845	0900	1000	1045	1100	1200	1300
Kr-83m	9.40E-01	9.40E-01	4.10E+03	3.36E+03	1.62E+03	6.14E+02	5.59E+02	3.06E+02	2.66E+02
Kr-85m	3.50E-01	3.80E-01	8.90E+03	7.70E+03	4.61E+03	2.05E+03	1.97E+03	1.69E+03	1.44E+03
Kr-85	9.80E-03	9.80E-03	4.70E+02	4.23E+02	2.96E+02	1.48E+02	1.48E+02	1.48E+02	1.48E+02
Kr-87	3.50E-01	3.50E-01	2.40E+04	1.80E+04	7.64E+03	2.54E+03	2.21E+03	1.28E+03	7.43E+02
Kr-88	4.50E-01	4.50E-01	3.20E+04	2.71E+04	1.48E+04	6.16E+03	5.80E+03	4.53E+03	3.54E+03
Kr-89	3.40E-01	3.40E-01	4.70E+04	1.56E+03	2.02E-03	5.07E-08	1.87E-09	0.00E+00	0.00E+00
Xe-131m	1.30E-02	1.30E-02	3.00E+02	2.70E+02	1.88E+02	9.40E+01	9.40E+01	9.37E+01	9.35E+01
Xe-133m	8.70E-02	8.70E-02	3.50E+03	3.14E+03	2.17E+03	1.07E+03	1.07E+03	1.06E+03	1.04E+03
Xe-133	3.70E+00	3.70E+00	1.10E+05	9.89E+04	6.88E+04	3.43E+04	3.42E+04	3.40E+04	3.38E+04
Xe-135m	4.10E-01	4.10E-01	4.10E+04	1.86E+04	6.84E+02	5.83E+01	2.97E+01	2.00E+00	1.34E-01
Xe-135	7.50E+00	7.50E+00	3.60E+04	3.18E+04	2.06E+04	9.70E+03	9.51E+03	8.80E+03	8.14E+03
Xe-137	9.40E+00	9.40E+00	6.50E+04	5.84E+04	1.39E+04	3.09E+03	2.36E+03	8.00E+02	2.72E+02
Xe-138	1.10E+01	1.10E+01	6.10E+04	3.50E+04	1.29E+03	7.13E+01	3.42E+01	1.81E+00	9.56E-02
Total	3.46E+01	3.46E+01	4.73E+05	3.05E+05	1.37E+05	5.99E+04	5.80E+04	5.28E+04	4.95E+04

und Liquid Activity: Scenario Time

microcuries per gram (UNDILUTED)

Nuclide	0800	0815	0845	0900	1000	1045	1100	1200	1300
I-130	NO SAMP	NO SAMP	NO SAMP	NO SAMP	1.96E+01	1.88E+01	1.85E+01	1.75E+01	1.66E+01
I-131	NO SAMP	NO SAMP	NO SAMP	NO SAMP	2.99E+04	2.98E+04	2.98E+04	2.97E+04	2.96E+04
I-132	NO SAMP	NO SAMP	NO SAMP	NO SAMP	2.98E+04	2.38E+04	2.21E+04	1.64E+04	1.21E+04
I-133	NO SAMP	NO SAMP	NO SAMP	NO SAMP	4.79E+04	4.67E+04	4.63E+04	4.48E+04	4.33E+04
I-134	NO SAMP	NO SAMP	NO SAMP	NO SAMP	2.45E+04	1.36E+04	1.12E+04	5.15E+03	2.36E+03
I-135	NO SAMP	NO SAMP	NO SAMP	NO SAMP	4.51E+04	4.16E+04	4.05E+04	3.63E+04	3.26E+04
I-136	NO SAMP	NO SAMP	NO SAMP	NO SAMP	2.74E-12	7.27E-22	4.67E-25	7.97E-38	1.36E-50
Total	NO SAMP	NO SAMP	NO SAMP	NO SAMP	1.77E+05	1.56E+05	1.50E+05	1.32E+05	1.20E+05
Cs-134m	NO SAMP	NO SAMP	NO SAMP	NO SAMP	7.41E+02	6.19E+02	5.83E+02	4.59E+02	3.61E+02
Cs-134	NO SAMP	NO SAMP	NO SAMP	NO SAMP	3.10E+03	3.10E+03	3.10E+03	3.10E+03	3.10E+03
Cs-137	NO SAMP	NO SAMP	NO SAMP	NO SAMP	7.50E+03	7.50E+03	7.50E+03	7.50E+03	7.50E+03
Cs-138	NO SAMP	NO SAMP	NO SAMP	NO SAMP	1.38E+05	5.13E+04	3.69E+04	9.85E+03	2.63E+03
Cs-139	NO SAMP	NO SAMP	NO SAMP	NO SAMP	1.95E+04	1.14E+04	9.49E+03	4.62E+03	2.25E+03
Rb-88	NO SAMP	NO SAMP	NO SAMP	NO SAMP	1.00E+03	1.73E+02	9.63E+01	9.28E+00	8.94E-01
Rb-89	NO SAMP	NO SAMP	NO SAMP	NO SAMP	5.51E+02	7.27E+01	3.70E+01	2.49E+00	1.67E-01
Rb-90	NO SAMP	NO SAMP	NO SAMP	NO SAMP	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Ba-140	NO SAMP	NO SAMP	NO SAMP	NO SAMP	3.80E-08	3.80E-08	3.80E-08	3.80E-08	3.80E-08
Ru-103	NO SAMP	NO SAMP	NO SAMP	NO SAMP	7.90E-08	7.90E-08	7.90E-08	7.90E-08	7.90E-08
Te-132	NO SAMP	NO SAMP	NO SAMP	NO SAMP	7.60E-08	7.60E-08	7.60E-08	7.60E-08	7.60E-08
Mn-54	NO SAMP	NO SAMP	NO SAMP	NO SAMP	2.60E-08	2.60E-08	2.60E-08	2.60E-08	2.60E-08
Mn-56	NO SAMP	NO SAMP	NO SAMP	NO SAMP	3.10E-02	3.10E-02	3.10E-02	3.10E-02	3.10E-02
Cr-51	NO SAMP	NO SAMP	NO SAMP	NO SAMP	1.60E-02	1.60E-02	1.60E-02	1.60E-02	1.60E-02
Co-58	NO SAMP	NO SAMP	NO SAMP	NO SAMP	4.10E-03	4.10E-03	4.10E-03	4.10E-03	4.10E-03
Co-60	NO SAMP	NO SAMP	NO SAMP	NO SAMP	5.40E-05	5.40E-05	5.40E-05	5.40E-05	5.40E-05
Total	NO SAMP	NO SAMP	NO SAMP	NO SAMP	1.70E+05	7.41E+04	5.77E+04	2.55E+04	1.58E+04

A" And "B" SG Liquid Activity: Senario Time

microcuries per gram (UNDILUTED)

Nuclide	0800	0815	0845	0900	1000	1045	1100	1200	1300
I-131	6.20E-05	6.20E-05	6.20E-05	6.20E-04	6.20E-04	6.20E-04	6.20E-04	6.20E-04	6.20E-04
I-132	1.90E-04	1.90E-04	1.90E-04	1.90E-03	1.90E-03	1.90E-03	1.90E-03	1.90E-03	1.90E-03
I-133	3.67E-04	3.67E-04	3.67E-04	3.67E-03	3.67E-03	3.67E-03	3.67E-03	3.67E-03	3.67E-03
I-134	4.80E-04	4.80E-04	4.80E-04	4.80E-03	4.80E-03	4.80E-03	4.80E-03	4.80E-03	4.80E-03
I-135	4.20E-04	4.20E-04	4.20E-04	4.20E-03	4.20E-03	4.20E-03	4.20E-03	4.20E-03	4.20E-03
Total	1.52E-03	1.52E-03	1.52E-03	1.52E-02	1.52E-02	1.52E-02	1.52E-02	1.52E-02	1.52E-02
Cs-134m	0.00E+00	0.00E+00	2.34E-08	2.34E-08	2.34E-08	2.34E-08	2.34E-08	2.34E-08	2.34E-08
Cs-134	1.45E-08	1.45E-08	1.45E-06	1.45E-06	1.45E-06	1.45E-06	1.45E-06	1.45E-06	1.45E-06
Cs-137	2.90E-08	2.90E-08	2.90E-05	2.90E-05	2.90E-05	2.90E-05	2.90E-05	2.90E-05	2.90E-05
Cs-138	0.00E+00	0.00E+00	4.60E-04	4.60E-04	4.60E-04	4.60E-04	4.60E-04	4.60E-04	4.60E-04
Cs-139	0.00E+00	0.00E+00	5.10E-04	5.10E-04	5.10E-04	5.10E-04	5.10E-04	5.10E-04	5.10E-04
Rb-88	1.20E-03	1.20E-03	1.20E-05	1.20E-05	1.20E-05	1.20E-05	1.20E-05	1.20E-05	1.20E-05
Rb-89	1.60E-08	1.60E-08	1.60E-05	1.60E-05	1.60E-05	1.60E-05	1.60E-05	1.60E-05	1.60E-05
Rb-90	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Rb-140	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Ru-103	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Te-132	2.00E-09	2.00E-09	2.00E-09	2.00E-09	2.00E-09	2.00E-09	2.00E-09	2.00E-09	2.00E-09
Mn-54	1.70E-06	1.70E-06	1.70E-05	1.70E-05	1.70E-05	1.70E-05	1.70E-05	1.70E-05	1.70E-05
Mn-56	4.30E-05	4.30E-05	4.30E-04	4.30E-04	4.30E-04	4.30E-04	4.30E-04	4.30E-04	4.30E-04
Cr-51	2.20E-05	2.20E-05	2.20E-04	2.20E-04	2.20E-04	2.20E-04	2.20E-04	2.20E-04	2.20E-04
Co-58	2.30E-04	2.30E-04	2.30E-03	2.30E-03	2.30E-03	2.30E-03	2.30E-03	2.30E-03	2.30E-03
Co-60	1.00E-06	1.00E-06	1.00E-05	1.00E-05	1.00E-05	1.00E-05	1.00E-05	1.00E-05	1.00E-05
Fe-59	4.30E-07	4.30E-07	4.30E-06	4.30E-06	4.30E-06	4.30E-06	4.30E-06	4.30E-06	4.30E-06
Ni-63	2.10E-06	2.10E-06	2.10E-05	2.10E-05	2.10E-05	2.10E-05	2.10E-05	2.10E-05	2.10E-05
Zr-95	7.30E-01	7.30E-01	7.30E+00	7.30E+00	7.30E+00	7.30E+00	7.30E+00	7.30E+00	7.30E+00
Mo-99	4.70E-07	4.70E-07	4.70E-06	4.70E-06	4.70E-06	4.70E-06	4.70E-06	4.70E-06	4.70E-06
Total	7.30E-01	7.30E-01	7.30E+00	7.30E+00	7.30E+00	7.30E+00	7.30E+00	7.30E+00	7.30E+00

17.5

RGEM PARTICULATE FILTERS

The particulate filters have the iodine activity divided by ten.

The dose rates, count rates, etc, are also 1/10 the iodine values.

GEM Noble Gas Grab Sample: Senario Time

microcuries per cubic centimeter (UNDILUTED)

Nuclide	1045	1100	1200	1300	1400
Kr-83m	2.84E-02	3.50E+00	3.30E+00	3.70E+00	2.22E-03
Kr-85m	6.12E-02	7.90E+00	9.30E+00	1.30E+01	7.80E-03
Kr-85	2.84E-03	3.80E-01	5.20E-01	8.50E-01	5.10E-04
Kr-87	1.09E-01	1.30E+01	1.00E+01	9.50E+00	5.70E-03
Kr-88	1.64E-01	2.00E+01	2.20E+01	2.80E+01	1.68E-02
Kr-89	1.94E-01	9.60E-01	2.80E-06	9.60E-12	5.76E-15
Xe-131m	1.64E-01	2.20E+01	3.00E+01	5.00E+01	3.00E-02
Xe-133m	1.79E-01	2.50E+01	3.30E+01	5.40E+01	3.24E-02
Xe-133	5.37E-01	7.10E+01	9.80E+01	1.60E+02	9.60E-02
Xe-135m	1.64E-01	1.10E+01	1.10E+00	1.50E-01	9.00E-05
Xe-135	9.25E-02	1.20E+01	1.50E+01	2.40E+01	1.44E-02
Xe-137	4.48E-02	3.90E+00	1.00E-04	3.20E-09	1.92E-12
Xe-138	4.18E-01	2.70E+01	2.00E+00	1.70E-01	1.02E-04
Total	2.16E+00	2.18E+02	2.24E+02	3.43E+02	2.06E-01
I-131	1.53E-05	1.96E-03	2.37E-03	2.09E-03	1.10E-06
I-132	2.21E-05	2.54E-03	2.32E-03	1.52E-03	8.03E-07
I-133	2.55E-05	3.18E-03	3.78E-03	3.65E-03	1.93E-06
I-134	3.32E-05	3.39E-03	1.89E-03	8.17E-04	4.31E-07
I-135	2.64E-05	3.23E-03	3.53E-03	3.18E-03	1.68E-06
Total	1.23E-04	1.43E-02	1.39E-02	1.13E-02	5.95E-06
Dose Rate	9.50E+02	1.60E+03	1.40E+03	2.20E+03	1.00E+01 mR/hr
5 cc serum	1.00E+02	1.50E+02	1.25E+02	2.50E+02	2.00E+00 mR/hr

The automatic grab taken at RGEM high alarm is the 1045 data

17.2

GEM Normal Range Filters: Scenario Time

microcuries

Nuclide	1045
I-131	1.37E+00
I-132	3.42E+00
I-133	3.94E+00
I-134	5.13E+00
I-135	4.08E+00
Total	1.89E+01

Nuclide	1045
Rb-86	1.82E-01
Rb-87	9.09E-02
Cs-136	3.64E-01
Cs-137	1.82E+01
Total	1.88E+01

Dose		
Rate	1.09E+01 mR/hr	2.73E+01 mR/hr
com	4.00E+04 com	9.73E+04 com

18.3


SEM Accident Filters: Senario Time

microcuries deposited during any 15 minute period and cummulative curies

Nuclide	1045	Cum	1100	Cum	1200	Cum	1300	Cum
I-131	2.37E-02	2.37E-02	5.18E-02	7.98E-02	3.30E-02	1.94E-01	3.14E-02	3.45E-01
I-132	3.42E-02	3.42E-02	6.72E-02	1.03E-01	3.24E-02	1.90E-01	3.08E-02	3.39E-01
I-133	3.94E-02	3.94E-02	8.40E-02	1.29E-01	5.28E-02	3.12E-01	5.02E-02	5.52E-01
I-134	5.13E-02	5.13E-02	8.96E-02	1.38E-01	2.64E-01	1.55E+00	2.51E-01	2.76E+00
I-135	4.08E-02	4.08E-02	8.47E-02	1.30E-01	4.92E-02	2.89E-01	4.67E-02	5.14E-01
Total	1.89E-01	1.89E-01	3.77E-01	5.81E-01	4.31E-01	2.53E+00	4.10E-01	4.51E+00
mR/hr	6.00E-01		1.10E+00		1.20E+00		1.15E+00	
cpm	2.20E+03		4.00E+03		4.40E+03		4.20E+03	
Cum mR/hr		6.00E-01		1.70E+00		6.80E+00		1.19E+01
Cum cpm		2.20E+03		8.50E+03		3.40E+04		5.90E+04

18.4

O-SOMi INGESTION PATHWAY MAP



PLEASE ISOTOPICS

DAY 1

Nuclide	0800	0815	0845	0900	1000	1045	1100	1200
I-131	9.85E-03	9.85E-03	1.25E-01	1.25E-01	1.25E-01	1.25E-01	1.37E-01	1.70E-01
I-132	1.97E-01	1.97E-01	1.81E-01	1.81E-01	1.81E-01	1.81E-01	1.78E-01	1.67E-01
I-133	3.94E-01	3.94E-01	2.08E-01	2.08E-01	2.08E-01	2.08E-01	2.22E-01	2.72E-01
I-134	1.03E-01	1.03E-01	2.71E-01	2.71E-01	2.71E-01	2.71E-01	2.37E-01	1.36E-01
I-135	2.96E-01	2.96E-01	2.15E-01	2.15E-01	2.15E-01	2.15E-01	2.26E-01	2.54E-01
Total	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00

DAY 1

DAY 2

Nuclide	1400	1600	2000	0000	0400	0800	1200	1600
I-131	2.27E-01	2.68E-01	3.34E-01	3.90E-01	4.40E-01	4.83E-01	5.27E-01	5.66E-01
I-132	1.23E-01	8.02E-02	3.05E-02	1.09E-02	3.75E-03	1.26E-03	4.20E-04	1.38E-04
I-133	3.40E-01	3.79E-01	4.19E-01	4.33E-01	4.33E-01	4.24E-01	4.08E-01	3.89E-01
I-134	3.60E-02	9.02E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	2.75E-01	2.64E-01	2.17E-01	1.66E-01	1.24E-01	8.98E-02	6.42E-02	4.54E-02
Total	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00

10 to 50 Mile INGESTION PATHWAY DATA

Area A

<u>TIME</u>	<u>100 cm² SMEAR (CPM)</u>	<u>DIRECT FRISK (CPM)</u>	<u>DE I-131 (uCi/m²)</u>
12:30 - 13:00	1.0K to 20K	150 to 3K	0.2 to 1.2
13:00 - 13:30	2.0K to 30K	300 to 4.5K	0.9 to 2.0
13:30 - 14:00	2.0K to 45K	300 to 6.8K	1.0 to 3.0
14:00 - 14:30	2.0K to 60K	300 to 9K	1.0 to 4.0
14:30 - 15:00	2.5K to 78K	375 to 12K	1.0 to 5.0
15:00 - 15:30	2.8K to 90K	420 to 14K	1.0 to 6.0
15:30 - 16:00	2.8K to 90K	420 to 14K	1.0 to 6.0
16:00 - 16:30	2.8K to 90K	420 to 14K	1.0 to 6.0
16:30 - 17:00	2.8K to 90K	420 to 14K	1.0 to 6.0
17:00 +	2.8K to 90K	420 to 14K	1.0 to 6.0

$$\text{DIRECT SURVEY (mR/hr)} = \frac{\text{DIRECT FRISK (CPM)}}{5000}$$

19.3

10 to 50 Mile INGESTION PATHWAY DATA

Area B

<u>TIME</u>	<u>100 cm² SMEAR (CPM)</u>	<u>DIRECT FRISK (CPM)</u>	<u>DE I-131 (μCi/m²)</u>
12:30 - 13:00	200 to 3K	300 to 450	0.001 to 0.2
13:00 - 13:30	200 to 3K	300 to 450	0.001 to 0.2
13:30 - 14:00	200 to 3K	300 to 450	0.001 to 0.2
14:00 - 14:30	200 to 3K	300 to 450	0.001 to 0.2
14:30 - 15:00	200 to 3K	300 to 450	0.001 to 0.2
15:00 - 15:30	200 to 4.7K	300 to 700	0.001 to 0.3
15:30 - 16:00	200 to 4.7K	300 to 700	0.001 to 0.3
16:00 - 16:30	200 to 4.7K	300 to 700	0.001 to 0.3
16:30 - 17:00	200 to 4.7K	300 to 700	0.001 to 0.3
17:00 +	200 to 4.7K	300 to 700	0.001 to 0.3

DIRECT SURVEY IS ALWAYS LESS THAN 0.1 mR/hr.

10 to 50 Mile INGESTION PATHWAY DATA

Area C

<u>TIME</u>	<u>100 cm² SHEAR (CPM)</u>	<u>DIRECT FRISK (CPM)</u>	<u>DE I-131 (uCi/m²)</u>
12:30 - 13:00	Bkg	Bkg	Bkg
13:00 - 13:30	Bkg	Bkg	Bkg
13:30 - 14:00	60 to 450	Bkg to 100	0.001 to 0.05
14:00 - 14:30	100 to 2.8K	65 to 420	0.001 to 0.2
14:30 - 15:00	100 to 5.5K	65 to 820	0.001 to 0.3
15:00 - 15:30	350 to 7K	100 to 1K	0.02 to 0.5
15:30 - 16:00	630 to 9.7K	95 to 1.5K	0.04 to 0.6
16:00 - 16:30	630 to 9.7K	95 to 1.5K	0.05 to 0.7
16:30 - 17:00	630 to 9.7K	95 to 1.5K	0.05 to 0.7
17:00 +	630 to 9.7K	95 to 1.5K	0.05 to 0.7

19.5

10 to 50 Mile INGESTION PATHWAY DATA

Area D

<u>TIME</u>	<u>100 cm² SMEAR (CPM)</u>	<u>DIRECT FRISK (CPM)</u>	<u>DE I-131 (uCi/m²)</u>
12:30 - 13:00	Bkg	Bkg	Bkg
13:00 - 13:30	Bkg	Bkg	Bkg
13:30 - 14:00	400 to 1.5K	110 to 270	0.03 to 0.08
14:00 - 14:30	400 to 4.2K	110 to 680	0.1 to 0.3
14:30 - 15:00	3.5K to 8K	550 to 1.2K	0.1 to 0.3
15:00 - 15:30	4.7K to 11K	700 to 1.7K	0.3 to 0.5
15:30 - 16:00	6.6K to 14K	1K to 2K	0.4 to 0.6
16:00 - 16:30	6.6K to 14K	1K to 2K	0.5 to 0.7
16:30 - 17:00	6.6K to 14K	1K to 2K	0.5 to 0.7
17:00 +	6.6K to 14K	1K to 2K	0.5 to 0.7

10 to 50 Mile INGESTION PATHWAY DATA

Area E

<u>TIME</u>	<u>100 cm² SMEAR (CPM)</u>	<u>DIRECT FRISK (CPM)</u>	<u>DE I-131 ($\mu\text{Ci}/\text{m}^2$)</u>
12:30 - 13:00	Bkg	Bkg	Bkg
13:00 - 13:30	Bkg	Bkg	Bkg
13:30 - 14:00	70 to 100	Bkg to 65	0.001 to 0.008
14:00 - 14:30	100 to 400	65 to 110	0.001 to 0.03
14:30 - 15:00	100 to 500	65 to 125	0.01 to 0.04
15:00 - 15:30	200 to 1K	80 to 200	0.01 to 0.07
15:30 - 16:00	200 to 1.8K	80 to 320	0.09 to 0.4
16:00 - 16:30	200 to 1.8K	80 to 320	0.1 to 0.4
16:30 - 17:00	200 to 1.8K	80 to 320	0.1 to 0.4
7:00 +	200 to 1.8K	80 to 320	0.1 to 0.4

10 to 50 Mile INGESTION PATHWAY DATA

Area F

<u>TIME</u>	<u>100 cm² SMEAR (CPM)</u>	<u>DIRECT FRISK (CPM)</u>	<u>DE I-131 (uCi/m²)</u>
12:30 - 13:00	Bka	Bka	Bka
13:00 - 13:30	Bka	Bka	Bka
13:30 - 14:00	Bka	Bka	Bka
14:00 - 14:30	Bka	Bka	0.0001 to 0.001
14:30 - 15:00	Bka	Bka	0.0001 to 0.001
15:00 - 15:30	Bka	Bka	0.0001 to 0.001
15:30 - 16:00	Bka	Bka	0.0001 to 0.004
16:00 - 16:30	Bka	Bka	0.0001 to 0.004
16:30 - 17:00	Bka	Bka	0.0001 to 0.004
17:00 +	Bka	Bka	0.0001 to 0.004

10 to 50 Mile INGESTION PATHWAY DATA

Area G

TIME	100 cm ² SMEAR (CFM)	DIRECT FRISK (CFM)	DE I-131 (uCi/m ²)
12:30 - 13:00	Bka	Bka	Bka
13:00 - 13:30	Bka	Bka	Bka
13:30 - 14:00	Bka	Bka	Bka
14:00 - 14:30	Bka	Bka	Bka
14:30 - 15:00	Bka	Bka	Bka
15:00 - 15:30	Bka	Bka	Bka
15:30 - 16:00	530 to 700	130 to 150	0.003 to 0.004
16:00 - 16:30	530 to 700	130 to 150	0.006 to 0.007
16:30 - 17:00	2.1K to 3.3K	320 to 500	0.14 to 0.22
17:00 +	3K to 6K	450 to 900	0.2 to 0.4

10 to 50 Mile INGESTION PATHWAY DATA

Area H

TIME	100 cm ² SMEAR (CPM)	DIRECT FRISK (CPM)	DE I-131 ($\mu\text{Ci}/\text{m}^2$)
12:30 - 13:00	Bkg	Bkg	Bkg
13:00 - 13:30	Bkg	Bkg	Bkg
13:30 - 14:00	Bkg	Bkg	Bkg
14:00 - 14:30	Bkg	Bkg	Bkg
14:30 - 15:00	Bkg	Bkg	Bkg
15:00 - 15:30	Bkg	Bkg	0.002 to 0.006
15:30 - 16:00	160 to 580	75 to 130	0.02 to 0.06
16:00 - 16:30	160 to 580	75 to 130	0.02 to 0.07
16:30 - 17:00	300 to 2.1K	95 to 350	0.02 to 0.14
17:00 +	300 to 4.5K	95 to 700	0.03 to 0.3

19.10

10 to 50 Mile INGESTION PATHWAY DATA

Area I

TIME	100 cm ² SMEAR (CPM)	DIRECT FRISK (CPM)	DE I-131 (uCi/m ²)
12:30 - 13:00	Bka	Bka	Bka
13:00 - 13:30	Bka	Bka	Bka
13:30 - 14:00	Bka	Bka	Bka
14:00 - 14:30	Bka	Bka	Bka
14:30 - 15:00	Bka	Bka	Bka
15:00 - 15:30	Bka	Bka	Bka
15:30 - 16:00	170 to 250	75 to 90	0.002 to 0.02
16:00 - 16:30	170 to 250	75 to 90	0.005 to 0.05
16:30 - 17:00	75 to 1.4K	100 to 250	0.005 to 0.09
:00 +	75 to 1.4K	100 to 250	0.005 to 0.09

14.11

10 to 50 Mile INGESTION PATHWAY DATA

Area J

TIME	100 cm ² SMEAR (CPM)	DIRECT FRISK (CPM)	DE I-131 (uCi/m ²)
12:30 - 13:00	Bka	Bka	Bka
13:00 - 13:30	Bka	Bka	Bka
13:30 - 14:00	Bka	Bka	Bka
14:00 - 14:30	Bka	Bka	Bka
14:30 - 15:00	Bka	Bka	Bka
15:00 - 15:30	Bka	Bka	Bka
15:30 - 16:00	Bka	Bka	0.001 to 0.01
16:00 - 16:30	Bka	Bka	0.001 to 0.01
16:30 - 17:00	50 to 1.2K	Bka to 230	0.003 to 0.08
17:00 +	50 to 1.2K	Bka to 230	0.003 to 0.08

19.12

10 to 50 Mile INGESTION PATHWAY DATA

Area K

TIME	100 cm ² SMEAR (CFM)	DIRECT FRISK (CFM)	DE I-131 ($\mu\text{Ci}/\text{m}^2$)
12:30 - 13:00	Bka	Bka	Bka
13:00 - 13:30	Bka	Bka	Bka
13:30 - 14:00	Bka	Bka	Bka
14:00 - 14:30	Bka	Bka	Bka
14:30 - 15:00	Bka	Bka	Bka
15:00 - 15:30	Bka	Bka	Bka
15:30 - 16:00	Bka	Bka	Bka
16:00 - 16:30	Bka	Bka	Bka
16:30 - 17:00	300 to 450	95 to 130	0.02 to 0.03
17:00 +	1.2K to 2.3K	200 to 400	0.08 to 0.15

10 to 50 Mile INGESTION PATHWAY DATA

Area L

TIME	100 cm ² SMEAR (CFM)	DIRECT FRISK (CFM)	DE I-131 (uCi/m ²)
12:30 - 13:00	Bkg	Bkg	Bkg
13:00 - 13:30	Bkg	Bkg	Bkg
13:30 - 14:00	Bkg	Bkg	Bkg
14:00 - 14:30	Bkg	Bkg	Bkg
14:30 - 15:00	Bkg	Bkg	Bkg
15:00 - 15:30	Bkg	Bkg	Bkg
15:30 - 16:00	Bkg	Bkg	Bkg
16:00 - 16:30	Bkg	Bkg	Bkg
16:30 - 17:00	50 to 300	Bkg to 100	0.002 to 0.02
17:00 +	50 to 300	Bkg to 100	0.002 to 0.02

19.7

10 to 50 Mile INGESTION PATHWAY DATA

Area M

TIME	100 cm ² SMEAR (CPM)	DIRECT FRISK (CPM)	DE I-131 (uCi/m ²)
12:30 - 13:00	Bkg	Bkg	Bkg
13:00 - 13:30	Bkg	Bkg	Bkg
13:30 - 14:00	Bkg	Bkg	Bkg
14:00 - 14:30	Bkg	Bkg	Bkg
14:30 - 15:00	Bkg	Bkg	Bkg
15:00 - 15:30	Bkg	Bkg	Bkg
15:30 - 16:00	Bkg	Bkg	Bkg
16:00 - 16:30	Bkg	Bkg	Bkg
16:30 - 17:00	50 to 450	Bkg to 110	0.0001 to 0.03
17:00 +	50 to 1.2K	Bkg to 110	0.001 to 0.05

19.15

10 to 50 Mile INGESTION PATHWAY DATA

Area N

TIME	100 cm ² SMEAR (CPM)	DIRECT FRISK (CPM)	DE I-131 (uCi/m ²)
12:30 - 13:00	Bka	Bka	Bka
13:00 - 13:30	Bka	Bka	Bka
13:30 - 14:00	Bka	Bka	Bka
14:00 - 14:30	Bka	Bka	Bka
14:30 - 15:00	Bka	Bka	Bka
15:00 - 15:30	Bka	Bka	Bka
15:30 - 16:00	Bka	Bka	Bka
16:00 - 16:30	Bka	Bka	Bka
16:30 - 17:00	Bka	Bka	Bka
17:00 +	Bka	Bka	Bka

19.16

IN-PLANT DATA

Only dose rates change within the plant. Smears, air samples, etc, results will be exactly what is measured normally.


Outside of the plant, smears, etc, in areas affected by the plume will be so hot as to be uncountable.

If any noble gas samples are taken in the plume onsite, use the RGEM data and divide by 100 for center line and more the farther from the center line.

Between 0800 and 0845, all radiological conditions in the plant are those normally encountered.

COMPONENT IN .JWS

WEST END BRIDGE	
17340	WEST END BRIDGE
17341	WEST END BRIDGE
17342	WEST END BRIDGE
17343	WEST END BRIDGE
17344	WEST END BRIDGE
17345	WEST END BRIDGE
17346	WEST END BRIDGE
17347	WEST END BRIDGE
17348	WEST END BRIDGE
17349	WEST END BRIDGE
17350	WEST END BRIDGE
17351	WEST END BRIDGE
17352	WEST END BRIDGE
17353	WEST END BRIDGE
17354	WEST END BRIDGE
17355	WEST END BRIDGE
17356	WEST END BRIDGE
17357	WEST END BRIDGE
17358	WEST END BRIDGE
17359	WEST END BRIDGE
17360	WEST END BRIDGE
17361	WEST END BRIDGE
17362	WEST END BRIDGE
17363	WEST END BRIDGE
17364	WEST END BRIDGE
17365	WEST END BRIDGE
17366	WEST END BRIDGE
17367	WEST END BRIDGE
17368	WEST END BRIDGE
17369	WEST END BRIDGE
17370	WEST END BRIDGE
17371	WEST END BRIDGE
17372	WEST END BRIDGE
17373	WEST END BRIDGE
17374	WEST END BRIDGE
17375	WEST END BRIDGE
17376	WEST END BRIDGE
17377	WEST END BRIDGE
17378	WEST END BRIDGE
17379	WEST END BRIDGE
17380	WEST END BRIDGE
17381	WEST END BRIDGE
17382	WEST END BRIDGE
17383	WEST END BRIDGE
17384	WEST END BRIDGE
17385	WEST END BRIDGE
17386	WEST END BRIDGE
17387	WEST END BRIDGE
17388	WEST END BRIDGE
17389	WEST END BRIDGE
17390	WEST END BRIDGE
17391	WEST END BRIDGE
17392	WEST END BRIDGE
17393	WEST END BRIDGE
17394	WEST END BRIDGE
17395	WEST END BRIDGE
17396	WEST END BRIDGE
17397	WEST END BRIDGE
17398	WEST END BRIDGE
17399	WEST END BRIDGE
17400	WEST END BRIDGE
17401	WEST END BRIDGE
17402	WEST END BRIDGE
17403	WEST END BRIDGE
17404	WEST END BRIDGE
17405	WEST END BRIDGE
17406	WEST END BRIDGE
17407	WEST END BRIDGE
17408	WEST END BRIDGE
17409	WEST END BRIDGE
17410	WEST END BRIDGE
17411	WEST END BRIDGE
17412	WEST END BRIDGE
17413	WEST END BRIDGE
17414	WEST END BRIDGE
17415	WEST END BRIDGE
17416	WEST END BRIDGE
17417	WEST END BRIDGE
17418	WEST END BRIDGE
17419	WEST END BRIDGE
17420	WEST END BRIDGE
17421	WEST END BRIDGE
17422	WEST END BRIDGE
17423	WEST END BRIDGE
17424	WEST END BRIDGE
17425	WEST END BRIDGE
17426	WEST END BRIDGE
17427	WEST END BRIDGE
17428	WEST END BRIDGE
17429	WEST END BRIDGE
17430	WEST END BRIDGE
17431	WEST END BRIDGE
17432	WEST END BRIDGE
17433	WEST END BRIDGE
17434	WEST END BRIDGE
17435	WEST END BRIDGE
17436	WEST END BRIDGE
17437	WEST END BRIDGE
17438	WEST END BRIDGE
17439	WEST END BRIDGE
17440	WEST END BRIDGE
17441	WEST END BRIDGE
17442	WEST END BRIDGE
17443	WEST END BRIDGE
17444	WEST END BRIDGE
17445	WEST END BRIDGE
17446	WEST END BRIDGE
17447	WEST END BRIDGE
17448	WEST END BRIDGE
17449	WEST END BRIDGE
17450	WEST END BRIDGE
17451	WEST END BRIDGE
17452	WEST END BRIDGE
17453	WEST END BRIDGE
17454	WEST END BRIDGE
17455	WEST END BRIDGE
17456	WEST END BRIDGE
17457	WEST END BRIDGE
17458	WEST END BRIDGE
17459	WEST END BRIDGE
17460	WEST END BRIDGE
17461	WEST END BRIDGE
17462	WEST END BRIDGE
17463	WEST END BRIDGE
17464	WEST END BRIDGE
17465	WEST END BRIDGE
17466	WEST END BRIDGE
17467	WEST END BRIDGE
17468	WEST END BRIDGE
17469	WEST END BRIDGE
17470	WEST END BRIDGE
17471	WEST END BRIDGE
17472	WEST END BRIDGE
17473	WEST END BRIDGE
17474	WEST END BRIDGE
17475	WEST END BRIDGE
17476	WEST END BRIDGE
17477	WEST END BRIDGE
17478	WEST END BRIDGE
17479	WEST END BRIDGE
17480	WEST END BRIDGE
17481	WEST END BRIDGE
17482	WEST END BRIDGE
17483	WEST END BRIDGE
17484	WEST END BRIDGE
17485	WEST END BRIDGE
17486	WEST END BRIDGE
17487	WEST END BRIDGE
17488	WEST END BRIDGE
17489	WEST END BRIDGE
17490	WEST END BRIDGE
17491	WEST END BRIDGE
17492	WEST END BRIDGE
17493	WEST END BRIDGE
17494	WEST END BRIDGE
17495	WEST END BRIDGE
17496	WEST END BRIDGE
17497	WEST END BRIDGE
17498	WEST END BRIDGE
17499	WEST END BRIDGE
17500	WEST END BRIDGE



ALL CONDITIONS NORMAL

TIME: 8:45 - 10:45


CONSUMERS POWER COMPANY

PALISADES PLANT

570'

COMPONENT DESCRIPTIONS	
100	REACTOR BLDG
101	REACTOR BLDG
102	REACTOR BLDG
103	REACTOR BLDG
104	REACTOR BLDG
105	REACTOR BLDG
106	REACTOR BLDG
107	REACTOR BLDG
108	REACTOR BLDG
109	REACTOR BLDG
110	REACTOR BLDG
111	REACTOR BLDG
112	REACTOR BLDG
113	REACTOR BLDG
114	REACTOR BLDG
115	REACTOR BLDG
116	REACTOR BLDG
117	REACTOR BLDG
118	REACTOR BLDG
119	REACTOR BLDG
120	REACTOR BLDG
121	REACTOR BLDG
122	REACTOR BLDG
123	REACTOR BLDG
124	REACTOR BLDG
125	REACTOR BLDG
126	REACTOR BLDG
127	REACTOR BLDG
128	REACTOR BLDG
129	REACTOR BLDG
130	REACTOR BLDG
131	REACTOR BLDG
132	REACTOR BLDG
133	REACTOR BLDG
134	REACTOR BLDG
135	REACTOR BLDG
136	REACTOR BLDG
137	REACTOR BLDG
138	REACTOR BLDG
139	REACTOR BLDG
140	REACTOR BLDG
141	REACTOR BLDG
142	REACTOR BLDG
143	REACTOR BLDG
144	REACTOR BLDG
145	REACTOR BLDG
146	REACTOR BLDG
147	REACTOR BLDG
148	REACTOR BLDG
149	REACTOR BLDG
150	REACTOR BLDG

DOSE RATES IN THE CORRIDOR \approx 100-200 mR/hr
 DOSE RATES BY ASSA \approx 10-30 R/hr
 DOSE RATES BY P-SSB/C \approx 5-10 R/hr
 DOSE RATES BY VCT \approx 75-100 R/hr




DOSE RATES \approx 10-20 R/hr

COMPONENT DESCRIPTIONS	
100	REACTOR BLDG
101	REACTOR BLDG
102	REACTOR BLDG
103	REACTOR BLDG
104	REACTOR BLDG
105	REACTOR BLDG
106	REACTOR BLDG
107	REACTOR BLDG
108	REACTOR BLDG
109	REACTOR BLDG
110	REACTOR BLDG
111	REACTOR BLDG
112	REACTOR BLDG
113	REACTOR BLDG
114	REACTOR BLDG
115	REACTOR BLDG
116	REACTOR BLDG
117	REACTOR BLDG
118	REACTOR BLDG
119	REACTOR BLDG
120	REACTOR BLDG
121	REACTOR BLDG
122	REACTOR BLDG
123	REACTOR BLDG
124	REACTOR BLDG
125	REACTOR BLDG
126	REACTOR BLDG
127	REACTOR BLDG
128	REACTOR BLDG
129	REACTOR BLDG
130	REACTOR BLDG
131	REACTOR BLDG
132	REACTOR BLDG
133	REACTOR BLDG
134	REACTOR BLDG
135	REACTOR BLDG
136	REACTOR BLDG
137	REACTOR BLDG
138	REACTOR BLDG
139	REACTOR BLDG
140	REACTOR BLDG
141	REACTOR BLDG
142	REACTOR BLDG
143	REACTOR BLDG
144	REACTOR BLDG
145	REACTOR BLDG
146	REACTOR BLDG
147	REACTOR BLDG
148	REACTOR BLDG
149	REACTOR BLDG
150	REACTOR BLDG

TIME: 8:45 - 10:45

CONTINUOUS PAPER COMPANY
 590'


COMPONENT DESIGNATIONS	
EL. 930 - 9	
ELCUM RESIN STORAGE TANK	
781	CLAMP DOWN TRANSPORT LAMP
	BECKE RM
787	WATER PUMP
	BORIC ACID BATCH TANK
777	S.A. BATCH TANK
100	CLAMP AND TANK
	ASPHALT REVERSE AREA
708	SPENT RESIN STORAGE TANK
7108	SPENT RESIN STORAGE TANK
7109	SPENT RESIN STORAGE TANK
7100	BECKET TRANSPORT PUMP
7101	BECKET TRANSPORT PUMP
7102	BECKET TRANSPORT PUMP
7103	BECKET TRANSPORT PUMP
7104	BECKET TRANSPORT PUMP
7105	BECKET TRANSPORT PUMP
7106	BECKET TRANSPORT PUMP
7107	BECKET TRANSPORT PUMP
7108	BECKET TRANSPORT PUMP
7109	BECKET TRANSPORT PUMP
7110	BECKET TRANSPORT PUMP
7111	BECKET TRANSPORT PUMP
7112	BECKET TRANSPORT PUMP
7113	BECKET TRANSPORT PUMP
7114	BECKET TRANSPORT PUMP
7115	BECKET TRANSPORT PUMP
7116	BECKET TRANSPORT PUMP
7117	BECKET TRANSPORT PUMP
7118	BECKET TRANSPORT PUMP
7119	BECKET TRANSPORT PUMP
7120	BECKET TRANSPORT PUMP
7121	BECKET TRANSPORT PUMP
7122	BECKET TRANSPORT PUMP
7123	BECKET TRANSPORT PUMP
7124	BECKET TRANSPORT PUMP
7125	BECKET TRANSPORT PUMP
7126	BECKET TRANSPORT PUMP
7127	BECKET TRANSPORT PUMP
7128	BECKET TRANSPORT PUMP
7129	BECKET TRANSPORT PUMP
7130	BECKET TRANSPORT PUMP
7131	BECKET TRANSPORT PUMP
7132	BECKET TRANSPORT PUMP
7133	BECKET TRANSPORT PUMP
7134	BECKET TRANSPORT PUMP
7135	BECKET TRANSPORT PUMP
7136	BECKET TRANSPORT PUMP
7137	BECKET TRANSPORT PUMP
7138	BECKET TRANSPORT PUMP
7139	BECKET TRANSPORT PUMP
7140	BECKET TRANSPORT PUMP
7141	BECKET TRANSPORT PUMP
7142	BECKET TRANSPORT PUMP
7143	BECKET TRANSPORT PUMP
7144	BECKET TRANSPORT PUMP
7145	BECKET TRANSPORT PUMP
7146	BECKET TRANSPORT PUMP
7147	BECKET TRANSPORT PUMP
7148	BECKET TRANSPORT PUMP
7149	BECKET TRANSPORT PUMP
7150	BECKET TRANSPORT PUMP
7151	BECKET TRANSPORT PUMP
7152	BECKET TRANSPORT PUMP
7153	BECKET TRANSPORT PUMP
7154	BECKET TRANSPORT PUMP
7155	BECKET TRANSPORT PUMP
7156	BECKET TRANSPORT PUMP
7157	BECKET TRANSPORT PUMP
7158	BECKET TRANSPORT PUMP
7159	BECKET TRANSPORT PUMP
7160	BECKET TRANSPORT PUMP
7161	BECKET TRANSPORT PUMP
7162	BECKET TRANSPORT PUMP
7163	BECKET TRANSPORT PUMP
7164	BECKET TRANSPORT PUMP
7165	BECKET TRANSPORT PUMP
7166	BECKET TRANSPORT PUMP
7167	BECKET TRANSPORT PUMP
7168	BECKET TRANSPORT PUMP
7169	BECKET TRANSPORT PUMP
7170	BECKET TRANSPORT PUMP
7171	BECKET TRANSPORT PUMP
7172	BECKET TRANSPORT PUMP
7173	BECKET TRANSPORT PUMP
7174	BECKET TRANSPORT PUMP
7175	BECKET TRANSPORT PUMP
7176	BECKET TRANSPORT PUMP
7177	BECKET TRANSPORT PUMP
7178	BECKET TRANSPORT PUMP
7179	BECKET TRANSPORT PUMP
7180	BECKET TRANSPORT PUMP
7181	BECKET TRANSPORT PUMP
7182	BECKET TRANSPORT PUMP
7183	BECKET TRANSPORT PUMP
7184	BECKET TRANSPORT PUMP
7185	BECKET TRANSPORT PUMP
7186	BECKET TRANSPORT PUMP
7187	BECKET TRANSPORT PUMP
7188	BECKET TRANSPORT PUMP
7189	BECKET TRANSPORT PUMP
7190	BECKET TRANSPORT PUMP
7191	BECKET TRANSPORT PUMP
7192	BECKET TRANSPORT PUMP
7193	BECKET TRANSPORT PUMP
7194	BECKET TRANSPORT PUMP
7195	BECKET TRANSPORT PUMP
7196	BECKET TRANSPORT PUMP
7197	BECKET TRANSPORT PUMP
7198	BECKET TRANSPORT PUMP
7199	BECKET TRANSPORT PUMP
7200	BECKET TRANSPORT PUMP




ALL RAD CONDITIONS
NORMAL

TIME: 8:45 - 10:45

CONSUMERS POWER COMPANY
PALISADES PLANT
625'



COMPONENT IDENTIFICATION	
178	CHIMNEY BRASS AND SWAGE TANK EL. 843'-0"
179	FUEL PUMP OPERATING FLOOR
180	COMPONENT ROOM AND WATER STORAGE TANK
181	REINFORCEMENT IN ACCESS YARD
182	SPENT FUEL STORAGE TANK
183	SPENT FUEL STORAGE TANK
184	SPENT FUEL STORAGE TANK
185	SPENT FUEL STORAGE TANK
186	SPENT FUEL STORAGE TANK
187	SPENT FUEL STORAGE TANK
188	SPENT FUEL STORAGE TANK
189	SPENT FUEL STORAGE TANK
190	SPENT FUEL STORAGE TANK
191	SPENT FUEL STORAGE TANK
192	SPENT FUEL STORAGE TANK
193	SPENT FUEL STORAGE TANK
194	SPENT FUEL STORAGE TANK
195	SPENT FUEL STORAGE TANK
196	SPENT FUEL STORAGE TANK
197	SPENT FUEL STORAGE TANK
198	SPENT FUEL STORAGE TANK
199	SPENT FUEL STORAGE TANK
200	SPENT FUEL STORAGE TANK



PLUME E


ALL RAD CONDITIONS
NORMAL




TIME: 8:45 - 10:45

COMMERCIAL POWER COMPANY

PALMER'S PLANT
6A7'



ALL TURBINE BLOW
DOSE RATES, ETC
ARE NORMAL FOR
ALL LOCATIONS
UNTIL 10:45




TIME: 8:45 - 10:45

CONGRESS POWER COMPANY
PALMBOSS PLANT 625'

COMPONENT ROOMS TYPES

100	REACTOR ROOM
101	REACTOR ROOM
102	REACTOR ROOM
103	REACTOR ROOM
104	REACTOR ROOM
105	REACTOR ROOM
106	REACTOR ROOM
107	REACTOR ROOM
108	REACTOR ROOM
109	REACTOR ROOM
110	REACTOR ROOM
111	REACTOR ROOM
112	REACTOR ROOM
113	REACTOR ROOM
114	REACTOR ROOM
115	REACTOR ROOM
116	REACTOR ROOM
117	REACTOR ROOM
118	REACTOR ROOM
119	REACTOR ROOM
120	REACTOR ROOM
121	REACTOR ROOM
122	REACTOR ROOM
123	REACTOR ROOM
124	REACTOR ROOM
125	REACTOR ROOM
126	REACTOR ROOM
127	REACTOR ROOM
128	REACTOR ROOM
129	REACTOR ROOM
130	REACTOR ROOM
131	REACTOR ROOM
132	REACTOR ROOM
133	REACTOR ROOM
134	REACTOR ROOM
135	REACTOR ROOM
136	REACTOR ROOM
137	REACTOR ROOM
138	REACTOR ROOM
139	REACTOR ROOM
140	REACTOR ROOM
141	REACTOR ROOM
142	REACTOR ROOM
143	REACTOR ROOM
144	REACTOR ROOM
145	REACTOR ROOM
146	REACTOR ROOM
147	REACTOR ROOM
148	REACTOR ROOM
149	REACTOR ROOM
150	REACTOR ROOM

CORRIDOR ≈ 100-200 mR/h
 PSSA ≈ 10-30 R/h
 PSSB/C ≈ 5-10 R/h
 VCT ≈ 75-100 R/h



DOSE RATES ≈ 10-20 R/h



DOSE RATES IN CONTACT WITH CONTAINMENT ARE ≈ 60-80 mR/h, DECREASING AS YOU MOVE AWAY FROM THE WALL.

TIME: 10:45 - 11:00

STATIONARY PERSON EQUIPMENT

PLANNED PLANT


590'

100	REACTOR ROOM
101	REACTOR ROOM
102	REACTOR ROOM
103	REACTOR ROOM
104	REACTOR ROOM
105	REACTOR ROOM
106	REACTOR ROOM
107	REACTOR ROOM
108	REACTOR ROOM
109	REACTOR ROOM
110	REACTOR ROOM
111	REACTOR ROOM
112	REACTOR ROOM
113	REACTOR ROOM
114	REACTOR ROOM
115	REACTOR ROOM
116	REACTOR ROOM
117	REACTOR ROOM
118	REACTOR ROOM
119	REACTOR ROOM
120	REACTOR ROOM
121	REACTOR ROOM
122	REACTOR ROOM
123	REACTOR ROOM
124	REACTOR ROOM
125	REACTOR ROOM
126	REACTOR ROOM
127	REACTOR ROOM
128	REACTOR ROOM
129	REACTOR ROOM
130	REACTOR ROOM
131	REACTOR ROOM
132	REACTOR ROOM
133	REACTOR ROOM
134	REACTOR ROOM
135	REACTOR ROOM
136	REACTOR ROOM
137	REACTOR ROOM
138	REACTOR ROOM
139	REACTOR ROOM
140	REACTOR ROOM
141	REACTOR ROOM
142	REACTOR ROOM
143	REACTOR ROOM
144	REACTOR ROOM
145	REACTOR ROOM
146	REACTOR ROOM
147	REACTOR ROOM
148	REACTOR ROOM
149	REACTOR ROOM
150	REACTOR ROOM

DOSE RATES TO THE NORTH AND EAST OF THE PLANT ARE $\approx 5-10 \text{ mR/hr}$

$60-80 \text{ mR/hr}$ CONTACT WITH CONTAINMENT

COMPONENT DESIGNATIONS	
EL. 855-8	EL. 855-8
EL. 855-9	EL. 855-9
EL. 855-10	EL. 855-10
EL. 855-11	EL. 855-11
EL. 855-12	EL. 855-12
EL. 855-13	EL. 855-13
EL. 855-14	EL. 855-14
EL. 855-15	EL. 855-15
EL. 855-16	EL. 855-16
EL. 855-17	EL. 855-17
EL. 855-18	EL. 855-18
EL. 855-19	EL. 855-19
EL. 855-20	EL. 855-20
EL. 855-21	EL. 855-21
EL. 855-22	EL. 855-22
EL. 855-23	EL. 855-23
EL. 855-24	EL. 855-24
EL. 855-25	EL. 855-25
EL. 855-26	EL. 855-26
EL. 855-27	EL. 855-27
EL. 855-28	EL. 855-28
EL. 855-29	EL. 855-29
EL. 855-30	EL. 855-30
EL. 855-31	EL. 855-31
EL. 855-32	EL. 855-32
EL. 855-33	EL. 855-33
EL. 855-34	EL. 855-34
EL. 855-35	EL. 855-35
EL. 855-36	EL. 855-36
EL. 855-37	EL. 855-37
EL. 855-38	EL. 855-38
EL. 855-39	EL. 855-39
EL. 855-40	EL. 855-40
EL. 855-41	EL. 855-41
EL. 855-42	EL. 855-42
EL. 855-43	EL. 855-43
EL. 855-44	EL. 855-44
EL. 855-45	EL. 855-45
EL. 855-46	EL. 855-46
EL. 855-47	EL. 855-47
EL. 855-48	EL. 855-48
EL. 855-49	EL. 855-49
EL. 855-50	EL. 855-50
EL. 855-51	EL. 855-51
EL. 855-52	EL. 855-52
EL. 855-53	EL. 855-53
EL. 855-54	EL. 855-54
EL. 855-55	EL. 855-55
EL. 855-56	EL. 855-56
EL. 855-57	EL. 855-57
EL. 855-58	EL. 855-58
EL. 855-59	EL. 855-59
EL. 855-60	EL. 855-60
EL. 855-61	EL. 855-61
EL. 855-62	EL. 855-62
EL. 855-63	EL. 855-63
EL. 855-64	EL. 855-64
EL. 855-65	EL. 855-65
EL. 855-66	EL. 855-66
EL. 855-67	EL. 855-67
EL. 855-68	EL. 855-68
EL. 855-69	EL. 855-69
EL. 855-70	EL. 855-70
EL. 855-71	EL. 855-71
EL. 855-72	EL. 855-72
EL. 855-73	EL. 855-73
EL. 855-74	EL. 855-74
EL. 855-75	EL. 855-75
EL. 855-76	EL. 855-76
EL. 855-77	EL. 855-77
EL. 855-78	EL. 855-78
EL. 855-79	EL. 855-79
EL. 855-80	EL. 855-80
EL. 855-81	EL. 855-81
EL. 855-82	EL. 855-82
EL. 855-83	EL. 855-83
EL. 855-84	EL. 855-84
EL. 855-85	EL. 855-85
EL. 855-86	EL. 855-86
EL. 855-87	EL. 855-87
EL. 855-88	EL. 855-88
EL. 855-89	EL. 855-89
EL. 855-90	EL. 855-90
EL. 855-91	EL. 855-91
EL. 855-92	EL. 855-92
EL. 855-93	EL. 855-93
EL. 855-94	EL. 855-94
EL. 855-95	EL. 855-95
EL. 855-96	EL. 855-96
EL. 855-97	EL. 855-97
EL. 855-98	EL. 855-98
EL. 855-99	EL. 855-99
EL. 855-100	EL. 855-100



TIME: 10:45 - 11:00


CONSUMER POWER COMPANY

PALLAS PLANT
625'


60-80 mR/hr CONTACT WITH CONTAINMENT WALL

~15 mR/hr
2372
EL. 848'-4"

MELTING & VENTILATION EQUIPMENT ROOM



COMPONENT OBSERVATIONS	
722	SHIELD COOLING SURGE TANK EL. 849'-0"
723	FUEL POOL OPERATING FLOOR
724	COMPONENT COOLING WATER SURGE TANK
725	SEMIBERALIZER RM 3 ACCESS TO
726	SPENT RESIN STORAGE TANK
727A & B	WMM WATER DEMINERALIZERS
728	POLYMER DEMINERALIZER EL. 849'-0"
729	ROOF
730	SURVEY METER/IN
731	SECULAR WATER TANK
732	N. REMOVAL MAKEUP SURGE TANK
733	W. REMOVAL MAKEUP SURGE TANK
734	W. REMOVAL MAKEUP SURGE TANK
735	W. REMOVAL MAKEUP SURGE TANK
736	W. REMOVAL MAKEUP SURGE TANK
737	W. REMOVAL MAKEUP SURGE TANK
738	W. REMOVAL MAKEUP SURGE TANK
739	W. REMOVAL MAKEUP SURGE TANK
740	W. REMOVAL MAKEUP SURGE TANK
741	W. REMOVAL MAKEUP SURGE TANK
742	W. REMOVAL MAKEUP SURGE TANK
743	W. REMOVAL MAKEUP SURGE TANK
744	W. REMOVAL MAKEUP SURGE TANK
745	W. REMOVAL MAKEUP SURGE TANK
746	W. REMOVAL MAKEUP SURGE TANK
747	W. REMOVAL MAKEUP SURGE TANK
748	W. REMOVAL MAKEUP SURGE TANK
749	W. REMOVAL MAKEUP SURGE TANK
750	W. REMOVAL MAKEUP SURGE TANK
751	W. REMOVAL MAKEUP SURGE TANK
752	W. REMOVAL MAKEUP SURGE TANK
753	W. REMOVAL MAKEUP SURGE TANK
754	W. REMOVAL MAKEUP SURGE TANK
755	W. REMOVAL MAKEUP SURGE TANK
756	W. REMOVAL MAKEUP SURGE TANK
757	W. REMOVAL MAKEUP SURGE TANK
758	W. REMOVAL MAKEUP SURGE TANK
759	W. REMOVAL MAKEUP SURGE TANK
760	W. REMOVAL MAKEUP SURGE TANK
761	W. REMOVAL MAKEUP SURGE TANK
762	W. REMOVAL MAKEUP SURGE TANK
763	W. REMOVAL MAKEUP SURGE TANK
764	W. REMOVAL MAKEUP SURGE TANK
765	W. REMOVAL MAKEUP SURGE TANK
766	W. REMOVAL MAKEUP SURGE TANK
767	W. REMOVAL MAKEUP SURGE TANK
768	W. REMOVAL MAKEUP SURGE TANK
769	W. REMOVAL MAKEUP SURGE TANK
770	W. REMOVAL MAKEUP SURGE TANK
771	W. REMOVAL MAKEUP SURGE TANK
772	W. REMOVAL MAKEUP SURGE TANK
773	W. REMOVAL MAKEUP SURGE TANK
774	W. REMOVAL MAKEUP SURGE TANK
775	W. REMOVAL MAKEUP SURGE TANK
776	W. REMOVAL MAKEUP SURGE TANK
777	W. REMOVAL MAKEUP SURGE TANK
778	W. REMOVAL MAKEUP SURGE TANK
779	W. REMOVAL MAKEUP SURGE TANK
780	W. REMOVAL MAKEUP SURGE TANK
781	W. REMOVAL MAKEUP SURGE TANK
782	W. REMOVAL MAKEUP SURGE TANK
783	W. REMOVAL MAKEUP SURGE TANK
784	W. REMOVAL MAKEUP SURGE TANK
785	W. REMOVAL MAKEUP SURGE TANK
786	W. REMOVAL MAKEUP SURGE TANK
787	W. REMOVAL MAKEUP SURGE TANK
788	W. REMOVAL MAKEUP SURGE TANK
789	W. REMOVAL MAKEUP SURGE TANK
790	W. REMOVAL MAKEUP SURGE TANK
791	W. REMOVAL MAKEUP SURGE TANK
792	W. REMOVAL MAKEUP SURGE TANK
793	W. REMOVAL MAKEUP SURGE TANK
794	W. REMOVAL MAKEUP SURGE TANK
795	W. REMOVAL MAKEUP SURGE TANK
796	W. REMOVAL MAKEUP SURGE TANK
797	W. REMOVAL MAKEUP SURGE TANK
798	W. REMOVAL MAKEUP SURGE TANK
799	W. REMOVAL MAKEUP SURGE TANK
800	W. REMOVAL MAKEUP SURGE TANK



PLUME E

~2-4 R/hr GENERAL AREA

~5 R/hr CONTACT WITH STACK

~100-200 mR/hr



TIME: 10:45-11:00

CONSUMERS POWER COMPANY

PALISADES PLANT

6A7'

Equipment Reference Tables	
200	200-2" FURNACE BURNERS
210	210-2" FURNACE BURNERS
220	220-2" FURNACE BURNERS
230	230-2" FURNACE BURNERS
240	240-2" FURNACE BURNERS
250	250-2" FURNACE BURNERS
260	260-2" FURNACE BURNERS
270	270-2" FURNACE BURNERS
280	280-2" FURNACE BURNERS
290	290-2" FURNACE BURNERS
300	300-2" FURNACE BURNERS
310	310-2" FURNACE BURNERS
320	320-2" FURNACE BURNERS
330	330-2" FURNACE BURNERS
340	340-2" FURNACE BURNERS
350	350-2" FURNACE BURNERS
360	360-2" FURNACE BURNERS
370	370-2" FURNACE BURNERS
380	380-2" FURNACE BURNERS
390	390-2" FURNACE BURNERS
400	400-2" FURNACE BURNERS
410	410-2" FURNACE BURNERS
420	420-2" FURNACE BURNERS
430	430-2" FURNACE BURNERS
440	440-2" FURNACE BURNERS
450	450-2" FURNACE BURNERS
460	460-2" FURNACE BURNERS
470	470-2" FURNACE BURNERS
480	480-2" FURNACE BURNERS
490	490-2" FURNACE BURNERS
500	500-2" FURNACE BURNERS
510	510-2" FURNACE BURNERS
520	520-2" FURNACE BURNERS
530	530-2" FURNACE BURNERS
540	540-2" FURNACE BURNERS
550	550-2" FURNACE BURNERS
560	560-2" FURNACE BURNERS
570	570-2" FURNACE BURNERS
580	580-2" FURNACE BURNERS
590	590-2" FURNACE BURNERS
600	600-2" FURNACE BURNERS
610	610-2" FURNACE BURNERS
620	620-2" FURNACE BURNERS
630	630-2" FURNACE BURNERS
640	640-2" FURNACE BURNERS
650	650-2" FURNACE BURNERS
660	660-2" FURNACE BURNERS
670	670-2" FURNACE BURNERS
680	680-2" FURNACE BURNERS
690	690-2" FURNACE BURNERS
700	700-2" FURNACE BURNERS
710	710-2" FURNACE BURNERS
720	720-2" FURNACE BURNERS
730	730-2" FURNACE BURNERS
740	740-2" FURNACE BURNERS
750	750-2" FURNACE BURNERS
760	760-2" FURNACE BURNERS
770	770-2" FURNACE BURNERS
780	780-2" FURNACE BURNERS
790	790-2" FURNACE BURNERS
800	800-2" FURNACE BURNERS
810	810-2" FURNACE BURNERS
820	820-2" FURNACE BURNERS
830	830-2" FURNACE BURNERS
840	840-2" FURNACE BURNERS
850	850-2" FURNACE BURNERS
860	860-2" FURNACE BURNERS
870	870-2" FURNACE BURNERS
880	880-2" FURNACE BURNERS
890	890-2" FURNACE BURNERS
900	900-2" FURNACE BURNERS
910	910-2" FURNACE BURNERS
920	920-2" FURNACE BURNERS
930	930-2" FURNACE BURNERS
940	940-2" FURNACE BURNERS
950	950-2" FURNACE BURNERS
960	960-2" FURNACE BURNERS
970	970-2" FURNACE BURNERS
980	980-2" FURNACE BURNERS
990	990-2" FURNACE BURNERS
1000	1000-2" FURNACE BURNERS

PLUME E = 2-4 R/m
 PLUME WIDTH ≈ 500 ft


≈ 1-2 R/m

OTHER AREAS
 = 1-500 R/m
 DEPENDING ON
 PROXIMITY TO
 PLUME


TIME: 10:45 - 11:00

COMBUSTION POWER COMPANY

PALISADES PLANT
 590'




COMPONENTS AND SERIAL NUMBERS
 607-42 Turbine
 718 GENERATOR 718
 811 GENERATOR 811
 7200 GENERATOR 7200



TIME: 10:45 - 11:00

COMMONWEALTH POWER COMPANY

FALGOUTS PLANT
 607'




OTHER AREAS
 ~10-200 mR/h
 DEPENDING ON
 PROXIMITY TO PLUME

TIME: 10:45 - 11:00

CONROUSE POWER COMPANY
FALLBROOK PLANT
625'

COMPONENT DECONTAMINATION SCHEMATIC	
100	WASTE GAS (PUMP & FILL)
101	WASTE GAS COND.
102	WASTE GAS DRYER
103	WASTE GAS FILTER
104	WASTE GAS PUMP
105	WASTE GAS STORAGE
106	WASTE GAS TANK
107	WASTE GAS TANK
108	WASTE GAS TANK
109	WASTE GAS TANK
110	WASTE GAS TANK
111	WASTE GAS TANK
112	WASTE GAS TANK
113	WASTE GAS TANK
114	WASTE GAS TANK
115	WASTE GAS TANK
116	WASTE GAS TANK
117	WASTE GAS TANK
118	WASTE GAS TANK
119	WASTE GAS TANK
120	WASTE GAS TANK

CORRIDOR $\approx 100-200 \text{ mR/hr}$
 PSSA $\approx 10-30 \text{ R/hr}$
 PSSB/C $\approx 5-10 \text{ R/hr}$
 VCT $\approx 75-100 \text{ R/hr}$



CONTAINMENT CONTACT DOSE RATES
 $\approx 500 - 1000 \text{ mR/hr}$
 LOWER AS YOU MOVE AWAY



COMPONENT DECONTAMINATION	
100	WASTE GAS (PUMP & FILL)
101	WASTE GAS COND.
102	WASTE GAS DRYER
103	WASTE GAS FILTER
104	WASTE GAS PUMP
105	WASTE GAS STORAGE
106	WASTE GAS TANK
107	WASTE GAS TANK
108	WASTE GAS TANK
109	WASTE GAS TANK
110	WASTE GAS TANK
111	WASTE GAS TANK
112	WASTE GAS TANK
113	WASTE GAS TANK
114	WASTE GAS TANK
115	WASTE GAS TANK
116	WASTE GAS TANK
117	WASTE GAS TANK
118	WASTE GAS TANK
119	WASTE GAS TANK
120	WASTE GAS TANK


TIME: 11:00 - 14:15

CONTAINMENT CONTACT DOSE RATES

590'

LOSE RATES TO THE NORTH AND EAST
OF THE PLANT $\approx 10-15 \text{ mR/hr}$

COMPONENT OPERATIONS	
11	EL. 528' - 9"
12	ELIMINATE STORAGE YE 20
13	GLASS BEAM TRANSDUCER 7 AM
14	BECAZ BIN
15	WATER PUMP
16	BORIC ACID BATCH YE 20
17	H. A. BATCH 12
18	GLASS ADD 12
19	ASPHALT EXTRUDER AREA
20	SPENT BEAM STORAGE LAMP
21	SPENT BEAM TRANSDUCER PUMP
22	GLASS TRANSDUCER PUMP
23	SPENT BEAM STORAGE LAMP
24	REACTOR BLEB
25	PERMISSIBLES SYSTEM 12
26	PERMISSIBLES



TIME: 11:00 - 14:15

CONSUMERS POWER COMPANY

≈ 500-1000 mR/hr CONTACT WITH CONTAINMENT

≈ 10 mR/hr

≈ 2 mR/hr

PALISADES PLANT
625'

CONTAMINANT IDENTIFICATION	
700	STRAINING UNIT
700.1	STRAINING UNIT
700.2	STRAINING UNIT
700.3	STRAINING UNIT
700.4	STRAINING UNIT
700.5	STRAINING UNIT
700.6	STRAINING UNIT
700.7	STRAINING UNIT
700.8	STRAINING UNIT
700.9	STRAINING UNIT
700.10	STRAINING UNIT
700.11	STRAINING UNIT
700.12	STRAINING UNIT
700.13	STRAINING UNIT
700.14	STRAINING UNIT
700.15	STRAINING UNIT
700.16	STRAINING UNIT
700.17	STRAINING UNIT
700.18	STRAINING UNIT
700.19	STRAINING UNIT
700.20	STRAINING UNIT
700.21	STRAINING UNIT
700.22	STRAINING UNIT
700.23	STRAINING UNIT
700.24	STRAINING UNIT
700.25	STRAINING UNIT
700.26	STRAINING UNIT
700.27	STRAINING UNIT
700.28	STRAINING UNIT
700.29	STRAINING UNIT
700.30	STRAINING UNIT
700.31	STRAINING UNIT
700.32	STRAINING UNIT
700.33	STRAINING UNIT
700.34	STRAINING UNIT
700.35	STRAINING UNIT
700.36	STRAINING UNIT
700.37	STRAINING UNIT
700.38	STRAINING UNIT
700.39	STRAINING UNIT
700.40	STRAINING UNIT
700.41	STRAINING UNIT
700.42	STRAINING UNIT
700.43	STRAINING UNIT
700.44	STRAINING UNIT
700.45	STRAINING UNIT
700.46	STRAINING UNIT
700.47	STRAINING UNIT
700.48	STRAINING UNIT
700.49	STRAINING UNIT
700.50	STRAINING UNIT
700.51	STRAINING UNIT
700.52	STRAINING UNIT
700.53	STRAINING UNIT
700.54	STRAINING UNIT
700.55	STRAINING UNIT
700.56	STRAINING UNIT
700.57	STRAINING UNIT
700.58	STRAINING UNIT
700.59	STRAINING UNIT
700.60	STRAINING UNIT
700.61	STRAINING UNIT
700.62	STRAINING UNIT
700.63	STRAINING UNIT
700.64	STRAINING UNIT
700.65	STRAINING UNIT
700.66	STRAINING UNIT
700.67	STRAINING UNIT
700.68	STRAINING UNIT
700.69	STRAINING UNIT
700.70	STRAINING UNIT
700.71	STRAINING UNIT
700.72	STRAINING UNIT
700.73	STRAINING UNIT
700.74	STRAINING UNIT
700.75	STRAINING UNIT
700.76	STRAINING UNIT
700.77	STRAINING UNIT
700.78	STRAINING UNIT
700.79	STRAINING UNIT
700.80	STRAINING UNIT
700.81	STRAINING UNIT
700.82	STRAINING UNIT
700.83	STRAINING UNIT
700.84	STRAINING UNIT
700.85	STRAINING UNIT
700.86	STRAINING UNIT
700.87	STRAINING UNIT
700.88	STRAINING UNIT
700.89	STRAINING UNIT
700.90	STRAINING UNIT
700.91	STRAINING UNIT
700.92	STRAINING UNIT
700.93	STRAINING UNIT
700.94	STRAINING UNIT
700.95	STRAINING UNIT
700.96	STRAINING UNIT
700.97	STRAINING UNIT
700.98	STRAINING UNIT
700.99	STRAINING UNIT
700.100	STRAINING UNIT

PLUME E PLUME E = 5-10 R/h


2-4 R/h

OTHER AREAS
2 - 800m R/h

TIME: 11:00 - 14:15

CONTAMINANT SOURCE SUMMARY

FALLBACKS PLANT
590





COMPANYS REPORT NUMBER	
437-2-10000	
FIG	NO. REVISED IN THIS
100	00
1000	00

PLUMBING
 ~ 4-8 R/hr
 OTHER AREAS
 5- 800 m R/hr

TIME: 11:00 - 14:15

COMPOSITE POWER COMPANY
 PLUMBING PLANT
 607'






TIME: 11:00 - 14:15

CONDENSER POWER SUPPLY
FALLOUT PLANT
625

COMPONENT IDENTIFICATION

WEST END SPACES	
0000	CONTINUOUS COOLING UNIT EXHAUSTERS
0001	CRIP PUMPS
0002	CRIP SPINNY PUMPS
0003	UP SAFETY BARRIER PUMP
0004	UP SAFETY BARRIER PUMP
0005	UP SAFETY BARRIER PUMP
0006	UP SAFETY BARRIER PUMP
0007	UP SAFETY BARRIER PUMP
0008	UP SAFETY BARRIER PUMP
0009	UP SAFETY BARRIER PUMP
0010	UP SAFETY BARRIER PUMP
0011	UP SAFETY BARRIER PUMP
0012	UP SAFETY BARRIER PUMP
0013	UP SAFETY BARRIER PUMP
0014	UP SAFETY BARRIER PUMP
0015	UP SAFETY BARRIER PUMP
0016	UP SAFETY BARRIER PUMP
0017	UP SAFETY BARRIER PUMP
0018	UP SAFETY BARRIER PUMP
0019	UP SAFETY BARRIER PUMP
0020	UP SAFETY BARRIER PUMP
0021	UP SAFETY BARRIER PUMP
0022	UP SAFETY BARRIER PUMP
0023	UP SAFETY BARRIER PUMP
0024	UP SAFETY BARRIER PUMP
0025	UP SAFETY BARRIER PUMP
0026	UP SAFETY BARRIER PUMP
0027	UP SAFETY BARRIER PUMP
0028	UP SAFETY BARRIER PUMP
0029	UP SAFETY BARRIER PUMP
0030	UP SAFETY BARRIER PUMP
0031	UP SAFETY BARRIER PUMP
0032	UP SAFETY BARRIER PUMP
0033	UP SAFETY BARRIER PUMP
0034	UP SAFETY BARRIER PUMP
0035	UP SAFETY BARRIER PUMP
0036	UP SAFETY BARRIER PUMP
0037	UP SAFETY BARRIER PUMP
0038	UP SAFETY BARRIER PUMP
0039	UP SAFETY BARRIER PUMP
0040	UP SAFETY BARRIER PUMP
0041	UP SAFETY BARRIER PUMP
0042	UP SAFETY BARRIER PUMP
0043	UP SAFETY BARRIER PUMP
0044	UP SAFETY BARRIER PUMP
0045	UP SAFETY BARRIER PUMP
0046	UP SAFETY BARRIER PUMP
0047	UP SAFETY BARRIER PUMP
0048	UP SAFETY BARRIER PUMP
0049	UP SAFETY BARRIER PUMP
0050	UP SAFETY BARRIER PUMP
0051	UP SAFETY BARRIER PUMP
0052	UP SAFETY BARRIER PUMP
0053	UP SAFETY BARRIER PUMP
0054	UP SAFETY BARRIER PUMP
0055	UP SAFETY BARRIER PUMP
0056	UP SAFETY BARRIER PUMP
0057	UP SAFETY BARRIER PUMP
0058	UP SAFETY BARRIER PUMP
0059	UP SAFETY BARRIER PUMP
0060	UP SAFETY BARRIER PUMP
0061	UP SAFETY BARRIER PUMP
0062	UP SAFETY BARRIER PUMP
0063	UP SAFETY BARRIER PUMP
0064	UP SAFETY BARRIER PUMP
0065	UP SAFETY BARRIER PUMP
0066	UP SAFETY BARRIER PUMP
0067	UP SAFETY BARRIER PUMP
0068	UP SAFETY BARRIER PUMP
0069	UP SAFETY BARRIER PUMP
0070	UP SAFETY BARRIER PUMP
0071	UP SAFETY BARRIER PUMP
0072	UP SAFETY BARRIER PUMP
0073	UP SAFETY BARRIER PUMP
0074	UP SAFETY BARRIER PUMP
0075	UP SAFETY BARRIER PUMP
0076	UP SAFETY BARRIER PUMP
0077	UP SAFETY BARRIER PUMP
0078	UP SAFETY BARRIER PUMP
0079	UP SAFETY BARRIER PUMP
0080	UP SAFETY BARRIER PUMP
0081	UP SAFETY BARRIER PUMP
0082	UP SAFETY BARRIER PUMP
0083	UP SAFETY BARRIER PUMP
0084	UP SAFETY BARRIER PUMP
0085	UP SAFETY BARRIER PUMP
0086	UP SAFETY BARRIER PUMP
0087	UP SAFETY BARRIER PUMP
0088	UP SAFETY BARRIER PUMP
0089	UP SAFETY BARRIER PUMP
0090	UP SAFETY BARRIER PUMP
0091	UP SAFETY BARRIER PUMP
0092	UP SAFETY BARRIER PUMP
0093	UP SAFETY BARRIER PUMP
0094	UP SAFETY BARRIER PUMP
0095	UP SAFETY BARRIER PUMP
0096	UP SAFETY BARRIER PUMP
0097	UP SAFETY BARRIER PUMP
0098	UP SAFETY BARRIER PUMP
0099	UP SAFETY BARRIER PUMP
0100	UP SAFETY BARRIER PUMP



DOSE RATES = 100-500 mR/hr CONTACT WITH CONTAINMENT
 LOWER AS YOU MOVE FARTHER AWAY

TIME: 14:15 - 16:00


CONGRESS POWER COMPANY

PALLASER PLANT
 570'

CONTAINMENT INFILTRATIONS SCHEMATIC	
1	WASTE GAS COMP & TR
2	WASTE GAS COMP
3	WASTE GAS DUCT
4	WASTE GAS DUCT
5	WASTE GAS DUCT
6	WASTE GAS DUCT
7	WASTE GAS DUCT
8	WASTE GAS DUCT
9	WASTE GAS DUCT
10	WASTE GAS DUCT
11	WASTE GAS DUCT
12	WASTE GAS DUCT
13	WASTE GAS DUCT
14	WASTE GAS DUCT
15	WASTE GAS DUCT
16	WASTE GAS DUCT
17	WASTE GAS DUCT
18	WASTE GAS DUCT
19	WASTE GAS DUCT
20	WASTE GAS DUCT
21	WASTE GAS DUCT
22	WASTE GAS DUCT
23	WASTE GAS DUCT
24	WASTE GAS DUCT
25	WASTE GAS DUCT
26	WASTE GAS DUCT
27	WASTE GAS DUCT
28	WASTE GAS DUCT
29	WASTE GAS DUCT
30	WASTE GAS DUCT
31	WASTE GAS DUCT
32	WASTE GAS DUCT
33	WASTE GAS DUCT
34	WASTE GAS DUCT
35	WASTE GAS DUCT
36	WASTE GAS DUCT
37	WASTE GAS DUCT
38	WASTE GAS DUCT
39	WASTE GAS DUCT
40	WASTE GAS DUCT
41	WASTE GAS DUCT
42	WASTE GAS DUCT
43	WASTE GAS DUCT
44	WASTE GAS DUCT
45	WASTE GAS DUCT
46	WASTE GAS DUCT
47	WASTE GAS DUCT
48	WASTE GAS DUCT
49	WASTE GAS DUCT
50	WASTE GAS DUCT

CORRIDOR $\approx 100-200 \text{ m R/h}$
 PSSB $\approx 10-30 \text{ R/h}$
 PSSB/C $\approx 5-10 \text{ R/h}$
 VCT $\approx 75-100 \text{ R/h}$

CONTAINMENT INFILTRATIONS SCHEMATIC	
1	WASTE GAS COMP & TR
2	WASTE GAS COMP
3	WASTE GAS DUCT
4	WASTE GAS DUCT
5	WASTE GAS DUCT
6	WASTE GAS DUCT
7	WASTE GAS DUCT
8	WASTE GAS DUCT
9	WASTE GAS DUCT
10	WASTE GAS DUCT
11	WASTE GAS DUCT
12	WASTE GAS DUCT
13	WASTE GAS DUCT
14	WASTE GAS DUCT
15	WASTE GAS DUCT
16	WASTE GAS DUCT
17	WASTE GAS DUCT
18	WASTE GAS DUCT
19	WASTE GAS DUCT
20	WASTE GAS DUCT
21	WASTE GAS DUCT
22	WASTE GAS DUCT
23	WASTE GAS DUCT
24	WASTE GAS DUCT
25	WASTE GAS DUCT
26	WASTE GAS DUCT
27	WASTE GAS DUCT
28	WASTE GAS DUCT
29	WASTE GAS DUCT
30	WASTE GAS DUCT
31	WASTE GAS DUCT
32	WASTE GAS DUCT
33	WASTE GAS DUCT
34	WASTE GAS DUCT
35	WASTE GAS DUCT
36	WASTE GAS DUCT
37	WASTE GAS DUCT
38	WASTE GAS DUCT
39	WASTE GAS DUCT
40	WASTE GAS DUCT
41	WASTE GAS DUCT
42	WASTE GAS DUCT
43	WASTE GAS DUCT
44	WASTE GAS DUCT
45	WASTE GAS DUCT
46	WASTE GAS DUCT
47	WASTE GAS DUCT
48	WASTE GAS DUCT
49	WASTE GAS DUCT
50	WASTE GAS DUCT



CONTAINMENT CONTACT DOSE RATES
 $\approx 500-1000 \text{ m R/h}$


TIME: 14:15 - 16:00

CONTAINMENT POWER COMPANY

FALGOUTS PLANT

590'

COMPONENT DESIGNATIONS	
EL. 997'-9"	
HEATING SYSTEMS	
900.5 STEAM GENERATORS	
902 CONDENSER	
903 PRIMARY CONDENSATE PUMPS	
904 HEATER, #1	
905 HEATER, #2	
906 EL. 997'-0" COMP. COOLING	
907 COND. PUMP STRAIGHT PUMP	
908 COND. PUMP TO RETURN #1	
909 COND. PUMP TO RETURN #2	
910 SWITCHGEAR #1	
911 CABLE OPERATING #1	
912 BATTERY #1	
913 ELECTRIC EQUIPMENT #1	
EL. 911'-0"	
914 900.5 WELD PANEL AREA	
915 WELD PANEL	
916 WELD PANEL	
917 CLEAR WASTE SAMPLING PLUMB.	
918 WELD PANEL	
919 VALVE GALLERY	
920 VALVE GALLERY	
921 VALVE GALLERY	
922 VALVE GALLERY	
923 VALVE GALLERY	
924 VALVE GALLERY	
925 VALVE GALLERY	
926 VALVE GALLERY	
927 VALVE GALLERY	
928 VALVE GALLERY	
929 VALVE GALLERY	
930 VALVE GALLERY	
931 VALVE GALLERY	
932 VALVE GALLERY	
933 VALVE GALLERY	
934 VALVE GALLERY	
935 VALVE GALLERY	
936 VALVE GALLERY	
937 VALVE GALLERY	
938 VALVE GALLERY	
939 VALVE GALLERY	
940 VALVE GALLERY	
941 VALVE GALLERY	
942 VALVE GALLERY	
943 VALVE GALLERY	
944 VALVE GALLERY	
945 VALVE GALLERY	
946 VALVE GALLERY	
947 VALVE GALLERY	
948 VALVE GALLERY	
949 VALVE GALLERY	
950 VALVE GALLERY	



TIME: 14:15 - 16:00

CONSUMERS POWER COMPANY


CONTAINMENT CONTACT 500-1000 mR/hr

GENERAL AREA 2 10-50 mR/hr

FALGOUTS PLANT
6/11'

DOSE RATES OUTSIDE ARE BACK TO NORMAL


COMPONENT DESIGNATIONS	
FL. 010-3	
101	ELVAN BEAM STORAGE TANK
102	ELVAN BEAM TRANSFER TANK
103	BECAZ DR
104	WATER PUMP
105	BORIC ACID BATCH TANK
106	CHD 400 T8
107	CHD 400 T8
108	ASPHALTY BITUMEN SUVE
109	SPENT BEAM STORAGE TANK
110	SPENT BEAM TRANSFER PUMP
111	BECAZ TRANSFER PUMP
112	SPENT BEAM DECAT TANK
113	REACTOR BLDG
114	PERSONNEL ADDRESS
115	PERSONNEL ADDRESS



TIME: 14:15-16:00

CONSUMER POWER COMPANY
PALISADES PLANT
625'

COMPONENT IDENTIFICATION	
100	STEAM DR. W/REHEATERS 10
101	STEAM DR. W/REHEATERS 10
102	STEAM DR. W/REHEATERS 10
103	STEAM DR. W/REHEATERS 10
104	STEAM DR. W/REHEATERS 10
105	STEAM DR. W/REHEATERS 10
106	STEAM DR. W/REHEATERS 10
107	STEAM DR. W/REHEATERS 10
108	STEAM DR. W/REHEATERS 10
109	STEAM DR. W/REHEATERS 10
110	STEAM DR. W/REHEATERS 10
111	STEAM DR. W/REHEATERS 10
112	STEAM DR. W/REHEATERS 10
113	STEAM DR. W/REHEATERS 10
114	STEAM DR. W/REHEATERS 10
115	STEAM DR. W/REHEATERS 10
116	STEAM DR. W/REHEATERS 10
117	STEAM DR. W/REHEATERS 10
118	STEAM DR. W/REHEATERS 10
119	STEAM DR. W/REHEATERS 10
120	STEAM DR. W/REHEATERS 10
121	STEAM DR. W/REHEATERS 10
122	STEAM DR. W/REHEATERS 10
123	STEAM DR. W/REHEATERS 10
124	STEAM DR. W/REHEATERS 10
125	STEAM DR. W/REHEATERS 10
126	STEAM DR. W/REHEATERS 10
127	STEAM DR. W/REHEATERS 10
128	STEAM DR. W/REHEATERS 10
129	STEAM DR. W/REHEATERS 10
130	STEAM DR. W/REHEATERS 10
131	STEAM DR. W/REHEATERS 10
132	STEAM DR. W/REHEATERS 10
133	STEAM DR. W/REHEATERS 10
134	STEAM DR. W/REHEATERS 10
135	STEAM DR. W/REHEATERS 10
136	STEAM DR. W/REHEATERS 10
137	STEAM DR. W/REHEATERS 10
138	STEAM DR. W/REHEATERS 10
139	STEAM DR. W/REHEATERS 10
140	STEAM DR. W/REHEATERS 10
141	STEAM DR. W/REHEATERS 10
142	STEAM DR. W/REHEATERS 10
143	STEAM DR. W/REHEATERS 10
144	STEAM DR. W/REHEATERS 10
145	STEAM DR. W/REHEATERS 10
146	STEAM DR. W/REHEATERS 10
147	STEAM DR. W/REHEATERS 10
148	STEAM DR. W/REHEATERS 10
149	STEAM DR. W/REHEATERS 10
150	STEAM DR. W/REHEATERS 10




COMPONENTS OF SUPPLY SYSTEM	
607 - 4	Flashing
718	IN SERVICE PUMP
851	IN SERVICE
1200	IN SERVICE

ALL DOSE RATES
NORMAL

TIME: 14:15 - 16:00

COMMONS POWER COMPANY

PLUMBING PLAN
607'




ALL DOSE RATES
NORMAL


TIME: 14:15 - 16:00

CONGRESS POWER COMPANY

PALMARES PLANT
625'



CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 1

TIME: 0HR 15MIN

ISOPLETH SCALE:

1. 00E+03

1. 00E+02

1. 00E+01

1. 00E+00

MAP LEGEND:

+ PALISADES


■ TOWN

□ AIRPORT

— ROAD

MAP SCALE IN MILES
+2.0

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 2

TIME: 0HR 30MIN

ISOPLETH SCALE:

A-1.00E+03

B-1.00E+02

C-1.00E+01

D-1.00E+00

MAP LEGEND:

+ PALISADES

• TOWER

□ AIRPORT

1/1000000

CURRENT WHOLE BODY DOSE RATE (MREM/HR)


SEGMENT NO.: 3
TIME: 0HR 45MIN

ISOPLETH SCALE:

- A 1.00E+03
- B 1.00E+01
- C 1.00E+01
- D 1.00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- AIRWAY



MAP SCALE IN MILES

CURRENT WHOLE BODY DOSE RATE (MREM/HR)


SEGMENT NO.: 4
TIME: 1HR 0MIN

ISOPLETH SCALE:

- a- 1.00E+03
- b- 1.00E+02
- c- 1.00E+01
- d- 1.00E+00


MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- RAILROAD



MAP SCALE IN MILES

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 5
TIME: 1HR 15MIN

ISOPLETH SCALE:


- A. 1.00E+03
- B. 1.00E+01
- C. 1.00E+00
- D. 1.00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD

MAP SCALE IN MILES

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 6

TIME: 1HR 30MIN

ISOPLETH SCALE:

1.00E+03

1.00E+02

1.00E+01

1.00E+00

MAP LEGEND:

+ PALISADES

* TOWN

o AIRPORT

— ROAD


MAP SCALE IN MILES

+10.

0.0

-10.

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 7

TIME: 1HR 45MIN

ISOPLETH SCALE:

A 1.00E+03

B 1.00E+02

C 1.00E+01

D 1.00E+00

MAP LEGEND:

+ PALISADES

* TURBINES

□ CONVERTER

By: [Signature]

CURRENT WHOLE BODY DOSE RATE (MREM/HR)


SEGMENT NO.: 8
TIME: 2HR 0MIN

ISOPLETH SCALE:

- A 1.00E+03
- B 1.00E+02
- C 1.00E+01
- D 1.00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- RAILROAD



MAP SCALE IN MILES +20.0

CURRENT WHOLE BODY DOSE RATE (MREM/HR)


SEGMENT NO.: 9
TIME: 2HR 15MIN

ISOPLETH SCALE:

- 1. 00E+03
- 1. 00E+01
- 1. 00E+00


MAP LEGEND:

- + PALISADES
- TOWN
- ◻ AIRPORT
- ROAD
- RAILROAD



MAP SCALE IN UNITS +20.0

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 10
TIME: 2HR 30MIN

ISOPLETH SCALE:


- 1. 00E+03
- 1. 00E+01
- 1. 00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- - - RIVER

MAP SCALE IN MILES
+20.

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 11
TIME: 2HR 45MIN

ISOPLETH SCALE:


- 1.00E+03
- 1.00E+01
- 1.00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- - - CONTOUR

MAP SCALE IN MILES
1:20,000

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 12
TIME: 3HR 0MIN

ISOPLETH SCALE:

- 1. 1. 00E+03
- 2. 1. 00E+01
- 3. 1. 00E+00

MAP LEGEND:

- + PALISADES
- ROAD
- - - RAILROAD
-

CURRENT WHOLE BODY DOSE RATE (MREM/HR)


SEGMENT NO.: 13
TIME: 3HR 15MIN

ISOPLETH SCALE:

- 1. 00E+03
- 1. 00E+02
- 1. 00E+01
- 1. 00E+00


MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- WATER



MAP SCALE IN MILES

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 14
TIME: 3HR 30MIN

ISOPLETH SCALE:


- A 1.00E+03
- B 1.00E+02
- C 1.00E+01
- D 1.00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- COASTLINE

MAP SCALE IN MILES
+20.

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 15
TIME: 3HR 45MIN

ISOPLETH SCALE:


- 1. 00E+03
- 1. 00E+02
- 1. 00E+01
- 1. 00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD

MAP SCALE IN MILES
+20.
0.0
-20.0

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 16

TIME: 4HR 0MIN

ISOPLETH SCALE:

1. 00E+03

2. 00E+02

3. 1. 00E+01

4. 1. 00E+00

MAP LEGEND:

+ PALISADES

■ TULLY

□ AIRPORT

— ROAD

--- MAP SCALE


MAP SCALE IN MILES

+20.

0.0

-20.20.

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 16A
TIME: 4HR 0MIN

ISOPLETH SCALE:

1.00E+03
1.00E+02
1.00E+01
1.00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT

6-1-60

CURRENT WHOLE BODY DOSE RATE (MREM/HR)


SEGMENT NO.: 17
TIME: 4HR 15MIN

ISOPLETH SCALE:

- A 1.00E+03
- B 1.00E+02
- C 1.00E+01
- D 1.00E+00


MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- RIVER/K/AKE



MAP SCALE IN MILES

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 18
TIME: 4HR 30MIN

ISOPLETH SCALE:

- A 1.00E+03
- B 1.00E+01
- C 1.00E+00
- D 1.00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD


1:50000/40K6

MAP SCALE IN MILES

+20.0

0.0

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 19
TIME: 4HR 45MIN

ISOPLETH SCALE:

- (A) 1.00E+03
- (B) 1.00E+02
- (C) 1.00E+01
- (D) 1.00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- R1/R2/R3/R4*


MAP SCALE IN MILES

+20.

0.0

-20.-20.

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 20

TIME: 5HR 0MIN

ISOPLETH SCALE:

A 1.00E+03

B 1.00E+02

C 1.00E+01

D 1.00E+00

MAP LEGEND:

+ PALISADES

■ TOWN


○ AIRPORT

— ROAD

Palisades

MAP SCALE IN MILES

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 20A
TIME: 5HR 0MIN

ISOPLETH SCALE:

- ④ 1. 00E+03
- ⑤ 1. 00E+02
- ⑥ 1. 00E+01
- ⑦ 1. 00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- RIVER

CURRENT WHOLE BODY DOSE RATE (MREM/HR)


SEGMENT NO.: 21
TIME: 5HR 15MIN

ISOPLETH SCALE:

- 1. 00E+03
- 1. 00E+02
- 1. 00E+01
- 1. 00E+00


MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- ⋈ AIRCRAFT



MAP SCALE IN MILES

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 22

TIME: 5HR 30MIN

ISOPLETH SCALE:

A 1.00E+03

B 1.00E+02

C 1.00E+01

D 1.00E+00

MAP LEGEND:

+ PALISADES

■ TOWN

○ AIRPORT

— ROAD

- - - - - WATERLIET

MAP SCALE IN MILES

CURRENT WHOLE BODY DOSE RATE (MREM/HR)

SEGMENT NO.: 23
TIME: 5HR 45MIN


ISOPLETH SCALE:

- A 1.00E+03
- B 1.00E+02
- C 1.00E+01
- D 1.00E+00

MAP LEGEND:


- + PALISADES
- TOWN
- AIRPORT
- ROAD

R. 100/6000



MAP SCALE IN MILES

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 24

TIME: 6HR 0MIN

ISOPLETH SCALE:

A 1.00E+03

B 1.00E+02

C 1.00E+01


D 1.00E+00

MAP LEGEND:

- + PALISADES
- TOWN
- AIRPORT
- ROAD
- Break/Link

MAP SCALE IN MILES +20.
0.0
-20

CURRENT WHOLE BODY DOSE RATE (MREM/HR)



SEGMENT NO.: 24A

TIME: 6HR 0MIN

ISOPLETH SCALE:

1. 00E+03

1. 00E+02

1. 00E+01

1. 00E+00

MAP LEGEND:

+ PALISADES

• TOWN

□ AIRPORT

— ROAD

— RAILROAD

OFFSITE RAD DATA INSTRUCTIONS

1. NOTE: DUE TO A LAST-MINUTE CHANGE IN THE SCENARIO, ALL VALUES OF CPM_I MUST BE DIVIDED BY 100. IF THE VALUE OF CPM_I/100 IS LESS THAN 50, THE VALUE OF CPM_I SHOULD BE REPORTED AS 50 CPM.
2. For each 15-minute time interval following the beginning of the release, 3 maps are provided. These maps display:

a. 0-0.5 mi $\frac{DR_{WB}/CPM_I}{CPM_S}$

b. 0-5 mi $\frac{DR_{WB}/CPM_I}{CPM_S}$

c. 5-10 mi $\frac{DR_{WB}/CPM_I}{CPM_S}$

Where: DR_{WB} = Wholebody dose rate at 3 feet measured with the window closed, $\frac{mR}{hr}$

CPM_I = Counts per minute from an iodine filter used to take a 5 ft³ air sample, cpm or K cpm

CPM_S = Counts per minute from a 100 cm² smear, cpm or K cpm

The format of the displayed data is:

$$\frac{DR_{WB}}{CPM_S} / CPM_I$$

or

$$CPM_S / \frac{DR_{WB}}{CPM_I}$$

The data separated by the slash are DR_{WB} and CPM_I . The data value above, below, next to, etc, is CPM_S .

On the maps, Bkg indicates normal background for surveys and counts on filters.

3. The following rules are to be used to supply other required data (unless otherwise noted on maps).
 - a. Open Window = 1.25 x closed window
 - b. 3-Inch Dose Rate = 3-foot dose rate (when in plume)
 - c. Particulate Filter CPM = Iodine filter cpm \div 10
 - d. mR/hr from smears, filters, etc \sim cpm \div 5,000
 - e. For each minute "in the plume," contaminate vehicles, people, equipment with \sim 100 cpm/100 cm²

- f. For air samples other than 5-cubic feet, ratio the provided value, appropriately

(Example: $1/2 \text{ ft}^3$ sample $\rightarrow 0.5/5 \rightarrow 0.10 \times \text{CPM}_I$, etc)

Do the same for smears other than 100 cm^2 (NCPM_S).

- g. EMT exposure is estimated from the dose rates and time in the plume.
- h. When EMT members are counting samples, be sure to consider the potential for elevated background due to other samples.
- i. Instrument ranges have been assumed to be:

Count Rate Max = 500 K cpm


Min = Bkg

Dose Rate Max = 50,000 mR/hr

Min = 0.5 mR/hr

- j. Normal background as measured by the EMT instruments is: 50 cpm and 0.1 mR/hr.
- k. Frisker response to plume is $\sim \text{mR/hr} \times 5,000$.
- l. Ground frisk is only after the plume blows away and is CPM_S (smear counts) $\div 10$ at 1/2 inch and $\text{CPM}_S \div 50$ at 3 feet from the ground.

Between 0800 and 1045, all offsite radiological conditions are normal background.




TIME: 1045 - 11:00

O - SMILE EMT MAP

TIME : 10:45 - 11:00



A B C D E F G H I J K L M N O



LEGEND

- RAILROAD OR RAILROAD SPUR
- CONTROLLED AREAS
- PROPERTY LINE
- FENCE LINE
- HIGHWAY OR RAILROAD RIGHT OF WAY
- PROTECTED AREA

PALISADES NUCLEAR PLANT,
EMERGENCY ONSITE MONITORING MAP



TIME: 11:00 - 11:15


5-10 MILE EMT MAP

TIME: 11:00-11:15




5-10 MILE EMT MAP

TIME: 11:15-11:30




A B C D E F G H I J K L M N O



PALISADES NUCLEAR PLANT.
EMERGENCY ONSITE MONITORING MAP

.... TIME: 11:30 - 11:45

A B C D E F G H I J K L M N O




PALISADES NUCLEAR PLANT,
EMERGENCY ONSITE MONITORING MAP



.... TIME: 11:45 - 12:00


A B C D E F G H I J K L M N O



TIME: 12:00 - 12:15


0 - SMILE EMT MAP

TIME : 12:00 - 12:15




5-10 MILE EMT MAP

TIME: 12:00 - 12:15



A B C D E F G H I J K L M N O

1 2 3 4 5 6 7 8 9 10 11



PALISADES NUCLEAR PLANT.
EMERGENCY ONSITE MONITORING MAP


.... TIME: 12:15 - 12:30

5-10 MILE EMT MAP

TIME: 12:15 - 12:30



A B C D E F G H I J K L M N O



LEGEND

- RAILWAY ON RAILWAY SPUR
- CONTROLLED DEEDED
- PROPERTY LINE
- FENCE LINE
- HIGHWAY OR RAILWAY RIGHT OF WAY
- PROTECTED AREA


PALISADES NUCLEAR PLANT,
EMERGENCY ONSITE MONITORING MAP



TIME: 12:30 - 12:45

O - SMILE EMT MAP


TIME : 12:30 - 12:45



Small illegible text at the bottom right corner.

A B C D E F G H I J K L M N O

1 2 3 4 5 6 7 8 9 10 11



LEGEND

- RAILWAY OR RAILWAY SPUR
- CONTROLLED DEEDED PROPERTY LINE
- FENCE LINE
- HIGHWAY OR RAILWAY RIGHT OF WAY
- PROTECTED AREA


**PALISADES NUCLEAR PLANT,
EMERGENCY ONSITE MONITORING MAP**



.... TIME: 12:45-13:00


O - SMILE EMT MAP

TIME: 12:45 - 13:00



A B C D E F G H I J K L M N O

1 2 3 4 5 6 7 8 9 10 11



LEGEND


- RAILWAY OR RAILWAY SPUR
- CONTROLLED DEERED PROPERTY LINE
- FENCE LINE
- RIGHTWAY OR RAILWAY RIGHT OF WAY
- PROTECTED AREA

Palisades Nuclear Plant,
EMERGENCY ONSITE MONITORING MAP

TIME: 13:00 - 13:15

O - SMILE EMT MAP

TIME: 13:00 - 13:15




SMILE EMT MAP

5-10 MILE EMT MAP

TIME: 15:00 - 13:15



A B C D E F G H I J K L M N O




PALISADES NUCLEAR PLANT,
EMERGENCY ONSITE MONITORING MAP



.... TIME: 13:15 - 13:30

1 2 3 4 5 6 7 8 9 10 11

A B C D E F G H I J K L M N O




LEGEND

+++++	RAILWAY OR RAILWAY SPUR
=====	CONTROLLED DECEED PROPERTY LINE
----	FENCE LINE
----	HIGHWAY OR RAILWAY RIGHT OF WAY
----	PROTECTED AREA

**PALISADES NUCLEAR PLANT,
EMERGENCY ONSITE MONITORING MAP**




TIME: 13:30 - 13:45




TIME: 13:45 - 14:00

5-10 MILE EMT MAP

TIME: 13:45-14:00




A B C D E F G H I J K L M N O




TIME: 14:00 - 14:15

5-10 MILE EMT MAP

TIME: 14:00-14:15



A B C D E F G H I J K L M N O




DOSE RATES FROM GROUND SHINE: 3" DOSE RATE IS X 2
 OPEN = CLOSED,


TIME: 14:30 - 14:45

5-10 MILE EMT MAP

TIME: 14:30 - 19:45



A B C D E F G H I J K L M N O




DOSE RATES FROM GROUND SHINE: 3" DOSE RATE IS X 2

.... TIME: 14:45 - 15:00

OPEN & CLOSED


O - SMILE EMT MAP

TIME: 15:15 - 15:30



0 - SMILE EMT MAP

TIME: 15:30-15:45



EMT 15:30-15:45

ENVIRONMENTAL AND ACCIDENT TLDs AND FIXED OFFSITE AIR SAMPLER DATA

Because of the time required to retrieve and analyze these samples, the results are assumed unavailable until 12-24 hours following collection. Other environmental samples (milk, grass, soil, etc) require similar evaluation times (except those samples collected by the State covered in the Ingestion Pathway data); therefore, the results are not available in the time frame of the exercise.