



Commonwealth Edison

One First National Plaza, Chicago, Illinois

Address Reply to: Post Office Box 767

Chicago, Illinois 60690 - 0767

August 21, 1986

Mr. Harold R. Denton
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, DC. 20555

Subject: Braidwood Station Units 1 & 2
Supplemental Information
for Exceptions to FSAR Appendix A
Regulatory Guides 1.52 and 1.140
NRC Docket Nos. 50-456 and 50-457

Reference: July 2, 1986 A.D. Miosi letter to H.R. Denton

Dear Mr. Denton:

Enclosed is information necessary to complete your review of our request identified in the referenced letter concerning exceptions to FSAR Appendix A Regulatory Guides 1.52 and 1.140. Additional information is being provided to address use of silicone sealant in HVAC ductwork as a permanent sealant and carbon testing.

Carbon Testing

Additional clarification is being provided concerning laboratory carbon testing. The attached Braidwood FSAR pages A1.140-3 and A1.152-4 reflects this clarification. Section 6a(2) of the Braidwood FSAR will now read:

All carbon furnished prior to 1985 as part of the original specification for atmospheric clean-up filtration units will be tested to the requirements of Table 5-1 of ANSI N509-1976. All replacement carbon or original carbon furnished in 1985 or later will be tested to the requirements of Table 5-1 of ANSI N509-1980 with the exception that the laboratory test for methyl iodine penetration at 30°C, 95% relative humidity will be less than 1%.

8609020071 860821
PDR ADOCK 05000456
A PDR

*Bool
11*

Use of Silicone Sealant


To satisfy the question of ductwork integrity, the following information is provided:

1. Braidwood Station commits to check the Control Room Ventilation system flow monitor indications located on the local control room ventilation system panel on a daily basis.
2. The above mentioned flow instrumentation will be calibrated on an eighteen month calibration frequency. Based on an acceptable review of calibration records, the calibration frequency may be lengthened to normal plant surveillance frequency.
3. Attached is the test and balancing program plan that Braidwood Station is following during construction testing. The details of this program were discussed with Jack Hayes of NRR.

Should you have any questions concerning this information, please contact this office.

One signed original and fifteen copies of this letter and attachment are provided for your review.

Very truly yours,



A. D. Miosi
Nuclear Licensing Administrator

/klj
cc: J. Stevens
2016K

BRADWOOD

BYA-FSAR

AMENDMENT 47
APRIL 1986

- 3a - The components of the heaters are manufactured and assembled as per Section 5.5 of ANSI N509-76, similar to the requirements of heaters in safety-related filter systems, but the traceability of the components is not established as it would be in the case of safety-related heaters. Thus, no complete qualification program is done.
- 5b - Airflow distribution and air-aerosol mixing tests will not be performed on the non-entry type filter units. Airflow distribution tests will be performed on all entry-type filter trains to ensure that the airflow through any individual filter element does not exceed 120% of the element's rated capacity.
- 5c - Silicone sealants or other temporary patching material will not be used in the non-ESF filter housings. Silicone sealant is used, however, as a permanent sealant for HVAC ductwork.
- 6a(2) - All carbon furnished prior to 1985 as part of the original specification for atmospheric clean-up filtration units will be tested to the requirements of Table 5-1 of ANSI N509-1976. All replacement carbon or original carbon furnished in 1985 or later will be tested to the requirements of Table 5-1 of ANSI N509-1980. With the exception that the laboratory test for methyl iodine penetration at 30 °C, 95% relative humidity is less than 1%.
- 6a(3) - Laboratory tests will be performed per the requirements of Table 2 of Regulatory Guide 1.140 with the exception that the temperature will be 30 °C.

5.b Airflow distribution tests will be performed to ensure that the airflow through any individual filter element does not exceed 120% of the element's rated capacity.

5.c ~~XXXXXXXXXXXXXXXXXXXX~~

Silicone sealant or other temporary patching material will not be used in the ESF filter housings. Silicone sealant is used, however, as

a perman
sealant
HVAC
ductwork

Further discussions on this subject can be found in Subsections 9.4.1.2 and 12.3.1.7.

Note 1: Exception to this section is no longer required because the Regulatory Guide has been revised to eliminate the criteria to which exception was originally taken.

6. a(2) All carbon furnished prior to 1985 as part of the original specification for atmospheric clean-up filtration units will be tested to the requirements of Table 5-1 of ANSI NSD9-1976. All replacement carbon or original carbon furnished in 1985 or later will be tested to the requirements of Table 5-1 of ANSI NSD9-1980. With the exception that

6. a(3) Laboratory tests will be performed per approved plant Technical Specifications.


the laboratory test for methyl iodine penetration at 30°C, 95% relative humidity is less than 1%.

SUBSYSTEM LIST


LEGEND

<u>Subsystem</u>	<u>Type</u>	<u>Area Served</u>	<u>Symbol</u>	<u>Name</u>	<u>Description</u>
0A	S,R	Common Supply and Return Headers Train A		System Resistance	Element Number
0B	S,R	Common Supply and Return Headers Train B		System Resistance	Element Number
01	S	Make-Up Air Filter Unit - Unit 1		Filter Resistance	-
02	S	Supply Unit 1 (Min. O.A.)		Coil Resistance	-
03	S	Make-Up Air Filter Unit - Unit 2		Coil Resistance	-
04	S	Supply Unit 2 (Min. O.A.)		Balancing Damper	Damper Number 0WXXY
05	S	Kitchen, Locker, Corridors, Record, Upper Cable Spreading Room, HVAC Equip. Room - Unit 1		Control Damper	Damper Number
06	S	Auxiliary Elec. Equip. Room - Unit 1		GRD-0BD	GRD Identity Number
07	S	Auxiliary Elec. Equip. Room - Unit 1, Storage, Locker		GRD-0BD	GRD Identity Number
08	-	N/A		Splitter	-
09	-	N/A		Splitter	-
10	S	Control Room - Unit 1		Gravity Shutter	Damper Number 0WXXY
11	R	Control Room - Unit 1		Gravity Shutter	Damper Number 0WXXY
12	-	N/A		Gravity Shutter	Damper Number 0WXXY
13	R	Control Room - Unit 2		Gravity Shutter	Damper Number 0WXXY
14	S	Control Room - Unit 2		Gravity Shutter	Damper Number 0WXXY
15	-	N/A		Gravity Shutter	Damper Number 0WXXY
16	-	N/A		Gravity Shutter	Damper Number 0WXXY
17	R	Auxiliary Elec. Equip. Room - Unit 2, Security Control Center, Electronics Shop		Gravity Shutter	Damper Number 0WXXY
18	S	Auxiliary Elec. Equip. Room - Unit 2		Gravity Shutter	Damper Number 0WXXY
19	S	Security Control Center, Electronics Shop		Gravity Shutter	Damper Number 0WXXY

- NOTES:
1. Subsystem number is the last two digits of the airflow measuring station except 00.
 2. S = Supply
R = Return
N/A = Not Applicable



	Room Number	Refer to Room List
	Room Number w/ Multiple GRD's	Refer to Room List Number of GRD's
	Pitot Traverse No.	S0101
	Pressure Drop Node Number	
	UNDUCTED RESISTANCE	



Client	Commonwealth Edison Company
Project	Braidwood - Units 1 & 2
Proj. No.	4683/84-00
Equip. No.	

Prepared by	W.B.Paschal	Date	8/14/86
Reviewed by		Date	
Approved by		Date	

Calcs. For	Control Room HITSS
Subsystem List - - Legend	
Safety-Related	Non-Safety-Related

Calc. No.	
Rev.	0
Date	8/14/86
Page	2 of

10 15 20 25 30 35 40 45 50

ROOM LIST

Room No.	Area Served	Elevation	Supply Air Design CFM	Acceptance Range	Design Pressure
1	Control Room - Unit 1	451'-0"	10,500	8750 - 11,550	
2	Control Room - Unit 2	451'-0"	10,500	8750 - 11,550	
3	Auxiliary Elect. Equip. Room - Unit 1	451'-0"	10,400	9900 - 11,440	
4	Auxiliary Elect. Equip. Room - Unit 2	451'-0"	10,100	9600 - 11,110	
5	HVAC Equipment Room - Unit 1	451'-0"	1000	870 - 1100	
6	HVAC Equipment Room - Unit 2	451'-0"	1000	870 - 1100	
7	Upper Cable Spreading Room	463'-5"	1300	1150 - 1430	
8	Men's Locker Room	451'-0"	430	380 - 475	
9	Corridor A-413	451'-0"	130	125 - 150	
10	Kitchen	451'-0"	850	760 - 935	
11	Corridor A-402	451'-0"	150	140 - 165	
12	Record Room	451'-0"	300	230 - 330	
13	Storage Room	451'-0"	300	200 - 330	
14	Corridor	451'-0"	140	130 - 155	
15	Security Control Center	451'-0"	1500	1110 - 1650	
16	Electronics Shop	451'-0"	700	630 - 770	
17	Storage Room Toilet	451'-0"	(100)	(MIN 70)	
18	Men's Toilet	451'-0"	(200)	(MIN 200)	
19	Janitor's Closet	451'-0"	(100)	(MIN 80)	

NOTE:

Airflow rates within the above acceptance ranges will be acceptable provided that design pressures with respect to areas not served by the Control Room HVAC system are maintained.



Client Commonwealth Edison Company	
Project Braidwood - Units 1 & 2	
Proj. No. 4683/84-00	Equip. No.

Prepared by W. B. Paschal	Date 8/14/86
Reviewed by	Date
Approved by	Date

Calc. For Control Room HITSS	
Room List	
Safety-Related	Non-Safety-Related

Calc. No.	
Rev. 0	Date 8/14/86
Page 3	of

5 10 15 20 25 30 35 40 45 50 55

Calc. No. <i>110</i>	Date <i>5/10/86</i>
Rev. <i>0</i>	Page <i>4</i> of <i>4</i>

Calc. For <i>BLANK PAGE</i>	Safety-Related	Non-Safety-Related
-----------------------------	----------------	--------------------

Prepared by <i>AP</i>	Date <i>5/10/86</i>
Reviewed by	Date
Approved by	Date

Client <i>PECO</i>	Equip. No.
Project <i>BRAIDWOOD - UNITS 1 & 2</i>	
Proj. No. <i>1683/84</i>	



5 10 15 20 25 30 35 40 45 50


SUPPLY

RETURN

SUBSYSTEM NUMBER	NUMBER OF PITOT TRAVERSE	SUBSYSTEM NUMBER	NUMBER OF PITOT TRAVERSE
50A	6	ROA	7
05	8	07	8
06	2	11	12
10	5	13	14
14	9	16	7
18	2		
19	7		
	<u>TOTAL 39</u>		<u>TOTAL 48</u>

SUPPLY 39
 RETURN 48
 MIN.OA 1
 TOTAL 88

	Client	PECO	Cal. No	VC
	Project	BRAIDWOOD - UNITS 1+2	Rev.	0
	Proj. No	4/03/04	Date	
	Equip. No.		Page	5 of
Prepared by 		Calls For CONTROL ROOM HVAC SYSTEM - TRAVERSE SUMMARY		
Reviewed by		Safety-Related		Non-Safety-Related
Approved by		Date		Date



SUMMARY	
6/6 TRAVERSES	
1 INLET	
6 OUTLETS	
19 NODES	
18 PATHS	

Calc No	VC
Rev	0
Date	8/14/86
Page	6 of

Calcs For CONTROL ROOM HVAC SUPPLY (TRAIN A) - SUBSYSTEM SOA

Safety-Related	Non-Safety-Related
----------------	--------------------

Prepared by	WBP
Reviewed by	
Approved by	
Date	8/14/86
Date	
Date	

Client	CECO
Project	OPAWD000 - UNITS 1 & 2
Prog. No.	4/283/84
Equip. No.	

PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE		FINAL VALUE
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	
1	O	OFF- VPO05	50508		50A05-0		50508				
2	O	OFF- VPO06	50602		50A05-0		50602				
3	O	OFF- VPO10	21005		50A04-0		51005				
4	O	OFF- VPO14	51409		50A03-0		51409				
5	O	OFF- VPO18	31802		50A01-0		51802				
6	O	OFF- VPO19	51907		50A01-0						
7	S	OVCO1A									
8	I		50A05		50A06- 50A05		50A05				
9	D	OVCO2SY									
10	D	OVCO9SY									
11	I		50A04		50A05- 50A04		50A04				
12	D	OVCO10Y									
13	I		50A03		50A04- 50A03		50A03				
14	D	OVCO140Y									
15	I		50A02		50A03- 50A02		50A02				

$B = \text{INCHES OF WATER}$
 $Q = \text{COLUMN DIFFERENTIAL VOLUME FLOWRATE ACFM}$
 $P = \text{DENSITY, lbm/ft}^3$

$R = (1.2015 \times 10^{-6}) \frac{B}{P Q^2}$

REPERMATION
 DEFAULT 0.00001
 DAMPER LIST
 R
 R
 DEFAULT 0.0001

DESCRIPTION
 DAMPER NUMBER
 DAMPER NUMBER
 ROOM NUMBER
 AIR, HEATS, STR. NO.


Client: **CECO**
 Project: **BRANDWOOD UNITS 1+2**
 Prepared by: **UBP**
 Date: **5/1/80**
 Calculated by: **UBP**
 Date: **5/1/80**
 Title: **RESISTANCE DETERMINATION**
 SUB-SYSTEM NUMBER: **50A**
 Calc No: **VC**
 Rev: **0**
 Date: **08/16/82**

PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE VALUE		
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	FINAL
16	I	-	50A01		50A02 50A01		50A01				
17	D	OVC175Y	-		-		-				
18	D	OVC199Y	-		-		-				

* PATH TYPE	PATH NAME	DESCRIPTION	DETERMINATION
C	CONTROL DAMPER	DAMPER NUMBER	DEFAULT 0.00001
D	BALANCE DAMPER	DAMPER NUMBER	DAMPER LIST
I	INTERNAL	-	Q
O	OUTLET/INLET	ROOM NUMBER	Q
S/R	INLET/OUTLET	AIR MEAS. STA. NO.	DEFAULT 0.00001

ΔP = INCHES OF WATER COLUMN DIFFERENTIAL
 \tilde{Q} = VOLUME FLOWRATE ACFM
 ρ = DENSITY, lbm/ft³

$$R = (1.2015 \times 10^{-6}) \frac{\Delta P}{\rho \tilde{Q}^2}$$



Client: CECO
 Project: BRANDWOOD UNIT 1 & 2

Prepared by: WPP
 Date: 8/16/86
 Reviewed by:
 Date:

Calc. For RESISTANCE DETERMINATION
 SUB-SYSTEM NUMBER 50A

Calc. No. VC
 Rev. 0 Date 08/16/86
 Page A of

Form 00 4.3.2 Rev. 1

DAMPER NUMBER	PATH NUMBER	PATH AFFECT (W(IN) H(IN))	AREA (L ²)	DAMPER NUMBER	LOSS COEFFICIENT	R
OVC035Y	9	1				
OVC095Y	10	2				
OVC104Y	12	3				
OVC140Y	14	4				
OVC175Y	17	5				
OVC199Y	18	6				


K: LOSS COEFF. = 0.46 FOR OPEN DAMPER (90°)

R = K / A²

Client: **CECO**
 Project: **ARMADILLO UNITS 1-2**
 Prepared by: **WBP**
 Reviewed by:
 Approved by:
 Date: 8/16/50
 Date:
 Date:
 Safety-Related
 Non-Safety-Related
 Calc. For: **BALANCING DAMPER LIST**
DUC SYSTEM NUMBER 50A
 Calc. No. **VC**
 Rev. **0**
 Date: **08/14/88**
 Page **9** of **9**



5 10 15 20 25 30 35 40 45 50 55



SUMMARY
8 TRAVERSSES
1 INLET
7 OUTLETS
20 NODES
19 PATHS

Calc. No. VC
Rev. 0
Date 08/14/06
Page 1/3 of 3

Calc. For CONTROL ROOM HVAC
SUPPLY - SUBSYSTEM 05
Safety-Related
Non-Safety-Related

Prepared by WBP/JTP	Date 08/14/06
Reviewed by	Date
Approved by	Date

Client CECO
Project BRAIDWOOD
Proj. No. 4683/04
Equip. No.



FORM 00432 Rev. 1

PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE		VALUE FINAL
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	
1	0	12	50508		50506-0		50506				
2	0	5	50505		50505-0		50507				
3	0	7	50507		50505-0		50506				
4	0	8	50504		50504-0		50504				
5	0	9	50503		50503-0		50503				
6	0	10	50502		50502-0		50502				
7	0	11	50511		50502-0		50511				
8	S	OFF-VC005									
9	D	OVC58Y									
10	I		50505		50508-50505		50505				
11	D	OVC80Y									
12	D	OVC303Y									
13	I		50504		50505-50504		50504				
14	D	OVC38Y									
15	D	OVC39Y									

$R = \text{INCHES OF WATER}$
 $Q = \text{COLUMN DIFFERENTIAL VOLUME FLOWRATE ACFM}$
 $P = \text{DENSITY, lbm/ft}^3$

$R = (1.2015 \times 10^{-6}) \frac{Q^2}{P^3}$

PERMISSION
 DEFAULT 0.00001
 DAMPER LIST
 R
 R
 DEFAULT 0.00001

Client: **CECO**
 Project: **BRANDWOOD UNITS 1+2**
 Path No. **583104**

Prepared by: **WBP** Date: **8/16/86**
 Reviewed by: _____ Date: _____
 Approved by: _____ Date: _____

Calculations For: **RESISTANCE DETERMINATION**
SUB-SYSTEM NUMBER 05
 Safety-Related: _____ Non-Safety-Related: _____

Calc. No. **12**
 Rev. **0** Date: **08/16/86**
 Page **11** of _____



5	10	15	20	25	30	35	40	45	50
PATH NO.	DESCRIPTION	ACTUAL AIRFLOW RATE REFERENCE VALUE	TOTAL PRESSURE DROP REFERENCE VALUE	AIR DENSITY REFERENCE VALUE	PATH RESISTANCE CALC.	PATH RESISTANCE ADJUST	VALUE FINAL		
16	I	50503	50504- 50503	50503					
17	D	SPLITTER					0.00001		
18	I	50502	50503- 50502	50502					
19	D	SPLITTER					0.00001		

Δ = INCHES OF WATER
 $\sim Q$ = COLUMN DIFFERENTIAL VOLUME FLOWRATE ACFM
 ρ = DENSITY, lbm/ft³

$Q = (1.2015 \times 10^6) \frac{\Delta P}{\rho Q^2}$

DETERMINATION
 DEFAULT 0.00001
 DAMPER LIST
 ρ
 ρ
 ROOM NUMBER
 AIR, HEAT. STR. NO.
 DEFAULT 0.00001

Client	CECO
Project	BRANDWOOD UNITS 1 & 2
Prop. No.	505104
Spec. No.	
Prepared by	WBP
Reviewed by	
Approved by	
Date	2/14/86
Date	
Date	
Calc. For	RESISTANCE DETERMINATION
Rev.	0
Page	12
of	
Calc. No.	VC
Date	08/16/86
Non-Safety-Related	
Safety-Related	




DAMPERS NUMBER	PATH NUMBER	PATH AFFECT. (W(IN) H(IN))	DIMENSIONS (W(IN) H(IN))	AREA (FT ²)	DAMPERS POSITION	LOSS COEFFICIENT	R
OVC 58Y	9	1					
OVC 80Y	11	2					
OVC 303Y	12	3					
OVC 38Y	14	4					
OVC 39Y	15	16					
SPLITTER	17	5					
SPLITTER	19	6					

* K = LOSS COEFF. = 2.46 FOR WIDE OPEN DAMPER (90°)

$R = \frac{K}{A^2}$

Client: CECO	Prepared by: WBP	Date: 6/10/06	Calc. For: BALANCING DAMPER LIST	Calc. No: VR
Project: GRANDWOOD UNITS 1-2	Reviewed by:	Date:	210 SYSTEM NUMBER 05	Rev: 0
Drawn: WBP	Approved by:	Date:	Safety-Related:	Page: 13 of
			Non-Safety-Related:	Date: 08/16/06



<u>SUMMARY</u>	
2 TRAVERSES	
1 INLET	
2 OUTLETS	
5 NODES	
4 PATHS	
Calc. No. VC	
Rev. 0	Date 08/14/86
Page 14	of

Calcs. For CONTROL ROOM HVAC
 SUPPLY-SUBSYSTEM 06

Safety-Related	Non-Safety-Related
----------------	--------------------

Prepared by	WEP/JTP	Date	08/14/86
Reviewed by		Date	
Approved by		Date	

Client	CECO
Project	ORAIWOOD
Proj. No.	4083/84
Equip. No.	



PATH NO.	DESCRIPTION	ACTUAL AIRFLOW RATE REFERENCE VALUE	TOTAL PRESSURE DROP REFERENCE VALUE	AIR DENSITY REFERENCE VALUE	PATH RESISTANCE CALC.	ADJUST	VALUE FINAL
1	3	50602-20601	50602-0	50602			
2	3	50601	50602-0	50601			
3	5 OFF-VELOC	-	-	-			
4	D SPLITTER	-	-	-			0.00001

$R = \text{INCHES OF WATER}$
 $Q = \text{COLUMN DIFFERENTIAL VOLUME FLOWRATE ACFM}$
 $\rho = \text{DENSITY, lbm/ft}^3$

$R = (1.2015 \times 10^{-6}) \frac{Q^2}{\rho^3}$

RETERMINATION
 DEFAULT 0.0001
 DAMPER LIST
 Q
 Q
 DEFAULT 0.0001

DESCRIPTION
 DAMPER NUMBER
 DAMPER NUMBER
 ROOM NUMBER
 AIR, HEAT, WTR. NO.

PATH NAME
 CENTRAL DAMPER
 PLUMBING DAMPER
 INTERM.
 OUTLET/INLET
 INLET/OUTLET

PATH TYPE
 C
 D
 I
 O
 S/R

Client: **CECO**
 Project: **Branwood Units 1 & R**
 Path No: **0-25104**

Prepared by: **U/BP**
 Reviewed by:
 Approved by:

Date: **5/14/86**
 Date:
 Date:

Calc. For RESISTANCE DETERMINATION
SUB-SYSTEM NUMBER 06
 Safety-Related
 Non-Safety-Related


Calc. No. **UC**
 Rev. **0**
 Date: **09/16/86**
 Page **15** of

DAMPER NUMBER	PATH NUMBER	PATH NUMBER AFFECT (W/IN) A (M)	AREA (FT ²)	DAMPER POSITION	LOSS COEFFICIENT	R
SPLITTER	4	2				

* K: LOSS COEFF. = 0.46 FOR MAX OPEN DAMPER (90°)

$$R = \frac{K}{A^2}$$

5 10 15 20 25 30 35 40 45 50 55



SUMMARY	
5 TRAVERSES	
1 INLETS	
5 OUTLETS	
14 NODES	
13 PATHS	

Calc. No. VC	
Rev. 0	Date 8/11/86
Page 17	of

Calc. For	CONTROL ROOM HVAC
	SUPPLY - SUBSYSTEM 10
Safety-Related	
Non-Safety-Related	

Prepared by	WBP/JJP	Date	08/11/86
Reviewed by		Date	
Approved by		Date	

Client	CECO
Project	CRAIGWOOD UNITS 1 + 2
Proj. No.	4683/84
Equip. No.	



PATH NO.	DESCRIPTION	ACTUAL AIRFLOW RATE REFERENCE	TOTAL PRESSURE DROP REFERENCE VALUE	AIR DENSITY REFERENCE VALUE	PATH RESISTANCE CALC.	ADJUST	VALUE FINAL
1	0	51005	51005-0	51005			
2	0	51004	51004-0	51004			
3	0	51003	51003-0	51003			
4	0	51002	51002-0	51002			
5	0	51001	51002-0	51001			
6	5	OFF-VC010					
7	D	SPLITTER					0.00001
8	I	51004	51005-51004	51004			
9	D	SPLITTER					0.00001
10	I	51003	51004-51003	51003			
11	D	SPLITTER					0.00001
12	I	51002	51003-51002	51002			
13	D	SPLITTER					0.00001

$R = \text{INCHES OF WATER}$
 $Q = \text{COLUMN DIFFERENTIAL VOLUME FLOWRATE ACFM}$
 $P = \text{DENSITY, lbm/ft}^3$

$Q = (1.2015 \times 10^6) \frac{R}{P}$

Client	CECO	Project	BRANDWOOD UNIT 1 & 2
Prepared by	VUBP	Checked by	
Approved by		Date	9/16/84
Calc. For	RESISTANCE DETERMINATION	Sub-System Number	10
Calc. No.	VC	Rev.	0
Date	08/16/86	Page	18 of


DAMPER NUMBER	PATH NUMBER	PATH AREA FEET. (W)(H)	ALIGN	AREA (FT ²)	DAMPER POSITION	LOSS COEFFICIENT	R RESISTANCE
SPLITTER	7	1	-	-	-	-	-
"	9	2	-	-	-	-	-
"	11	3	-	-	-	-	-
"	13	4	-	-	-	-	-

* K: LOSS COEFF. = 0.46 FOR WIRE OPEN DAMPER (90°)

$$R = \frac{K}{A^2}$$

Client	CECO	Date	5/16/84
Project	CANADIAN UNITS 1+2	Date	
Eng. No.	9628/84	Date	
Prepared by	WBP	Date	5/16/84
Reviewed by		Date	
Approved by		Date	
Calc. For		BALANCING DAMPER LIST	
SUBSYSTEM NUMBER		10	
Safety-Related		Non-Safety-Related	
Calc. No.	VC	Rev.	0
Date	09/16/84	Page	19 of





SUMMARY	
9	TRAVERSES
1	INLETS
8	OUTLETS
22	NODES
21	PATHS



Client **CECO**
 Project **BRAIDWOOD UNITS 142**
 Proj. No. **4683/8-1** Equip. No.

Prepared by **WBP/JJP** Date **08/14/86**
 Reviewed by _____ Date _____
 Approved by _____ Date _____

Calcs. For **CONTROL ROOM HVAC SUPPLY-SUBSYSTEM 14**
 Safety-Related _____ Non-Safety-Related _____


Calc. No. **VC**
 Rev. **0** Date **8/14/86**
 Page **20** of _____

DAMPER NUMBER	PATH NUMBER	PATH AREA (SQ IN)	DIMENSIONS (H x W)	AREA (ETA)	DAMPER POSITION	LOSS COEFFICIENT	R
SPLITTER	10	1					
"	11	2					
"	13	3					
"	15	4					
"	17	5					
"	19	6					
"	21	7					

* K: LOSS COEFF. = 0.46 AND WAVE OPEN DAMPER (90°)

$R = \frac{K}{A^2}$

Client	CECO	Prepared by	WBP	Date	08/10/86
Project	ARMADADO UNITS 1 + 2	Reviewed by		Date	
Contract No.	100-100000	Approved by		Date	
Calcs For BALANCING DAMPER LIST		SUBSYSTEM NUMBER 14		Date	08/10/86
Safety-Related		Non-Safety-Related		Page	23 of
Calc. No.		VC		Rev.	0



SUMMARY	Calc. No. VC
2 TRAVERSES	Rev. 0 Date 9/14/86
1 INLET	Page 24 of
2 OUTLETS	
5 NODES	
4 PATHS	

Calcs. For	CONTROL ROOM HVAC
SUPPLY - SUBSYSTEM 1B	
Safety-Related	Non-Safety-Related

Prepared by	WBP/JTP	Date	9/14/86
Reviewed by		Date	
Approved by		Date	

Client	CECO
Project	BRAUNWOOD UNITS 1 + 2
Proj. No.	4603/84
Equip. No.	



PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE REFERENCE VALUE	TOTAL PRESSURE DROP REFERENCE VALUE	AIR DENSITY REFERENCE VALUE	PATH RESISTANCE CALC.	PATH RESISTANCE VALUE	ADJUST	FINAL VALUE
1	0	4	51802	51802-0	51802				
2	0	4	51801	51802-0	51801				
3	5	OFF-VC01B							
4	D	SPLITTER							0.00001

$R = \text{INCHES OF WATER}$
 $Q = \text{COLUMN DIFFERENTIAL VOLUME FLOWRATE ACFM}$
 $P = \text{DENSITY, lbm/ft}^3$

$R = (1.2015 \times 10^{-6}) \frac{Q^2}{P}$

DETERMINATION
 DEFAULT 0.00001
 DAMPER LIST
 R
 R
 DEFAULT 0.00001

DESCRIPTION
 DAMPER NUMBER
 DAMPER NUMBER
 ROOM NUMBER
 AIR, MEAS. STA. NO.

PATH NAME
 CONTROL DAMPER
 BALANCING DAMPER
 INTERNAL
 OUTLET/INLET
 INLET/OUTLET

PATH TYPE
 C
 D
 I
 O
 S/R

Client: **CECO**
 Project: **BRANDWOOD UNITS 1-2**
 Drawing No: **08100**


Prepared by: **UFB**
 Reviewed by:
 Approved by:

Date: **09/14/86**
 Date:
 Date:

Safety-Related
 Safety-Related
 Safety-Related

Calc. For RESISTANCE DETERMINATION
SUB-SYSTEM NUMBER 18

Calc. No. **VC**
 Rev. **0**
 Date **08/10/86**



SUMMARY
7 TRAVERSES
1 INLETS
7 OUTLETS
22 NODES
21 PATHS

Calc. No. VC
 Rev. 0 Date 08/14/16
 Page 27 of

Calc. For CONTROL ROOM HVAC
 SUPPLY SUBSYSTEM 19
 Safety-Related Non-Safety-Related

Prepared by WBP/JSP Date 08/14/16
 Reviewed by Date
 Approved by Date

Client CECO
 Project BRAIDWOOD - UNITS 191
 Proj. Nr. 4603/84 Equip. No.



PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE		VALUE FINAL
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	
1	0	13	51907- 51906		51907-0		51907				
2	0	6	51906- 51905		51906-0		51906				
3	0	16	51905- 51904		51905-0		51905				
4	0	15	51904- 51903		51904-0		51904				
5	0	15	51903- 51902		51903-0		51903				
6	0	15	51902- 51901		51902-0		51902				
7	0	14	51901		51902-0		51901				
8	S	OFF- 15019									
9	D	0UC225Y									
10	I		51906		51907- 51906		51906				0.00001
11	I	00D									
12	D	0UC224Y									
13	I		51905		51906- 51905		51905				0.00001
14	D	00D									
15	I		51904		51905- 51904		51904				

ΔP = INCHES OF WATER
 Q = COLUMN DIFFERENTIAL
 P = DENSITY, Lbm/FT^3
 \dot{Q} = VOLUME FLOW RATE
 PCFM

Calc For RESISTANCE DETERMINATION
 $Q = (1.2015 \times 10^6) \sqrt{\Delta P}$
 P

DETERMINATION
 DEFAULT 0.00001
 DAMPER LIST
 Q
 Q
 DEFAULT 0.00001

DESCRIPTION
 DAMPER NUMBER
 DAMPER NUMBER
 ROOM NUMBER
 AIR, NEAR, STR. NO.

PATH NAME
 CONTROL DAMPER
 BALANCING DAMPER
 INTERMIX
 OUTLET / INLET
 INLET / OUTLET

* PATH TYPE
 C
 D
 I
 O
 S/R

Client: CECO
 Project: BRADWOOD UNIT 6 1 & 2
 Prepared by: [Signature]
 Date: 08/14/81
 Checked by: [Signature]
 Date: 09/16/81
 Calc. No. UC
 Rev. 0
 Date 09/16/81
 SUB-SYSTEM NUMBER 19

50
45
40
35
30
25
20
15
10
5

PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE		AIR DENSITY		PATH RESISTANCE		VALUE FINAL
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	
16	D	OVC300Y	-	-	-	-	-	-	-	-	-
17	I	-	51903	51904- 51903	-	51903	-	51903	-	-	0.00001
18	D	00D	-	-	51903- 51902	-	51902	-	-	-	0.00001
19	I	-	51902	-	-	-	-	-	-	-	-
20	D	OVC39Y	-	-	-	-	-	-	-	-	-
21	D	00D	-	-	-	-	-	-	-	-	0.00001

Δ = INCHES OF WATER
 \dot{Q} = COLUMN DIFFERENTIAL VOLUME FLOWRATE ACFM
 ρ = DENSITY, lbm/ft³

$Q = (1.2015 \times 10^6) \frac{\Delta}{\rho}$

DEFINITIONS
 DEFAULT 0.00001
 DAMPER LIST
 ROOM NUMBER
 AIR, MEAS. STR. NO.
 DEFAULT 0.00001

DESCRIPTION
 DAMPER NUMBER
 DAMPER NUMBER
 ROOM NUMBER
 AIR, MEAS. STR. NO.

Client: CECO
 Project: BRANWOOD UNITS 1+2
 Prepared by: WAP
 Reviewed by:
 Approved by:
 Date: 08/14/86
 Date:
 Date:
 Calc. For: RESISTANCE DETERMINATION
 SUB-SYSTEM NUMBER 19
 Safety-Related
 Non-Safety-Related
 Rev. 0
 Page 29 of
 Calc. No. UC
 Date 08/14/86

CAMPER NUMBER	PATH NUMBER	PATH DIMENSIONS AFFCT. (W)(H) H(H/W)	AREA (FT ²)	CAMPER POSITION	LOSS COEFFICIENT	R RESISTANCE
0VC225Y	9	1	—	—	—	—
0BD	11	2	—	—	—	—
0VC224Y	12	13	—	—	—	—
0BD	14	3	—	—	—	—
0VC200Y	16	4	—	—	—	—
0BD	18	5	—	—	—	—
0VC34Y	20	6	—	—	—	—
0BD	21	7	—	—	—	—

* K: LOSS COEFF. = 0.46 FOR WIND OPEN CAMPER (90°)

$$R = \frac{K}{A^2}$$

Client: **CECO**
 Project: **BRIDGE 300 UNITS 1 + 2**

Prepared by: **UAB**
 Reviewed by:
 Assessed by:

Date: **8/10/84**
 Date:
 Date:


Calc. For: **BALANCING DAMPER LIST**
SUBSYSTEM NUMBER 19

Calc. No: **VC**
 Rev: **0**
 Date: **08/10/84**

Page **30** of

Safety-Related
 Non-Safety-Related

5 10 15 20 25 30 35 40 45 50 55



SUMMARY
7 TRAINS
6 INLET
1 OUTLET
19 NODES
18 PATHS

Calc. No	VC
Rev	0
Date	8/17/86
Page	31 of

Calc. For CONTROL ROOM HVAC
 RETAIN (TRAIN A) - SUBSYSTEM FOR
 Safety-Related

Prepared by	WBP	Date	08/17/86
Reviewed by		Date	
Approved by		Date	

Client: CERO
 Project: BRADWOOD - UNITS 1 & 2
 Rev. No: 4/23/86

50
45
40
35
30
25
20
15
10
5

PATH NO	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE		VALUE FINAL
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	
2	O	OFF V0007	ROA06		ROA07-0		ROA06				
3	O	OFF V0011	RO708		ROA05-0		RO708				
4	O	OFF V0013	RO712		ROA04-0		RO712				
5	O	OFF V0017	R1314		ROA03-0		R1314				
6	O	OFF V0017	R1707		ROA02-0		R1707				
7	R	OVC010A	ROA01		ROA02-0		ROA01				
8	D	OVC302Y									
9	I		ROA05		ROA07- ROA05		ROA05				
10	D	OVC094Y									
11	I		ROA04		ROA05- ROA04		ROA04				
12	D	OVC133Y									
13	I		ROA03		ROA04- ROA03		ROA03				
14	O	OVC217Y									
15	I		ROA02		ROA03- ROA02		ROA02				

* PATH TYPE
 C CONTROL DAMPER
 O OFFLINE DAMPER
 I INTERNAL
 O OUTLET/INLET
 S/R INLET/OUTLET

REDESCRIPTION
 DAMPER NUMBER
 DAMPER NUMBER
 ROOM NUMBER
 AIR, HEAT, STR. NO.

DETERMINATION
 DEFAULT 0.00001
 DAMPER LIST
 R
 R
 DEFAULT 0.00001

$Q = (1.2015 \times 10^6) \frac{L^3}{P \cdot Q^2}$
 $Q = \text{INCHES OF WATER}$
 $Q = \text{COLUMN DIFFERENTIAL}$
 $Q = \text{VOLUME FLOWRATE}$
 $Q = \text{ACFM}$
 $\rho = \text{DENSITY, lbm/ft}^3$

Client: CECO
 Project: SANDWOOD UNITS 1+2
 Draw No: SDR 180
 Scale: N

Prepared by: W.P.P.
 Reviewed by:
 Approved by:
 Date: 8/17/86
 Date: 8/17/86
 Date:

Calc. No. VC
 Rev. 0
 Date 8/17/86
 Page 30 of

Calc. For RESISTANCE DETERMINATION
 SUB-SYSTEM NUMBER ROA
 Safety-Related
 Non-Safety-Related

PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE		VALUE FINAL
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	
16	D	OVCL82Y	—	—	—	—	—	—	—	—	0.00001
17	I	SPACE	—	—	—	—	—	—	—	—	
18	O	OVV304Y	—	—	—	—	—	—	—	—	

ΔP = INCHES OF WATER
 \dot{Q} = COLUMN DIFFERENTIAL VOLUME FLOWRATE / CFM
 ρ = DENSITY, Lbm/FT^3


$R = (1.2015 \times 10^{-6}) \frac{L}{P \dot{Q}^2}$

PATH TYPE	PATH NAME	DESCRIPTION	PERMITTANCE
C	CENTRAL DAMPER	DAMPER NUMBER	DEFAULT 0.00001
D	EXHAUSTING DAMPER	DAMPER NUMBER	DAMPER LIST
I	INTERNAL	—	—
O	OUTLET / INLET	ROOM NUMBER	—
S/R	INLET / OUTLET	AIR, HEAT. STA. NO.	DEFAULT 0.0001

Client: **CECO**
 Program: **BRANDHOOD UNITS 1+R**
 Date: **5/17/84**
 Prepared by: **WPR**
 Reviewed by: _____
 Approved by: _____
 Calc. For: **RESISTANCE DETERMINATION**
 SUB-SYSTEM NUMBER: **RoA**
 Safety-Related: _____ Non-Safety-Related: _____
 Calc. No: **VC**
 Rev: **0** Date: **8/17/84**
 Page: **33** of _____



10 15 20 25 30 35 40 45 50 55



SUMMARY	
8 TRAVERSES	
7 INLETS	
1 OUTLET	
22 NODES	
21 PATHS	

Calc. No. VC
 Rev. 0 Date 08/14/06
 Page 25 of

Calc. For CONTROL ROOM HVAC
 RETURN - SUBSYS 27Y 07
 Safety-Related
 Non-Safety-Related

Prepared by WBP/JJP
 Date 08/14/06
 Reviewed by
 Date
 Approved by
 Date

Client CECO
 Project BRAIDWOOD - UNITS 1+2
 Proj. No. 4403/14
 Equip. No.



Form 00432 Rev 1

PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE VALUE		
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	FINAL
1	O	8	R0707- R0706		R0707-0		R0707				
2	O	8	R0706		R0707-0		R0707				
3	O	3	R0705		R0708-0		R0705				
4	O	3	R0704- R0703		R0704-0		R0704				
5	O	3	R0703- R0702		R0703-0		R0703				
6	O	3	R0702- R0701		R0702-0		R0702				
7	O	13	R0701		R0702-0		R0701				
8	R	OFF- VC007	—		—		—				
9	D	OVC056Y	—		—		—				
10	I	—	R0707		R0708- R0707		R0707				
11	D	OBD	—		—		—				0.00001
12	D	OBD	—		—		—				0.00001
13	I	DEFAULT	—		—		—				0.00001
14	D	OBD	—		—		—				
15	I	—	R0704		R0705- R0704		R0704				

* PATH TYPE	PATH NAME	DESCRIPTION	DETERMINATION
C	CONTROL DAMPER	DAMPER NUMBER	DEFAULT 0.00001
D	BALANCING DAMPER	DAMPER NUMBER	DAMPER LIST
I	INTERNAL	—	Q
O	OUTLET/INLET	ROOM NUMBER	Q
S/R	INLET/OUTLET	AIR, HEAT. STA. NO.	DEFAULT 0.00001

$Q = (1.2015 \times 10^4) \frac{\Delta P}{\rho Q^2}$
 ΔP = INCHES OF WATER COLUMN DIFFERENTIAL
 Q = VOLUME FLOWRATE ACFM
 ρ = DENSITY, lbm/ft³



Client: CECO
 Project: BRAIDWOOD UNITS 1+2

Prepared by: WJP
 Date: 08/16/86
 Reviewed by:
 Date:

Calcs. For RESISTANCE DETERMINATION
 SUB-SYSTEM NUMBER 07

Calc. No. UC
 Rev. 0 Date 08/16/86
 Page 2/ of

PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE		FINAL VALUE
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	
16	D	OBD	—	—	—	—	—	—	—	—	0.00001
17	I	—	R0703	—	R0704- R0703	—	R0703	—	—	—	0.00001
18	D	OBD	—	—	—	—	—	—	—	—	0.00001
19	I	—	R0702	—	R0703- R0702	—	R0702	—	—	—	0.00001
20	D	OBD	—	—	—	—	—	—	—	—	0.00001
21	D	OBD	—	—	—	—	—	—	—	—	0.00001

Δ = INCHES OF WATER
 Δ = COLUMN DIFFERENTIAL
 \dot{Q} = VOLUME FLOWRATE
 ACFM
 ρ = DENSITY, Lbm/FT^3

$Q = (1.2015 \times 10^6) \frac{\Delta}{\rho Q}$

PATH TYPE	PATH NAME	DESCRIPTION	DETERMINATION
C	CONTROL DAMPER	DAMPER NUMBER	DEFAULT 0.00001
D	BALANCING DAMPER	DAMPER NUMBER	DAMPER LIST
I	INTERNAL	—	—
O	OUTLET / INLET	ROOM NUMBER	—
S/R	INLET / OUTLET	AIR MEAS. STA. NO.	DEFAULT 0.00001

Client: **CECO**
 Project: **BRAUNWOOD UNITS 1 & 2**
 Prepared by: **WAB**
 Reviewed by: _____
 Date: 08/16/86
 Date: _____
 Calc. For RESISTANCE DETERMINATION
 SUB-SYSTEM NUMBER 07
 Calc. No. **VC**
 Rev. **0**
 Date: 08/16/86
 Page 27 of _____
 Non-Safety-Related
 C. E. Sargent & Lundy


DAMPER NUMBER	PATH NUMBER	PATH AFFECT. (W(IN) H(IN))	AREA (SQ FT)	DAMPER POSITION	COEFFICIENT	R
OVC0564	9	70	-	-	-	-
OBD	11	1	-	-	-	-
"	12	2	-	-	-	-
"	14	3	-	-	-	-
"	16	4	-	-	-	-
"	18	5	-	-	-	-
"	20	6	-	-	-	-
"	21	7	-	-	-	-

* K = LOSS COEFF. = 0.46 FOR WIDE OPEN DAMPER (90°)

$$R = \frac{K}{A^2}$$

Client: **CECO**
 Project: **CAHIDDOO UNITS 1+2**
 Prepared by: **WJP**
 Reviewed by:
 Approved by:
 Date: **3/16/86**
 Date:
 Date:
 Calc. For: **BALANCING DAMPER LIST**
 SUBSYSTEM NUMBER: **07**
 Safety-Related
 Non-Safety-Related
 Calc. No: **VC**
 Rev: **0**
 Date: **03/11/86**
 Page: **38** of

3.5 4.0 4.5 5.0 5.5



SUMMARY	
12 TRAVERSES	580
10 INLETS	580
1 OUTLET	580
32 NODES	580
31 PATHS	580

Calc. No. VC
 Rev 0 Date 8/17/86
 Page 39 of

Calc. For CONTROL ROOM HVAC
 RETURN - SUBSYSTEM 11
 Safety-Related
 Non-Safety-Related

Prepared by WBP/JSP
 Reviewed by
 Approved by
 Date 08/17/86
 Date
 Date

Client C.E. 10
 Project BRADWOOD UNITS 1/2
 Equip. No.



PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE		VALUE
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	
1	0		R1109		R1110-0		R1109				
2	0		R1110		R1110-0		R1110				
3	0		R1108		R1108-0		R1108				
4	0		R1107		R1107-0		R1107				
5	0		R1106		R1106-C		R1106				
6	0		R1105		R1105-0		R1105				
7	0		R1104		R1104-0		R1104				
8	0		R1103		R1103-0		R1103				
9	0		R1102		R1102-0		R1102				
10	0		R1101		R1102-0		R1101				
11	R	OFF VEON									
12	D	OVC305Y									
13	I		R1111		R1112		R1111				
14	I		R1110		R1111		R1110				
15	D	OVC302Y									

$Q = (1.2015 \times 10^6) \sqrt{\Delta P}$
 $\Delta P = \text{INCHES OF WATER}$
 $Q = \text{VOLUME FLOWRATE ACFM}$
 $\rho = \text{DENSITY, lbm/ft}^3$

DETERMINATION
 DEFAULT 0.00001
 DAMPER LIST
 R
 R
 DEFAULT 0.00001

Client: **CECO** Project: **BRANDWOOD UNITS 1+2**
 Prepared by: **WJP** Date: **8/17/06**
 Reviewed by: _____ Date: _____
 Calc. For RESISTANCE DETERMINATION
2108-SYSTEM NUMBER 11
 Calc No. **12** Date **8/17/06**
 Rev. **0** Page **1/1** of **1**

PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE		FINAL VALUE
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	
16	D	OVC261Y									
17	I		R1108		R1108						
18	D	OVC260Y									
19	D	OVC259Y									
20	I		R1106		R1106						
21	D	OVC253Y									
22	D	OVC314Y									
23	I		R1105		R1106 R1105			R1105			
24	D	OVC258Y									
25	I		R1104		R1105 R1104			R1104			
26	D	OVC257Y									
27	I		R1103		R1104 R1103			R1103			
28	D	OVC256Y									
29	I		R1102		R1103 R1102			R1102			
30	D	OVC254Y									

Δ = INCHES OF WATER
 Δ = COLUMN DIFFERENTIAL
 \dot{Q} = VOLUME FLOWRATE
 ACFM
 ρ = DENSITY, lbm/ft³

$Q = (1.2015 \times 10^6) \Delta \rho$

REDEFINITION
 DEFAULT 0.0000
 DAMPER LIST
 \dot{Q}
 \dot{Q}
 DEFAULT 0.0000

DESCRIPTION
 DAMPER NUMBER
 DAMPER NUMBER
 ROOM NUMBER
 AIR. MEAS. STA. NO.

PATH NAME
 CONTROL DAMPER
 BALANCING DAMPER
 INTERNAL
 OUTLET / INLET
 INLET / OUTLET

Calc No. VC
 Rev. 0
 Date 9/17/80

Calc For RESISTANCE DETERMINATION
 SUB-SYSTEM NUMBER 11

Date 9/17/80
 Date

Prepared by WBP
 Reviewed by

Client CECO
 8881061000 UNITS 1+2

S/R

5	10	15	20	25	30	35	40	45	50
PATH NO.	DESCRIPTION	ACTUAL AIRFLOW RATE REFERENCE VALUE	TOTAL PRESSURE DROP REFERENCE VALUE	AIR DENSITY REFERENCE VALUE	PATH RESISTANCE CALC.	PATH RESISTANCE ADJUST	PATH RESISTANCE VALUE	PATH RESISTANCE VALUE	FINAL
31	D	0.00255							

Δ = INCHES OF WATER
 \dot{Q} = COLUMN DIFFERENTIAL VOLUME FLOWRATE ACFM
 ρ = DENSITY, lbm/ft³

$$R = (1.2015 \times 10^{-4}) \frac{\Delta P}{\rho \dot{Q}^2}$$

DESCRIPTION	REESTIMATION
DAMPER NUMBER	DEFAULT 0.00001
DAMPER LIST	
ROOM NUMBER	DEFAULT 0.00001
AIR, HEAT. STR. NO.	

PATH NAME	DESCRIPTION
CENTRAL DAMPER	DAMPER NUMBER
BALANCING DAMPER	DAMPER NUMBER
INTERNAL	
OUTLET / INLET	ROOM NUMBER
INLET / OUTLET	AIR, HEAT. STR. NO.

PATH TYPE
C
D
I
O
S/R

Client: CECO
 Project: BRANWOOD UNITS 1 & 2
 Prepared by: WBP
 Reviewed by:
 Date: 8/17/82
 Date:
 Calc. For: RESISTANCE DETERMINATION
 SUB-SYSTEM NUMBER 11
 Safety-Related
 Non-Safety-Related
 Calc. No. 12
 Rev. 0
 Date: 8/17/82
 Page 42 of

DAMPER NUMBER	PATH NUMBER	PATH AFFECT. (IN)	DIMENSION (IN)	AREA (FT ²)	DAMPER POSITION	LOSS COEFFICIENT	R RESISTANCE
OVC 215Y	12	13					
OVC 218Y	15	2					
OVC 216Y	16	1					
OVC 210Y	18	3					
OVC 259Y	19	4					
OVC 253Y	21	5					
OVC 314Y	22	23					
OVC 258Y	24	6					
OVC 257Y	26	7					
OVC 252Y	28	8					
OVC 254Y	30	9					
OVC 255Y	31	10					

K: LOSS COEFF. = 0.46 FOR WIRE OPEN DAMPER (90°)

$$R = \frac{K}{A^2}$$

5 10 15 20 25 30 35 40 45 50

PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE		FINAL VALUE
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	
1	O	2	R1310		R1311-0		R1310				
2	O	2	R1311- R1310		R1311-0		R1311				
3	O	2	R1309- R1308		R1309-0		R1309				
4	O	2	R1308		R1309-0		R1308				
5	O	2	R1305		R1306-0		R1305				
6	O	2	R1306- R1305		R1306-0		R1306				
7	O	2	R1303		R1304-0		R1303				
8	O	2	R1302		R1304-0		R1302				
9	O	2	R1313		R1304-0		R1313				
10	O	2	R1301		R1304-0		R1301				
11	R	OFF- VCO13									
12	I		R1312		R1314- R1312		R1312				
13	I		R1311		R1312- R1311		R1311				
14	D	OVC2694									
15	D	OVC2074									

Δ = INCHES OF WATER
 Q = COLUMN DIFFERENTIAL
 \tilde{Q} = VOLUME FLOWRATE
 ρ = DENSITY, lbm/ft³

$Q = (1.2015 \times 10^4) \frac{\Delta}{\rho}$

REITERMINATION
 DEFAULT 0.00001
 DAMPER LIST
 Q
 Q
 DEFAULT 0.00001

DESCRIPTION
 DAMPER NUMBER
 DAMPER NUMBER
 ROOM NUMBER
 AIR, HEAS. STR. NO.

PATH NAME
 CONTROL DAMPER
 BALANCING DAMPER
 INTERNAL
 OUTLET / INLET
 INLET / OUTLET

Date No. VC
 Rev. 0 Date 8/11/86
 of 45

Calc. For RESISTANCE DETERMINATION
 SUB-SYSTEM NUMBER 13

Date 8/17/86
 Date
 Prepared by WBP
 Reviewed by

Client CECO
 Project BRANWOOD UNITS 1+2

SARGENT & LUNDY

PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE		TOTAL PRESSURE DROP		AIR DENSITY		PATH RESISTANCE VALUE		
			REFERENCE	VALUE	REFERENCE	VALUE	REFERENCE	VALUE	CALC.	ADJUST	FINAL
16	I	-	R1309		R1312 - R1309		R1309				
17	D	OVC271Y	-		-		-				
18	D	OVC272Y	-		-		-				
19	D	OVC318Y	-		-		-				
20	I	-	R1307		R1314 - R1307		R1307				
21	I	-	R1306		R1307 - R1306		R1306				
22	D	OVC273Y	-		-		-				
23	D	OVC274Y	-		-		-				
24	I	-	R1304		R1307 - R1304		R1304				
25	D	OVC277Y	-		-		-				
26	D	OVC276Y	-		-		-				
27	D	OVC275Y	-		-		-				
28	D	OVC278Y	-		-		-				

Form GO 432 Rev 1

PATH TYPE	PATH NAME	DESCRIPTION	DETERMINATION
C	CONTROL DAMPER	DAMPER NUMBER	DEFAULT 0.00001
D	BALANCING DAMPER	DAMPER NUMBER	DAMPER LIST
I	INTERNAL	-	Q
O	OUTLET/INLET	ROOM NUMBER	Q
S/R	INLET/OUTLET	AIR MEAS. STR. NO.	DEFAULT 0.00001

$R = (1.2015 \times 10^{-4}) \frac{\Delta P}{\rho Q^2}$

ΔP = INCHES OF WATER COLUMN DIFFERENTIAL
 Q = VOLUME FLOWRATE ACFM
 ρ = DENSITY, lbm/ft³



Client **CECO**
 Project **BRANDWOOD UNITS 1 & 2**
 Est. No. **423184** Equip. No.

Prepared by **WBP** Date **6/17/86**
 Reviewed by _____ Date _____
 Approved by _____ Date _____

Calcs. For **RESISTANCE DETERMINATION**
SUB-SYSTEM NUMBER 13
 Safety-Related Non-Safety-Related

Calc. No. **1/C**
 Rev. **0** Date **6/17/86**
 Page **46** of

DAMPER NUMBER	PATH NUMBER	PATH AFFECT (W(IN) H(IN))	DIMENSIONS (W(IN) H(IN))	AREA (FT ²)	DAMPER POSITION	LOSS COEFFICIENT	R
OVC269Y	14	1					
OVC267Y	15	2					
OVC271Y	17	3					
OVC272Y	18	4					
OVC318Y	19	20					
OVC273Y	22	5					
JWC274Y	23	6					
OVC277Y	25	7					
OVC276Y	26	8					
OVC275Y	27	9					
OVC278Y	28	10					

K = LOSS COEFF. = 0.46 FOR WIDE OPEN DAMPER (90°)


$$R = \frac{K}{A^2}$$

Client: **CECO**
 Project: **BRIDGEWAY UNITS 1-2**
 Prepared by: **WAF**
 Date: **1/17/86**
 Reviewed by: _____
 Approved by: _____
 Date: _____
 Date: _____

Calcs. For **BALANCING DAMPER LIST**
210 SYSTEM NUMBER 13
 Safety-Related
 Non-Safety-Related

Calc. No. **12**
 Rev. **0**
 Date **3/77**
 Page **47** of _____

5 10 15 20 25 30 35 40 45 50 55



SUMMARY	
7 TRAVERSES	
7 INLETS	
1 OUTLET	
22 ROOMS	
21 PATHS	
Calc. No. VC	
Rev. 0	Date 8/17/06
Page 48	of

Calcs For CONTROL ROOM HVAC
 RETURN - SUBSYSTEM 17
 Safety-Related | Non-Safety-Related

Prepared by WAP/JJP
 Reviewed by
 Approved by
 Date 8/17/06
 Date
 Date

Client: CECO
 Project: BRANWOOD - UNITS 1 & 2
 Proj. No. 4683187
 Equip. No.



PATH NO.	PATH TYPE	DESCRIPTION	ACTUAL AIRFLOW RATE REFERENCE	VALUE	TOTAL PRESSURE REFERENCE	VALUE	DROP VALUE	AIR DENSITY REFERENCE	VALUE	PATH RESISTANCE CALC.	ADJUST	FINAL VALUE
1	O	4	R1706		R1707-0			R1706				
2	O	15	R1705- R1704		R1705-0			R1705				
3	O	16	R1704		R1705-0			R1704				
4	O	4	R1703- R1702		R1703-0			R1703				
5	O	13	R1702- R1701		R1702-0			R1702				
6	O	SPACE										
7	O	4	R1701		R1702-0			R1701				
8	R	OFF- VCO17										
9	I	SPACE										
10	D	OVC3164										0.00001
11	I		R1705		R1706- R1705			R1705				
12	D	OVC2344										
13	D	OVC2364										
14	D	OVC3174										
15	I		R1703		R1707- R1703			R1703				

$B =$ INCHES OF WATER
 $Q =$ COLUMN DIFFERENTIAL
 $PQ =$ VOLUME FLOW RATE
 ACFM
 $P =$ DENSITY, LB/M³

$Q = (1.2015 \times 10^6) \sqrt{PQ}$

DESCRIPTION	DAMPERS NUMBER	DAMPERS NUMBER	ROOM NUMBER	AIR, MEAS. STA. NO.
DEFAULT	0.00001			
DAMPERS		2		
DEFAULT				0.00001

Client: CECO
 Project: BRAIDWOOD UNITS 1 & 2
 Prepared by: WBP
 Reviewed by:
 Approved by:
 Date: 8/17/84
 Date: 8/17/84
 Date:

Calc. For RESISTANCE DETERMINATION
 SUB-SYSTEM NUMBER 17
 Safety-Related
 Non-Safety-Related

Ulic. No. 10
 Rev. 0
 Page 49 of

1	5	10	15	20	25	30	35	40	45	50	
PATH NO.	DESCRIPTION	ACTUAL AIRFLOW RATE REFERENCE	TOTAL PRESSURE DROP VALUE	AIR DENSITY REFERENCE VALUE	PATH RESISTANCE CALC.	PATH RESISTANCE ADJUST	VALUE FINAL				
16	D SPLITTER						0.00001				
17	I	R1702	R1703 R1702	R1702			0.00001				
18	D SPLITTER						0.00001				
19	I SPACE						0.00001				
20	D OVCROSS						0.00001				
21	D SPLITTER						0.00001				
<p>* PATH TYPE</p> <p>C CONTROL DAMPER</p> <p>D BALANCING DAMPER</p> <p>I INTERNAL</p> <p>O OUTLET / INLET</p> <p>S/R INLET / OUTLET</p>											

Δ = INCHES OF WATER
 Δ = COLUMN DIFFERENTIAL
 \dot{Q} = VOLUME FLOWRATE
 ACFM
 ρ = DENSITY, LB/FT³

$R = (1.2015 \times 10^{-6}) \frac{L}{\rho \dot{Q}}$

REFINEMENT
 DEFAULT 0.00001
 DAMPER LIST
 \dot{Q}
 \dot{Q}
 ROOM NUMBER
 AIR, MEAS. STR. NO. DEFAULT 0.0001

Client: CECO
 Project: BRANWOOD UNITS 1+2
 Prepared by: WBP
 Date: 8/17/80
 Reviewed by:
 Date:
 Calc. For RESISTANCE DETERMINATION
 SUB-SYSTEM NUMBER 17
 Calc. No. VC
 Rev. 0
 Date 8/17/80
 Page 50 of

DAMPER NUMBER	PATH NUMBER	PATH AFFECT (W) (IN)	DISCUSSION	AREA (FT ²)	DAMPER POSITION	LOSS COEFFICIENT	R
OVC 3164	10	1					RESISTANCE
OVC 2344	12	2					
OVC 2364	13	3					
OVC 9174	14	15					
SPLITTER	16	4					
SPLITTER	18	5					
OVC 2054	20	6					
SPLITTER	21	7					

K = LOSS COEFF. = 0.46 FOR WIDE OPEN DAMPER (90°)

$$R = \frac{K}{A^2}$$

Client: CECO	Prepared by: WBP	Date: 8/17/84	Calc. For: BALANCING DAMPER LIST	Calc. No: 12
Project: BRAIDWOOD UNITS 1-2	Reviewed by:	Date:	Rev. 0	Rev. 0
Proj. No. 4625/84	Approved by:	Date:	Page 51	of FINAL
			Safety-Related	Non-Safety-Related

