

APR 28 1986

Docket Nos.: 50-443
and 50-444

Mr. Robert J. Harrison
President & Chief Executive Officer
Public Service Company of New Hampshire
P.O. Box 330
Manchester, NH 03105

Dear Mr. Harrison:

SUBJECT: SEABROOK - REQUESTS FOR ADDITIONAL INFORMATION RELATED TO
THE INSTRUMENTATION AND CONTROL DESIGN

The purpose of this letter is to forward the enclosed request for additional information related to the atmospheric dump valve control system design to be implemented at Seabrook.

Subsequent to staff approval of a manual control system associated with electrohydraulic actuator operated atmospheric dump valves (ADVs), the Public Service Company of New Hampshire (PSNH) elected to modify the design by providing air operated ADVs with safety-related backup air (gas bottles) systems and controls. PSNH provided information by letter dated February 14, 1986 to describe the latest design. However, upon review, the staff has concluded that the information is insufficient and, thus, the staff is not able to complete the review for this issue. The information identified in the enclosure is required for staff review before this item can be resolved. I would appreciate you providing me your response within a week after receipt of this letter. This expedited schedule is necessary if we are to meet a June 30 fuel load date.

Questions or additional information regarding this matter should be directed to the Seabrook Project Manager, Mr. V. Nerses, (301) 492-8535).

Victor Nerses, Project Manager
PWR Project Directorate No. 5
Division of PWR Licensing-B

Enclosure:
As stated

cc: See next page

Distribution:

Docket Files

NRC PDR
ACRS (10)
F. Rosa
LPDR
PD#5 Rdg. File
C.E. Rossi
OEID Attorney
R. Stevens

~~J. Lee~~
w/o enclos: J. Partlow
B. Grimes
E. Jordan

PM:PD#5
V.Nerses:js
04/28/86

8605020399 860428
PDR ADOCK 05000443
A PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

APR 28 1986

Docket Nos.: 50-443
and 50-444

Mr. Robert J. Harrison
President & Chief Executive Officer
Public Service Company of New Hampshire
P.O. Box 330
Manchester, NH 03105

Dear Mr. Harrison:

SUBJECT: SEABROOK - REQUESTS FOR ADDITIONAL INFORMATION RELATED TO
THE INSTRUMENTATION AND CONTROL DESIGN

The purpose of this letter is to forward the enclosed request for additional information related to the atmospheric dump valve control system design to be implemented at Seabrook.

Subsequent to staff approval of a manual control system associated with electrohydraulic actuator operated atmospheric dump valves (ADVs), the Public Service Company of New Hampshire (PSNH) elected to modify the design by providing air operated ADVs with safety-related backup air (gas bottles) systems and controls. PSNH provided information by letter dated February 14, 1986 to describe the latest design. However, upon review, the staff has concluded that the information is insufficient and, thus, the staff is not able to complete the review for this issue. The information identified in the enclosure is required for staff review before this item can be resolved. I would appreciate you providing me your response within a week after receipt of this letter. This expedited schedule is necessary if we are to meet a June 30 fuel load date.

Questions or additional information regarding this matter should be directed to the Seabrook Project Manager, Mr. V. Nerses, (301) 492-8535).

Victor Nerses, Project Manager
PWR Project Directorate No. 5
Division of PWR Licensing-B

Enclosure:
As stated

cc: See next page

Mr. Robert J. Harrison
Public Service Company of New Hampshire

Seabrook Nuclear Power Station

cc:

Thomas Dignan, Esq.
John A. Ritscher, Esq.
Ropes and Gray
225 Franklin Street
Boston, Massachusetts 02110

E. Tupper Kinder, Esq.
G. Dana Bisbee, Esq.
Assistant Attorney General
Office of Attorney General
208 State Hosue Annex
Concord, New Hampshire 03301

Mr. Bruce B. Beckley, Project Manager
Public Service Company of New Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Resident Inspector
Seabrook Nuclear Power Station
c/o US Nuclear Regulatory Commission
Post Office Box 700
Seabrook, New Hampshire 03874

Dr. Mauray Tye, President
Sun Valley Association
209 Summer Street
Haverhill, Massachusetts 01839

Mr. John DeVincentis, Director
Engineering and Licensing
Yankee Atomic Electric Company
1671 Worchester Road
Framingham, Massachusetts 01701

Robert A. Backus, Esq.
O'Neil, Backus and Spielman
116 Lowell Street
Manchester, New Hampshire 03105

Mr. A. M. Ebner, Project Manager
United Engineers & Constructors
30 South 17th Street
Post Office Box 8223
Philadelphia, Pennsylvania 19101

William S. Jordan, III
Diane Curran
Harmon, Weiss & Jordan
20001 S Street, NW
Suite 430
Washington, D.C. 20009

Mr. Philip Ahrens, Esq.
Assistant Attorney General
State House, Station #6
Augusta, Maine 04333

Jo Ann Shotwell, Esq.
Office of the Assistant Attorney General
Environmental Protection Division
One Ashburton Place
Boston, Massachusetts 02108

Mr. Warren Hall
Public Service Company of
New Hampshire
Post Office Box 330
Seabrook, New Hampshire 03874

D. Pierre G. Cameron, Jr., Esq.
General Counsel
Public Service Company of New Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Seacoast Anti-Pollution League
Ms. Jane Doughty
5 Market Street
Portsmouth, New Hampshire 03801

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. Diana P. Randall
70 Collins Street
Seabrook, New Hampshire 03874

Richard Hampe, Esq.
New Hampshire Civil Defense Agency
107 Pleasant Street
Concord, New Hampshire 03301

Public Service Company of
New Hampshire

- 2 -

Seabrook Nuclear Power Station

cc:

Mr. Calvin A. Canney, City Manager
City Hall
126 Daniel Street
Portsmouth, New Hampshire 03801

Ms. Letty Hett
Town of Brentwood
RFD Dalton Road
Brentwood, New Hampshire 03833

Ms. Roberta C. Pevear
Town of Hampton Falls, New Hampshire
Drinkwater Road
Hampton Falls, New Hampshire 03844

Ms. Sandra Gavutis
Town of Kensington, New Hampshire
RDF 1
East Kingston, New Hampshire 03827

Chairman, Board of Selectmen
RFD 2
South Hampton, New Hampshire 03827

Mr. Angie Machiros, Chairman
Board of Selectmen
for the Town of Newbury
Newbury, Massachusetts 01950

Ms. Cashman, Chairman
Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, Massachusetts 01913

Honorable Peter J. Matthews
Mayor, City of Newburyport
Office of the Mayor
City Hall
Newburyport, Massachusetts 01950

Mr. Donald E. Chick, Town Manager
Town of Exeter
10 Front Street
Exeter, New Hampshire 03823

Mr. Alfred V. Sargent,
Chairman
Board of Selectmen
Town of Salisbury, MA 01950

Senator Gordon J. Humphrey
ATTN: Tom Burack
U.S. Senate
Washington, D.C. 20510

Mr. Owen B. Durgin, Chairman
Durham Board of Selectmen
Town of Durham
Durham, New Hampshire 03824

Charles Cross, Esq.
Shaines, Mardrigan and
McEaschern
25 Maplewood Avenue
Post Office Box 366
Portsmouth, New Hampshire 03801

Mr. Guy Chichester, Chairman
Rye Nuclear Intervention
Committee
c/o Rye Town Hall
10 Central Road
Rye, New Hampshire 03870

Jane Spector
Federal Energy Regulatory
Commission
825 North Capital Street, NE
Room 8105
Washington, D. C. 20426

Mr. R. Sweeney
New Hampshire Yankee Division
Public Service of New Hampshire
Company
7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. William B. Derrickson
Senior Vice President
Public Service Company of
New Hampshire
Post Office Box 700, Route 1
Seabrook, New Hampshire 03874

ENCLOSURE

SEABROOK

REQUEST FOR ADDITIONAL INFORMATION

The information provided to date is insufficient to allow the staff to complete its review associated with the atmospheric dump valves (ADVs). Additional information should be provided on the backup safety-related air supply system and the safety-related control system. The following should be provided as a minimum:

1. Information on the technical specification requirements to be implemented for the safety-related portion of the design (include a discussion on the provisions provided for surveillance testing of the ADVs and associated safety-related manual controls including the design features used for isolation from the nonsafety-related portion of the system).
2. Information on the failure modes and effects associated with the Train A and Train B solenoid operated valves utilized to control operation of the ADVs. This should show as a minimum:
 - That the capability of the subject valves to perform the required safety functions (open/close as required for safe plant shutdown) cannot be degraded below an acceptable level as a result of all possible circumstances (i.e., overvoltage, undervoltage, etc.) associated with the power supply to these valves. The main concern is with solenoid valves that are continuously energized during normal plant operation.
 - That the atmospheric dump valves fail to the closed position on loss of power,
 - That at least two (2) ADVs will be available for safe plant shutdown after assuming a single failure, and
 - That the nonsafety-related positioner will be isolated when required.
3. A complete set of drawings (electrical schematics, logics, switch development tables, etc.) which show the latest design implementation associated with the ADVs.

4. Information on the design criteria associated with the mechanical aspects of the backup air supply system (bottles, tubing, valves, etc.). Include details on the control room indications available for the operator to verify operability of the backup air supply system.
5. Information detailing the actuator design associated with the ADVs.
6. Information on the safety-related backup air system as related to the following concern. FSAR Section 7.3.2.3 implies that the safety-related backup air system may not have sufficient capacity to ensure that the necessary equipment is maintained in service to allow operation at hot standby for at least four hours and the additional time required for cooldown to conditions permitting operation of the RHR system. It is stated that the plant air system (nonsafety-related) can be manually loaded onto the diesel generator bus, or that local manual control will be established. Information is required to detail how this planned operation complies with the requirements of Branch Technical Position RSB 5-1, items A.1 and A. 3. Details of the operator actions necessary for the operation of the ADVs for safe plant shutdown should be provided including identification of all deviations from the subject BTP requirements. Justification information for each identified deviation should be provided.

ENCLOSURE

SEABROOK

REQUEST FOR ADDITIONAL INFORMATION

The information provided to date is insufficient to allow the staff to complete its review associated with the atmospheric dump valves (ADV's). Additional information should be provided on the backup safety-related air supply system and the safety-related control system. The following should be provided as a minimum:

1. Information on the technical specification requirements to be implemented for the safety-related portion of the design (include a discussion on the provisions provided for surveillance testing of the ADV's and associated safety-related manual controls including the design features used for isolation from the nonsafety-related portion of the system).
2. Information on the failure modes and effects associated with the Train A and Train B solenoid operated valves utilized to control operation of the ADV's. This should show as a minimum:
 - That the capability of the subject valves to perform the required safety functions (open/close as required for safe plant shutdown) cannot be degraded below an acceptable level as a result of all possible circumstances (i.e., overvoltage, undervoltage, etc.) associated with the power supply to these valves. The main concern is with solenoid valves that are continuously energized during normal plant operation.
 - That the atmospheric dump valves fail to the closed position on loss of power,
 - That at least two (2) ADV's will be available for safe plant shutdown after assuming a single failure, and
 - That the nonsafety-related positioner will be isolated when required.
3. A complete set of drawings (electrical schematics, logics, switch development tables, etc.) which show the latest design implementation associated with the ADV's.

4. Information on the design criteria associated with the mechanical aspects of the backup air supply system (bottles, tubing, valves, etc.). Include details on the control room indications available for the operator to verify operability of the backup air supply system.
5. Information detailing the actuator design associated with the ADVs.
6. Information on the safety-related backup air system as related to the following concern. FSAR Section 7.3.2.3 implies that the safety-related backup air system may not have sufficient capacity to ensure that the necessary equipment is maintained in service to allow operation at hot standby for at least four hours and the additional time required for cooldown to conditions permitting operation of the RHR system. It is stated that the plant air system (nonsafety-related) can be manually loaded onto the diesel generator bus, or that local manual control will be established. Information is required to detail how this planned operation complies with the requirements of Branch Technical Position RSB 5-1, items A.1 and A. 3. Details of the operator actions necessary for the operation of the ADVs for safe plant shutdown should be provided including identification of all deviations from the subject BTP requirements. Justification information for each identified deviation should be provided.